

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Jun/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	174.085	1187.523	1) Gujrat	-3.852	-25.537
2) Hydro	5.737	180.421	2) Madhya Pradesh	3.957	55.507
3) Gas	4.958	41.229	3) Chattisgarh	3.110	24.600
Total MSPGCL	184.780	1409.173	4) Maharashtra	212.521	1739.372
B) 1) APMIL	73.086	526.048	5) Goa (Amona)	-1.661	-11.990
2) JSWEL	24.789	199.891	Total	214.075	1781.952
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.208	348.383
4) RPL(AMT)	31.279	246.671	b) Mumbai Drawl	47.023	385.157
5) SWPGPL	10.817	83.274	c) MSEDCL Bilateral *	100.900	870.763
6) Other IPP	5.032	22.133	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.177	348.344
C) 1) TPCL Thermal	14.100	102.066	Include PX	0.000	0.000
2) TPCL Hydro	6.161	44.059	Standby	0.031	0.040
3) TPCL Gas	1.852	17.052	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.166	68.314	1) MSEDCL	533.330	4144.497
D) STATE			2) Mumbai Discoms	80.302	616.648
1) Thermal	344.354	2435.920	3) Other Discoms	10.820	85.574
(A1+C1+C4+(B1-B6))			TOTAL STATE	624.452	4846.719
2) Hydro	11.898	224.480			
(A2+C2)					
3) Gas	6.810	58.281			
(A3+B7+C3)					
4) Wind	30.854	217.478			
6) SOLAR	16.461	128.608			
TOTAL STATE	410.377	3064.767			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	7042	7321	7262	7266
MSPGCL Hydro	210	114	200	259
MSPGCL Gas	195	196	210	218
MSPGCL Total Generation	7447	7631	7672	7743
Central Sector Receipt	9845	9533	7936	8819
WIND	708	838	1433	1196
CPP / IPP Thermal	5736	6382	6469	5782
CPP / IPP Gas	0	0	0	0
SOLAR	2238	1339	0	656
Exchange with Mumbai	-2451	-2405	-1732	-1788
MSEDCL DEMAND MET	23019	22843	21303	21951
Load Shedding	0	865	477	0
MSEDCL DEMAND	23019	23708	21780	21951
TPCL GENERATION	797	1067	1146	608
AEML GENERATION	496	498	498	359
MUMBAI DEMAND	3744	3970	3376	2755
OTHER DISCOM DEMAND	504	476	475	457
STATE DEMAND MET	27267	27288	25154	25163
STATE DEMAND	27267	28153	25631	25163
Frequency (Hz)	49.97	50.03	49.93	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.29 Hz at 18.02 Hrs	49.83 Hz at 14.10 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.85	37.92	205	200
Unit 8	14.27	34.00	614	558
Unit 9	12.84	18.03	557	514
Unit 10	13.33	104.96	603	526
Total	45.28	194.91		
Bhusawal				
Unit 3	0.17	15.68	100	0
Unit 4	10.28	78.36	440	410
Unit 5	10.94	85.32	480	410
Total	21.38	179.36		
Parli				
Unit 6	5.05	39.98	250	145
Unit 7	5.05	39.16	245	148
Unit 8	4.45	34.98	205	148
Total	14.55	114.12		
Chandrapur				
Unit 3	3.70	19.32	161	132
Unit 4	3.66	29.34	160	138
Unit 5	0.00	0.00	0	0
Unit 6	9.55	52.43	415	340
Unit 7	9.37	74.24	423	336
Unit 8	11.07	89.63	491	395
Unit 9	11.14	90.42	495	400
Total	48.50	355.38		
Paras				
Unit 3	5.26	39.91	225	211
Unit 4	5.22	41.36	231	172
Total	10.48	81.27		
Khaparkheda				
Unit 1	2.75	23.70	130	100
Unit 2	2.74	23.46	136	96
Unit 3	3.76	22.49	171	140
Unit 4	4.02	32.32	185	146
Unit 5	10.72	86.02	470	355
Total	23.98	188.00		
Nasik				
Unit 3	1.87	10.09	176	0
Unit 4	4.05	32.58	180	141
Unit 5	4.00	31.81	173	160
Total	9.92	74.49		
Uran				
All Units	4.96	41.23	226	194
Total	4.96	41.23		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.11	0.81	24	0
Total	0.11	0.81		
Koyna				
Stage 1-2	2.05	41.12	490	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.19	27.85	160	0
Total	2.24	150.20		
Hydro				
KDPH	0.28	3.42	14	11
VTRNA	1.15	9.04	60	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.41	2.97	80	0
SMLHY_PTN	1.55	12.76	66	62
GHATGHAR	0.00	0.19	0	0
Total	3.39	29.42		
Wind				
Total	30.85	217.48	0	0
Total	30.85	217.48		
CPP				
APML(Mus)	73.09	526.05	0	0
JSWEL(Mus)	24.79	199.89	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.28	246.67	0	0
SWPGPL-Mus	10.82	83.27	0	0
Dhariwal	0.00	0.00	0	0
IEPL	2.81	2.81	200	0
Other(Mus)	2.22	19.32	0	0
Total	145.00	1078.02		
SOLAR				
Total	16.46	128.61	0	0
Total	16.46	128.61		
Tata				
Trombay 5	9.22	66.92	417	283
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.98	9.37	58	36
Trombay 7B	0.87	7.68	48	33
TATA Hydro	6.16	44.06	440	90
Trombay 8	4.88	35.14	227	129
Total	22.11	163.18		
AEML				
DTPS U-1&2	11.17	68.31	502	325
Total	11.17	68.31		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	174.08	1187.52	MSPGCL Total	184.78	1409.17
			MSPGCL Thml+Gas	179.04	1228.75	Koyna 1,2 & 4 Total	2.05	122.34
			MSPGCL Hydro	5.74	180.42	State Total	410.38	3064.77

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7376	184	220	7780	2078	6307	0	0	8006	8534	-1708	22590	0	0	22590	3330	400	26321	49.99
2	7263	399	218	7880	1913	6331	0	0	7854	8444	-1549	22639	0	0	22639	3111	381	26130	50.00
3	7373	227	220	7820	1831	6310	0	0	8176	8329	-1429	22516	0	0	22516	2913	345	25774	50.03
4	7283	177	221	7681	1672	6238	0	0	7974	8265	-1431	22078	0	0	22078	2757	348	25182	50.04
5	7405	177	220	7802	1597	6266	0	0	8203	8728	-1464	22565	0	0	22565	2678	364	25607	50.04
6	7428	182	222	7832	1425	6000	0	9	8931	9075	-1370	22572	0	0	22572	2679	399	25650	50.01
7	7410	177	226	7813	1200	6013	0	176	8883	8803	-1338	22230	0	0	22230	2644	437	25311	50.02
8	7266	259	218	7743	1196	5782	0	656	8546	8819	-1788	21951	0	0	21951	2755	457	25163	50.06
9	7270	257	208	7735	1283	5119	0	1217	8950	9151	-2137	21892	0	0	21892	3074	476	25442	50.12
10	7046	217	200	7463	1026	5232	0	1672	9339	9521	-2310	22111	0	0	22111	3422	493	26026	50.02
11	7073	217	200	7490	774	5452	0	2020	9756	9697	-2469	22464	0	44	22464	3663	500	26627	49.98
12	7042	210	195	7447	708	5736	0	2238	9710	9845	-2451	23019	0	160	23019	3744	504	27267	49.97
13	7148	138	197	7483	593	6006	0	2202	9885	9680	-2423	23056	0	114	23056	3722	485	27263	50.02
14	7154	120	196	7470	637	5627	0	2008	9841	9780	-2332	22720	0	42	22720	3652	470	26842	49.98
15	7285	114	195	7594	679	6008	0	1657	9981	10228	-2400	23304	85	253	23389	3824	461	27675	49.96
16	7321	114	196	7631	838	6382	0	1339	9447	9533	-2405	22843	865	378	23708	3970	476	28153	50.03
17	7266	132	195	7593	1260	6411	0	844	9636	9122	-2272	22472	239	224	22711	3911	486	27108	50.04
18	7030	178	194	7402	1443	5504	0	366	9994	9722	-2401	21543	0	37	21543	3739	493	25775	50.04
19	7138	251	195	7584	1430	5952	0	57	8740	8380	-2181	20716	0	8	20716	3505	506	24727	50.08
20	7276	231	200	7707	1553	6436	0	0	8340	8153	-1986	21366	0	0	21366	3438	497	25301	49.98
21	7275	222	203	7700	1257	6468	0	0	7687	8285	-1786	21439	191	0	21630	3404	485	25519	49.98
22	7262	200	210	7672	1433	6469	0	0	7557	7936	-1732	21303	477	0	21780	3376	475	25631	49.93
23	7337	567	206	8110	1522	6473	0	0	7849	7963	-1785	21836	364	0	22200	3452	446	26099	49.96
24	7358	787	203	8348	1506	6483	0	0	7588	8082	-1876	22110	353	0	22463	3539	434	26435	49.97
MUs	174.08	5.74	4.96	184.78	30.85	145.00	0.00	16.46	210.87	214.08	-47.02	533.33	2.57	1.26	535.90	80.30	10.82	627.03	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)Due to overloading jejuri-Ionand line.2)Due to overloading of 132Kv Satana-dindori,132Kv BBLR-Rahuri line.3)FLS due to undervoltage at 400Kv Lonikand I substation.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Jun/2023

Position as on 6.30 Hrs of 09/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10	08/06/2023	09:19	Clinker formation in furnace	07/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Bhusawal Unit 3	210	05/06/2023	15:40	08/06/2023	21:35	Boiler Tube Leakage	08/06/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	13/06/2023
MSPGCL	Koyna STG-IV Unit-4	250	06/06/2023	14:20	08/06/2023	03:25	GOP Problem	08/06/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (414) OF PADGHE PG CKT - 1 @ KUDUS	InterState	09/06/2023	11:01		Continued.	PO	CT Replacement Work
400 KV MAINBAY Outages/Trippings							
MAIN BAY (401) OF GT 9 @ 400KV CHANDRAPUR SWITCHING S/S	InterState	09/06/2023	11:59	09/06/2023	15:24	PO	Diagnostic testing and allied bay maintenance work
MAIN BAY (415) OF PADGHE PG CKT - 1 @ KUDUS	InterState	09/06/2023	18:34	09/06/2023	20:40	T	Tie bay 414 of Padghe PG ckt 1 outage was under progress for CT replacement , during testing of CT of said bay due to maloperation DT send to other end.
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 2	InterState	09/06/2023	09:07	09/06/2023	19:55	PO	Under MTAMC Project work, Main -II Dist Protn relay replacement work
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/06/2023	23:37		Continued.	HT	HT for load management
LONIKAND I - KOYNA STAGE-IV	IntraState	06/06/2023	21:04		Continued.	T	Tripped on distance protection
DHULE - DHULE(BDTCL) CKT - 1	IntraState	08/06/2023	09:49	08/06/2023	10:30	T	DT received from BDTCL Dhule end
PADGHE - NAGOTHANE CKT - 2	IntraState	08/06/2023	13:08			PO	Work of shifting/height raising of various EHV (220/110KV) transmission lines infringing in Samruddhi crossing . 1) Erection of 5 no. of Monopple 2) Stringing of 6.nos. of spans between location nos. 310-313
CHANDRAPUR-PARLI CKT-3	IntraState	08/06/2023	16:02	08/06/2023	22:50	T	Tripped on Distance Protection.
LONIKAND - JEJURI CKT - 2	IntraState	08/06/2023	17:04	08/06/2023	21:46	T	Tripped on Distance Protection.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	08/06/2023	05:31	08/06/2023	06:54	PO	For pre-mansoon maintenance work (e.g-for polythin paper wrapping work)
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	09/06/2023	10:37	09/06/2023	14:40	PO	(1) IV breaker testing work. (2) Bay maintenance work.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	09/06/2023	11:01	09/06/2023	20:35	EO	For attending red hot spot on 29A isolator B-Ph 220KV Bus side by hot line unit.
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	09/06/2023	11:04	09/06/2023	16:52	PO	Diagnostic testing & routine maintenance work
220 KV TIEBAY Outages/Trippings							
220 KV TBC	IntraState	09/06/2023	08:22	09/06/2023	17:30	PO	220 KV BUS-2 ISOLATOR ALLIGNMENT WORK
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV MAIN BUS - I	IntraState	08/06/2023	10:51	08/06/2023	19:19	PO	At that time whole 220 kv bus-1 free for work & bus-2 jump removed & reconnected with the help of hot line unit, Jalgaon & 220 kv pt-1 diagnostic testing work.
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	08/06/2023	10:57	08/06/2023	12:15	PO	Premonsoon maintenance of Circuit Breaker
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	07/06/2023	07:22	08/06/2023	19:46	PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	07/06/2023	07:28	08/06/2023	19:45	PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
KALWA SALSETTE - 4	IntraState	07/06/2023	22:33	08/06/2023	01:38	PO	For 2 nd phase LA replacement at Salsette
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	08/06/2023	02:01	08/06/2023	08:46	PO	1. Attending of low clearance in between loc.no.62 to 63 & 63-64. 2. Conversion of single jump into twin jump of tension tower at various locations. (as per current loading, frequent Red-Hot comes frequently).
TALOJA II - OCIL 2	IntraState	08/06/2023	07:55	08/06/2023	18:10	PO	220KV OCIL-2 Bay Maintenance OCIL end
220 KV NANDED(400 KV) - WAGHALA CKT- II	IntraState	08/06/2023	07:56	08/06/2023	09:09	PO	At loc85 bphase cross arm one angle piece came near to jumper hence for refixing it.
KURKUMBH - SHIRSHUPHAL CKT	IntraState	08/06/2023	09:10	08/06/2023	14:30	PO	Premonsoon Maintenance, attending HOT spot on R CT.
HALKARNI - TILARI LINE	IntraState	08/06/2023	09:30	08/06/2023	20:38	PO	Erection of Bph and Yph Pedestrial Wave Traps at 220KV Halkarni bay @ Tillari SS, cleaning of EHV equipments and line side tension, suspension insulator strings
AMBAZARI-KALMESHVAR	IntraState	08/06/2023	10:00	08/06/2023	15:27	PO	Faulty dist prot relay replacement & bus-2 isolator alignment work.
IPCL - SPCL	IntraState	08/06/2023	10:22	09/06/2023	16:13	PO	ABB MAKE CB OVERHAULING WORK AT IPCL END CB
VANKUSWADE - KDPH	IntraState	08/06/2023	11:00	08/06/2023	11:45	PO	Fixing of earth wire expansion clamp at Loc No.99
KANDALGAON - PIRANGUT	IntraState	08/06/2023	12:20	08/06/2023	18:18	PO	Work :-1) Attending hot spots. Loc no 36,61,63,64,81,83,88 2) Earth wire restringing loc no 37,38,40,68-72
220 KV PHULAMBRI - BHOKARDHAN	IntraState	08/06/2023	13:06	08/06/2023	17:12	PO	Diagnostic testing i.e ct tandelta measurment test.
MALEGAON (ZODGA) - BALAPUR CKT 1	IntraState	08/06/2023	13:24	08/06/2023	16:10	PO	For relay testing work and scada point to point testing with Id.
WARORA - HINGANGHAT	IntraState	08/06/2023	14:04	08/06/2023	17:53	PO	For replacement of keypad & display of backup relay by agency & relay testing work.
MIRAJ - ICHALKARANJI	IntraState	08/06/2023	17:19	09/06/2023	02:38	HT	Emergency outage for project work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY MSETCL TIE - 2	IntraState	09/06/2023	00:05	09/06/2023	02:48	PO	Attending to CT oil leakage.
MAHAD - KANDALGAON	IntraState	09/06/2023	01:15		Continued.	PO	1. Erection of 2 nos. inline monopole 2. Stringing of 3 nos. conductor on new erected monopole. 3. Stringing of 3 nos. conductor both sides of 2 nos. erected monopole. 4. Dismantling of old conductor.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/06/2023	02:58	09/06/2023	08:11	PO	Conversion Of single to Twin Jump at Various Cut point
CHEMBUR (AEML) - NERUL (M)	IntraState	09/06/2023	04:52	09/06/2023	19:10	PO	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL
SONKHAR - TROMBAY	IntraState	09/06/2023	05:29	09/06/2023	08:10	PO	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL
CHIKHALI-JALNA I	IntraState	09/06/2023	10:31	09/06/2023	13:01	HT	IN VIEW OF 220KV PARAS-CHIKHLI CKT 2 UNDER OUTAGE.
CHIKHALI-JALNA II	IntraState	09/06/2023	10:36	09/06/2023	13:08	HT	IN VIEW OF 220KV PARAS-CHIKHLI CKT 2 UNDER OUTAGE.
KANHAN-UMRED 1	IntraState	09/06/2023	10:38	09/06/2023	17:22	PO	FOR DIAGNOSTIC TESTING WORK.
PARAS-CHIKHALI CKT NO-II	IntraState	09/06/2023	10:40	09/06/2023	12:51	PO	REPLACEMENT OF JUMPER FROM LINE ISOLATOR 29D TO CT -R PHASE FOR ATTENDING HOT SPOT.
KARAD -NIGADE	IntraState	09/06/2023	10:59	09/06/2023	16:31	PO	Replacement work of Y & B Ph damaged jump between Bus to isolator.
KOLSHET - KHARBAO	IntraState	09/06/2023	13:04	09/06/2023	19:05	EO	1) R-phase line wave trap to line isolator jumper replacement due to hotspot of 150+ °C temperature 2) R-phase CT to CB jumper replacement. 3) R-phase Bus isolator to PT jumper Replacement.
WPCL-WARORA 2	IntraState	09/06/2023	13:25	09/06/2023	22:05	HT	CKT EMERGENCY HANDTRIPPED DUE TO BURNING OF WAVE TRAP AT WPCI END.
MALINAGAR - TEMBHURNI	IntraState	09/06/2023	16:40	09/06/2023	18:12	EO	Outage is required for Tree trimming coming under induction zone at Loc no. 79-80, 81-82
COLOURCHEM - TEMGHAR	IntraState	09/06/2023	22:32		Continued.	EO	To attend Hotspot on B phase jumper Cone at Line Incoming gantry near LA. Also Y phase WT jumper will be replace which looks deteriorated.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	08/06/2023	07:36	08/06/2023	11:30	PO	For 1) Premonsoon maintenance work & 2) RM work.
220/132KV 100 MVA ICT 2@ PETH	IntraState	08/06/2023	10:01	08/06/2023	12:16	PO	Structure Painting Work
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	08/06/2023	10:15	08/06/2023	16:05	PO	Plastic paper wrapping & RM Work
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	09/06/2023	07:06	09/06/2023	12:05	PO	Pre monsoon bus maintenance work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	09/06/2023	09:00	09/06/2023	12:45	PO	Plastic wrapping work to be carried out.
220/132 KV 80 MVA ICT 1	IntraState	09/06/2023	09:06	09/06/2023	12:01	EO	FOR REPLACEMENT OF HV Y PH LA DUE TO HIGH LCM VALUE.(IR CORRECTED-2025μA).
220/33KV 100MVA TF No.1 @ BOTHE	IntraState	09/06/2023	09:16	09/06/2023	12:28	PO	Overhauling work of drive mechanism of HV CB & Quarterly maintenance work
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	09/06/2023	10:35	09/06/2023	17:15	PO	Diagnostic testing & Quarterly maintenance work
220/132KV 100MVA ICT 1	IntraState	09/06/2023	11:35	09/06/2023	14:55	PO	PREMONSOON MAINTENANCE WORK
100 MVA 220/132 KV ICT - II	IntraState	09/06/2023	12:10	09/06/2023	18:01	PO	PREMONSOON MAINTENANCE WORK
220/33KV 50MVA PTR 2@ PETH	IntraState	09/06/2023	12:15	09/06/2023	15:30	PO	Structure painting work
220/33KV 100MVA TF No.2 @ BOTHE	IntraState	09/06/2023	12:30	09/06/2023	18:24	PO	Overhauling work of drive mechanism of HV CB & Quarterly maintenance work
220/132 KV 100 MVA ICT 1 @ BHENDA	IntraState	09/06/2023	18:05	09/06/2023	19:30	EO	To attend the red hot on 100MVA ICT -1 at LV Y Phase CT P1 Side
100 MVA 220/132 KV ICT - I	IntraState	09/06/2023	18:24	09/06/2023	19:43	PO	PREMONSOON MAINTENANCE WORK
100 MVA 220/132 KV ICT 2	IntraState	09/06/2023	18:40	09/06/2023	19:50	HT	LV SIDE PRV OPTD
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	09/06/2023	20:55	09/06/2023	23:33	PO	For 1) Premonsoon maintenance work & 2) RM work.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	07/06/2023	21:00	08/06/2023	04:55	PO	Tower erection & conductor shifting at loc 165
BHIRA (T) - KHOPOLI 2	IntraState	08/06/2023	07:25	08/06/2023	12:01	PO	Replacement of Porcelain LA on cable section on Tower

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage