

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Jun/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.188	1292.744	1) Gujrat	-3.938	17.745
2) Hydro	5.930	86.514	2) Madhya Pradesh	-0.168	28.054
3) Gas	6.777	58.681	3) Chattisgarh	2.320	21.710
Total MSPGCL	169.895	1437.939	4) Maharashtra	202.221	1641.980
B) 1) APLM	58.962	520.430	5) Goa (Amona)	-2.031	-17.739
2) JSWEL	26.104	217.188	Total	198.404	1691.750
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.576	380.983
4) RPL(AMT)	31.534	230.460	b) Mumbai Drawl	47.704	394.587
5) SWPGPL	12.252	98.112	c) MSEDCL Bilateral *	91.954	750.284
6) Other IPP	14.493	119.847	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.576	380.931
C) 1) TPCL Thermal	12.713	106.743	Include PX	0.000	0.000
2) TPCL Hydro	4.289	48.507	Standby	0.000	0.053
3) TPCL Gas	4.127	32.585	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.691	74.767	1) MSEDCL	474.159	4087.466
D) STATE			2) Mumbai Discoms	79.524	657.189
1) Thermal	323.937	2660.291	3) Other Discoms	11.594	93.192
(A1+C1+C4+(B1-B6))			TOTAL STATE	565.277	4837.847
2) Hydro	10.219	135.021			
(A2+C2)					
3) Gas	10.904	91.266			
(A3+B7+C3)					
4) Wind	7.295	133.618			
6) SOLAR	14.518	125.901			
TOTAL STATE	366.873	3146.097			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5924	6926	6966	6456
MSPGCL Hydro	113	114	407	209
MSPGCL Gas	277	276	283	285
MSPGCL Total Generation	6314	7316	7656	6950
Central Sector Receipt	8874	8962	8319	7887
WIND	206	273	148	295
CPP / IPP Thermal	5155	6084	6972	5193
CPP / IPP Gas	0	0	0	0
SOLAR	2083	1192	0	448
Exchange with Mumbai	-2374	-2334	-2019	-1565
MSEDCL DEMAND MET	19741	20981	20545	18711
Load Shedding	0	0	0	0
MSEDCL DEMAND	19741	20981	20545	18711
TPCL GENERATION	842	1022	913	652
AEML GENERATION	332	503	419	471
MUMBAI DEMAND	3548	3859	3351	2688
OTHER DISCOM DEMAND	517	512	531	497
STATE DEMAND MET	23806	25352	24427	21896
STATE DEMAND	23806	25352	24427	21896
Frequency (Hz)	49.96	49.97	49.96	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.13 Hz at 17.46 Hrs	49.77 Hz at 18.40 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.16	33.68	184	147
Unit 8	13.96	111.21	608	547
Unit 9	13.81	84.94	603	544
Unit 10	13.14	103.68	571	535
Total	45.07	333.50		
Bhusawal				
Unit 3	3.24	8.86	170	115
Unit 4	10.27	84.88	485	300
Unit 5	10.00	75.78	485	290
Total	23.50	169.52		
Parli				
Unit 6	3.35	34.93	225	0
Unit 7	3.39	26.47	230	0
Unit 8	4.05	35.03	229	144
Total	10.79	96.43		
Chandrapur				
Unit 3	3.57	29.64	164	125
Unit 4	3.60	30.04	168	128
Unit 5	0.00	49.84	0	0
Unit 6	0.03	43.23	32	0
Unit 7	9.50	73.43	470	308
Unit 8	10.12	82.06	450	299
Unit 9	11.38	57.09	500	310
Total	38.19	365.33		
Paras				
Unit 3	4.90	36.25	222	160
Unit 4	0.00	7.43	0	0
Total	4.90	43.68		
Khaparkheda				
Unit 1	3.78	29.18	170	130
Unit 2	4.16	35.57	195	139
Unit 3	4.06	21.59	175	143
Unit 4	4.35	34.87	188	144
Unit 5	11.48	89.06	490	455
Total	27.83	210.28		
Nasik				
Unit 3	3.54	27.49	173	129
Unit 4	0.00	19.19	0	0
Unit 5	3.37	27.31	163	118
Total	6.91	73.99		
Uran				
All Units	6.78	58.68	287	276
Total	6.78	58.68		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	0.26	51	0
Total	0.13	0.26		
Koyna				
Stage 1-2	2.68	26.79	475	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.02	25.21	21	0
Stage 3	0.45	12.38	80	0
Total	3.15	64.38		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	1.03	4.58	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.66	12.92	74	62
GHATGHAR	0.09	1.67	92	0
Total	2.78	22.14		
Wind				
Total	7.30	133.62	0	0
Total	7.30	133.62		
CPP				
APML(Mus)	58.96	520.43	0	0
JSWEL(Mus)	26.10	217.19	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.53	230.46	0	0
SWPGPL-Mus	12.25	98.11	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.00	45.86	268	219
Other(Mus)	4.10	36.76	0	0
JPL	4.40	37.22	269	129
Total	143.34	1186.04		
SOLAR				
Total	14.52	125.90	0	0
Total	14.52	125.90		
Tata				
Trombay 5	8.42	71.37	438	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	20.40	108	107
Trombay 7B	1.54	12.18	65	64
TATA Hydro	4.29	48.51	395	43
Trombay 8	4.29	35.38	227	131
Total	21.13	187.84		
AEML				
DTPS U-1&2	10.69	74.77	503	332
Total	10.69	74.77		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.19	1292.74	MSPGCL Total	169.90	1437.94
			MSPGCL Thml+Gas	163.96	1351.42	Koyna 1,2 & 4 Total	2.71	52.00
			MSPGCL Hydro	5.93	86.51	State Total	366.87	3146.10

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7116	223	285	7624	202	6838	0	0	7871	7786	-1901	20108	0	0	20108	3578	441	24127	49.98
2	6769	165	287	7221	239	6336	0	0	8375	8635	-2026	19998	0	0	19998	3331	407	23736	49.95
3	6733	164	285	7182	265	6052	0	0	8225	8213	-1894	19432	0	0	19432	3134	386	22952	50.00
4	6720	163	285	7168	348	5888	0	0	8165	7956	-1852	19127	0	0	19127	2988	381	22496	50.02
5	6390	162	284	6836	388	5474	0	0	8572	8281	-1867	18728	0	0	18728	2873	384	21985	49.98
6	6635	173	285	7093	313	5275	0	2	8675	8418	-1732	18941	0	0	18941	2822	428	22191	50.00
7	6354	219	284	6857	330	5249	0	115	8507	8677	-1683	19089	0	0	19089	2691	456	22236	50.01
8	6456	209	285	6950	295	5193	0	448	7735	7887	-1565	18711	0	0	18711	2688	497	21896	49.99
9	6109	177	285	6571	365	5166	0	871	7924	8215	-1808	18882	0	0	18882	2825	498	22205	50.02
10	5659	337	284	6280	390	5150	0	1452	8307	8419	-2018	19165	0	0	19165	3099	508	22772	49.99
11	6273	123	278	6674	270	5149	0	1942	8578	7988	-2106	19386	0	0	19386	3406	531	23323	49.95
12	5924	113	277	6314	206	5155	0	2083	8835	8874	-2374	19741	0	0	19741	3548	517	23806	49.96
13	6264	158	279	6701	220	5114	0	2151	8754	8555	-2379	19849	0	0	19849	3598	513	23960	49.94
14	6137	127	280	6544	406	5143	0	1804	8947	8689	-2144	19942	0	0	19942	3578	500	24020	49.99
15	6448	213	276	6937	343	5228	0	1533	9333	9309	-2267	20586	0	0	20586	3737	497	24820	49.97
16	6926	114	276	7316	273	6084	0	1192	9364	8962	-2334	20981	0	0	20981	3859	512	25352	49.97
17	6849	170	276	7295	323	6646	0	576	9237	8670	-2266	20720	0	0	20720	3745	524	24989	50.01
18	6771	181	279	7231	363	6506	0	303	8956	8534	-2035	20362	0	0	20362	3557	540	24459	50.04
19	6781	228	281	7290	248	6697	0	46	8783	8607	-2183	20166	0	0	20166	3358	539	24063	49.91
20	6966	407	283	7656	148	6972	0	0	8611	8319	-2019	20545	0	0	20545	3351	531	24427	49.96
21	6977	259	285	7521	118	7006	0	0	8332	7857	-1802	20193	0	0	20193	3355	507	24055	50.01
22	6702	461	287	7450	284	6995	0	0	7518	7294	-1732	19796	0	0	19796	3357	495	23648	50.02
23	6665	608	285	7558	490	7006	0	0	7228	7176	-1802	19912	0	0	19912	3455	516	23883	49.98
24	6564	776	286	7626	468	7023	0	0	7333	7083	-1915	19797	0	0	19797	3591	488	23876	49.98
MUs	157.19	5.93	6.78	169.90	7.30	143.35	0.00	14.52	202.17	198.40	-47.70	474.16	0.00	0.00	474.16	79.52	11.59	565.28	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Jun/2024

Position as on 6.30 Hrs of 09/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	16/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Chandrapur Unit 5	500	07/06/2024	09:57	09/06/2024	22:07	Suspected BTL	09/06/2024
MSPGCL	Chandrapur Unit 6	500	08/06/2024	00:14		Continued.	Boiler Tube Leakage	10/06/2024
MSPGCL	Uran Unit 8	108	09/06/2024	01:41	09/06/2024	17:53	Air Filter Replacement.	09/06/2024
MSPGCL	Uran Unit B0	120	09/06/2024	02:22	09/06/2024	08:29	Instrumentation problem	09/06/2024
Total Capacity MSPGCL		1933						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2253						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		966						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		966						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Jun/2024

Position as on 6.30 Hrs of 09/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV MAINBAY Outages/Trippings							
MAIN BAY (407) OF ICT-1 @ KUDUS	IntraState	09/06/2024	14:23	09/06/2024	18:13	PO	FOR Safety purpose to carry out R phase of ICT-2 bottom plate Oil leakage attending by main gasket replacement by M/s GE . Currently 400/220/33kV, 500MVA ICT-1 is charged through Spare ICT Unit as Rph Unit of ICT-1 is faulty. And its Neutral IPS is crossing thru ICT -2 units.
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	07/06/2024	19:06	08/06/2024	00:10	T	Attending sound observed at loc 112 & attend broken conductor strands at loc 28-29.
PARLI - KARJAT CKT - 1	IntraState	08/06/2024	05:51	08/06/2024	13:33	T	Y ph LA failure at Parly end
BABHALESHWAR - PADGHE CKT-1	IntraState	09/06/2024	01:56	09/06/2024	10:49	T	Tripped on distance protection
MAIN BUS-1 @ BABHALESHWAR	IntraState	09/06/2024	11:15	09/06/2024	16:05	PO	Connection of Hanger rod assembly on 400 kV Main Bus-I in Reactor-II Bay by Hot Line Method
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	09/06/2024	11:29	09/06/2024	16:57	EO	Attending red hot glow on B-ph 89L isolator
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/11.5KV STATION TRANSFORMER - 3 @ TIRORA	IntraState	08/06/2024	09:48	08/06/2024	19:03	PO	MCT Testing work
400/220/33 KV 501MVA ICT - 5 @ BABHALESHWAR	IntraState	08/06/2024	10:34	08/06/2024	20:41	PO	Bushing tan D testing work and bay maintenance work
400 KV BR Outages/Trippings							
50 MVAR BUS REACTOR - 1 @ JAIGAD	IntraState	04/06/2024	10:29	08/06/2024	16:00	PO	CSD RELAY INTALLATION AND COMMISIONING AT JAIGAD END
BUS REACTOR (125 MVAR) @ LONIKAND 2	IntraState	08/06/2024	08:46	08/06/2024	16:00	PO	DT and HYM
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
PANCHALI TSS - BOISAR (PG)	InterState	09/06/2024	05:46	09/06/2024	06:38	PO	Maintenance Work at Panchali TSS.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	07/06/2024	18:02	08/06/2024	14:05	T	Tripped on distance protection.
GHODBUNDER - MSETCL BOISAR	IntraState	07/06/2024	22:29	08/06/2024	07:01	PO	or the installation of saver assembly sets at TL no. 181, 182 & 184 (Total 24 sets to be installed).
BORIVALI - BOISAR II LINE	IntraState	07/06/2024	22:31	08/06/2024	07:06	PO	For the installation of saver assembly sets at TL no. 181, 182 & 184 (Total 24 sets to be installed).
WAGHIVALI - DHARAVI 8	IntraState	08/06/2024	00:14	08/06/2024	09:05	PO	MANDALE PROJECT WORK IN VICINITY
CHIKHALI-JALNA I	IntraState	08/06/2024	00:35	08/06/2024	00:44	T	Distance Protection
KOLSHET - KHARBAO	IntraState	08/06/2024	04:17	08/06/2024	15:47	T	Tripped on distance protection
AMBAZARI-KALMESHVAR	IntraState	08/06/2024	10:53	08/06/2024	11:42	PO	Testing work
NTT - BAPGAON	IntraState	08/06/2024	12:36	08/06/2024	16:42	PO	1) Currently 220kV Bapgaon-NTT line is tapped on 220kV AKP-Eklahare line & jumper at LILO tower to NTT is open towards 220kV Kalwa. Therefore during above work /s NTT will not have power supply during outage. 2) To open jumpers of 220 kV AKP-Nashik line at TL No. 396 to make portion of the line from loc no.396 to Eklahare dead for erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333. This arrangement will be kept for 2 days.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	08/06/2024	12:36	08/06/2024	16:42	PO	To open jumpers of 220 kV AKP-Nashik line at TL No. 396 to make portion of the line from loc no.396 to Eklahare dead for erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333. This arrangement will be kept for 2 days.
BOISAR II - VIRAJ	IntraState	08/06/2024	14:19	08/06/2024	17:57	PO	Pre Monsoon Maintenance.
MHAISAL - ALKUD	IntraState	08/06/2024	18:11	08/06/2024	21:24	PO	Wedge connector work
KHARGHAR - SONKHAR	IntraState	08/06/2024	22:40	09/06/2024	02:27	PO	FOR FIXING OF 220KV SONKHAR LINE B PHASE BUSHING AFTER CONNECTION OF NEW CABLE END TERMINATION AND STRAIGHT JOINT
NERLE - PEDAMBE	IntraState	09/06/2024	01:26	09/06/2024	02:36	T	Tripped on distance protection
PADGHE - NALASOPARA	IntraState	09/06/2024	06:03	09/06/2024	10:56	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PIRANGUT - HINJAWADI 2	IntraState	09/06/2024	07:32	09/06/2024	16:37	PO	Erection of monopole Loc No. 154 & 155 for height raising purpose and stringing of conductor at New Monopole Loc. No. 154-155
VIKHROLI (GIS) - SAKI 7	IntraState	09/06/2024	11:01	09/06/2024	18:11	PO	ATTENDING HOT SPOT
SADAWAGHAPUR KARAD CKT 2	IntraState	09/06/2024	11:26	09/06/2024	13:12	HT	Emergency outage availed by Karad
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	09/06/2024	23:20		Continued.	T	Tripped on distance protection from Nashik end only.
SADAWAGHAPUR KARAD CKT 1	IntraState	09/06/2024	23:43	09/06/2024	11:16	HT	HT due to sparking at Karad end Bph WT
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 200 MVA PTR NO 5 @ PARVATI	IntraState	08/06/2024	07:50	08/06/2024	12:55	PO	For 132 kV Half Bus Maint. work before monsoon
220 / 110 / 33kV 250MVA ICT 2 @ BORIVALI (TATA)	IntraState	08/06/2024	08:08	08/06/2024	09:09	PO	BIRD NEST REMOVAL
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	08/06/2024	09:35	08/06/2024	14:03	PO	Pre-monsoon maintenance work & main tank oil top up
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	08/06/2024	10:06	08/06/2024	15:18	PO	1) Diagnostic testing, premonsoon work,Attending oil leakage 2) Premonsoon work.
220/100 KV 200 MVA ICT 1 @ APTA	IntraState	08/06/2024	10:14	08/06/2024	11:40	PO	"1. CTR NIFPS reinstallation and preventive maintenance work 2.Arresting of oil leakages 3. Bay maintenance work"
220/33 KV 25MVA PTR2 @ NIWALI	IntraState	08/06/2024	10:21	09/06/2024	13:15	PO	HV CB overhauling work
220/132 KV 100 MVA ICT 1 @ BALAPUR	IntraState	08/06/2024	11:38	08/06/2024	18:00	PO	Oil Top Up work
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	08/06/2024	11:45	08/06/2024	12:34	PO	Pre monsoon polythene paper wrapping work.
220/132 KV 100MVA ICT - 1 @ MANMAD	IntraState	08/06/2024	13:08	08/06/2024	17:42	PO	Diagnostic Testing work & Quarterly Bay maintenance work.
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	08/06/2024	16:17	08/06/2024	17:21	PO	1) Diagnostic testing, premonsoon work,Attending oil leakage 2) Premonsoon work.
220/132kV 100 MVA ICT- 2 @ PALGHAR-220 KV	IntraState	09/06/2024	06:35	09/06/2024	06:47	HT	HT for safety purpose since Palghar ss went into dark
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	09/06/2024	11:13	09/06/2024	13:55	PO	For Premonsoon maintenance work, CTR AMC, Hotspot attending, Panel shifting at 100kV Vasai.
220/132 KV 100 MVA ICT 1 @ BUTIBORI	IntraState	09/06/2024	15:11	09/06/2024	19:01	EO	Oil leakage on Y ph bushing
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1& 2) @ KHOPOLI	IntraState	09/06/2024	06:51	09/06/2024	13:46	PO	R/M AND TESTING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage