

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 08/Jul/2019 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 106.052        | 887.927         | 1) Gujrat                      | -2.629         | -33.248         |
| 2) Hydro            | 5.576          | 32.405          | 2) Madhya Pradesh              | 10.659         | 64.028          |
| 3) Gas              | 9.191          | 57.908          | 3) Chattisgarh                 | 4.810          | 35.320          |
| <b>Total MSPGCL</b> | <b>120.819</b> | <b>978.240</b>  | 4) Maharashtra                 | 95.189         | 725.305         |
| B) 1) APMIL         | 50.366         | 412.934         | 5) Goa (Amona)                 | -0.616         | -4.136          |
| 2) JSWEL            | 20.107         | 159.823         | <b>Total</b>                   | <b>107.413</b> | <b>787.269</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 23.532         | 163.727         |
| 4) RPL(AMT)         | 0.000          | 3.657           | b) Mumbai Drawl                | 31.355         | 219.208         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 6.940          | 29.689          |
| 6) Other IPP        | 2.871          | 21.069          | Include PX                     | -4.419         | -70.319         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 23.532         | 163.727         |
| C) 1) TPCL Thermal  | 12.235         | 100.197         | Include PX                     | 8.450          | 60.894          |
| 2) TPCL Hydro       | 4.960          | 31.971          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.803          | 28.586          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.278          | 74.418          | 1) MSEDCL                      | 331.714        | 2610.608        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 60.634         | 454.381         |
| 1) Thermal          | 200.909        | 1660.025        | <b>TOTAL STATE</b>             | <b>392.348</b> | <b>3064.989</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 10.536         | 64.376          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.994         | 86.494          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 57.089         | 435.581         |                                |                |                 |
| 6) SOLAR            | 4.404          | 31.243          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>284.932</b> | <b>2277.719</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4507                      | 4531                  | 4406                      | 4507                      |
| MSPGCL Hydro             | 193                       | 238                   | 339                       | 64                        |
| MSPGCL Gas               | 405                       | 387                   | 394                       | 400                       |
| MSPGCL Total Generation  | 5105                      | 5156                  | 5139                      | 4971                      |
| Central Sector Receipt   | 5133                      | 4612                  | 5049                      | 3412                      |
| WIND                     | 2448                      | 2604                  | 2395                      | 2184                      |
| CPP / IPP Thermal        | 3286                      | 2807                  | 3464                      | 2735                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 387                       | 560                   | 0                         | 0                         |
| Exchange with Mumbai     | -1486                     | -1666                 | -1417                     | -840                      |
| <b>MSEDCL DEMAND MET</b> | <b>14873</b>              | <b>14073</b>          | <b>14630</b>              | <b>12462</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14873                     | 14073                 | 14630                     | 12462                     |
| TPCL GENERATION          | 973                       | 1009                  | 948                       | 609                       |
| AEML GENERATION          | 374                       | 373                   | 407                       | 374                       |
| <b>MUMBAI DEMAND</b>     | <b>2833</b>               | <b>3048</b>           | <b>2772</b>               | <b>1823</b>               |
| STATE DEMAND MET         | 17706                     | 17121                 | 17402                     | 14285                     |
| <b>STATE DEMAND</b>      | <b>17706</b>              | <b>17121</b>          | <b>17402</b>              | <b>14285</b>              |
| Frequency (Hz)           | 50.04                     | 49.98                 | 49.98                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 08.02 Hrs | 49.83 Hz at 06.15 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 08/Jul/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.26         | 21.58         | 155      | 120      |
| Unit 7             | 0.00         | 11.71         | 0        | 0        |
| Unit 8             | 7.70         | 66.14         | 371      | 256      |
| Unit 9             | 8.34         | 62.92         | 450      | 295      |
| Unit 10            | 8.02         | 15.71         | 440      | 246      |
| <b>Total</b>       | <b>27.33</b> | <b>178.07</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.58         | 75.12         | 500      | 360      |
| Unit 5             | 9.27         | 73.46         | 450      | 350      |
| <b>Total</b>       | <b>18.85</b> | <b>148.57</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.97         | 10.07         | 145      | 75       |
| Unit 4             | 3.46         | 27.91         | 157      | 103      |
| Unit 5             | 5.50         | 56.04         | 243      | 205      |
| Unit 6             | 5.11         | 54.69         | 260      | 180      |
| Unit 7             | 6.30         | 57.06         | 290      | 246      |
| Unit 8             | 5.98         | 60.73         | 260      | 220      |
| Unit 9             | 6.26         | 58.32         | 270      | 250      |
| <b>Total</b>       | <b>35.58</b> | <b>324.82</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.02         | 39.29         | 250      | 185      |
| Unit 4             | 0.00         | 23.68         | 0        | 0        |
| <b>Total</b>       | <b>5.02</b>  | <b>62.97</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.98         | 24.51         | 140      | 110      |
| Unit 2             | 2.28         | 13.75         | 130      | 80       |
| Unit 3             | 3.24         | 27.91         | 151      | 125      |
| Unit 4             | 3.44         | 26.95         | 160      | 130      |
| Unit 5             | 0.00         | 3.85          | 0        | 0        |
| <b>Total</b>       | <b>11.93</b> | <b>96.97</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.24         | 30.69         | 166      | 0        |
| Unit 4             | 4.10         | 32.09         | 196      | 158      |
| Unit 5             | 0.00         | 13.74         | 0        | 0        |
| <b>Total</b>       | <b>7.34</b>  | <b>76.52</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 9.19         | 57.91         | 405      | 274      |
| <b>Total</b>       | <b>9.19</b>  | <b>57.91</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 0.00          | 0        | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 1.52         | 10.88         | 220      | 35       |
| Stage 4         | 0.00         | 0.23          | 0        | 0        |
| Stage 3         | 1.76         | 9.48          | 160      | 0        |
| <b>Total</b>    | <b>3.28</b>  | <b>20.59</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.00          | 0        | 0        |
| VTRNA           | 0.00         | 0.79          | 0        | 0        |
| TILLARI         | 0.54         | 1.98          | 60       | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.43         | 3.23          | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 0.00          | 0        | 0        |
| BHANDARDRA      | 0.28         | 0.78          | 34       | 0        |
| ELDARY          | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.56         | 0.56          | 24       | 23       |
| GHATGHAR        | 0.48         | 4.46          | 125      | 0        |
| <b>Total</b>    | <b>2.30</b>  | <b>11.81</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 57.09        | 435.58        | 0        | 0        |
| <b>Total</b>    | <b>57.09</b> | <b>435.58</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 50.37        | 412.93        | 0        | 0        |
| JSWEL(Mus)      | 20.11        | 159.82        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 3.66          | 0        | 0        |
| WPCL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| Other(Mus)      | 2.87         | 21.07         | 0        | 0        |
| <b>Total</b>    | <b>73.34</b> | <b>597.48</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 4.40         | 31.24         | 0        | 0        |
| <b>Total</b>    | <b>4.40</b>  | <b>31.24</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 7.48         | 61.95         | 400      | 291      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 1.60         | 17.42         | 115      | 56       |
| Trombay 7B      | 1.21         | 11.17         | 65       | 46       |
| Trombay 8       | 4.75         | 38.25         | 202      | 193      |
| TATA Hydro      | 4.96         | 31.97         | 395      | 4        |
| <b>Total</b>    | <b>20.00</b> | <b>160.75</b> |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 9.28         | 74.42         | 497      | 372      |
| <b>Total</b>    | <b>9.28</b>  | <b>74.42</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 106.05      | 887.93        | MSPGCL Total        | 120.82      | 978.24        |
|                |             |         | MSPGCL Thml+Gas | 115.24      | 945.84        | Koyna 1,2 & 4 Total | 1.52        | 11.11         |
|                |             |         | MSPGCL Hydro    | 5.58        | 32.40         | State Total         | 284.93      | 2277.72       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 08/Jul/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4502        | 189  | 274  | 4965   | 2265  | 2935      | 0    | 0     | 3531        | 3681        | -1186                | 12660                 | 0                    | 12660                     | 2177             | 14837           | 50.00         |
| 2                  | 4500        | 123  | 307  | 4930   | 2152  | 2757      | 0    | 0     | 3423        | 3631        | -1019                | 12451                 | 0                    | 12451                     | 2006             | 14457           | 50.04         |
| 3                  | 4527        | 59   | 340  | 4926   | 2239  | 2750      | 0    | 0     | 3569        | 3592        | -897                 | 12610                 | 0                    | 12610                     | 1881             | 14491           | 50.03         |
| 4                  | 4507        | 64   | 400  | 4971   | 2184  | 2735      | 0    | 0     | 3143        | 3412        | -840                 | 12462                 | 0                    | 12462                     | 1823             | 14285           | 50.02         |
| 5                  | 4512        | 69   | 389  | 4970   | 2254  | 2740      | 0    | 0     | 3246        | 3835        | -833                 | 12966                 | 0                    | 12966                     | 1816             | 14782           | 50.02         |
| 6                  | 4498        | 64   | 397  | 4959   | 2037  | 2759      | 0    | 0     | 4195        | 4763        | -934                 | 13584                 | 0                    | 13584                     | 1914             | 15498           | 49.96         |
| 7                  | 4550        | 328  | 397  | 5275   | 1995  | 3178      | 0    | 35    | 4575        | 5429        | -1067                | 14845                 | 0                    | 14845                     | 2045             | 16890           | 49.94         |
| 8                  | 4752        | 149  | 403  | 5304   | 2059  | 3422      | 0    | 144   | 4880        | 5162        | -1220                | 14871                 | 0                    | 14871                     | 2245             | 17116           | 50.07         |
| 9                  | 4654        | 128  | 405  | 5187   | 2246  | 3409      | 0    | 318   | 4967        | 4993        | -1352                | 14801                 | 0                    | 14801                     | 2554             | 17355           | 50.08         |
| 10                 | 4507        | 193  | 405  | 5105   | 2448  | 3286      | 0    | 387   | 5064        | 5133        | -1486                | 14873                 | 0                    | 14873                     | 2833             | 17706           | 50.04         |
| 11                 | 4451        | 221  | 403  | 5075   | 2520  | 2985      | 0    | 501   | 4799        | 5053        | -1620                | 14514                 | 0                    | 14514                     | 3042             | 17556           | 50.02         |
| 12                 | 4463        | 267  | 399  | 5129   | 2465  | 3026      | 0    | 596   | 5006        | 4730        | -1672                | 14274                 | 0                    | 14274                     | 3059             | 17333           | 50.03         |
| 13                 | 4531        | 238  | 387  | 5156   | 2604  | 2807      | 0    | 560   | 4497        | 4612        | -1666                | 14073                 | 0                    | 14073                     | 3048             | 17121           | 49.98         |
| 14                 | 4346        | 238  | 386  | 4970   | 2635  | 2772      | 0    | 556   | 4530        | 4468        | -1595                | 13806                 | 0                    | 13806                     | 2952             | 16758           | 50.00         |
| 15                 | 4296        | 238  | 392  | 4926   | 2834  | 2726      | 0    | 445   | 4317        | 4429        | -1569                | 13791                 | 0                    | 13791                     | 2950             | 16741           | 49.94         |
| 16                 | 4244        | 248  | 394  | 4886   | 2643  | 2738      | 0    | 423   | 4460        | 4458        | -1563                | 13585                 | 0                    | 13585                     | 2946             | 16531           | 50.02         |
| 17                 | 4229        | 238  | 383  | 4850   | 2772  | 2743      | 0    | 298   | 4513        | 4458        | -1534                | 13587                 | 0                    | 13587                     | 2920             | 16507           | 50.00         |
| 18                 | 4226        | 388  | 392  | 5006   | 2751  | 2748      | 0    | 119   | 4259        | 4665        | -1485                | 13804                 | 0                    | 13804                     | 2870             | 16674           | 49.97         |
| 19                 | 4271        | 427  | 385  | 5083   | 2410  | 2969      | 0    | 22    | 4586        | 5029        | -1466                | 14047                 | 0                    | 14047                     | 2810             | 16857           | 50.03         |
| 20                 | 4406        | 339  | 394  | 5139   | 2395  | 3464      | 0    | 0     | 4966        | 5049        | -1417                | 14630                 | 0                    | 14630                     | 2772             | 17402           | 49.98         |
| 21                 | 4263        | 252  | 385  | 4900   | 2495  | 3602      | 0    | 0     | 4728        | 4744        | -1282                | 14459                 | 0                    | 14459                     | 2682             | 17141           | 50.01         |
| 22                 | 4231        | 282  | 395  | 4908   | 2479  | 3614      | 0    | 0     | 3834        | 4411        | -1267                | 14145                 | 0                    | 14145                     | 2532             | 16677           | 50.02         |
| 23                 | 4283        | 495  | 394  | 5172   | 2167  | 3644      | 0    | 0     | 3540        | 3881        | -1275                | 13589                 | 0                    | 13589                     | 2413             | 16002           | 49.99         |
| 24                 | 4303        | 339  | 385  | 5027   | 2040  | 3535      | 0    | 0     | 3687        | 3795        | -1110                | 13287                 | 0                    | 13287                     | 2341             | 15628           | 50.05         |
| MUs                | 106.05      | 5.58 | 9.19 | 120.82 | 57.09 | 73.34     | 0.00 | 4.40  | 102.32      | 107.41      | -31.35               | 331.71                | 0.00                 | 331.71                    | 60.63            | 392.34          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 08/Jul/2019**

**Position as on 6.30 Hrs of 09/Jul/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                  |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                      |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.              |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                     |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.(water shortage from 25/06/2019)   |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                    |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                    |               |
| MSPGCL                | Parli Unit 8            | 250      | 04/06/2019   | 00.00        |            | Continued. | Zero Schedule (converted to AOH from 25/06/2019) |               |
| MSPGCL                | Koyna Unit 6            | 80       | 17/06/2019   | 08.40        |            | Continued. | needle stuck up problem.                         |               |
| IPP                   | Adani U-4               | 660      | 19/06/2019   | 16.09        |            | Continued. | MS Drain Bonnet Leakage.                         |               |
| MSPGCL                | Parli Unit 7            | 250      | 25/06/2019   | 09.45        |            | Continued. | Water Shortage                                   |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 28/06/2019   | 18.35        |            | Continued. | Zero schedule.                                   |               |
| IPP                   | RPL(AMT) U-2            | 270      | 29/06/2019   | 00.00        |            | Continued. | Zero schedule.                                   |               |
| IPP                   | RPL(AMT) U-5            | 270      | 29/06/2019   | 03.00        |            | Continued. | Zero Schedule.                                   |               |
| IPP                   | RPL(AMT) U-1            | 270      | 30/06/2019   | 16.00        |            | Continued. | Zero Schedule                                    |               |
| IPP                   | RPL(AMT) U-3            | 270      | 01/07/2019   | 00.00        |            | Continued. | ZERO SCHEDULE.                                   |               |
| IPP                   | Dhariwal                | 300      | 01/07/2019   | 00.01        |            | Continued. | NO SCHEDULE                                      |               |
| IPP                   | RPL(AMT) U-4            | 270      | 01/07/2019   | 17.45        |            | Continued. | Zero schedule.                                   |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 01/07/2019   | 19.15        | 08/07/2019 | 04.41      | Water Box Cleaning and Maintenance work          |               |
| MSPGCL                | Khaparkheda Unit 5      | 500      | 02/07/2019   | 01.25        |            | Continued. | Generator Elect. Fault                           |               |
| MSPGCL                | Nasik Unit 5            | 210      | 04/07/2019   | 15.27        |            | Continued. | Zero Schedule.                                   |               |
| MSPGCL                | Koradi Unit 7           | 210      | 05/07/2019   | 21.16        |            | Continued. | Heavy steam leakage                              |               |
| MSPGCL                | Paras Unit 4            | 250      | 06/07/2019   | 15.32        | 09/07/2019 | 06.39      | Coal mill problem                                |               |
| MSPGCL                | Uran Unit 6             | 108      | 07/07/2019   | 20.53        | 08/07/2019 | 00.26      | Boiler Protection.                               |               |
| MSPGCL                | Nasik Unit 3            | 210      | 08/07/2019   | 19.56        |            | Continued. | Zero Schedule.                                   |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/Jul/2019**

**Statement-VII**

Position as on 6.30 Hrs of 09/Jul/2019

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                        |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                         |
| Karad Solapur (PG)                           | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                |
| Dhule Sar'Sarovar II                         | InterState                | 27/06/2019   | 19.16        |            | Continued. | HT          | Over Voltage                                                                                                            |
| Khadka-Aurangabad (Waluj)                    | IntraState                | 29/06/2019   | 16.33        |            | Continued. | HT          | Over Voltage                                                                                                            |
| Akola II - RPL(Rattanindia) Ckt-II           | IntraState                | 01/07/2019   | 21.50        |            | Continued. | T           | Over Voltage                                                                                                            |
| Dhule- Bableshwar - I                        | IntraState                | 07/07/2019   | 11.04        | 08/07/2019 | 08.57      | HT          | Over voltage at Bableshwar.                                                                                             |
| Lonikand I - Koyna stage-IV                  | IntraState                | 08/07/2019   | 01.31        | 08/07/2019 | 07.30      | HT          | Over Voltage                                                                                                            |
| koaradi II - Wardha(PG)                      | IntraState                | 08/07/2019   | 22.04        |            | Continued. | T           | Distance Protection                                                                                                     |
| Dhule - Bableshwar - II                      | IntraState                | 08/07/2019   | 23.15        |            | Continued. | HT          | Over Voltage                                                                                                            |
| Lonikand I - Koyna stage-IV                  | IntraState                | 09/07/2019   | 00.58        |            | Continued. | HT          | Over Voltage                                                                                                            |
| <b>400 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                         |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe          | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                                                               |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2   | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.                                                                  |
| 400/220/33 Kv 315 MVA ICT II @Chandrapur GCR | IntraState                | 24/06/2019   | 14.14        |            | Continued. | PO          | Oil Filtration Work due to High PPM.                                                                                    |
| 400/220kv 315 Mva ICT I @Karad               | IntraState                | 08/07/2019   | 09.33        |            | Continued. | PO          | Replacement of Old Panel Replay Under Les.                                                                              |
| 400/220kv Spare Ict 1 105 Mva @Karad         | IntraState                | 08/07/2019   | 09.33        |            | Continued. | PO          | Replacement of Old Panel Relay Under Les.                                                                               |
| 400/220/33kv, 500 Mva Ict-2 @Khaparkheda     | IntraState                | 08/07/2019   | 11.58        | 08/07/2019 | 16.33      | PO          | Attending Oil Leakage                                                                                                   |
| <b>220 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                         |
| Talandage - Chikodi                          | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                             |
| Mudshingi - Chikodi                          | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                            |
| BOISAR BORIVALI                              | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                                                            |
| Chandrapur GCR - Warora - I                  | IntraState                | 24/06/2019   | 14.01        |            | Continued. | HT          | Outage on Chandrapur ICT 2.                                                                                             |
| Bableshwar -Bhenda                           | IntraState                | 08/07/2019   | 09.39        | 08/07/2019 | 16.30      | HT          | Avail Outage On Main Bus Section At Bhenda SS.                                                                          |
| Badnera-Akola li                             | IntraState                | 08/07/2019   | 11.12        | 08/07/2019 | 19.42      | PO          | Erection of Tower At Loc NO.8                                                                                           |
| Badnera-Akola I                              | IntraState                | 08/07/2019   | 11.12        | 08/07/2019 | 19.43      | PO          | Erection of Tower At Loc No.8                                                                                           |
| Koyna (Pophali) - Kdph                       | IntraState                | 08/07/2019   | 12.05        | 08/07/2019 | 18.15      | T           | Distance Protection, R-Ph, Z1, 6.03KA, 8.25KM, Patrolling In Progress.                                                  |
| Chikhli-Jalna-I                              | IntraState                | 08/07/2019   | 12.05        | 08/07/2019 | 13.32      | PO          | For DC Separation of Control And Relay Panel.                                                                           |
| Chikhli-Jalna-II                             | IntraState                | 08/07/2019   | 13.35        | 08/07/2019 | 14.07      | PO          | For DC Separation of Control And Relay Panel.                                                                           |
| Nalasopara-Boisar                            | IntraState                | 08/07/2019   | 16.46        | 08/07/2019 | 18.05      | PO          | Y-Phase jumper replacement.                                                                                             |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                         |
| 220/132 kV 200 MVA ICT-III @ Nanded          | IntraState                | 08/07/2019   | 19.50        | 08/07/2019 | 20.20      | T           | 132KV Bus Bar Operated.                                                                                                 |
| 220/132 kV 200 MVA ICT- I @ Nanded           | IntraState                | 08/07/2019   | 19.50        | 08/07/2019 | 20.20      | T           | 132KV Bus Bar Operated.                                                                                                 |
| <b>132 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                         |
| Amalner - Nardhana                           | IntraState                | 23/06/2019   | 20.02        |            | Continued. | T           | DISTANCE PROTECTION NRD--> Y, PHASE, IY=8.33KA, IB=8.309KA, 45.86KM 5 NO TOWERS COLLAPSED TOWER NO 9 TO 13 FROM AMALNER |
| Waghala-Vishnupuri Ckt 2                     | IntraState                | 08/07/2019   | 19.20        | 08/07/2019 | 20.20      | T           | 132KV Bus Bar Operated.                                                                                                 |
| Waghala (Nanded2) - Elichpur                 | IntraState                | 08/07/2019   | 19.50        | 08/07/2019 | 20.20      | T           | 132KV Bus Bar Operated.                                                                                                 |
| Waghala(Nanded2) - Ardhapur                  | IntraState                | 08/07/2019   | 19.50        | 08/07/2019 | 20.20      | T           | R-Ph, TBC CT Flash Over.                                                                                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/Jul/2019**

**Statement-VII**

Position as on 6.30 Hrs of 09/Jul/2019

| Name of Line                  | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage         |
|-------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------------|
| Nanded - Umri II              | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | 132KV Bus Bar Operated.  |
| Main Bus @ Nanded             | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | R-Ph, TBC CT Flash Over. |
| Nanded - Jangamwadi II        | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | R-Ph, TBC CT Flash Over. |
| Nanded - Kandhar              | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | 132KV Bus Bar Operated.  |
| Waghala (Nanded2) - Umri 1    | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | R-Ph, TBC CT Flash Over. |
| Waghala -Nanded-I(Jangamwadi) | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | R-Ph, TBC CT Flash Over. |
| Waghala (Nanded2) - Narsi     | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | R-Ph, TBC CT Flash Over. |
| Waghala-Vishnupurickt1        | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | 132KV Bus Bar Operated.  |
| Waghala (Nanded2) - Tamsa     | IntraState                   | 08/07/2019      | 19.50           | 08/07/2019 | 20.20         | T              | 132KV Bus Bar Operated.  |