

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Jul/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	113.813	1046.041	1) Gujrat	-10.931	-81.164
2) Hydro	9.860	90.304	2) Madhya Pradesh	3.998	40.209
3) Gas	3.227	39.618	3) Chattisgarh	3.810	30.260
Total MSPGCL	126.900	1175.963	4) Maharashtra	151.595	1256.086
B) 1) APLM	50.356	395.528	5) Goa (Amona)	-1.355	-9.803
2) JSWEL	14.170	113.404	Total	147.117	1235.588
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.157	266.141
4) RPL(AMT)	24.409	152.036	b) Mumbai Drawl	36.526	290.094
5) SWPGPL	8.769	62.082	c) MSEDCL Bilateral *	69.679	615.305
6) Other IPP	8.004	62.153	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.157	264.097
C) 1) TPCL Thermal	10.317	70.980	Include PX	0.000	0.000
2) TPCL Hydro	3.596	24.524	Standby	0.000	2.044
3) TPCL Gas	0.000	6.389	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.392	83.893	1) MSEDCL	387.285	3229.179
D) STATE			2) Mumbai Discoms	60.831	475.881
1) Thermal	240.230	1986.117	3) Other Discoms	8.945	71.354
(A1+C1+C4+(B1-B6))			TOTAL STATE	457.061	3776.414
2) Hydro (A2+C2)	13.456	114.828			
3) Gas (A3+B7+C3)	3.227	46.007			
4) Wind	49.343	336.803			
6) SOLAR	3.688	57.070			
TOTAL STATE	309.944	2540.825			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4848	4620	4598	5047
MSPGCL Hydro	465	471	733	265
MSPGCL Gas	129	129	138	140
MSPGCL Total Generation	5442	5220	5469	5452
Central Sector Receipt	7804	7376	5999	4555
WIND	1773	2046	2694	1525
CPP / IPP Thermal	4721	4021	4334	4715
CPP / IPP Gas	0	0	0	0
SOLAR	446	511	0	0
Exchange with Mumbai	-2219	-2196	-1524	-935
MSEDCL DEMAND MET	17555	16587	16574	14999
Load Shedding	0	0	0	0
MSEDCL DEMAND	17555	16587	16574	14999
TPCL GENERATION	498	489	866	470
AEML GENERATION	360	402	394	435
MUMBAI DEMAND	3077	3087	2784	1840
OTHER DISCOM DEMAND	412	391	398	313
STATE DEMAND MET	21044	20065	19756	17152
STATE DEMAND	21044	20065	19756	17152
Frequency (Hz)	49.99	50.02	50.01	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 14.00 Hrs	49.62 Hz at 09.41 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.58	16.11	135	65
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	0.00	46.99	0	0
Unit 10	11.94	91.34	520	440
Total	14.52	197.71		
Bhusawal				
Unit 3	3.02	24.19	140	115
Unit 4	8.76	73.34	425	285
Unit 5	8.95	60.57	435	290
Total	20.73	158.10		
Parli				
Unit 6	4.84	40.58	238	152
Unit 7	4.45	35.03	227	140
Unit 8	0.00	0.00	0	0
Total	9.29	75.61		
Chandrapur				
Unit 3	2.01	20.10	110	44
Unit 4	1.64	21.78	102	45
Unit 5	6.60	57.84	300	255
Unit 6	6.37	53.02	318	218
Unit 7	0.00	0.00	0	0
Unit 8	10.46	81.21	482	400
Unit 9	10.19	80.60	456	377
Total	37.27	314.55		
Paras				
Unit 3	3.04	33.81	191	86
Unit 4	3.68	33.87	180	133
Total	6.71	67.68		
Khaparkheda				
Unit 1	2.00	23.16	105	0
Unit 2	2.38	24.64	120	80
Unit 3	0.00	24.69	0	0
Unit 4	0.00	0.00	0	0
Unit 5	10.65	79.58	480	320
Total	15.03	152.07		
Nasik				
Unit 3	3.74	29.81	184	126
Unit 4	3.32	27.06	158	123
Unit 5	3.20	23.45	155	119
Total	10.26	80.33		
Uran				
All Units	3.23	39.62	140	127
Total	3.23	39.62		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.22	1.21	34	0
Total	0.22	1.21		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.04	18.20	375	40
Stage 4	0.00	7.89	0	0
Stage 3	1.44	10.77	80	0
Total	3.49	36.87		
Hydro				
KDPH	0.00	0.65	0	0
VTRNA	0.40	5.56	60	0
TILLARI	0.35	2.36	58	0
BHIRA T.R.	0.42	2.23	80	0
SMLHY_PTN	4.99	41.44	225	176
GHATGHAR	0.00	0.00	0	0
Total	6.15	52.23		
Wind				
Total	49.34	336.80	0	0
Total	49.34	336.80		
CPP				
APML(Mus)	50.36	395.53	0	0
JSWEL(Mus)	14.17	113.40	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.41	152.04	0	0
SWPGPL-Mus	8.77	62.08	0	0
Other(Mus)	8.00	62.15	0	0
Total	105.71	785.20		
SOLAR				
Total	3.69	57.07	0	0
Total	3.69	57.07		
Tata				
Trombay 5	6.54	36.82	350	258
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.82	0	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	3.60	24.52	424	34
Trombay 8	3.78	34.16	210	135
Total	13.91	101.89		
AEMIL				
DTPS U-1&2	10.39	83.89	495	360
Total	10.39	83.89		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	113.81	1046.04	MSPGCL Total	126.90	1175.96
			MSPGCL Thml+Gas	117.04	1085.66	Koyna 1,2 & 4 Total	2.04	26.09
			MSPGCL Hydro	9.86	90.30	State Total	309.94	2540.82

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 08/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5108	280	130	5518	1766	4381	0	0	4665	4833	-949	15205	0	15205	2136	344	17685	50.02
2	5153	263	140	5556	1593	4450	0	0	4537	5280	-892	15663	0	15663	1997	324	17984	50.03
3	5070	263	130	5463	1591	4630	0	0	4592	4481	-849	15021	0	15021	1888	295	17204	50.02
4	5047	265	140	5452	1525	4715	0	0	4539	4555	-935	14999	0	14999	1840	313	17152	50.01
5	5011	251	130	5392	1495	4671	0	0	5025	5067	-950	15380	0	15380	1818	295	17493	50.01
6	4998	317	140	5455	1608	4812	0	0	5823	6227	-1107	16656	0	16656	1930	339	18925	50.02
7	5048	734	130	5912	1663	4884	0	38	6341	6663	-1181	17603	0	17603	2089	376	20068	50.01
8	5000	611	140	5751	1601	4792	0	118	6836	7080	-1351	17613	0	17613	2283	378	20274	50.01
9	4905	510	130	5545	1653	4813	0	299	7284	7490	-1699	17708	0	17708	2603	393	20704	50.00
10	4821	455	140	5416	1558	4841	0	340	7738	7837	-2015	17562	0	17562	2881	415	20858	49.85
11	4848	465	129	5442	1773	4721	0	446	8284	7804	-2219	17555	0	17555	3077	412	21044	49.99
12	4738	463	139	5340	1883	4243	0	423	8208	7796	-2265	17011	0	17011	3131	409	20551	50.03
13	4620	471	129	5220	2046	4021	0	511	7574	7376	-2196	16587	0	16587	3087	391	20065	50.02
14	4473	460	139	5072	2120	3906	0	478	6949	6817	-2083	15930	0	15930	2948	380	19258	50.09
15	4425	429	138	4992	2427	3781	0	417	6769	6671	-2091	15820	0	15820	2935	377	19132	50.04
16	4436	390	137	4963	2675	3771	0	304	6592	6084	-2002	15414	0	15414	2919	381	18714	50.01
17	4335	343	127	4805	2811	3791	0	195	6196	5943	-1945	15208	0	15208	2884	392	18484	50.02
18	4373	315	137	4825	2965	3787	0	109	6759	6335	-1864	15748	0	15748	2845	409	19002	50.05
19	4213	355	128	4696	2757	3609	0	10	7212	7313	-1702	16279	0	16279	2806	404	19489	50.04
20	4598	733	138	5469	2694	4334	0	0	6080	5999	-1524	16574	0	16574	2784	398	19756	50.01
21	4671	383	130	5184	2351	4865	0	0	5838	5468	-1248	16219	0	16219	2672	401	19292	49.99
22	4744	378	138	5260	2124	4817	0	0	4962	5123	-1264	15676	0	15676	2528	384	18588	50.03
23	4676	358	129	5163	2324	4788	0	0	4656	4379	-1059	15217	0	15217	2426	378	18021	50.03
24	4502	368	139	5009	2340	4285	0	0	4931	4496	-1136	14637	0	14637	2324	357	17318	50.03
MUs	113.81	9.86	3.23	126.90	49.34	105.71	0.00	3.69	148.39	147.12	-36.53	387.28	0.00	387.28	60.83	8.95	457.06	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Jul/2022

Position as on 6.30 Hrs of 09/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Parli Unit 8	250	25/06/2022	00:00		Continued.	Short overhauling	10/07/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Annual Overhaul	22/07/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	17/07/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	15/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	15/07/2022
IPP	SWPGPL U-1	135	04/07/2022	02:38		Continued.	PA Fan problem	15/07/2022
MSPGCL	Uran Unit 6	108	06/07/2022	17:51		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-1	250	06/07/2022	18:30		Continued.	Governor problem	16/07/2022
TPC-G	Trombay 7A	120	07/07/2022	01:09		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 3	210	07/07/2022	13:03	09/07/2022	20:57	Boiler Tube Leakage	10/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Jul/2022

Position as on 6.30 Hrs of 09/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 9	660	07/07/2022	13:54		Continued.	Boiler Tube Leakage	10/07/2022
MSPGCL	Khaparkheda Unit 1	210	08/07/2022	10:29	08/07/2022	13:11	Furnace Pressure High	08/07/2022
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58		Continued.	Furnace Pressure High	16/07/2022
MSPGCL	Paras Unit 4	250	09/07/2022	15:04	09/07/2022	17:34	Furnace Pressure High	
MSPGCL	Paras Unit 4	250	09/07/2022	20:58	09/07/2022	23:59	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 08/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 09/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Tripping							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	08/07/2022	18:00	08/07/2022	20:25	EO	To attend 2 Nos hot spot in Y & B -Phase capacitor bank.
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	08/07/2022	11:03	09/07/2022	11:30	PO	Hardware Tightening & Fitting Work
KORADI-NANDGAONPETH (RPL)	IntraState	09/07/2022	03:52	09/07/2022	06:38	T	Over Voltage.
LONIKAND I - CHAKAN	IntraState	09/07/2022	11:28	09/07/2022	14:35	PO	DT, line maintenance, SSN-DSN work.
KARAD - TALANDGE CKT - 2	IntraState	09/07/2022	13:26	09/07/2022	19:05	EO	For attending hot spot at B ph 29D IPS clamp towards CT side Temp: -377 0C & 141
400 KV ICT Outages/Tripping							
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	07/07/2022	11:10	08/07/2022	18:26	PO	ICT-3 LV (220kV Side) CB Mechanism O/H work. ICT-3 LV (220kV Side) will be in service through 220kV TBC
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	08/07/2022	11:27	08/07/2022	18:14	PO	1. Relay testing work 2. Quarterly maint. work.
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	08/07/2022	12:03	08/07/2022	15:51	EO	"On dt. 03-07-2022 at around 10:20 hrs. the newly retrofitted relay was found in hang mode showing �Run Time Error� (000f:2586) on its display and was not responding, as reported by 400kv GCR Chandrapur control room. Hence the relay restarted manually after 15 minutes and brought into service. Again, on dt. 04-07-2022, at around 08:58 hrs, the the newly retrofitted relay was found in hang mode showing on its display �Lockout� (8c0f:0000) and was not responding as reported by 400kv GCR Chandrapur control room. Hence the relay again restarted manually after 15 minutes and brought into service. Apart from above, on dt. 04-07-2022, it is also observed that, the relay is continuously restarting automatically within every 5-10 minutes on ""Software Failure"" and ""System Error"" as per relay event list, the same is attached herewith for reference. Due to such unpredictable behaviour of the relay, many times, NDR protection remains out of service which is not desirable. In view of above,

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 09/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	08/07/2022	12:44	08/07/2022	21:14	PO	1)Retrofitting of REF numerical relay, 2) connection of metering CT & PT cores , Testing of BI & BOs to HV & LV BCUs. under MTAMC 3) Diagnostic Testing work 4)Bay maint work
220 KV LINE Outages/Trippings							
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
ROAD SIDE BUS @ KALWA	IntraState	08/07/2022	07:45	08/07/2022	11:09	EO	For attending Hot spot of 200MVA ICT -3 at: 1.ICT-3 stub bus T clamp y ph between isolator and PT isolator(100deg) 2. ICT -3 Bus isolator B ph jaw (breaker
KARAD - KADEGAON	IntraState	08/07/2022	10:47	08/07/2022	16:35	PO	For Relay Testing Work
BHAVEGHAR - ROMA	IntraState	08/07/2022	10:47	08/07/2022	15:04	EO	1)Replacement of PID Faulty insulator strings at loc.67 (Y-Ph).2)Emergency Tree cutting work near Biloshi (Ghart Pada) Under Police Protection. As the trees are very near to conductor and while tree cutting it may fall on conductor and tripping on line also any electrical accident may occur.
PADGHE - WADA	IntraState	08/07/2022	15:34	08/07/2022	19:08	EO	Emergency Tree cutting work near Biloshi (GhartPada) under Police Protection. As the trees are very near to conductor and while tree cutting it may fall on conductor and tripping on line also any electrical accident may occur.
MAHALAXMI - BACKBAY	IntraState	08/07/2022	23:27	09/07/2022	01:55	PO	Breaker testing, protection testing
BOISAR II - BOISAR (PG) CKT - 1	IntraState	09/07/2022	07:45		Continued.	PO	220kV PGCIL Line 1 Bay Strengthening work at 220kV Boisar 2 S/S by replacing existing all jumpers by Twin Jumpers.
KANDALGAON - PIRANGUT	IntraState	09/07/2022	10:34	09/07/2022	16:12	PO	1) Fixing of bird divertor. 2) Emergency tree cutting. 3) Replacement of polymer insulator by longrod insulator, loc no-32,33,34
VITA - GHATNANDRE	IntraState	09/07/2022	13:16	09/07/2022	18:21	EO	For attending hot spot of line bay CT and double jumping ring arrangement as per OEM M/s Meharu recommendation
TEMGHAR - KALWA	IntraState	09/07/2022	23:58		Continued.	T	Tripped on Distance Protection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
250 MVA ICT-5 @ TROMBAY	IntraState	07/07/2022	11:20	08/07/2022	21:45	PO	Protection relay replacement work, Devices relay replacement and Isolator replacement Oil leakage arresting, Conservator painting
250 MVA ICT-5 @ TROMBAY	IntraState	07/07/2022	11:20	08/07/2022	21:45	PO	Relay and isolator replacement work at TATA Trombay
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	08/07/2022	09:11	08/07/2022	12:52	PO	Diagnostic testing work
220/132 KV 200MVA ICT NO 2 @ THEUR	IntraState	09/07/2022	08:12	09/07/2022	17:43		ICT 02 LV bay stringing work
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 08/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 09/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BHIVPURI MSETCL NERAL	IntraState	08/07/2022	14:38	08/07/2022	16:28	PO	Closure inspection of Insulators at Bhivpuri Generating station Gantry.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage