

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 08/Aug/2021 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 151.358        | 889.840         | 1) Gujrat                      | -6.691         | -63.711         |
| 2) Hydro            | 9.947          | 88.217          | 2) Madhya Pradesh              | 6.134          | 43.074          |
| 3) Gas              | 3.333          | 40.952          | 3) Chattisgarh                 | 3.740          | 34.830          |
| <b>Total MSPGCL</b> | <b>164.638</b> | <b>1019.009</b> | 4) Maharashtra                 | 156.723        | 1119.288        |
| B) 1) APML          | 64.410         | 461.820         | 5) Goa (Amona)                 | -0.840         | -11.088         |
| 2) JSWEL            | 20.508         | 166.568         | <b>Total</b>                   | <b>159.066</b> | <b>1122.393</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 18.629         | 191.043         |
| 4) RPL(AMT)         | 25.623         | 188.644         | b) Mumbai Drawl                | 21.181         | 204.013         |
| 5) SWPGPL           | 5.147          | 34.627          | c) MSEDCL Bilateral *          | 46.197         | 302.573         |
| 6) Other IPP        | 6.751          | 49.090          | Include PX                     | 14.894         | 66.244          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 18.629         | 191.043         |
| C) 1) TPCL Thermal  | 15.127         | 103.784         | Include PX                     | 10.485         | 91.879          |
| 2) TPCL Hydro       | 3.011          | 37.126          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 0.000          | 12.476          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 11.367         | 78.583          | 1) MSEDCL                      | 444.045        | 3264.588        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 50.686         | 435.982         |
| 1) Thermal          | 300.291        | 1972.956        | <b>TOTAL STATE</b>             | <b>494.731</b> | <b>3700.570</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 12.958         | 125.343         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 3.333          | 53.428          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 12.664         | 383.140         |                                |                |                 |
| 6) SOLAR            | 6.419          | 43.310          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>335.665</b> | <b>2578.177</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6469                      | 6580                  | 6640                      | 6169                      |
| MSPGCL Hydro             | 410                       | 416                   | 347                       | 327                       |
| MSPGCL Gas               | 139                       | 135                   | 138                       | 139                       |
| MSPGCL Total Generation  | 7018                      | 7131                  | 7125                      | 6635                      |
| Central Sector Receipt   | 7785                      | 7527                  | 5970                      | 5573                      |
| WIND                     | 193                       | 236                   | 988                       | 614                       |
| CPP / IPP Thermal        | 5013                      | 5069                  | 5205                      | 5046                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 820                       | 666                   | 0                         | 0                         |
| Exchange with Mumbai     | -1013                     | -945                  | -1106                     | -831                      |
| <b>MSEDCL DEMAND MET</b> | <b>19816</b>              | <b>19684</b>          | <b>18182</b>              | <b>17037</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 19816                     | 19684                 | 18182                     | 17037                     |
| TPCL GENERATION          | 768                       | 731                   | 752                       | 622                       |
| AEML GENERATION          | 501                       | 501                   | 331                       | 501                       |
| <b>MUMBAI DEMAND</b>     | <b>2282</b>               | <b>2177</b>           | <b>2189</b>               | <b>1954</b>               |
| STATE DEMAND MET         | 22098                     | 21861                 | 20371                     | 18991                     |
| <b>STATE DEMAND</b>      | <b>22098</b>              | <b>21861</b>          | <b>20371</b>              | <b>18991</b>              |
| Frequency (Hz)           | 50.04                     | 50.05                 | 50.04                     | 50.04                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 15.20 Hrs | 49.84 Hz at 09.09 Hrs | 50.03         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 08/Aug/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 2.99         | 5.12          | 145      | 100      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.80        | 56.00         | 547      | 0        |
| Unit 9             | 10.40        | 81.47         | 503      | 370      |
| Unit 10            | 11.76        | 51.98         | 520      | 392      |
| <b>Total</b>       | <b>36.95</b> | <b>194.57</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 2.24         | 2.24          | 165      | 0        |
| Unit 4             | 10.59        | 78.84         | 485      | 335      |
| Unit 5             | 10.42        | 76.42         | 470      | 370      |
| <b>Total</b>       | <b>23.26</b> | <b>157.50</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 3.76         | 3.87          | 222      | 90       |
| Unit 7             | 4.51         | 5.94          | 205      | 162      |
| Unit 8             | 4.87         | 17.75         | 213      | 193      |
| <b>Total</b>       | <b>13.14</b> | <b>27.57</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.38         | 25.73         | 148      | 123      |
| Unit 4             | 3.83         | 27.70         | 165      | 125      |
| Unit 5             | 8.30         | 63.58         | 382      | 280      |
| Unit 6             | 8.69         | 61.71         | 400      | 285      |
| Unit 7             | 9.15         | 40.66         | 415      | 288      |
| Unit 8             | 10.98        | 80.42         | 475      | 435      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>44.34</b> | <b>299.79</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.65         | 35.46         | 242      | 152      |
| <b>Total</b>       | <b>4.65</b>  | <b>35.46</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.19         | 12.18         | 155      | 100      |
| Unit 2             | 3.48         | 16.26         | 170      | 115      |
| Unit 3             | 4.24         | 18.86         | 205      | 130      |
| Unit 4             | 3.98         | 18.97         | 191      | 135      |
| Unit 5             | 11.09        | 79.92         | 490      | 448      |
| <b>Total</b>       | <b>25.98</b> | <b>146.18</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.77         | 0.77          | 142      | 0        |
| Unit 4             | 2.27         | 2.27          | 153      | 0        |
| Unit 5             | 0.00         | 25.72         | 0        | 0        |
| <b>Total</b>       | <b>3.04</b>  | <b>28.77</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 3.33         | 40.95         | 149      | 135      |
| <b>Total</b>       | <b>3.33</b>  | <b>40.95</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.59         | 2.44          | 25       | 24       |
| <b>Total</b>       | <b>0.59</b>  | <b>2.44</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 1.58          | 16.18         | 360      | 20       |
| Stage 4         | 0.00          | 0.00          | 0        | 0        |
| Stage 3         | 0.54          | 6.99          | 160      | 0        |
| <b>Total</b>    | <b>2.12</b>   | <b>23.17</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.86          | 6.57          | 36       | 36       |
| VTRNA           | 0.00          | 0.00          | 0        | 0        |
| TILLARI         | 0.44          | 4.34          | 58       | 0        |
| BHIRA T.R.      | 0.40          | 3.41          | 40       | 0        |
| SMLHY_PTN       | 6.13          | 47.14         | 260      | 245      |
| GHATGHAR        | 0.00          | 3.59          | 0        | 0        |
| <b>Total</b>    | <b>7.83</b>   | <b>65.04</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 12.66         | 383.14        | 0        | 0        |
| <b>Total</b>    | <b>12.66</b>  | <b>383.14</b> |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 64.41         | 461.82        | 0        | 0        |
| JSWEL(Mus)      | 20.51         | 166.57        | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 25.62         | 188.64        | 0        | 0        |
| SWPGPL-Mus      | 5.15          | 34.63         | 0        | 0        |
| Other(Mus)      | 6.75          | 49.09         | 0        | 0        |
| <b>Total</b>    | <b>122.44</b> | <b>900.75</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 6.42          | 43.31         | 0        | 0        |
| <b>Total</b>    | <b>6.42</b>   | <b>43.31</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 10.19         | 69.04         | 478      | 278      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 0.00          | 6.95          | 0        | 0        |
| Trombay 7B      | 0.00          | 5.53          | 0        | 0        |
| Trombay 8       | 4.94          | 34.74         | 220      | 140      |
| TATA Hydro      | 3.01          | 37.13         | 334      | 0        |
| <b>Total</b>    | <b>18.14</b>  | <b>153.39</b> |          |          |
| <b>AEMIL</b>    |               |               |          |          |
| DTPS U-1&2      | 11.37         | 78.58         | 503      | 293      |
| <b>Total</b>    | <b>11.37</b>  | <b>78.58</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 151.36      | 889.84        | MSPGCL Total        | 164.64      | 1019.01       |
|                |             |         | MSPGCL Thml+Gas | 154.69      | 930.79        | Koyna 1,2 & 4 Total | 1.58        | 16.18         |
|                |             |         | MSPGCL Hydro    | 9.95        | 88.22         | State Total         | 335.66      | 2578.18       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 08/Aug/2021

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6236        | 328  | 138  | 6702   | 744   | 5148      | 0    | 0     | 5510        | 5725        | -865                 | 17454                 | 0                    | 17454                     | 2228             | 19682           | 50.01         |
| 2                  | 6256        | 331  | 139  | 6726   | 704   | 5129      | 0    | 0     | 5378        | 5433        | -773                 | 17219                 | 0                    | 17219                     | 2083             | 19302           | 50.02         |
| 3                  | 6169        | 327  | 139  | 6635   | 614   | 5046      | 0    | 0     | 5332        | 5573        | -831                 | 17037                 | 0                    | 17037                     | 1954             | 18991           | 50.04         |
| 4                  | 6132        | 325  | 140  | 6597   | 531   | 5083      | 0    | 0     | 5454        | 5850        | -804                 | 17257                 | 0                    | 17257                     | 1876             | 19133           | 50.02         |
| 5                  | 6044        | 498  | 149  | 6691   | 468   | 5085      | 0    | 0     | 5535        | 6031        | -665                 | 17610                 | 0                    | 17610                     | 1855             | 19465           | 50.01         |
| 6                  | 5983        | 655  | 139  | 6777   | 406   | 4992      | 0    | 0     | 5973        | 6812        | -659                 | 18328                 | 0                    | 18328                     | 1892             | 20220           | 49.98         |
| 7                  | 6190        | 604  | 140  | 6934   | 378   | 4967      | 0    | 35    | 7587        | 7621        | -656                 | 19279                 | 0                    | 19279                     | 1885             | 21164           | 50.03         |
| 8                  | 6252        | 482  | 140  | 6874   | 274   | 4962      | 0    | 200   | 8014        | 8046        | -797                 | 19559                 | 0                    | 19559                     | 1930             | 21489           | 50.05         |
| 9                  | 6365        | 509  | 138  | 7012   | 273   | 5037      | 0    | 498   | 7478        | 7711        | -1136                | 19395                 | 0                    | 19395                     | 2019             | 21414           | 50.03         |
| 10                 | 6370        | 446  | 138  | 6954   | 292   | 5005      | 0    | 644   | 7514        | 7260        | -931                 | 19224                 | 0                    | 19224                     | 2151             | 21375           | 49.99         |
| 11                 | 6361        | 411  | 138  | 6910   | 254   | 5083      | 0    | 817   | 7349        | 7283        | -934                 | 19413                 | 0                    | 19413                     | 2240             | 21653           | 50.05         |
| 12                 | 6469        | 410  | 139  | 7018   | 193   | 5013      | 0    | 820   | 7495        | 7785        | -1013                | 19816                 | 0                    | 19816                     | 2282             | 22098           | 50.04         |
| 13                 | 6628        | 410  | 137  | 7175   | 160   | 5030      | 0    | 768   | 7597        | 7353        | -980                 | 19506                 | 0                    | 19506                     | 2249             | 21755           | 50.03         |
| 14                 | 6595        | 415  | 137  | 7147   | 207   | 5028      | 0    | 730   | 7398        | 7367        | -929                 | 19550                 | 0                    | 19550                     | 2198             | 21748           | 50.02         |
| 15                 | 6580        | 416  | 135  | 7131   | 236   | 5069      | 0    | 666   | 7378        | 7527        | -945                 | 19684                 | 0                    | 19684                     | 2177             | 21861           | 50.05         |
| 16                 | 6555        | 355  | 136  | 7046   | 348   | 5159      | 0    | 562   | 7495        | 7462        | -927                 | 19650                 | 0                    | 19650                     | 2156             | 21806           | 50.06         |
| 17                 | 6334        | 336  | 136  | 6806   | 400   | 5138      | 0    | 413   | 7202        | 7203        | -848                 | 19112                 | 0                    | 19112                     | 2110             | 21222           | 50.06         |
| 18                 | 6370        | 316  | 136  | 6822   | 491   | 5147      | 0    | 240   | 6428        | 6647        | -841                 | 18506                 | 0                    | 18506                     | 2084             | 20590           | 50.01         |
| 19                 | 6390        | 331  | 136  | 6857   | 796   | 5190      | 0    | 26    | 6115        | 6080        | -1103                | 17846                 | 0                    | 17846                     | 2077             | 19923           | 50.03         |
| 20                 | 6640        | 347  | 138  | 7125   | 988   | 5205      | 0    | 0     | 5921        | 5970        | -1106                | 18182                 | 0                    | 18182                     | 2189             | 20371           | 50.04         |
| 21                 | 6395        | 501  | 148  | 7044   | 1032  | 5178      | 0    | 0     | 5575        | 5537        | -958                 | 17833                 | 0                    | 17833                     | 2242             | 20075           | 50.00         |
| 22                 | 5975        | 425  | 138  | 6538   | 974   | 5161      | 0    | 0     | 5418        | 5536        | -810                 | 17399                 | 0                    | 17399                     | 2264             | 19663           | 50.03         |
| 23                 | 6152        | 363  | 139  | 6654   | 972   | 5284      | 0    | 0     | 5024        | 5656        | -803                 | 17763                 | 0                    | 17763                     | 2255             | 20018           | 50.02         |
| 24                 | 5917        | 406  | 140  | 6463   | 929   | 5300      | 0    | 0     | 5109        | 5598        | -867                 | 17423                 | 0                    | 17423                     | 2290             | 19713           | 50.03         |
| MUs                | 151.36      | 9.95 | 3.33 | 164.64 | 12.66 | 122.44    | 0.00 | 6.42  | 155.28      | 159.07      | -21.18               | 444.04                | 0.00                 | 444.04                    | 50.69            | 494.73          | 50.03         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 08/Aug/2021**

**Position as on 6.30 Hrs of 09/Aug/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                  |               |
| IPP                   | RPL(AMT) U-3            | 270      | 15/07/2021   | 00.00        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 15/07/2021   | 02.00        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Paras Unit 3            | 250      | 20/07/2021   | 00.35        |            | Continued. | Annual Overhaul                                                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                  |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                          |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                             |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                             |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                           |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                          |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                           |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                            |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        | 08/08/2021 | 16.20      | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                    |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 08/06/2021   | 00.34        | 08/08/2021 | 03.08      | Zero Schedule.                                                                   |               |
| MSPGCL                | Uran Unit 6             | 108      | 29/06/2021   | 22.18        |            | Continued. | Gas shortage                                                                     |               |
| MSPGCL                | Nasik Unit 4            | 210      | 04/07/2021   | 11.03        | 08/08/2021 | 06.00      | Boiler Tube Leakage(Converted into to Zero Schedule from 20.00Hrs DT.06-07-2021) |               |
| IPP                   | JSW (J) U4              | 300      | 16/07/2021   | 17.44        |            | Continued. | Air Preheater problem.                                                           |               |
| IPP                   | SWPGPL U-4              | 135      | 05/08/2021   | 03.04        |            | Continued. | Turbine Vibration High.                                                          |               |
| MSPGCL                | Uran Unit A0            | 120      | 05/08/2021   | 20.02        |            | Continued. | Gas shortage                                                                     |               |
| MSPGCL                | Uran Unit 5             | 108      | 05/08/2021   | 20.02        |            | Continued. | Gas shortage                                                                     |               |
| MSPGCL                | Koyana Unit 6           | 80       | 05/08/2021   | 21.25        |            | Continued. | Differential protection                                                          |               |
| TPC-G                 | Trombay 7B              | 60       | 05/08/2021   | 22.19        |            | Continued. | Gas shortage                                                                     |               |
| TPC-G                 | Trombay 7A              | 120      | 05/08/2021   | 22.39        |            | Continued. | Gas shortage                                                                     |               |
| MSPGCL                | Nasik Unit 5            | 210      | 07/08/2021   | 20.45        |            | Continued. | Boiler Tube Leakage                                                              |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 08/08/2021   | 03.40        | 08/08/2021 | 05.18      | Due To Drum Level High.                                                          |               |
| MSPGCL                | Koradi Unit-8           | 660      | 08/08/2021   | 22.53        | 09/08/2021 | 03.07      | Generator protection of other system.                                            |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/Aug/2021**

**Statement-VII**

Position as on 6.30 Hrs of 09/Aug/2021

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                             |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                              |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                     |
| Padghe - Kalwa-II                                 | IntraState                | 08/08/2021   | 09.30        | 08/08/2021 | 17.24      | PO          | Diagnostic Testing Work                                                                                                                      |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 08/08/2021   | 18.18        |            | Continued. | HT          | Over Voltage                                                                                                                                 |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                              |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                                                        |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                              |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                  |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                       |
| Balapur-Akola I                                   | IntraState                | 22/07/2021   | 07.48        |            | Continued. | T           | Distance Protection(tower collapse At LOC. No.15.)                                                                                           |
| Balapur-Akola li                                  | IntraState                | 22/07/2021   | 07.48        |            | Continued. | T           | Distance Protection(tower collapse At LOC. No.15.)                                                                                           |
| Mahad - Pedambe                                   | IntraState                | 22/07/2021   | 19.35        |            | Continued. | T           | Distance Protection                                                                                                                          |
| Kandalgaon - Pirangut                             | IntraState                | 22/07/2021   | 19.37        |            | Continued. | T           | Distance Protection                                                                                                                          |
| Kharghar-Borivali ckt II                          | IntraState                | 23/07/2021   | 08.43        |            | Continued. | PO          | To Carry out bunching work.                                                                                                                  |
| Kalwa-TIFIL                                       | IntraState                | 23/07/2021   | 11.12        |            | Continued. | PO          | For Complete Tower erection work at loc no. 75A & 76 (behind M/s Siemens).                                                                   |
| Kharghar-Borivali ckt I                           | IntraState                | 24/07/2021   | 08.46        |            | Continued. | PO          | Tower Erection & Bunching work                                                                                                               |
| Kalwa - Siemens                                   | IntraState                | 24/07/2021   | 18.16        |            | Continued. | PO          | Tower Erection & Bunching work                                                                                                               |
| Miraj - ICHALKARANJI - II (TILWANI)               | IntraState                | 28/07/2021   | 08.19        |            | Continued. | T           | Tower collapsed at loc no.27.                                                                                                                |
| Wadkhal(GIS)-JSW(GIS) II                          | IntraState                | 04/08/2021   | 09.26        |            | Continued. | PO          | Outage required for replacement of existing 1200/1A GIS Metering CTs with New 1600/1A GIS CTs.(CB Opened At JSW End On 02/04/2021 At 10:18). |
| Pohali-Nerle                                      | IntraState                | 05/08/2021   | 21.25        | 08/08/2021 | 18.35      | T           | Y-Ph wave trap jumper of kandalgaon line broken                                                                                              |
| Salsette - Sahara                                 | IntraState                | 08/08/2021   | 09.43        | 08/08/2021 | 12.47      | PO          | Tree Trimming                                                                                                                                |
| Salsette - Saki 7                                 | IntraState                | 08/08/2021   | 13.59        | 08/08/2021 | 16.31      | PO          | Tree Trimming                                                                                                                                |
| Gangapur-Valve                                    | IntraState                | 08/08/2021   | 18.50        | 08/08/2021 | 19.33      | T           | B-PH of T/F 1 burst.                                                                                                                         |
| Boisar Versova Line                               | IntraState                | 09/08/2021   | 01.01        |            | Continued. | PO          | MMRDA WORK                                                                                                                                   |
| Dahanu Versova                                    | IntraState                | 09/08/2021   | 01.04        |            | Continued. | PO          | MMRDA WORK                                                                                                                                   |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage