

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Aug/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	101.157	917.264	1) Gujrat	3.937	56.780
2) Hydro	10.289	111.297	2) Madhya Pradesh	0.474	36.222
3) Gas	6.383	42.887	3) Chattisgarh	2.550	19.900
Total MSPGCL	117.829	1071.448	4) Maharashtra	154.510	1352.953
B) 1) APLM	48.397	408.323	5) Goa (Amona)	-1.675	-8.335
2) JSWEL	14.868	116.209	Total	159.796	1457.520
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.400	267.946
4) RPL(AMT)	19.185	152.113	b) Mumbai Drawl	34.299	283.830
5) SWPGPL	8.433	49.993	c) MSEDCL Bilateral *	70.851	559.277
6) Other IPP	6.340	53.130	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.339	267.733
C) 1) TPCL Thermal	9.767	85.750	Include PX	0.000	0.000
2) TPCL Hydro	4.384	40.269	Standby	0.061	0.214
3) TPCL Gas	2.517	21.869	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.448	75.058	1) MSEDCL	376.793	3193.785
D) STATE			2) Mumbai Discoms	60.415	506.776
1) Thermal	217.595	1857.840	3) Other Discoms	8.777	70.882
(A1+C1+C4+(B1-B6))			TOTAL STATE	445.985	3771.443
2) Hydro	14.673	151.566			
(A2+C2)					
3) Gas	8.900	64.756			
(A3+B7+C3)					
4) Wind	40.442	175.349			
6) SOLAR	4.579	64.412			
TOTAL STATE	286.189	2313.923			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4382	4103	4221	4538
MSPGCL Hydro	466	463	547	346
MSPGCL Gas	270	259	259	271
MSPGCL Total Generation	5118	4825	5027	5155
Central Sector Receipt	7675	7124	7466	5174
WIND	1557	2085	2147	1155
CPP / IPP Thermal	4222	4087	4506	3774
CPP / IPP Gas	0	0	0	0
SOLAR	468	74	0	0
Exchange with Mumbai	-1735	-1621	-1481	-902
MSEDCL DEMAND MET	16898	16172	17265	14074
Load Shedding	0	0	0	0
MSEDCL DEMAND	16898	16172	17265	14074
TPCL GENERATION	739	788	828	578
AEML GENERATION	451	417	417	388
MUMBAI DEMAND	2925	2826	2726	1868
OTHER DISCOM DEMAND	407	403	400	281
STATE DEMAND MET	20230	19400	20391	16224
STATE DEMAND	20230	19400	20391	16224
Frequency (Hz)	49.92	49.98	50.01	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 13:01 Hrs	49.73 Hz at 09:30 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	1.69	21.46	105	40
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	46.51	0	0
Unit 10	9.18	83.95	450	332
Total	10.87	151.92		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.44	65.42	400	305
Unit 5	3.68	55.81	320	0
Total	12.12	121.22		
Parli				
Unit 6	4.24	33.62	198	155
Unit 7	4.20	24.95	191	151
Unit 8	3.89	29.23	175	146
Total	12.32	87.80		
Chandrapur				
Unit 3	1.77	18.88	92	44
Unit 4	1.78	11.18	93	35
Unit 5	5.14	42.13	240	194
Unit 6	1.54	42.43	121	0
Unit 7	0.00	0.00	0	0
Unit 8	9.70	77.44	435	387
Unit 9	9.62	78.84	432	372
Total	29.55	270.90		
Paras				
Unit 3	3.30	31.59	151	118
Unit 4	3.48	32.06	155	136
Total	6.78	63.66		
Khaparkheda				
Unit 1	2.42	21.90	120	75
Unit 2	2.92	22.94	130	105
Unit 3	4.17	30.49	190	136
Unit 4	4.06	29.66	185	148
Unit 5	9.13	68.65	450	295
Total	22.70	173.64		
Nasik				
Unit 3	3.59	24.47	168	119
Unit 4	0.00	0.00	0	0
Unit 5	3.23	23.66	153	120
Total	6.83	48.13		
Uran				
All Units	6.38	42.89	274	259
Total	6.38	42.89		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.61	4.87	27	23
Total	0.61	4.87		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.30	23.56	295	30
Stage 4	0.00	21.64	0	0
Stage 3	1.43	13.55	94	0
Total	2.73	58.74		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.78	3.03	60	0
TILLARI	0.77	1.43	58	0
BHIRA T.R.	0.46	3.44	80	0
SMLHY_PTN	4.92	37.34	217	186
GHATGHAR	0.00	2.45	0	0
Total	6.94	47.69		
Wind				
Total	40.44	175.35	0	0
Total	40.44	175.35		
CPP				
APML(Mus)	48.40	408.32	0	0
JSWEL(Mus)	14.87	116.21	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.18	152.11	0	0
SWPGPL-Mus	8.43	49.99	0	0
Other(Mus)	6.34	53.13	0	0
Total	97.22	779.77		
SOLAR				
Total	4.58	64.41	0	0
Total	4.58	64.41		
Tata				
Trombay 5	6.56	56.68	286	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.49	12.73	114	23
Trombay 7B	1.03	9.14	68	0
TATA Hydro	4.38	40.27	308	16
Trombay 8	3.21	29.07	135	133
Total	16.67	147.89		
AEML				
DTPS U-1&2	9.45	75.06	500	328
Total	9.45	75.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	101.16	917.26	MSPGCL Total	117.83	1071.45
			MSPGCL Thml+Gas	107.54	960.15	Koyna 1,2 & 4 Total	1.30	45.19
			MSPGCL Hydro	10.29	111.30	State Total	286.19	2313.92

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 08/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4464	360	272	5096	1489	3675	0	0	5175	5183	-960	14166	0	14166	2091	316	16574	49.99
2	4557	346	274	5177	1193	3771	0	0	5090	5090	-871	14064	0	14064	1958	296	16318	50.00
3	4538	346	271	5155	1155	3774	0	0	5233	5174	-902	14074	0	14074	1868	281	16224	50.00
4	4456	345	273	5074	1200	3784	0	0	5393	5378	-908	14263	0	14263	1805	266	16333	50.00
5	4440	309	271	5020	1189	3996	0	0	5501	5803	-924	14790	0	14790	1812	294	16896	49.99
6	4456	269	271	4996	1316	4443	0	0	6565	6260	-1014	15671	0	15671	1935	330	17936	49.98
7	4445	308	270	5023	1185	4455	0	22	7372	7359	-1048	16639	0	16639	2109	357	19105	49.99
8	4388	371	272	5031	1402	4390	0	142	7357	7768	-1175	17189	0	17189	2304	368	19862	50.03
9	4340	456	271	5067	1547	4520	0	325	6874	7094	-1469	16671	0	16671	2631	413	19715	50.03
10	4382	466	270	5118	1557	4222	0	468	7695	7675	-1735	16898	0	16898	2925	407	20230	49.92
11	4281	431	268	4980	1463	3986	0	548	8343	7968	-2024	16504	0	16504	3126	417	20047	50.02
12	4244	449	266	4959	1419	3773	0	647	7987	7865	-2102	16171	0	16171	3126	390	19687	50.05
13	4039	442	269	4750	1664	3830	0	687	7562	7212	-1983	15768	0	15768	3050	391	19210	50.04
14	3760	454	269	4483	1757	3718	0	576	7193	7454	-1855	15743	0	15743	2898	390	19031	50.10
15	3827	457	264	4548	1967	3798	0	507	7439	7227	-1854	15805	0	15805	2881	388	19074	50.02
16	3735	457	259	4451	2018	3708	0	381	7490	7228	-1867	15526	0	15526	2905	393	18824	50.01
17	4074	457	259	4790	2051	4081	0	193	7069	6748	-1776	15693	0	15693	2865	394	18952	49.97
18	4103	463	259	4825	2085	4087	0	74	7138	7124	-1621	16172	0	16172	2826	403	19400	49.98
19	4161	471	259	4891	2149	4127	0	9	7505	7523	-1620	16672	0	16672	2779	407	19858	50.02
20	4221	547	259	5027	2147	4506	0	0	7765	7466	-1481	17265	0	17265	2726	400	20391	50.01
21	4005	546	259	4810	2106	4168	0	0	7271	6667	-1357	16013	0	16013	2607	382	19001	50.01
22	4062	483	259	4804	2020	4405	0	0	6269	6042	-1353	15530	0	15530	2494	388	18412	49.98
23	4094	691	259	5044	2049	4177	0	0	5401	5732	-1240	15404	0	15404	2389	359	18151	49.93
24	4085	365	260	4710	2314	3829	0	0	5322	4756	-1160	14102	0	14102	2305	347	16754	50.01
MUs	101.16	10.29	6.38	117.83	40.44	97.22	0.00	4.58	162.01	159.80	-34.30	376.79	0.00	376.79	60.41	8.78	445.99	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Aug/2022

Position as on 6.30 Hrs of 09/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	17/08/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	10/08/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
MSPGCL	Bhusawal Unit 3	210	16/07/2022	06:30	09/08/2022	11:29	Critical coal stock	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	03/08/2022	03:00		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	03/08/2022	21:45		Continued.	Boiler Validity Renevoation	
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage	09/08/2022
MSPGCL	Koyna Unit 5	80	07/08/2022	23:59		Continued.	Major Gov.Failure	
MSPGCL	Ghatghar Unit-2	125	08/08/2022	01:05		Continued.	CW PUMP PROBLEM	
MSPGCL	Chandrapur Unit 6	500	08/08/2022	07:17	08/08/2022	16:51	Generator Elect. Fault	
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler	10/09/2022
TPC-G	Trombay 7B	60	08/08/2022	17:35	08/08/2022	19:23	Signal problem	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Aug/2022

Position as on 6.30 Hrs of 09/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7A	120	08/08/2022	17:35	08/08/2022	18:31	signal problem	
MSPGCL	Nasik Unit 5	210	09/08/2022	04:50	09/08/2022	07:05	Flame Failure	
MSPGCL	Uran Unit 6	108	09/08/2022	06:02	09/08/2022	08:22	BUS 2 FAULT AT 220 KV URAN S/S.	
MSPGCL	Uran Unit 8	108	09/08/2022	06:02	09/08/2022	15:58	BUS 2 FAULT AT 220 KV URAN S/S.	
MSPGCL	Uran Unit A0	120	09/08/2022	06:02	09/08/2022	21:01	BUS 2 FAULT AT 220 KV URAN S/S.	
MSPGCL	Uran Unit B0	120	09/08/2022	06:02		Continued.	BUS 2 FAULT AT 220 KV URAN S/S.	
MSPGCL	Uran Unit 6	108	09/08/2022	12:24		Continued.	BUS 2 FAULT AT 220KV URAN S/S	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 09/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
400KV TIE BAY 411 STN T/F 2-KORADI CKT	InterState	09/08/2022	14:49			EO	Gas Replenishment in Tie breaker (411) due to low SF6 Gas Alarm is persisting
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
GTR - 6 @ CHANDRAPUR	IntraState	09/08/2022	09:36	09/08/2022	18:59	EO	To investigate tripping of CB on PDR and attend /rectify the same along with measurement of Timing. "On dt. 08-08-2022, during synchronizing the 500MW GT-6 unit, main own 400KV CGL make CB of GTR-6 bay is tripped on PDR. In view of above, It is very necessary to investigate tripping of CB on PDR and attend /rectify the same along with measurement of Timing. "
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	05/08/2022	00:06			HT	For load management
KARAD - TALANDGE CKT - 1	IntraState	05/08/2022	18:14			EO	Sparking observed at B -phase C Bus isolator own bay during shifting on TBC for CB overhauling work.
KARAD - LONIKAND I	IntraState	06/08/2022	10:31	08/08/2022	14:50	HT	H/T TO CONTROL LINE LOADING
KHADKA-AURANGABAD (WALUJ)	IntraState	07/08/2022	00:52			HT	To control overvoltage
PADGHE - KALWA CKT - 2	IntraState	07/08/2022	16:33	08/08/2022	01:18	T	TRIPPED ON DISTANCE PROTECTION
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	08/08/2022	05:24	08/08/2022	12:58	T	Distance Protection
KARAD - LONIKAND I	IntraState	09/08/2022	13:07			HT	To control loading
PADGHE - NAGOTHANE CKT - 2	IntraState	09/08/2022	15:50	09/08/2022	18:07	T	Tripped at Padghe end only.
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	09/08/2022	11:52	09/08/2022	18:53	PO	1) BI & BO wiring and Testing work , SCADA trials under MTAMC project 2) Bay maint work 3) Oil leakage attending work if any
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	03/08/2022	05:03		Continued.	HT	H/T for Line Loading.
SALSETTE BORIVLI - 2	IntraState	07/08/2022	10:13	09/08/2022	19:45	PO	THIRD PARTY WORK-FOR CONDUCTOR SHIFTING ON NEW TOWER AT LOC-2A
BOISAR II - TARAPUR	IntraState	07/08/2022	22:42	08/08/2022	20:13	T	Tripped on Distance protection
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	08/08/2022	06:28	08/08/2022	07:11	T	Tripped on distance protection
GHODBUNDER - GORAI	IntraState	08/08/2022	10:35	08/08/2022	15:36	EO	Hotspot to be attended on R-Phase LA connection on CTT tower no. LS 303A at Gorai. (Temp > 150 deg.)
POPHLI PEDHMBE LINE- 2	IntraState	08/08/2022	11:15	08/08/2022	18:20	HT	EMERGENCY OUTAGE AVAILED AT PEDAMBE END FOR DAMAGED CONDUCTER REPLACEMENT WORK

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 09/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
HINJEWADI 3 - NXTRA GIS CKT - 1	IntraState	08/08/2022	11:22	08/08/2022	20:03	PO	Annual Relay testing
MALINAGAR - TEMBHURNI	IntraState	08/08/2022	12:17	08/08/2022	20:28	PO	Outage is required for Work of Numerical Distance Relay replacement and modification in 220kV BUS BAR protection wiring.
NERLE - POPHALI	IntraState	08/08/2022	12:35	08/08/2022	22:25	T	Tripped at Nerle end due to overloading after HT of 220 kV Pedambe -Nerle line at Pedambe end
NERLE - PEDAMBE	IntraState	08/08/2022	13:03	08/08/2022	22:25	PO	For attending defects
VANKUSWADE - KDPH	IntraState	08/08/2022	21:55	09/08/2022	13:20	T	WANKUSWADE LINE BAY CONDUCTOR SNAPPED AT KDPH
VANKUSWADE - AJINKYATARA	IntraState	08/08/2022	21:55	08/08/2022	22:17	T	TRIPPED AT THE TIME OF KDPH-WANKUSWADE LINE TRIPPING.
KHARGHAR - TOPWORTH	IntraState	09/08/2022	01:22	09/08/2022	15:30	T	TRIPPED ON DISTANCE PROTECTION
TOPWORTH - Vile - bhagad	IntraState	09/08/2022	01:22	09/08/2022	04:00	T	TRIPPED ON BACKUP PROTECTION
URAN - SEZ JNPT	IntraState	09/08/2022	06:02	09/08/2022	07:44	T	Bus Fault
MAIN BUS @ URAN	IntraState	09/08/2022	06:02	09/08/2022	07:04	T	1) AT 06:02 HRS, MAIN BUS-2 TRIPPED DUE TO GT-B0 STUB BUS HORIZONTAL STRING BROKEN AND FALL ON BUS-2 AT 06:02 HRS TO TILL CONTINUE 2) AT 06:35 HRS, 220KV MAIN BUS-I TRIPPED DUE TO 220KV KHARGHAR-I BAY Y-PHASE LINE ISOLATOR INSULATOR BROKEN AND LINE CONDUCTOR TOUCH ON STRUCTURE AND RESTORE AT 07:04 HRS.
URAN - KHARGHAR 2	IntraState	09/08/2022	06:02	09/08/2022	07:36	T	Bus Fault
URAN - APTA CKT - 1	IntraState	09/08/2022	06:02	09/08/2022	07:53	T	Bus Fault
URAN - APTA 4	IntraState	09/08/2022	06:02	09/08/2022	09:53	T	Bus Fault
URAN - ONGC URAN	IntraState	09/08/2022	06:35	09/08/2022	07:40	T	Bus Fault
URAN - KHARGHAR 1	IntraState	09/08/2022	06:35	09/08/2022	19:26	T	Bus Fault
URAN - APTA 3	IntraState	09/08/2022	06:35	09/08/2022	07:08	T	Bus Fault
URAN - APTA 2	IntraState	09/08/2022	06:35	09/08/2022	07:04	T	Bus Fault
LONAND-PHALTAN MIDC	IntraState	09/08/2022	09:36	09/08/2022	15:32	PO	For CT tan delta & relay testing work
ADLABS - PEDAMBE	IntraState	09/08/2022	09:50	09/08/2022	14:16	PO	L.S.iso to CT R Phase conductor some strand broken. Same conductor need to be replace. Bay R/M work.
URAN - JNPT	IntraState	09/08/2022	12:24	09/08/2022	13:06	T	Due to Bus fault
URAN - ONGC URAN	IntraState	09/08/2022	12:24	09/08/2022	13:06	T	Due to bus fault
URAN - KHARGHAR 2	IntraState	09/08/2022	12:24	09/08/2022	13:28	T	Due to bus fault
URAN - APTA 4	IntraState	09/08/2022	12:24	09/08/2022	13:09	T	Due to bus fault
URAN - APTA 3	IntraState	09/08/2022	12:24	09/08/2022	13:10	T	Due to bus fault
URAN - APTA 2	IntraState	09/08/2022	12:24	09/08/2022	13:01	T	Due to bus Fault
MAIN BUS @ URAN	IntraState	09/08/2022	12:24	09/08/2022	13:01	T	Due to bus fault
URAN - APTA CKT - 1	IntraState	09/08/2022	12:24	09/08/2022	13:02	T	Due to bus fault
WARDHA (PG) - BADNERA	IntraState	09/08/2022	13:03	09/08/2022	19:06	PO	Routine line maintenance work
KHARGHAR - SONKHAR	IntraState	09/08/2022	18:08	09/08/2022	22:10	EO	To attend hotspot at Loc. No. 2B & Sonkhar gantry.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 09/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 200 MVA ICT 1 @ KOLSHET	IntraState	08/08/2022	09:34	08/08/2022	17:30	PO	1. Isolator servicing and alignment work. 2.100kV Bus 1 maintenance work . 3. Bay maintenance work. 4. Diagnostic work. 5.Red hotspot attending work.6. Jumper replacement work . 7. Isolator gear box replacement work. 8.RMW
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	08/08/2022	10:27	08/08/2022	14:32	PO	Shifting of MB for ICT CB replacement work
132 KV LINE Outages/Trippings							
THEUR-KHARADI	IntraState	08/08/2022	10:54	08/08/2022	19:00	PO	Double Jumpering work at cut point L.N.- 1,2,7,14,18,24,30,38,41,42,44,45
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
KHOPOLI - BHOKARPADA	IntraState	08/08/2022	09:20	08/08/2022	11:29	PO	for insulator inspection at Khopoli generating station gantry and testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage