

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Aug/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.018	974.300	1) Gujrat	12.730	84.737
2) Hydro	16.810	96.696	2) Madhya Pradesh	10.229	57.535
3) Gas	0.055	0.055	3) Chattisgarh	1.550	20.730
Total MSPGCL	152.883	1071.051	4) Maharashtra	158.657	1211.941
B) 1) APML	58.757	370.214	5) Goa (Amona)	-1.482	-12.678
2) JSWEL	14.158	114.338	Total	181.684	1362.265
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.761	276.656
4) RPL(AMT)	25.556	200.445	b) Mumbai Drawl	39.127	305.987
5) SWPGPL	7.131	53.748	c) MSEDCL Bilateral *	95.346	761.466
6) Other IPP	6.518	48.103	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.761	276.656
C) 1) TPCL Thermal	11.030	80.977	Include PX	0.000	0.000
2) TPCL Hydro	5.400	35.406	Standby	0.000	0.000
3) TPCL Gas	2.689	19.563	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.839	69.723	1) MSEDCL	454.035	3372.668
D) STATE			2) Mumbai Discoms	67.085	511.656
1) Thermal	268.007	1911.848	3) Other Discoms	10.132	79.673
(A1+C1+C4+(B1-B6))			TOTAL STATE	531.252	3963.997
2) Hydro	22.210	132.102			
(A2+C2)					
3) Gas	2.744	19.618			
(A3+B7+C3)					
4) Wind	46.128	457.202			
6) SOLAR	10.479	80.962			
TOTAL STATE	349.568	2601.732			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5793	5632	5783	5660
MSPGCL Hydro	526	334	1892	302
MSPGCL Gas	0	0	53	0
MSPGCL Total Generation	6319	5966	7728	5962
Central Sector Receipt	9091	8596	6996	6213
WIND	2044	2321	1501	2232
CPP / IPP Thermal	4362	4601	5555	3995
CPP / IPP Gas	0	0	0	0
SOLAR	1263	1297	0	0
Exchange with Mumbai	-2320	-2420	-1333	-1108
MSEDCL DEMAND MET	20314	19930	19999	16978
Load Shedding	0	0	286	0
MSEDCL DEMAND	20314	19930	20285	16978
TPCL GENERATION	638	590	1230	620
AEML GENERATION	437	309	479	299
MUMBAI DEMAND	3395	3319	3042	2027
OTHER DISCOM DEMAND	445	431	448	316
STATE DEMAND MET	24154	23680	23489	19321
STATE DEMAND	24154	23680	23775	19321
Frequency (Hz)	50.04	50.00	49.76	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 13.02 Hrs	49.55 Hz at 19.17 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.48	24.71	170	100
Unit 8	13.61	100.64	605	519
Unit 9	12.24	95.09	568	459
Unit 10	0.00	0.00	0	0
Total	29.34	220.44		
Bhusawal				
Unit 3	3.08	23.04	140	110
Unit 4	9.66	69.08	435	330
Unit 5	10.30	67.48	475	370
Total	23.04	159.60		
Parli				
Unit 6	0.50	0.50	120	0
Unit 7	0.00	0.00	0	0
Unit 8	3.45	3.55	177	79
Total	3.95	4.05		
Chandrapur				
Unit 3	3.30	21.79	151	115
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	8.48	58.98	390	310
Unit 7	7.47	56.71	336	292
Unit 8	10.73	80.31	480	410
Unit 9	10.86	82.03	476	397
Total	40.84	299.82		
Paras				
Unit 3	4.76	36.12	215	176
Unit 4	4.59	34.27	213	147
Total	9.35	70.39		
Khaparkheda				
Unit 1	1.78	15.48	85	60
Unit 2	2.42	20.69	121	75
Unit 3	3.79	28.85	175	131
Unit 4	4.06	29.40	185	132
Unit 5	9.61	72.92	451	350
Total	21.67	167.34		
Nasik				
Unit 3	3.83	28.50	178	59
Unit 4	4.00	11.09	184	131
Unit 5	0.00	13.08	0	0
Total	7.83	52.66		
Uran				
All Units	0.06	0.06	53	0
Total	0.06	0.06		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.23	8.25	52	50
Total	1.23	8.25		
Koyna				
Stage 1-2	3.70	18.80	450	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.94	10.83	753	0
Stage 3	1.98	10.08	240	0
Total	9.61	39.70		
Hydro				
KDPH	0.86	6.79	36	36
VTRNA	0.05	0.48	21	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.46	3.46	80	0
SMLHY_PTN	4.24	35.63	182	168
GHATGHAR	0.35	2.38	125	0
Total	5.97	48.74		
Wind				
Total	46.13	457.20	0	0
Total	46.13	457.20		
CPP				
APML(Mus)	58.76	370.21	0	0
JSWEL(Mus)	14.16	114.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.56	200.44	0	0
SWPGPL-Mus	7.13	53.75	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.45	40.04	273	197
Other(Mus)	1.07	8.06	0	0
Total	112.12	786.85		
SOLAR				
Total	10.48	80.96	0	0
Total	10.48	80.96		
Tata				
Trombay 5	7.26	54.05	433	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.58	11.18	108	39
Trombay 7B	1.11	8.38	64	35
TATA Hydro	5.40	35.41	402	131
Trombay 8	3.77	26.93	225	127
Total	19.12	135.95		
AEML				
DTPS U-1&2	8.84	69.72	486	295
Total	8.84	69.72		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.02	974.30	MSPGCL Total	152.88	1071.05
			MSPGCL Thml+Gas	136.07	974.36	Koyna 1,2 & 4 Total	7.64	29.63
			MSPGCL Hydro	16.81	96.70	State Total	349.57	2601.73

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5466	324	0	5790	2093	4484	0	0	6353	6093	-1273	16790	0	0	16790	2415	397	19602	49.96
2	5574	305	0	5879	2082	4339	0	0	6386	6101	-1192	16843	0	0	16843	2234	366	19443	49.97
3	5513	313	0	5826	2240	4040	0	0	6574	6358	-1146	16983	0	0	16983	2110	335	19428	49.95
4	5660	302	0	5962	2232	3995	0	0	6441	6213	-1108	16978	0	0	16978	2027	316	19321	49.99
5	5617	301	0	5918	2095	4317	0	0	6656	6567	-1133	17418	0	0	17418	2029	346	19793	50.02
6	5643	777	0	6420	1994	4682	0	0	7090	7121	-1227	18604	0	0	18604	2152	386	21142	49.98
7	5758	1393	0	7151	1859	4780	0	71	7914	7693	-1269	19889	0	0	19889	2320	396	22605	49.93
8	5826	848	0	6674	1831	4706	0	313	9068	8718	-1521	20310	0	0	20310	2532	411	23253	49.99
9	5817	786	0	6603	2030	4208	0	779	9399	9328	-1862	20625	0	0	20625	2868	461	23954	50.01
10	5700	490	0	6190	2127	3964	0	1091	9449	9433	-2048	20286	0	0	20286	3140	471	23897	49.92
11	5699	703	0	6402	2049	3880	0	1274	9352	9566	-2360	20354	0	0	20354	3333	457	24144	50.03
12	5793	526	0	6319	2044	4362	0	1263	8945	9091	-2320	20314	0	0	20314	3395	445	24154	50.04
13	5632	334	0	5966	2321	4601	0	1297	8954	8596	-2420	19930	0	0	19930	3319	431	23680	50.00
14	5207	425	0	5632	2196	4017	0	1277	8958	8646	-2291	19045	0	0	19045	3200	432	22677	50.00
15	5615	450	0	6065	2132	4096	0	1113	8814	8677	-2277	19373	0	0	19373	3232	433	23038	49.98
16	5726	398	0	6124	2107	4407	0	968	8682	8486	-2179	19466	0	0	19466	3248	447	23161	49.98
17	5674	371	0	6045	2069	4959	0	644	8434	7986	-2033	19200	0	0	19200	3179	470	22849	49.97
18	5693	373	0	6066	1759	5306	0	332	8101	7841	-1886	18953	0	0	18953	3137	465	22555	49.98
19	5706	1282	0	6988	1536	5432	0	57	7603	7241	-1671	19124	168	0	19292	3080	459	22831	49.98
20	5783	1892	53	7728	1501	5555	0	0	7153	6996	-1333	19999	286	0	20285	3042	448	23775	49.76
21	5576	1848	2	7426	1462	5465	0	0	6824	6656	-1245	19311	224	0	19535	2943	453	22931	49.96
22	5770	1249	0	7019	1360	5522	0	0	6535	6283	-1162	18576	0	0	18576	2806	446	21828	49.91
23	5818	722	0	6540	1431	5512	0	0	6495	6207	-1128	18128	0	0	18128	2718	434	21280	49.82
24	5752	402	0	6154	1578	5491	0	0	6222	5783	-1043	17536	0	0	17536	2626	427	20589	49.98
MUs	136.02	16.81	0.05	152.88	46.13	112.12	0.00	10.48	186.40	181.68	-39.13	454.04	0.68	0.00	454.71	67.09	10.13	531.93	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Aug/2023

Position as on 6.30 Hrs of 09/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	13/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00	08/08/2023	10:24	Annual Overhaul	08/08/2023
MSPGCL	Uran Unit 7	108	20/07/2023	20:00		Continued.	No schedule	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
IPP	SWPGPL U-3	135	21/07/2023	01:54	08/08/2023	19:00	Non-availability of linkage coal stock and due to continuous rains.	07/08/2023
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	DUE TO HPT DIFFERENTIAL EXPANSION ON HIGHER SIDE	22/08/2023
MSPGCL	Uran Unit 6	108	27/07/2023	20:10	08/08/2023	19:14	No Schedule	
MSPGCL	Parli Unit 7	250	28/07/2023	15:30	09/08/2023	05:48	Zero Schedule.	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	12/08/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Aug/2023

Position as on 6.30 Hrs of 09/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00		Continued.	ID Fan Problem.	09/08/2023
IPP	RPL(AMT) U-3	270	05/08/2023	19:07		Continued.	Due to TG shaft vibration high.	09/08/2023
MSPGCL	Uran Unit 6	108	08/08/2023	20:03	09/08/2023	04:36	due to low gas pressure from ONGC side.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 08/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 09/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Tripping							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20	08/08/2023	10:24	PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
765/400kV 1500 MVA ICT-1 @ EKTUNI	IntraState	08/08/2023	16:05	09/08/2023	01:19	PO	Diagnostic testing
500 KV LR Outages/Tripping							
Pole-2 Non base AC filter Z4 (80 MVAR) @ PADGHE HVDC	IntraState	07/08/2023	22:43	08/08/2023	00:46	EO	For removing grass, bushes and weed control work in Non Base Filter switch yard area 500 kV HVDC Pole-2
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	08/08/2023	01:09	08/08/2023	02:54	EO	For removing grass, bushes and weed control work in Base Filter 500 kV HVDC Pole-2
400 KV TIEBAY Outages/Tripping							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Tripping							
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	04/08/2023	09:22			PO	400 kV 125 MVar Bus Reactor to be kept OFF during Outage on 400 kV Bus-2 as it is connected to 400 kV Bus-2
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - KHANDWA CKT - 2	InterState	09/08/2023	09:45	09/08/2023	11:09	HT	plan outage on L/R at khandwa end
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ȳȳ phase Protection CT Of NTPP I (RPL 1)
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03			PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	07/08/2023	20:24	08/08/2023	06:36	HT	H/T on overvoltage
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	09/08/2023	10:58			PO	(1)Reactor back up relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44			PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 09/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	06/08/2023	09:44			PO	Cooling System Renovation, commissioning, HV CB timing/DCRM,SFRA,REF,NDR relay & bay Maintenance work
400/220 KV 500 MVA ICT @ ALKUD	IntraState	08/08/2023	10:35	08/08/2023	20:20	PO	For routine maintenance & diagnostic testing work
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	08/08/2023	21:46	09/08/2023	01:28	T	Tripped on OLTC bucholz
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
BOMBAY DYEING - SAHARA	IntraState	03/08/2023	12:24			T	Tripped on distance protection
APTA - BOMBAY DYEING	IntraState	03/08/2023	12:24			T	Tripped on distance protection
TROMBAY - SALSETTE CKT - 1	IntraState	07/08/2023	23:20	08/08/2023	08:18	PO	- Loop closing at loc. 48 for making "T" connection on 220 kV Trombay Salsette 1 Line for soak test of 220 kV cable and 220 kV GIS at 400 kV KVTL Vikhroli S/S
TROMBAY - SALSETTE CKT - 1	IntraState	08/08/2023	00:22	08/08/2023	03:49	EO	For test charging 220KV KVPTL remaining 3 bay
KHAREPATAN -PAWAS LINE	IntraState	08/08/2023	10:13	08/08/2023	17:02	PO	Auto-Reclose Relay configuration and Relay testing for 220kV Pawas-Kharepatan Line at 220kV Kharepatan S/s.
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	IntraState	08/08/2023	11:15	08/08/2023	13:07	PO	Removal of Kite Manja
NERLE - DASGAON	IntraState	08/08/2023	11:35	08/08/2023	14:31	EO	Replacement of damaged R Ph Wave Trap Jump
LONAND-PHALTAN MIDC	IntraState	08/08/2023	11:37	08/08/2023	14:40	PO	TBC Wiring & Testing Work
WANI-WARORA 1	IntraState	08/08/2023	13:25	08/08/2023	16:19	PO	Replacement of Flash-over Insulator String
220KV BADNERA -220KV AVAADA(DHAMANGAON) SOLAR	IntraState	08/08/2023	13:51	08/08/2023	14:16	T	Tripped at Avaada end
KHARGHAR - SONKHAR	IntraState	08/08/2023	21:46	09/08/2023	12:20	T	Tripped on distance protection
KHARGHAR - NERUL	IntraState	08/08/2023	22:58	09/08/2023	11:42	T	H/T after sparking at cable terminal
URAN - KHARGHAR 1	IntraState	09/08/2023	02:00	09/08/2023	10:25	T	Tripped on distance protection
URAN - KHARGHAR 2	IntraState	09/08/2023	03:54	09/08/2023	08:25	T	Tripped on distance protection
NERUL - SEAWOOD CABLE CKT - 1	IntraState	09/08/2023	08:46	09/08/2023	09:54	T	TRIPPED WHILE CHARGING 220KV KHARGHAR-SONKHAR CKT
URAN - KHARGHAR 2	IntraState	09/08/2023	08:46	09/08/2023	10:28	T	TRIPPED WHILE CHARGING 220KV KHARGHAR-SONKHAR CKT
CHEMBUR (AEML) - NERUL (M)	IntraState	09/08/2023	08:46	09/08/2023	09:23	T	TRIPPED WHILE CHARGING 220KV KHARGHAR-SONKHAR CKT
NERUL - SEAWOOD CABLE CKT - 2	IntraState	09/08/2023	08:46	09/08/2023	09:54	T	TRIPPED WHILE CHARGING 220KV KHARGHAR-SONKHAR CKT
WARDHA (PG) - BADNERA	IntraState	09/08/2023	10:53			PO	For Amp of Line Bay.
BHOSARI- BHOSARI 2	IntraState	09/08/2023	11:25			PO	220kV Bhosari 2 Line Bay ,CB to Control relay panel 19c Cable having DC leakage . Outage required for replacement of 19C control cable of CB .
MAIN BUS @ TEMBHURNI	IntraState	09/08/2023	11:54			PO	Outage is required for Quarterly Maintenance
MAIN BUS - 2 @ MALINAGAR	IntraState	09/08/2023	11:54			PO	Outage is required for Quarterly Maintenance

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 09/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MALINAGAR - TEMBHURNI	IntraState	09/08/2023	11:57			PO	Outage is required for Quarterly Maintenance
MALINAGAR - TEMBHURNI	IntraState	09/08/2023	11:57			PO	Outage is required for Quarterly Maintenance
VANKUSWADE - KDPH	IntraState	09/08/2023	12:35			PO	Fixing & repair sleeve between loc No.47-48 B ph & tightening of nut bolt at cut point location of KDPH LILO line.
KALWA - BORIVALI	IntraState	09/08/2023	12:43			PO	For replacement of Wave Traps and Annual Diagnostic Tests.
PADGHE - TEMGHAR - 1	IntraState	09/08/2023	13:01			T	TRIPPED ON DISTANCE PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132kv 100MVA ICT - 2 @ KALWAN	IntraState	09/08/2023	11:15			PO	Diagnostic Testing Work.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage