

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 08/Sep/2021 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 97.082         | 881.042         | 1) Gujrat                      | -12.883        | -87.898         |
| 2) Hydro            | 9.558          | 107.418         | 2) Madhya Pradesh              | 2.640          | 15.423          |
| 3) Gas              | 7.878          | 70.386          | 3) Chattisgarh                 | 5.360          | 31.080          |
| <b>Total MSPGCL</b> | <b>114.518</b> | <b>1058.846</b> | 4) Maharashtra                 | 135.330        | 1208.466        |
| B) 1) APML          | 45.049         | 413.323         | 5) Goa (Amona)                 | -1.130         | -6.223          |
| 2) JSWEL            | 11.410         | 112.435         | <b>Total</b>                   | <b>129.317</b> | <b>1160.848</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 28.157         | 196.877         |
| 4) RPL(AMT)         | 18.547         | 201.731         | b) Mumbai Drawl                | 22.620         | 188.991         |
| 5) SWPGPL           | 2.922          | 40.172          | c) MSEDCL Bilateral *          | 28.411         | 268.001         |
| 6) Other IPP        | 4.716          | 46.269          | Include PX                     | 2.218          | 37.574          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 28.157         | 196.877         |
| C) 1) TPCL Thermal  | 14.859         | 118.794         | Include PX                     | 5.400          | 46.593          |
| 2) TPCL Hydro       | 3.145          | 28.797          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.875          | 13.047          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 11.561         | 90.401          | 1) MSEDCL                      | 362.799        | 3076.236        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 56.066         | 440.035         |
| 1) Thermal          | 206.146        | 1904.167        | <b>TOTAL STATE</b>             | <b>418.865</b> | <b>3516.271</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 12.703         | 136.215         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.753         | 83.433          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 54.274         | 190.383         |                                |                |                 |
| 6) SOLAR            | 4.666          | 41.220          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>289.542</b> | <b>2355.418</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4342                      | 4104                  | 4404                      | 3825                      |
| MSPGCL Hydro             | 306                       | 568                   | 863                       | 342                       |
| MSPGCL Gas               | 378                       | 235                   | 245                       | 372                       |
| MSPGCL Total Generation  | 5026                      | 4907                  | 5512                      | 4539                      |
| Central Sector Receipt   | 6227                      | 5508                  | 5650                      | 4199                      |
| WIND                     | 2040                      | 2601                  | 2610                      | 2042                      |
| CPP / IPP Thermal        | 3986                      | 3452                  | 4203                      | 2816                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 496                       | 87                    | 0                         | 0                         |
| Exchange with Mumbai     | -1189                     | -1038                 | -948                      | -585                      |
| <b>MSEDCL DEMAND MET</b> | <b>16586</b>              | <b>15517</b>          | <b>17027</b>              | <b>13011</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 16586                     | 15517                 | 17027                     | 13011                     |
| TPCL GENERATION          | 982                       | 1089                  | 1125                      | 661                       |
| AEML GENERATION          | 493                       | 494                   | 500                       | 492                       |
| <b>MUMBAI DEMAND</b>     | <b>2664</b>               | <b>2621</b>           | <b>2573</b>               | <b>1738</b>               |
| STATE DEMAND MET         | 19250                     | 18138                 | 19600                     | 14749                     |
| <b>STATE DEMAND</b>      | <b>19250</b>              | <b>18138</b>          | <b>19600</b>              | <b>14749</b>              |
| Frequency (Hz)           | 50.04                     | 49.97                 | 49.93                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.16 Hz at 13.01 Hrs | 49.71 Hz at 19.21 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 08/Sep/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 23.96         | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 8.72         | 16.85         | 405      | 310      |
| Unit 9             | 8.07         | 73.50         | 420      | 310      |
| Unit 10            | 8.31         | 76.18         | 490      | 300      |
| <b>Total</b>       | <b>25.10</b> | <b>190.49</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 17.05         | 0        | 0        |
| Unit 4             | 7.51         | 60.92         | 405      | 280      |
| Unit 5             | 7.77         | 41.25         | 430      | 275      |
| <b>Total</b>       | <b>15.28</b> | <b>119.22</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.98         | 37.72         | 188      | 148      |
| Unit 8             | 2.55         | 33.84         | 190      | 0        |
| <b>Total</b>       | <b>6.54</b>  | <b>71.56</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 11.53         | 0        | 0        |
| Unit 4             | 0.00         | 15.71         | 0        | 0        |
| Unit 5             | 5.40         | 53.82         | 295      | 170      |
| Unit 6             | 4.78         | 42.68         | 245      | 135      |
| Unit 7             | 6.59         | 57.77         | 288      | 247      |
| Unit 8             | 8.08         | 73.57         | 410      | 275      |
| Unit 9             | 8.32         | 10.48         | 435      | 275      |
| <b>Total</b>       | <b>33.18</b> | <b>265.56</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 20.70         | 0        | 0        |
| Unit 4             | 3.57         | 31.33         | 185      | 98       |
| <b>Total</b>       | <b>3.57</b>  | <b>52.03</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.73         | 17.33         | 135      | 105      |
| Unit 2             | 2.89         | 25.24         | 140      | 115      |
| Unit 3             | 3.28         | 28.32         | 160      | 130      |
| Unit 4             | 3.35         | 28.36         | 185      | 130      |
| Unit 5             | 0.00         | 56.07         | 0        | 0        |
| <b>Total</b>       | <b>12.25</b> | <b>155.32</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 25.70         | 0        | 0        |
| Unit 5             | 1.17         | 1.17          | 170      | 0        |
| <b>Total</b>       | <b>1.17</b>  | <b>26.86</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.88         | 70.39         | 387      | 235      |
| <b>Total</b>       | <b>7.88</b>  | <b>70.39</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.50         | 3.34          | 27       | 3        |
| <b>Total</b>       | <b>0.50</b>  | <b>3.34</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 1.36         | 18.77         | 225      | 40       |
| Stage 4         | 0.90         | 23.98         | 250      | 0        |
| Stage 3         | 1.27         | 11.93         | 160      | 0        |
| <b>Total</b>    | <b>3.52</b>  | <b>54.67</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.00          | 0        | 0        |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.42         | 3.05          | 40       | 0        |
| SMLHY_PTN       | 5.18         | 44.93         | 226      | 195      |
| GHATGHAR        | 0.44         | 4.76          | 125      | 0        |
| <b>Total</b>    | <b>6.03</b>  | <b>52.74</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 54.27        | 190.38        | 0        | 0        |
| <b>Total</b>    | <b>54.27</b> | <b>190.38</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 45.05        | 413.32        | 0        | 0        |
| JSWEL(Mus)      | 11.41        | 112.44        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 18.55        | 201.73        | 0        | 0        |
| SWPGPL-Mus      | 2.92         | 40.17         | 0        | 0        |
| Other(Mus)      | 4.72         | 46.27         | 0        | 0        |
| <b>Total</b>    | <b>82.64</b> | <b>813.93</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 4.67         | 41.22         | 0        | 0        |
| <b>Total</b>    | <b>4.67</b>  | <b>41.22</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 9.75         | 80.58         | 472      | 275      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.40         | 9.14          | 117      | 88       |
| Trombay 7B      | 1.48         | 3.90          | 68       | 59       |
| Trombay 8       | 5.11         | 38.22         | 222      | 144      |
| TATA Hydro      | 3.14         | 28.80         | 267      | 0        |
| <b>Total</b>    | <b>21.88</b> | <b>160.64</b> |          |          |
| <b>AEMIL</b>    |              |               |          |          |
| DTPS U-1&2      | 11.56        | 90.40         | 500      | 319      |
| <b>Total</b>    | <b>11.56</b> | <b>90.40</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 97.08       | 881.04        | MSPGCL Total        | 114.52      | 1058.85       |
|                |             |         | MSPGCL Thml+Gas | 104.96      | 951.43        | Koyna 1,2 & 4 Total | 2.26        | 42.74         |
|                |             |         | MSPGCL Hydro    | 9.56        | 107.42        | State Total         | 289.54      | 2355.42       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 08/Sep/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3833        | 455  | 378  | 4666   | 1963  | 2900      | 0    | 0     | 4701        | 4375        | -702                 | 13202                 | 0                    | 13202                     | 2011             | 15213           | 50.01         |
| 2                  | 3865        | 335  | 387  | 4587   | 1931  | 2832      | 0    | 0     | 4176        | 4273        | -625                 | 12998                 | 0                    | 12998                     | 1885             | 14883           | 49.99         |
| 3                  | 3848        | 332  | 387  | 4567   | 2007  | 2834      | 0    | 0     | 4150        | 4233        | -590                 | 13051                 | 0                    | 13051                     | 1794             | 14845           | 49.99         |
| 4                  | 3825        | 342  | 372  | 4539   | 2042  | 2816      | 0    | 0     | 4232        | 4199        | -585                 | 13011                 | 0                    | 13011                     | 1738             | 14749           | 50.00         |
| 5                  | 3813        | 349  | 378  | 4540   | 2066  | 2751      | 0    | 0     | 4540        | 4503        | -530                 | 13330                 | 0                    | 13330                     | 1729             | 15059           | 50.00         |
| 6                  | 3914        | 285  | 367  | 4566   | 1982  | 3124      | 0    | 0     | 5154        | 5302        | -554                 | 14420                 | 0                    | 14420                     | 1794             | 16214           | 49.99         |
| 7                  | 4257        | 265  | 380  | 4902   | 2067  | 3786      | 0    | 22    | 5902        | 5530        | -648                 | 15660                 | 0                    | 15660                     | 1877             | 17536           | 50.01         |
| 8                  | 4168        | 280  | 358  | 4806   | 1939  | 4040      | 0    | 144   | 6458        | 6501        | -1102                | 16328                 | 0                    | 16328                     | 2064             | 18392           | 49.96         |
| 9                  | 4343        | 302  | 369  | 5014   | 1979  | 4079      | 0    | 297   | 6726        | 6401        | -1308                | 16462                 | 0                    | 16462                     | 2363             | 18825           | 50.04         |
| 10                 | 4342        | 306  | 378  | 5026   | 2040  | 3986      | 0    | 496   | 6496        | 6227        | -1189                | 16586                 | 0                    | 16586                     | 2664             | 19250           | 50.04         |
| 11                 | 4024        | 299  | 366  | 4689   | 2019  | 3571      | 0    | 568   | 7061        | 6729        | -1275                | 16301                 | 0                    | 16301                     | 2835             | 19136           | 49.97         |
| 12                 | 3750        | 302  | 368  | 4420   | 2159  | 3266      | 0    | 652   | 6881        | 6610        | -1290                | 15817                 | 0                    | 15817                     | 2877             | 18694           | 49.95         |
| 13                 | 3682        | 311  | 366  | 4359   | 2259  | 3143      | 0    | 561   | 6735        | 6123        | -1246                | 15199                 | 0                    | 15199                     | 2826             | 18025           | 50.02         |
| 14                 | 3730        | 305  | 352  | 4387   | 2403  | 2993      | 0    | 586   | 6363        | 5621        | -1175                | 14815                 | 0                    | 14815                     | 2688             | 17503           | 50.01         |
| 15                 | 3792        | 303  | 360  | 4455   | 2462  | 2841      | 0    | 578   | 5850        | 5693        | -1212                | 14817                 | 0                    | 14817                     | 2715             | 17532           | 49.97         |
| 16                 | 4008        | 282  | 361  | 4651   | 2635  | 3081      | 0    | 438   | 5716        | 5860        | -1246                | 15419                 | 0                    | 15419                     | 2708             | 18127           | 50.00         |
| 17                 | 4054        | 339  | 271  | 4664   | 2704  | 3274      | 0    | 235   | 5927        | 5745        | -1212                | 15410                 | 0                    | 15410                     | 2671             | 18081           | 49.99         |
| 18                 | 4104        | 568  | 235  | 4907   | 2601  | 3452      | 0    | 87    | 5604        | 5508        | -1038                | 15517                 | 0                    | 15517                     | 2621             | 18138           | 49.97         |
| 19                 | 4401        | 745  | 236  | 5382   | 2687  | 3910      | 0    | 2     | 5604        | 5642        | -977                 | 16646                 | 0                    | 16646                     | 2584             | 19230           | 49.94         |
| 20                 | 4404        | 863  | 245  | 5512   | 2610  | 4203      | 0    | 0     | 5940        | 5650        | -948                 | 17027                 | 0                    | 17027                     | 2573             | 19600           | 49.93         |
| 21                 | 4409        | 738  | 246  | 5393   | 2566  | 4261      | 0    | 0     | 5051        | 4863        | -850                 | 16233                 | 0                    | 16233                     | 2445             | 18678           | 49.99         |
| 22                 | 4317        | 468  | 246  | 5031   | 2513  | 4202      | 0    | 0     | 5146        | 4500        | -807                 | 15439                 | 0                    | 15439                     | 2325             | 17764           | 50.00         |
| 23                 | 4092        | 433  | 236  | 4761   | 2401  | 3821      | 0    | 0     | 5119        | 4627        | -772                 | 14838                 | 0                    | 14838                     | 2179             | 17017           | 49.98         |
| 24                 | 4107        | 351  | 236  | 4694   | 2239  | 3478      | 0    | 0     | 4983        | 4602        | -739                 | 14274                 | 0                    | 14274                     | 2094             | 16368           | 49.98         |
| MUs                | 97.08       | 9.56 | 7.88 | 114.52 | 54.27 | 82.64     | 0.00 | 4.67  | 134.52      | 129.32      | -22.62               | 362.80                | 0.00                 | 362.80                    | 56.06            | 418.86          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 08/Sep/2021

Position as on 6.30 Hrs of 09/Sep/2021

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                             |               |
| IPP                   | Adani U-1               | 660      | 25/08/2021   | 00.06        |            | Continued. | Annual Overhaul                                                             |               |
| IPP                   | RPL(AMT) U-4            | 270      | 02/09/2021   | 00.00        |            | Continued. | Annual Overhaul                                                             |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 04/09/2021   | 23.58        |            | Continued. | Annual Overhaul                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                             |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                     |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                        |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                     |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                      |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                       |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                               |               |
| IPP                   | SWPGPL U-4              | 135      | 05/08/2021   | 03.04        |            | Continued. | Turbine Vibration High.                                                     |               |
| MSPGCL                | Nasik Unit 5            | 210      | 19/08/2021   | 00.00        | 08/09/2021 | 14.40      | Coal Shortage. Which Was Tripped On BTL From 07:08:2021 At 20:45.           |               |
| MSPGCL                | Parli Unit 6            | 250      | 26/08/2021   | 21.06        |            | Continued. | Coal Shortage (Converted to AOH 00.00Hrs from Dt.01/09/2021)                |               |
| MSPGCL                | Nasik Unit 3            | 210      | 30/08/2021   | 22.51        |            | Continued. | Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021 |               |
| IPP                   | JSW (J) U1              | 300      | 02/09/2021   | 08.41        |            | Continued. | Turbine vibrations high.                                                    |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 05/09/2021   | 20.05        |            | Continued. | Zero schedule.                                                              |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 06/09/2021   | 07.05        |            | Continued. | Generator Elect. Fault                                                      |               |
| MSPGCL                | Paras Unit 3            | 250      | 06/09/2021   | 09.20        |            | Continued. | Turbine bearing Vabration high                                              |               |
| MSPGCL                | Khaparkheda Unit 5      | 500      | 06/09/2021   | 15.29        | 09/09/2021 | 17.28      | Boiler Tube Leakage                                                         |               |
| IPP                   | JSW (J) U3              | 300      | 07/09/2021   | 10.20        |            | Continued. | Non availability of load scheduling.                                        |               |
| IPP                   | SWPGPL U-2              | 135      | 07/09/2021   | 15.17        |            | Continued. | ID Fan Problem                                                              |               |
| MSPGCL                | Koradi Unit 6           | 210      | 07/09/2021   | 19.36        |            | Continued. | PA Fan problem                                                              |               |
| MSPGCL                | Nasik Unit 4            | 210      | 07/09/2021   | 20.03        |            | Continued. | PA Fan problem(Converted to Zero schedule from 12.00Hrs DT.13-09-2021)      |               |
| MSPGCL                | Parli Unit 8            | 250      | 08/09/2021   | 09.38        | 08/09/2021 | 12.37      | Flame Failure                                                               |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2021   | 16.14        | 09/09/2021 | 02.33      | Due to Y-Phase jumper broken at Transco side fault.                         |               |
| IPP                   | RPL(AMT) U-3            | 270      | 09/09/2021   | 09.30        | 09/09/2021 | 13.00      | Turbine Vibration High.                                                     |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 09/09/2021   | 13.28        |            | Continued. | Wet Coal.                                                                   |               |
| MSPGCL                | Parli Unit 7            | 250      | 09/09/2021   | 20.00        |            | Continued. | Zero Schedule.                                                              |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 08/Sep/2021**

Position as on 6.30 Hrs of 09/Sep/2021

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------|---------------|
| MSPGCL             | Uran Unit 6             | 108      | 09/09/2021   | 23.48        |           | Continued. | Gas Shortage.    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/Sep/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 09/Sep/2021**

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                   |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                    |
| Koradi III - Akola II- ckt-II                 | IntraState                | 09/09/2021   | 10.50        | 09/09/2021 | 18.49      | EO          | For checking healthiness DC supply circuit and Tripping circuit.                                                   |
| <b>500 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                    |
| Chandrapur - Padghe Hvdc Pole 2               | IntraState                | 08/09/2021   | 00.24        | 08/09/2021 | 04.30      | EO          | Buccholz alarm of smoothing reactor work.                                                                          |
| <b>400 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                    |
| Karad Solapur (PG)                            | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                           |
| Chandrapur Bhadravati I                       | InterState                | 01/09/2021   | 09.50        | 08/09/2021 | 22.32      | PO          | Replacement of HCB Isolators                                                                                       |
| Warora -IEPL                                  | IntraState                | 02/09/2021   | 22.38        |            | Continued. | PO          | Height raising work across Samruddhi highway at ch 27-400km.                                                       |
| Dhule- Bableshtar - I                         | IntraState                | 04/09/2021   | 06.37        |            | Continued. | PO          | Samruddhi expressway crossing tower erection work.                                                                 |
| Dhule - Bableshtar - II                       | IntraState                | 04/09/2021   | 06.40        |            | Continued. | PO          | Samruddhi expressway crossing tower erection work.                                                                 |
| Taptitanda Waluj                              | IntraState                | 07/09/2021   | 21.10        | 08/09/2021 | 14.40      | T           | Distance Protection                                                                                                |
| Bus Coupler @ Kalwa                           | IntraState                | 08/09/2021   | 04.54        | 08/09/2021 | 06.26      | EO          | Attending Hot Spot                                                                                                 |
| Lonikand I - Koyna stage-IV                   | IntraState                | 08/09/2021   | 09.29        | 08/09/2021 | 14.30      | PO          | Polymer string replacement work under R&M scheme.                                                                  |
| Khadka-Aurangabad (Waluj)                     | IntraState                | 08/09/2021   | 22.06        | 09/09/2021 | 07.35      | HT          | Over Voltage                                                                                                       |
| Lonikand 1 - Talegaon(Pgcil)                  | IntraState                | 09/09/2021   | 08.35        | 09/09/2021 | 16.18      | PO          | Routine Maintenance Work                                                                                           |
| Chandrapur-II - Nanded ckt II                 | IntraState                | 09/09/2021   | 13.05        | 09/09/2021 | 19.51      | PO          | For CB DCRM, CT Tan-d, Line CVT Tan-d & Bay Maintenance.                                                           |
| Nagothane - Dabhol I                          | IntraState                | 09/09/2021   | 13.19        | 09/09/2021 | 18.02      | T           | Distance Protection                                                                                                |
| Khadka-Aurangabad (Waluj)                     | IntraState                | 09/09/2021   | 20.06        |            | Continued. | HT          | Over Voltage                                                                                                       |
| <b>400 KV ICT Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                    |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2    | IntraState                | 07/09/2021   | 20.23        |            | Continued. | T           | Differential protection.                                                                                           |
| 400/220/33 Kv 315 Mva Ict 1 @Dhule            | IntraState                | 08/09/2021   | 13.50        | 08/09/2021 | 18.50      | PO          | Carry out maintenance on auxiliary bus (89C) isolator.                                                             |
| 400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali) | IntraState                | 09/09/2021   | 09.45        | 09/09/2021 | 17.03      | PO          | 1) REF relay testing and IV side CT testing work.2) Bay maintenance work.                                          |
| 400/220 Kv 500 Mva ICT- I @Jejuri             | IntraState                | 09/09/2021   | 10.41        | 09/09/2021 | 19.42      | PO          | Annual Testing & Maintenance work. Also CTR fire protection system work.                                           |
| <b>220 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                    |
| Mudshingi Chikodi                             | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                        |
| Talandage - Chikodi                           | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                             |
| EKLAHARE (OCR) Nasik - Navsari I              | InterState                | 07/09/2021   | 23.48        | 09/09/2021 | 06.15      | HT          | To control line loading of 220kv Nasik-Bableshtar ckt.                                                             |
| Raymond - Washala                             | IntraState                | 03/09/2021   | 09.50        | 09/09/2021 | 04.39      | PO          | Samruddhi highway project work                                                                                     |
| Uran - Kharghar I                             | IntraState                | 08/09/2021   | 08.04        | 08/09/2021 | 09.26      | PO          | Stringing on newly erected CT tower at proposed waghivali GIS and charging of cable from CTT to proposed Ulwe GIS. |
| New Koyna - Pedambe                           | IntraState                | 08/09/2021   | 08.47        | 08/09/2021 | 19.40      | PO          | R-Phase CT to line side isolator conductor strands found open.                                                     |
| Theur- Magar Patta City                       | IntraState                | 08/09/2021   | 08.48        | 08/09/2021 | 13.56      | EO          | Attending Hot Spot                                                                                                 |
| Khaparkheda-Ambazari-II                       | IntraState                | 08/09/2021   | 09.51        | 08/09/2021 | 18.33      | PO          | Replacement of Flashover String                                                                                    |
| K'Kheda- Suryalakshmi                         | IntraState                | 08/09/2021   | 10.00        | 08/09/2021 | 17.24      | T           | Replacement of Flashover String                                                                                    |
| Osmanabad - Barshi                            | IntraState                | 08/09/2021   | 10.05        | 08/09/2021 | 13.44      | PO          | Quarterly Maintenance Work                                                                                         |
| Malinagar - Tembhurni                         | IntraState                | 08/09/2021   | 10.36        | 08/09/2021 | 17.35      | PO          | Quarterly Maintenance Work                                                                                         |
| Kalmeshwar-Pandhurna                          | IntraState                | 08/09/2021   | 10.42        | 08/09/2021 | 15.36      | PO          | Routine Maintenance Work                                                                                           |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/Sep/2021**

**Statement-VII**

Position as on 6.30 Hrs of 09/Sep/2021

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                         |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| Dondaicha- Shahada                      | IntraState                | 08/09/2021   | 11.17        | 08/09/2021 | 18.14      | PO          | CB Overhauling work                                                                                                                                      |
| Main Bus Section-I@ Pedambe             | IntraState                | 08/09/2021   | 15.13        | 08/09/2021 | 18.48      | EO          | Y-Ph main bus side isolator to main bus conductor damaged, due to heavy sparking.                                                                        |
| 220KV Chalisagaon-Kopergaon             | IntraState                | 08/09/2021   | 16.15        | 08/09/2021 | 19.51      | EO          | To attend Hot Spot                                                                                                                                       |
| Kalwa1- Airoli Knowledge Park           | IntraState                | 08/09/2021   | 17.44        | 08/09/2021 | 21.38      | EO          | Attending Hot Spot                                                                                                                                       |
| Kandalgaon - Sona Alloys                | IntraState                | 08/09/2021   | 21.16        | 09/09/2021 | 15.00      | T           | Distance Protection                                                                                                                                      |
| Raymond - Washala                       | IntraState                | 09/09/2021   | 05.25        | 09/09/2021 | 12.58      | T           | Distance Protection                                                                                                                                      |
| Lonand Sona Alloys                      | IntraState                | 09/09/2021   | 11.15        | 09/09/2021 | 12.38      | T           | Distance Protection                                                                                                                                      |
| Kandalgaon - Sona Alloys                | IntraState                | 09/09/2021   | 11.15        | 09/09/2021 | 15.00      | T           | Distance Protection                                                                                                                                      |
| Phursungi-Serum                         | IntraState                | 09/09/2021   | 15.43        | 09/09/2021 | 18.32      | EO          | Pilot string disconnected from clamp Hence Chattering & sparking at that point due to jump moving Local citizen call due to heavy chattering & sparking. |
| <b>220 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                          |
| 220/132 Kv 100 Mva Bhel Ict 1 @Padegaon | IntraState                | 07/09/2021   | 21.02        | 08/09/2021 | 00.15      | T           | LV side tripped, Bus protection optd.                                                                                                                    |
| 220/132 KV 200MVA Vijai ICT-2 @Theur    | IntraState                | 09/09/2021   | 09.35        | 09/09/2021 | 13.13      | PO          | For attending oil leakage from HV R phase Terrait.                                                                                                       |
| 220/100 Kv 100 MVA ICT II @Vasai-li     | IntraState                | 09/09/2021   | 11.50        | 09/09/2021 | 17.51      | PO          | For Diagnostic Testing work & LV CB repair at 220kV Vasai S/S end & Relay commissioning work on 100kV Vasai line-2 at 100kV Vasai S/S end.               |
| 220/100 Kv 200 MVA ICT-II @Trombay      | IntraState                | 09/09/2021   | 13.19        | 09/09/2021 | 17.01      | EO          | Hot spot attending work at HV side 'B' Phase CT clamp (Temp=109 degree) & LV side 'Y' Phase breaker top pad nut-bolt(146 degree).                        |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage