

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Sep/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	121.825	1110.410	1) Gujrat	0.393	35.615
2) Hydro	6.925	137.076	2) Madhya Pradesh	-1.438	10.389
3) Gas	6.901	55.767	3) Chattisgarh	3.170	23.910
Total MSPGCL	135.651	1303.253	4) Maharashtra	170.514	1577.785
B) 1) APLM	49.830	469.079	5) Goa (Amona)	-1.682	-13.820
2) JSWEL	24.974	211.214	Total	170.957	1633.879
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.619	254.159
4) RPL(AMT)	24.368	202.190	b) Mumbai Drawl	40.362	288.544
5) SWPGPL	11.409	94.854	c) MSEDCL Bilateral *	102.033	793.586
6) Other IPP	5.647	53.667	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.619	254.110
C) 1) TPCL Thermal	10.461	108.014	Include PX	0.000	0.000
2) TPCL Hydro	2.847	34.051	Standby	0.000	0.049
3) TPCL Gas	2.329	17.728	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.267	78.878	1) MSEDCL	435.534	3922.514
D) STATE			2) Mumbai Discoms	65.266	527.216
1) Thermal	257.781	2328.306	3) Other Discoms	10.401	82.918
(A1+C1+C4+(B1-B6))			TOTAL STATE	511.201	4532.648
2) Hydro	9.772	171.127			
(A2+C2)					
3) Gas	9.230	73.495			
(A3+B7+C3)					
4) Wind	56.826	233.015			
6) SOLAR	6.635	92.825			
TOTAL STATE	340.244	2898.768			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5392	4433	5186	5346
MSPGCL Hydro	460	169	478	232
MSPGCL Gas	282	283	291	279
MSPGCL Total Generation	6134	4885	5955	5857
Central Sector Receipt	8944	8530	6743	5626
WIND	2059	2611	2647	2250
CPP / IPP Thermal	5060	4093	5407	4897
CPP / IPP Gas	0	0	0	0
SOLAR	479	1201	0	0
Exchange with Mumbai	-2146	-2408	-1520	-1464
MSEDCL DEMAND MET	20079	18477	18784	16484
Load Shedding	0	0	0	0
MSEDCL DEMAND	20079	18477	18784	16484
TPCL GENERATION	583	592	993	661
AEML GENERATION	435	294	385	344
MUMBAI DEMAND	3164	3294	2898	2469
OTHER DISCOM DEMAND	451	435	448	682
STATE DEMAND MET	23694	22206	22130	19635
STATE DEMAND	23694	22206	22130	19635
Frequency (Hz)	50.02	50.04	50.01	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 13.24 Hrs	49.79 Hz at 06.14 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Sep/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.82	28.96	150	90
Unit 8	12.41	105.04	640	405
Unit 9	11.31	91.28	523	361
Unit 10	0.00	0.00	0	0
Total	26.53	225.28		
Bhusawal				
Unit 3	2.54	21.16	135	5
Unit 4	8.61	75.33	430	285
Unit 5	6.94	74.38	410	0
Total	18.10	170.87		
Parli				
Unit 6	4.06	36.63	211	149
Unit 7	1.50	33.60	212	0
Unit 8	3.62	33.88	170	143
Total	9.17	104.11		
Chandrapur				
Unit 3	3.20	28.22	156	120
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	6.02	43.04	320	165
Unit 7	5.89	51.00	270	227
Unit 8	8.94	75.83	410	282
Unit 9	9.32	80.34	419	314
Total	33.37	278.43		
Paras				
Unit 3	3.92	37.50	198	136
Unit 4	4.23	39.04	217	143
Total	8.15	76.54		
Khaparkheda				
Unit 1	2.45	22.22	135	65
Unit 2	1.49	16.63	90	35
Unit 3	2.66	27.60	137	73
Unit 4	2.76	27.70	140	96
Unit 5	8.85	82.94	430	290
Total	18.21	177.09		
Nasik				
Unit 3	2.74	24.19	148	0
Unit 4	3.25	27.89	148	123
Unit 5	2.31	26.01	152	0
Total	8.30	78.08		
Uran				
All Units	6.90	55.77	294	279
Total	6.90	55.77		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.42	5.45	45	0
Total	0.42	5.45		
Koyna				
Stage 1-2	1.49	27.26	305	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.23	48.99	185	0
Stage 3	0.93	17.45	214	0
Total	2.65	93.70		
Hydro				
KDPH	0.43	3.46	18	18
VTRNA	0.22	0.22	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.28	3.08	77	0
SMLHY_PTN	2.92	30.34	131	105
GHATGHAR	0.00	0.83	0	0
Total	3.86	37.93		
Wind				
Total	56.83	233.02	0	0
Total	56.83	233.02		
CPP				
APML(Mus)	49.83	469.08	0	0
JSWEL(Mus)	24.97	211.21	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.37	202.19	0	0
SWPGPL-Mus	11.41	94.85	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.24	47.58	258	174
Other(Mus)	0.41	6.09	0	0
Total	116.23	1031.00		
SOLAR				
Total	6.64	92.82	0	0
Total	6.64	92.82		
Tata				
Trombay 5	6.86	70.86	365	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.31	9.89	108	38
Trombay 7B	1.02	7.84	64	35
TATA Hydro	2.85	34.05	329	21
Trombay 8	3.60	37.16	190	131
Total	15.64	159.79		
AEML				
DTPS U-1&2	9.27	78.88	495	291
Total	9.27	78.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	121.82	1110.41	MSPGCL Total	135.65	1303.25
			MSPGCL Thml+Gas	128.73	1166.18	Koyna 1,2 & 4 Total	1.72	76.25
			MSPGCL Hydro	6.92	137.08	State Total	340.24	2898.77

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Sep/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5246	193	294	5733	1936	5157	0	0	6165	6164	-1277	17322	0	0	17322	2408	391	20121	49.96
2	5322	188	286	5796	2042	5361	0	0	6149	5845	-1268	17420	0	0	17420	2256	356	20032	49.98
3	5119	188	286	5593	2187	5097	0	0	6360	5958	-1228	17265	0	0	17265	2121	342	19728	50.01
4	5191	175	287	5653	2236	4745	0	0	6271	6179	-1155	17316	0	0	17316	2044	342	19702	49.99
5	5325	189	287	5801	2297	4723	0	0	6472	6253	-1064	17652	0	0	17652	2033	358	20043	50.01
6	5425	194	289	5908	2170	4708	0	0	7243	7062	-1214	18259	0	0	18259	2132	375	20766	49.97
7	5551	196	288	6035	2282	5376	0	15	7327	7384	-1165	19518	0	0	19518	2317	409	22244	49.93
8	5469	376	284	6129	2186	5076	0	123	7805	8004	-1482	19613	0	0	19613	2531	423	22567	50.01
9	5417	456	286	6159	2077	5074	0	321	8504	8625	-1852	19963	0	2	19963	2861	441	23265	50.03
10	5392	460	282	6134	2059	5060	0	479	9000	8944	-2146	20079	0	3	20079	3164	451	23694	50.02
11	5273	240	288	5801	2217	4795	0	750	9720	9081	-2407	19757	0	1	19757	3361	480	23598	50.03
12	4642	202	286	5130	2285	4218	0	969	10183	9337	-2473	19030	0	2	19030	3382	436	22848	50.01
13	4433	169	283	4885	2611	4093	0	1201	9206	8530	-2408	18477	0	0	18477	3294	435	22206	50.04
14	4371	170	281	4822	2711	3939	0	955	8451	7950	-2186	17761	0	0	17761	3047	430	21238	50.13
15	4532	222	291	5045	2509	4209	0	841	7684	7561	-2151	17584	0	0	17584	3021	430	21035	49.96
16	4671	330	289	5290	2592	4512	0	527	7193	7293	-2097	17678	0	0	17678	3046	439	21163	49.96
17	4696	252	288	5236	2771	4591	0	301	7076	6893	-2007	17331	0	0	17331	2998	454	20783	50.00
18	4827	565	294	5686	2575	4885	0	138	6428	6491	-1914	17398	0	0	17398	2972	463	20833	50.01
19	5002	431	286	5719	2782	5545	0	15	6707	6465	-1516	18548	0	0	18548	2935	462	21945	49.98
20	5186	478	291	5955	2647	5407	0	0	7168	6743	-1520	18784	0	0	18784	2898	448	22130	50.01
21	5036	398	290	5724	2678	4898	0	0	6792	6489	-1544	17781	0	0	17781	2777	464	21022	50.00
22	5048	374	292	5714	2527	4760	0	0	6283	6272	-1401	17415	0	0	17415	2659	457	20531	49.99
23	5305	247	294	5846	2199	5102	0	0	5760	5808	-1423	17099	0	0	17099	2540	433	20072	50.00
24	5346	232	279	5857	2250	4897	0	0	5769	5626	-1464	16484	0	0	16484	2469	682	19635	50.04
MUs	121.83	6.93	6.90	135.65	56.83	116.23	0.00	6.63	175.72	170.96	-40.36	435.53	0.00	0.01	435.53	65.27	10.40	511.20	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)220/33 KV 50 MVA T/F I & II OVERLOAD at 220 Kv Kopargaon sstn (134 A / 44 MW).

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 08/Sep/2023

Position as on 6.30 Hrs of 09/Sep/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	20/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	13/09/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00	09/09/2023	18:38	OVERHAUL	08/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	20/09/2023
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
MSPGCL	Uran Unit 6	108	02/09/2023	07:16		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	08/09/2023	00:47	08/09/2023	03:15	Flame Failure	
MSPGCL	Parli Unit 7	250	08/09/2023	08:51		Continued.	Generator Elect. Fault	10/09/2023
MSPGCL	Bhusawal Unit 5	500	08/09/2023	15:48	08/09/2023	18:12	Flame Failure	
MSPGCL	Bhusawal Unit 3	210	08/09/2023	17:08	08/09/2023	18:48	Drum level high	
MSPGCL	Nasik Unit 5	210	08/09/2023	17:12	08/09/2023	22:13	Furnace Pressure High	
MSPGCL	Uran Unit 7	108	09/09/2023	00:03		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	09/09/2023	01:24		Continued.	Boiler Tube Leakage	11/09/2023
MSPGCL	Chandrapur Unit 6	500	09/09/2023	06:20	09/09/2023	13:57	Electrical fault	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 08/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 09/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Tripping							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	07/09/2023	22:22	08/09/2023	00:23	T	Tripped on level 3, jumper found broken
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	09/09/2023	22:57		Continued.	EO	Attending Hotspot in Pole-2 Base Filter
400 KV MAINBAY Outages/Tripping							
MAIN BAY (404) OF ICT - 2 @ KORADI 3	IntraState	08/09/2023	09:40	08/09/2023	17:41	PO	Annual Maintenance of CB at Koradi-III SS.
400 KV LINE Outages/Tripping							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
CHAKAN - TALEGAON(PG)	InterState	08/09/2023	00:42	08/09/2023	06:18	EO	For attending 2 No's of Hotspots and repairing of damaged conductor at R Phase Wave Trap.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 2Y2 phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	04/09/2023	08:38	09/09/2023	11:57	HT	H/T to control PUNE GIS line loading.
KHADKA-AURANGABAD (WALUJ)	IntraState	07/09/2023	17:07	08/09/2023	09:11	HT	H/T For Voltage management.
KHADKA-AURANGABAD (WALUJ)	IntraState	08/09/2023	13:08	09/09/2023	09:29	HT	HT due to Overvoltage
EKTUNI - BABLESHWAR CKT - 1	IntraState	09/09/2023	09:51		Continued.	PO	Line Maintainence and Diagnostic Testing work.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	09/09/2023	11:47	09/09/2023	19:09	T	Tripped on distance protection.
KHADKA-AURANGABAD (WALUJ)	IntraState	09/09/2023	21:56		Continued.	HT	H/T For Voltage Management.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	09/09/2023	22:51			HT	H/T For load Management.
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	05/09/2023	09:21			PO	1.Replacement of HV CB under LES Scheme.2.A & B Bus PG isolator Maintenance Work.3.ICT HV Side will be in service through TBC.
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	08/09/2023	10:31	09/09/2023	02:45	PO	C bus 400kV PG isolator overhauling work. Quarterly maintenance work.
400/220/33 KV 315 MVA ICT - 1 @ DHULE	IntraState	08/09/2023	13:12	08/09/2023	17:58	T	33KV LA Burst
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09	09/09/2023	05:45	HT	As per usual practice line is H/T
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	06/09/2023	15:15	09/09/2023	04:52	HT	H/T for load management
PADGHE - JAMBHUL 2	IntraState	08/09/2023	00:05	08/09/2023	01:30	T	Tripped on distance protection
TALANDGE - SAWANTWADI	IntraState	08/09/2023	09:14	08/09/2023	16:27	PO	Replacement of Faulty insulator found in PID
CHAKAN (400KV) - VOLKSWAGEN	IntraState	08/09/2023	10:10	08/09/2023	17:57	PO	SCADA Trial and Commissioning work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 09/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - WADA	IntraState	08/09/2023	10:34	08/09/2023	18:44	PO	For replacement of R , Y & B phase CT due to Minor oil leakage & Aging.
AURANGABAD (WALUJ)-DEOGAON RANGARI	IntraState	08/09/2023	11:00	08/09/2023	12:16	EO	Attend Hot Spot
THEUR-PHURSUNGI CKT II	IntraState	08/09/2023	11:00	08/09/2023	17:09	PO	Bay Half yearly maintenance & CB CRM & Timing.
JAMBHUL - ANANDNAGAR	IntraState	08/09/2023	11:53	08/09/2023	15:45	PO	For attending hot spot on wave trap of Jambhul Line R Ph Bottom
220 KV DEVGAONRANGARI - BABHALESHWAR CKT	IntraState	08/09/2023	13:33	08/09/2023	16:24	EO	To attend hot spot on B phase of C.T
BABHALESHWAR - DEOGAON RANGARI	IntraState	08/09/2023	13:33	08/09/2023	16:24	EO	Attend Hot Spot on B-ph of CT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/09/2023	05:39	09/09/2023	19:28	PO	For TOWER erection WORK of the additional 220kV D/C tower (NC + 6) between location No. 213- 214 to 220kV Babhaleshwar-Nasik 1 & 2 ckt under EHV O&M Division Babhaleshwar. BOTH CKT REQUIRED TO BE KEPT OFF FOR THE ABOVE SAID WORK. (All the three GCR EklaHare generation will be in service till 30.09.2023.)AFTER THE OUTAGE IS COMPLETED THE BOTH THE 220 KV BBLR 1 and 2 Ckt will be in servise.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	09/09/2023	05:51	09/09/2023	17:00	PO	for TOWER erection WORK of the additional 220kV D/C tower (NC + 6) between location No. 213- 214 to 220kV Babhaleshwar- Nsk 1 & 2 ckt under EHV O&M Dn Babhaleshwar. BOTH CKT REQUIRED TO BE KEPT OFF FOR THE ABOVE SAID WORK. (All the three GCR EklaHare generation will be in service till 30.09.2023.)
PEDAMBE-KALAMBANI(TSS)	IntraState	09/09/2023	08:36	09/09/2023	16:00	PO	For attending unwound conductors of B phase between line side isolator to transfer bus isolators near CT clamp and Bay R/M work
TALANDGE - BIDRI	IntraState	09/09/2023	09:33	09/09/2023	16:30	PO	For replacement faulty of Disc Insulator
PETH- MUDSHINGI 1 LINE	IntraState	09/09/2023	10:00	09/09/2023	17:39	PO	For SSN to DSN string work at loc no. 87 & 88.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/09/2023	10:11	09/09/2023	19:28	PO	Replacement of CT due to consistent hotspot and ageing
LONIKAND 2 - BHOSARI	IntraState	09/09/2023	11:03	09/09/2023	14:39	PO	For Replacement of Tension Insulator string detected faulty in PID at LOC No. 63 Y Phase (Bhosari Side)
220 KV DONDAICHA SHAHADA CKT II	IntraState	09/09/2023	11:07	09/09/2023	16:40	PO	Testing work
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	09/09/2023	14:58	09/09/2023	15:27	EO	FOR RAISING SF6 GAS PRESSURE
EKLAHARE (OCR) - PADGHE	IntraState	09/09/2023	16:45			HT	HT for Load Management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	09/09/2023	17:04	09/09/2023	19:35	HT	HT for Load management
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	09/09/2023	18:23		Continued.	HT	HT for Load Management
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 09/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 200MVA PTR 1 @ LONAND	IntraState	08/09/2023	11:53	08/09/2023	16:26	PO	TBC Wiring & Testing Work
220/33KV 50MVA TF NO.1 @ SAYNE	IntraState	08/09/2023	12:40	08/09/2023	14:58	PO	Bay Quarterly Maintenance
220/22 KV 50 MVA PTR 3 @ LONIKAND	IntraState	08/09/2023	13:07	09/09/2023	16:40	PO	PTR-3 HV CB mechanism overhauling work.
220/132 KV 200 MVA ICT 1	IntraState	09/09/2023	01:25	09/09/2023	06:25	T	OSR Bucchohz tripped
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	09/09/2023	10:22	09/09/2023	18:10	PO	1) Anticorrosive painting of ICT 2) Arresting of Oil leakage. 3) R M W
220/110KV 100MVA ICT-2@ NIWALI	IntraState	09/09/2023	12:50	09/09/2023	17:33	PO	Quarterly maintenance and Diagnostic testing work.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KHOPOLI - KARANJADE	IntraState	09/09/2023	10:55	09/09/2023	13:48	PO	BIRD NEST REMOVAL
100 KV LINE Outages/Trippings							
KALWA - SALSETTE CKT - 1	IntraState	05/09/2023	09:41			PO	CB pole Overhauling work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage