

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Oct/2021 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	125.517	882.806	1) Gujrat	-10.287	-59.352
2) Hydro	27.965	268.175	2) Madhya Pradesh	5.830	75.771
3) Gas	4.174	36.884	3) Chattisgarh	4.120	41.220
Total MSPGCL	157.656	1187.865	4) Maharashtra	136.337	1138.275
B) 1) APML	62.469	416.894	5) Goa (Amona)	-1.256	-9.472
2) JSWEL	20.058	155.100	Total	134.744	1186.442
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.283	184.204
4) RPL(AMT)	12.684	114.610	b) Mumbai Drawl	26.189	203.984
5) SWPGPL	5.857	35.297	c) MSEDCL Bilateral *	39.805	327.827
6) Other IPP	5.218	40.477	Include PX	8.257	98.716
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.283	184.204
C) 1) TPCL Thermal	16.121	131.928	Include PX	0.941	18.337
2) TPCL Hydro	7.079	42.970	Standby	0.000	0.000
3) TPCL Gas	3.356	19.940	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.468	90.155	1) MSEDCL	386.208	3036.350
D) STATE			2) Mumbai Discoms	64.213	488.977
1) Thermal	259.392	1867.267	TOTAL STATE	450.421	3525.327
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	35.044	311.145			
3) Gas (A3+B7+C3)	7.530	56.824			
4) Wind	6.986	47.743			
6) SOLAR	6.725	55.906			
TOTAL STATE	315.677	2338.885			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5231	5320	5448	5074
MSPGCL Hydro	1284	342	1576	1271
MSPGCL Gas	139	135	228	140
MSPGCL Total Generation	6654	5797	7252	6485
Central Sector Receipt	6607	6628	5775	4630
WIND	37	52	900	112
CPP / IPP Thermal	4479	4499	4641	4636
CPP / IPP Gas	0	0	0	0
SOLAR	598	906	0	0
Exchange with Mumbai	-1072	-1607	-1219	-818
MSEDCL DEMAND MET	17303	16275	17349	15045
Load Shedding	0	0	0	0
MSEDCL DEMAND	17303	16275	17349	15045
TPCL GENERATION	1012	1044	1250	846
AEML GENERATION	488	493	484	475
MUMBAI DEMAND	2572	3144	2953	2139
STATE DEMAND MET	19875	19419	20302	17184
STATE DEMAND	19875	19419	20302	17184
Frequency (Hz)	50.00	49.93	49.95	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.12 Hz at 13.02 Hrs	49.64 Hz at 18.21 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 08/Oct/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.64	18.02	170	0
Unit 7	0.00	0.00	0	0
Unit 8	13.85	102.68	630	555
Unit 9	12.93	93.43	555	519
Unit 10	11.88	15.52	539	400
Total	39.30	229.65		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.57	63.59	465	350
Unit 5	0.00	43.71	0	0
Total	10.57	107.30		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	4.30	34.36	223	165
Unit 8	4.20	33.58	203	162
Total	8.50	67.94		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	3.00	3.88	143	100
Unit 5	0.00	40.51	0	0
Unit 6	6.15	39.07	284	210
Unit 7	7.12	54.00	314	280
Unit 8	9.36	65.01	440	355
Unit 9	8.85	66.15	415	345
Total	34.49	268.63		
Paras				
Unit 3	4.42	34.87	205	119
Unit 4	0.00	0.00	0	0
Total	4.42	34.87		
Khaparkheda				
Unit 1	2.92	21.45	135	85
Unit 2	3.70	25.90	165	130
Unit 3	3.97	26.52	180	140
Unit 4	3.91	28.71	171	142
Unit 5	9.98	44.94	460	400
Total	24.48	147.52		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.76	26.90	167	143
Unit 5	0.00	0.00	0	0
Total	3.76	26.90		
Uran				
All Units	4.17	36.88	239	135
Total	4.17	36.88		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.84	4.16	43	10
Total	0.84	4.16		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.52	56.22	525	35
Stage 4	11.43	116.45	1037	0
Stage 3	3.92	36.64	320	0
Total	20.87	209.31		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.67	2.41	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.41	2.98	40	0
SMLHY_PTN	5.77	48.28	256	229
GHATGHAR	0.24	5.20	125	0
Total	7.09	58.86		
Wind				
Total	6.99	47.74	0	0
Total	6.99	47.74		
CPP				
APML(Mus)	62.47	416.89	0	0
JSWEL(Mus)	20.06	155.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	12.68	114.61	0	0
SWPGPL-Mus	5.86	35.30	0	0
Other(Mus)	5.22	40.48	0	0
Total	106.29	762.38		
SOLAR				
Total	6.72	55.91	0	0
Total	6.72	55.91		
Tata				
Trombay 5	10.84	90.05	487	393
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.03	11.32	118	48
Trombay 7B	1.32	8.62	67	40
Trombay 8	5.28	41.88	222	219
TATA Hydro	7.08	42.97	434	51
Total	26.56	194.84		
AEMIL				
DTPS U-1&2	11.47	90.16	496	416
Total	11.47	90.16		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	125.52	882.81	MSPGCL Total	157.66	1187.86
			MSPGCL Thml+Gas	129.69	919.69	Koyna 1,2 & 4 Total	16.95	172.67
			MSPGCL Hydro	27.96	268.18	State Total	315.68	2338.88

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 08/Oct/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5043	1584	140	6767	172	4476	0	0	5103	4900	-1012	15303	0	15303	2482	17785	49.98
2	5050	1435	140	6625	132	4512	0	0	4980	4674	-905	15038	0	15038	2286	17324	49.92
3	5074	1271	140	6485	112	4636	0	0	4867	4630	-818	15045	0	15045	2139	17184	49.96
4	5086	1413	140	6639	99	4622	0	0	4785	4477	-609	15228	0	15228	2051	17279	49.97
5	5066	1455	141	6662	143	4615	0	0	4820	4637	-440	15617	0	15617	2017	17634	49.97
6	5107	1736	140	6983	130	4615	0	0	5059	5288	-482	16534	0	16534	2058	18592	49.96
7	5208	1876	140	7224	97	4575	0	40	5714	5592	-511	17017	0	17017	2120	19137	49.90
8	5254	1673	140	7067	62	4535	0	276	6086	6050	-730	17260	0	17260	2277	19537	49.99
9	5231	1284	139	6654	37	4479	0	598	6371	6607	-1072	17303	0	17303	2572	19875	50.00
10	5178	810	138	6126	50	4436	0	797	6675	6446	-1285	16570	0	16570	2873	19443	49.98
11	5097	746	137	5980	28	4478	0	913	6916	6848	-1457	16790	0	16790	3073	19863	50.01
12	5194	645	136	5975	42	4509	0	1028	6953	6647	-1519	16682	0	16682	3145	19827	49.93
13	5320	342	135	5797	52	4499	0	906	7008	6628	-1607	16275	0	16275	3144	19419	49.93
14	5178	324	135	5637	147	4291	0	897	6904	6212	-1522	15662	0	15662	3015	18677	49.99
15	5106	406	141	5653	211	4200	0	653	6512	6565	-1422	15860	0	15860	3088	18948	49.91
16	5314	406	217	5937	348	4486	0	378	6135	5981	-1463	15667	0	15667	3142	18809	49.96
17	5311	389	227	5927	502	4514	0	193	6161	5763	-1376	15523	0	15523	3065	18588	49.91
18	5346	891	236	6473	568	4580	0	46	5856	5502	-1268	15901	0	15901	2964	18865	49.89
19	5431	1746	237	7414	655	4645	0	0	5961	5612	-1259	17067	0	17067	2998	20065	49.87
20	5448	1576	228	7252	900	4641	0	0	6117	5775	-1219	17349	0	17349	2953	20302	49.95
21	5497	1097	239	6833	859	4421	0	0	5458	5266	-1100	16279	0	16279	2829	19108	49.96
22	5389	1632	239	7260	744	3920	0	0	5070	4898	-1024	15798	0	15798	2703	18501	49.95
23	5339	1600	239	7178	500	3780	0	0	5135	4977	-1008	15427	0	15427	2615	18042	49.90
24	5250	1628	230	7108	396	3821	0	0	5163	4769	-1081	15013	0	15013	2604	17617	49.94
MUs	125.52	27.97	4.17	157.66	6.99	106.29	0.00	6.73	139.81	134.74	-26.19	386.21	0.00	386.21	64.21	450.42	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Oct/2021

Position as on 6.30 Hrs of 09/Oct/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 3	210	04/09/2021	23.58		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	SWPGPL U-4	135	05/08/2021	03.04		Continued.	Turbine Vibration High.	
MSPGCL	Parli Unit 6	250	26/08/2021	21.06		Continued.	Coal Shortage (Converted to AOH 00.00Hrs from Dt.01/09/2021)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Bhusawal Unit 3	210	18/09/2021	03.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 5	210	19/09/2021	20.50		Continued.	Coal Shortage.	
IPP	RPL(AMT) U-5	270	23/09/2021	00.44		Continued.	Bottom Ash Prob.(conv. to coal shortage 18.00hrs,28.09.2021)	
MSPGCL	Paras Unit 4	250	26/09/2021	07.47		Continued.	Coal Shortage	
IPP	RPL(AMT) U-2	270	29/09/2021	01.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	02/10/2021	20.45		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	05/10/2021	22.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 6	210	06/10/2021	03.22	08/10/2021	18.28	sparking at exciter of the generator	
MSPGCL	Bhusawal Unit 5	500	06/10/2021	21.05		Continued.	Poor coal receipt.	
MSPGCL	Chandrapur Unit 5	500	07/10/2021	21.26		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	07/10/2021	22.09		Continued.	Gas shortage	
MSPGCL	Koyna Unit 7	80	08/10/2021	12.00	08/10/2021	16.55	Carbon brush replacement and oil checking work.	
IPP	Adani U-3	660	08/10/2021	21.12		Continued.	APH-B hot PA below leakage.	
MSPGCL	Koyna Unit 2	70	09/10/2021	12.00	09/10/2021	17.05	Carbon brush replacement and oil checking work	
MSPGCL	Uran Unit 6	108	09/10/2021	15.10	09/10/2021	19.20	Gas shortage	
MSPGCL	Uran Unit 8	108	09/10/2021	18.39	09/10/2021	20.26	excitation fault.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Oct/2021

Position as on 6.30 Hrs of 09/Oct/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit B0	120	09/10/2021	18.39	09/10/2021	22.31	Due To GT 8 Tripped.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 09/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	08/10/2021	14.16	08/10/2021	19.08	T	Distance Protection
Chakan Talegaon(Pg)	InterState	09/10/2021	11.15	09/10/2021	12.42	EO	To attend Hot Spot
Koradi 2-IEPL	IntraState	26/09/2021	07.00	09/10/2021	21.10	PO	For height raising work.
koaradi II - Wardha(PG)	IntraState	26/09/2021	07.29	08/10/2021	15.40	PO	For height raising work across Samruddhi highway at chainage No.23+650 (tower no 192 & 193)
Bhusawal-Aurangabad	IntraState	06/10/2021	22.31		Continued.	HT	Over Voltage
Ektuni-Bableshwar ckt II	IntraState	08/10/2021	16.36	08/10/2021	20.05	T	Distance Protection
Jejuri- Koynastage-IV	IntraState	08/10/2021	23.58	09/10/2021	04.16	PO	Chemical washing of insulator.
Padghe - Kalwa- I	IntraState	09/10/2021	04.50	09/10/2021	07.23	EO	Attending Hot Spot
Jaigad-New Koyna Ckt-II	IntraState	09/10/2021	09.55	09/10/2021	19.27	PO	for additional earthing.
Ektuni-Bableshwar ckt II	IntraState	09/10/2021	15.36	09/10/2021	19.17	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 MVA ICT-I @Aurangabad (Waluj)	IntraState	07/10/2021	11.18	09/10/2021	18.28	PO	PG Isolator overhauling work
400/220/33 Kv 315 Mva Ict 2 @Parali (Girwali)	IntraState	08/10/2021	08.24	09/10/2021	00.19	PO	33kv (tertiary) bushing of y phase unit of 400/220kv, 315 mva ict-2 is to be replaced due to earthed tan delta point.
400/220kv, 500 MVA ICT-III @Bableshwar	IntraState	09/10/2021	09.44	09/10/2021	22.27	PO	Diagnostic Testing Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Aurangabad PG (Chitepimpalgaon)-Chitegaon Ckt-II	InterState	07/10/2021	18.27	08/10/2021	00.21	HT	To control Overdrawal
WARDHA WARDHA (PG) (DEOLI)	InterState	07/10/2021	18.55	08/10/2021	00.15	HT	To control Overdrawal
PARLY (PG) - OSMANABAD	InterState	07/10/2021	18.59	08/10/2021	00.44	HT	To control Overdrawal
PARLY (PG) - OLD GCR PARLI	InterState	07/10/2021	19.11	08/10/2021	00.47	HT	To control Overdrawal
Chandrapur MIDC - GEPL Ckt I	IntraState	02/10/2021	18.36		Continued.	HT	Energy bill pending at GEPL end.
Theur-Jejuri	IntraState	07/10/2021	11.45	08/10/2021	16.01	PO	Testing Work
Pedhambe - Oni	IntraState	07/10/2021	16.01	08/10/2021	19.55	T	Distance Protection
Pusad-WardhaPG(Deoli)	IntraState	07/10/2021	18.22	08/10/2021	00.11	HT	To control Overdrawal
Niwali - Pawas Line	IntraState	07/10/2021	19.30	08/10/2021	05.14	T	Distance Protection
Trombay Salsette 1 Backbay	IntraState	07/10/2021	23.30	08/10/2021	06.33	PO	Metro work
Trombay-Salsette II	IntraState	07/10/2021	23.30	08/10/2021	06.41	PO	Metro work
Hingoli- Girawali	IntraState	08/10/2021	05.51	08/10/2021	06.17	T	Distance Protection
Kalwa Panchanand	IntraState	08/10/2021	08.10	08/10/2021	10.59	EO	For attending the partial discharge of insulator and conductor of Y phase Cable Bushing.
Dhamangaon New- Tss-II	IntraState	08/10/2021	08.30	08/10/2021	14.07	PO	Measurement of c&tan delta of ct crm, timing and ir of cb of tss-1 bay. and quarterly routine maintenance work etc. relay testing work by testing unit.
Chandrapur GCR - Wani	IntraState	08/10/2021	09.08	08/10/2021	19.27	PO	Tan Delta Measurment of CTs
Theur-Phursungi	IntraState	08/10/2021	09.24	08/10/2021	13.47	PO	Half yearly Maintenance and Tan Delta testing work.
Padghe-Kamba II	IntraState	08/10/2021	09.31	08/10/2021	14.10	PO	For attending hot spot on Y & B phase CT.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 09/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Eklahara(Gcr)(Nasik)- Bableswhar 2	IntraState	08/10/2021	09.57	08/10/2021	14.14	PO	Urgent basis to attend red hot at loc.guide tower ckt 2(temp 105 deg cel). and loc.4 ckt 1, temp 81 and 72.7 deg cel works shall be done by hot line unit Nashik.
Karad - Vita Ckt- I	IntraState	08/10/2021	10.02	08/10/2021	13.05	PO	C & Tan delta testing of CTs.
Kandalgaon - Sona Alloys	IntraState	08/10/2021	10.33	08/10/2021	18.10	PO	Replacement of polymer insulators by long rod porcelain insulators or conductor restringing work.
ANANDNAGAR - PALAVA	IntraState	08/10/2021	10.34	08/10/2021	13.03	PO	Attending hotspot on bottom of Y-phase Wavetrap on 220kv Palava line at Anandnagar S/S.
Bableswhar- Bableswhar-II	IntraState	08/10/2021	10.57	08/10/2021	19.05	PO	CT and relay testing.
Butibori - Khaperkheda	IntraState	08/10/2021	11.01	08/10/2021	16.03	PO	CTS & cvts tan delta & capacitances testing work.
Jamde-Dondaicha 1	IntraState	08/10/2021	11.07	08/10/2021	16.30	PO	Cut point nut bolt tightening work.
Ghugus- Lloyds	IntraState	08/10/2021	11.15	08/10/2021	19.30	PO	C & tan-delta of metering & protection ct, ir value measurement, crm & cb timing measurement work.
New Koyna - Pedambe	IntraState	08/10/2021	11.35	08/10/2021	15.3	EO	Emergency to attend red hot.
Apta - Taloja	IntraState	08/10/2021	11.39	08/10/2021	14.52	EO	Replacement of damaged twin conductor.
New Koyna - Pedambe	IntraState	08/10/2021	11.43	08/10/2021	15.02	PO	Line Maintenance work
Midc Chandrapur-Gadchandur	IntraState	08/10/2021	12.41	08/10/2021	13.05	T	Distance Protection
Padghe - Kambha	IntraState	08/10/2021	14.46	08/10/2021	17.00	EO	Attending red hot on a bus y phase isolator jumper & b bus r phase bus side jumper by hot line unit kalwa/ kharghar
Adlabs - Pedambe	IntraState	08/10/2021	15.35	08/10/2021	22.25	T	Distance Protection
220 KV KRUSHNOOR - NANDED (KUMBHARGAON) CKT -1	IntraState	08/10/2021	19.57	08/10/2021	20.20	T	Distance Protection
Chandrapur GCR - Sicom II	IntraState	09/10/2021	09.04	09/10/2021	19.53	PO	MFM Meter Retrofitting.
Kandalgaon - Sona Alloys	IntraState	09/10/2021	09.20	09/10/2021	17.55	PO	Replacement of polymer Insulator strings
Kadegaon-Miraj	IntraState	09/10/2021	09.56	09/10/2021	17.42	PO	Conversion of SSN to DSN work.
Bableswhar -Ahamadnagar-I	IntraState	09/10/2021	11.32	09/10/2021	16.40	PO	Attending hotspot at R-ph. wave trap jumper.
Umred-Kanhan 2	IntraState	09/10/2021	11.42	09/10/2021	12.56	T	Distance Protection
Hingoli- Girawali	IntraState	09/10/2021	13.16	09/10/2021	17.14	PO	Line Maintenance work
Aurangabad (Waluj)-Bhenda	IntraState	09/10/2021	13.55		Continued.	T	Distance Protection
Vita Alkud	IntraState	09/10/2021	14.12	09/10/2021	17.58	PO	Testing Work.
Ghatghar - Bapgaon	IntraState	09/10/2021	16.10	09/10/2021	18.26	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	08/10/2021	10.05	08/10/2021	14.55	PO	Quarterly Maintanance Work
220/132 Kv 200 Mva Bbl Ict 1 @Beed	IntraState	08/10/2021	10.20	08/10/2021	18.32	PO	CTR maintenance work.
220/100kv 100mva Cgl Ict 1 @Pandharpur	IntraState	08/10/2021	11.30	08/10/2021	18.30	PO	Outage is required for OLTC Overhauling work.
220/33kv 100 MVA Transformer 1 @Aarey R/S	IntraState	08/10/2021	11.53	08/10/2021	13.55	EO	Attending Hot Spot
220/132 Kv 200 Mva Bb Ict 2 @Chikhali	IntraState	09/10/2021	10.20		Continued.	PO	Diagnostic Testing Work.
220/132 Kv 200 Mva Cgl Ict 1 @Raymond (Nasik 2)	IntraState	09/10/2021	10.22	09/10/2021	16.45	PO	Oil Sample Collection & Work Of Attending Red Hot Spots & Bay Maintenance Work.
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	09/10/2021	10.35	09/10/2021	14.16	PO	Survey work for 110KV GIS work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 09/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132kV 100MVA ICT @ KALWAN (BHENDI)	IntraState	09/10/2021	10.44	09/10/2021	13.33	PO	Maintenance Work.