

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Oct/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.456	954.562	1) Gujrat	11.412	79.700
2) Hydro	6.091	55.798	2) Madhya Pradesh	9.909	52.399
3) Gas	2.761	18.427	3) Chattisgarh	5.770	44.490
Total MSPGCL	117.308	1028.787	4) Maharashtra	153.663	1369.488
B) 1) APLM	48.645	355.443	5) Goa (Amona)	-1.731	-10.945
2) JSWEL	16.232	138.199	Total	179.023	1535.132
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.986	268.000
4) RPL(AMT)	22.139	180.380	b) Mumbai Drawl	32.248	290.379
5) SWPGPL	6.483	54.627	c) MSEDCL Bilateral *	70.694	595.146
6) Other IPP	8.857	59.797	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.986	267.994
C) 1) TPCL Thermal	10.835	84.710	Include PX	0.000	0.000
2) TPCL Hydro	2.482	24.559	Standby	0.000	0.007
3) TPCL Gas	2.021	17.395	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.562	71.248	1) MSEDCL	384.552	3199.571
D) STATE			2) Mumbai Discoms	56.148	488.267
1) Thermal	230.209	1898.966	3) Other Discoms	8.942	73.719
(A1+C1+C4+(B1-B6))			TOTAL STATE	449.642	3761.557
2) Hydro (A2+C2)	8.573	80.357			
3) Gas (A3+B7+C3)	4.782	35.822			
4) Wind	17.402	131.733			
6) SOLAR	9.653	79.571			
TOTAL STATE	270.619	2226.449			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4375	4728	5407	4098
MSPGCL Hydro	189	160	811	145
MSPGCL Gas	91	121	123	145
MSPGCL Total Generation	4655	5009	6341	4388
Central Sector Receipt	8067	8526	8128	5930
WIND	706	344	378	1337
CPP / IPP Thermal	4128	4486	5322	4026
CPP / IPP Gas	0	0	0	0
SOLAR	1413	118	0	0
Exchange with Mumbai	-1728	-1628	-1378	-941
MSEDCL DEMAND MET	16840	16450	18375	14454
Load Shedding	0	0	0	0
MSEDCL DEMAND	16840	16450	18375	14454
TPCL GENERATION	627	595	809	540
AEML GENERATION	358	370	446	283
MUMBAI DEMAND	2713	2593	2633	1764
OTHER DISCOM DEMAND	401	405	416	286
STATE DEMAND MET	19954	19448	21424	16504
STATE DEMAND	19954	19448	21424	16504
Frequency (Hz)	50.06	49.92	50.01	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 13.01 Hrs	49.65 Hz at 16.54 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.32	84.51	539	365
Unit 9	5.12	25.67	401	0
Unit 10	9.53	79.99	436	375
Total	24.97	190.17		
Bhusawal				
Unit 3	2.80	14.38	140	100
Unit 4	7.38	66.94	370	275
Unit 5	7.72	62.31	425	265
Total	17.89	143.62		
Parli				
Unit 6	3.85	31.26	210	142
Unit 7	3.84	31.83	209	144
Unit 8	3.30	25.11	151	118
Total	10.99	88.20		
Chandrapur				
Unit 3	3.13	23.43	165	120
Unit 4	0.19	19.28	72	0
Unit 5	4.05	53.30	188	155
Unit 6	6.95	59.22	345	275
Unit 7	7.52	60.59	337	277
Unit 8	0.00	0.00	0	0
Unit 9	7.87	68.83	437	282
Total	29.72	284.64		
Paras				
Unit 3	0.00	32.43	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	32.43		
Khaparkheda				
Unit 1	2.94	23.38	130	115
Unit 2	2.86	23.01	130	100
Unit 3	3.26	28.72	180	125
Unit 4	3.28	25.73	185	125
Unit 5	6.92	64.90	370	273
Total	19.25	165.73		
Nasik				
Unit 3	2.60	25.32	141	0
Unit 4	3.05	24.45	145	117
Unit 5	0.00	0.00	0	0
Total	5.64	49.77		
Uran				
All Units	2.76	18.43	145	76
Total	2.76	18.43		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	4.76	25	24
Total	0.60	4.76		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.51	16.84	465	40
Stage 4	0.88	8.81	489	0
Stage 3	0.68	6.60	160	0
Total	3.07	32.26		
Hydro				
KDPH	0.43	2.27	18	18
VTRNA	0.00	1.82	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.22	1.94	77	0
SMLHY_PTN	1.65	11.63	76	63
GHATGHAR	0.13	1.12	80	0
Total	2.43	18.78		
Wind				
Total	17.40	131.73	0	0
Total	17.40	131.73		
CPP				
APML(Mus)	48.64	355.44	0	0
JSWEL(Mus)	16.23	138.20	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	22.14	180.38	0	0
SWPGPL-Mus	6.48	54.63	0	0
Other(Mus)	8.86	59.80	0	0
Total	102.36	788.45		
SOLAR				
Total	9.65	79.57	0	0
Total	9.65	79.57		
Tata				
Trombay 5	7.44	57.24	466	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.09	9.46	55	37
Trombay 7B	0.93	7.93	45	33
TATA Hydro	2.48	24.56	318	4
Trombay 8	3.39	27.46	171	127
Total	15.34	126.66		
AEMIL				
DTPS U-1&2	8.56	71.25	492	283
Total	8.56	71.25		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	108.46	954.56	MSPGCL Total	117.31	1028.79
			MSPGCL Thml+Gas	111.22	972.99	Koyna 1,2 & 4 Total	2.39	25.65
			MSPGCL Hydro	6.09	55.80	State Total	270.62	2226.45

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 08/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4102	152	145	4399	1310	4153	0	0	6443	6120	-1189	14459	0	14459	2130	334	16923	50.01
2	4106	158	145	4409	1418	3924	0	0	6340	6209	-1062	14579	0	14579	1960	319	16858	50.00
3	4105	152	145	4402	1344	3779	0	0	5934	6205	-1008	14417	0	14417	1850	305	16572	50.00
4	4098	145	145	4388	1337	4026	0	0	5884	5930	-941	14454	0	14454	1764	286	16504	50.02
5	4111	148	145	4404	1269	4228	0	0	6354	6220	-927	14900	0	14900	1755	294	16949	50.00
6	4196	148	143	4487	1276	4308	0	0	6839	7188	-1006	15921	0	15921	1824	332	18077	50.00
7	4431	159	82	4672	1239	4351	0	55	8098	7852	-1083	16735	0	16735	1881	351	18967	50.01
8	4413	194	83	4690	1113	4385	0	358	8129	7935	-1185	16930	0	16930	2020	366	19316	49.99
9	4210	187	78	4475	1136	4363	0	781	7963	7940	-1406	16899	0	16899	2265	390	19554	49.99
10	4241	189	80	4510	968	4328	0	1186	7747	7870	-1502	16952	0	16952	2553	408	19913	50.03
11	4375	189	91	4655	706	4128	0	1413	8055	8067	-1728	16840	0	16840	2713	401	19954	50.06
12	4429	149	97	4675	590	3711	0	1344	8215	7975	-1737	16149	0	16149	2795	409	19353	49.99
13	4388	159	102	4649	420	3674	0	1184	7509	7654	-1601	15596	0	15596	2803	384	18783	50.00
14	4445	154	76	4675	322	3743	0	1095	7562	7483	-1513	15435	0	15435	2678	370	18483	50.06
15	4420	154	100	4674	320	3995	0	946	8026	7830	-1589	15794	0	15794	2689	382	18865	50.01
16	4496	184	118	4798	273	3949	0	724	7768	7672	-1526	15486	0	15486	2674	404	18564	49.92
17	4588	165	121	4874	329	4346	0	449	8115	7975	-1652	15909	0	15909	2575	412	18896	49.88
18	4728	160	121	5009	344	4486	0	118	8460	8526	-1628	16450	0	16450	2593	405	19448	49.92
19	5327	1209	124	6660	365	4903	0	0	8196	7687	-1530	17670	0	17670	2662	415	20747	49.93
20	5407	811	123	6341	378	5322	0	0	8017	8128	-1378	18375	0	18375	2633	416	21424	50.01
21	5199	316	122	5637	254	4785	0	0	8362	8134	-1334	17066	0	17066	2509	410	19985	50.02
22	4944	315	125	5384	262	4496	0	0	8024	7826	-1287	16281	0	16281	2374	400	19055	50.02
23	4947	313	125	5385	200	4473	0	0	7532	7417	-1232	15863	0	15863	2259	380	18502	49.98
24	4750	181	125	5056	229	4500	0	0	7359	7180	-1204	15391	0	15391	2189	370	17950	49.92
MUs	108.46	6.09	2.76	117.31	17.40	102.36	0.00	9.65	180.93	179.02	-32.25	384.55	0.00	384.55	56.15	8.94	449.64	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Oct/2022

Position as on 6.30 Hrs of 09/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	10/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35	09/10/2022	18:38	Tripped on Furnace Pressure High(converted to Overhaul)	08/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/10/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26	08/10/2022	14:07	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	10/10/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	29/09/2022	21:00		Continued.	Seal Trough Leakage(converted to Critical Coal Stock w.e.f.21.00 Hrs Dt.30-09-	
MSPGCL	Koradi Unit 9	660	03/10/2022	03:12	08/10/2022	08:23	Boiler Tube Leakage	09/10/2022
IPP	Adani U-4	660	04/10/2022	12:05		Continued.	due to APH-A hot PA bellow leakage.	10/10/2022
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	10/10/2022
MSPGCL	Chandrapur Unit 4	210	07/10/2022	00:55	08/10/2022	20:32	Air heater problem	08/10/2022
MSPGCL	Paras Unit 3	250	07/10/2022	17:30	09/10/2022	18:48	High pressure heater leakage	10/10/2022
IPP	SWPGPL U-1	135	07/10/2022	19:50	08/10/2022	10:07	Main Steam Line Leakage	10/10/2022
MSPGCL	Uran Unit 8	108	08/10/2022	06:02	08/10/2022	07:17	Tripped while taking B0 in service. expected to be restored very soon.	08/10/2022
MSPGCL	Uran Unit 6	108	08/10/2022	13:01	09/10/2022	17:05	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Oct/2022

Position as on 6.30 Hrs of 09/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work	10/10/2022
IPP	RPL(AMT) U-1	270	09/10/2022	11:00	09/10/2022	15:47	M.S. PIPE LEAKAGE	09/10/2022
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	10/10/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 09/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
LONIKAND I - KOYNA STAGE-IV	IntraState	07/10/2022	08:59	08/10/2022	03:10	PO	Restingining of conductor Between Loc No 89-92 to achieve Ground clarence
KHADKA-AURANGABAD (WALUJ)	IntraState	07/10/2022	22:50	08/10/2022	08:57	HT	HT for Overvoltage control
JAIGAD - KARAD CKT - 1	IntraState	08/10/2022	00:23	08/10/2022	09:00	HT	HAND TRIPPED FOR OVER VOLTAGE
KALWA - KHARGHAR	IntraState	08/10/2022	08:53	08/10/2022	19:42	PO	Additional Jumpering at cut point locations by using Fired Wedge type Connector.
KHADKA-AURANGABAD (WALUJ)	IntraState	08/10/2022	22:17	09/10/2022	05:48	HT	H/T on overvoltage
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	09/10/2022	06:00	09/10/2022	17:54	PO	Replacement of Disc Insulator Strings by Long Rod Porcelain strings
KHARGHAR - TALEGAON (PG)	IntraState	09/10/2022	06:48	09/10/2022	21:05	PO	Additional Jumpering at cut point locations by using Fired Wedge type Connector
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	09/10/2022	17:54			PO	Distance Protection
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	09/10/2022	6	09/10/2022	17:35		Disc Insulator string Replacement by Long Rod Porcelain string
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	08/10/2022	08:25	08/10/2022	23:06	PO	Dignostic testing work
220 KV LINE Outages/Trippings							
GHATGHAR - BAPGAON	IntraState	04/10/2022	08:05	08/10/2022	21:55	PO	1.Stringing of 9nos. Of Span. 2.Erection of 3 nos. Of Monopole, 3. Bunching work at location no.329 to from 220kV AKP
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	04/10/2022	08:10	08/10/2022	21:36	PO	1.Stringing of 9nos. Of Span. 2.Erection of 3 nos. Of Monopole, 3.Bunching work at location no.329 to from 220kV AKP Bapgaon line.
BOISAR - VERSOVA	IntraState	06/10/2022	08:15			PO	Bunching of lines at location no.SS 82 to facilitate the following project work: NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223. DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	06/10/2022	08:22			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 09/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TIFIL - KALWA	IntraState	08/10/2022	00:06	08/10/2022	08:45	T	TRIPPED ON DISTANCE PROTECTION, B PHASE, ZONE-1
KHARGHAR - BORIVALI CKT - 2	IntraState	08/10/2022	05:46	08/10/2022	08:33	HT	Emergency Handtripped For Safety Purpose, to remove jumpers of the 220 KV Pawane - Cable TAP line on 220 KV Kalwa-TFIPL
MALEGAON - KALWAN CKT-1	IntraState	08/10/2022	09:18	08/10/2022	16:01	PO	For Isolator & Bay Maintenance work.
KARAD -MUDSHINGI CKT 2-TAK	IntraState	08/10/2022	09:20	08/10/2022	18:36	PO	For repairing of damaged Y & B ph conductor due to stone mine blasting at Loc no-164 to 165
VITA - KHANAPUR LINE	IntraState	08/10/2022	13:38	08/10/2022	17:45	PO	Diagnostic Testing Work
EKLAHARE (OCR) - PADGHE	IntraState	08/10/2022	22:52			HT	For load management
KAMBA - VASAI	IntraState	09/10/2022	10:47	09/10/2022	13:44	EO	Shifting of 220kV Kamba Vasai line on TBC for attending hot spot on 89D Yph Isolator CB side.
KANDALGAON - PIRANGUT	IntraState	09/10/2022	10:50	09/10/2022	17:10	PO	Replacement of Flashover & deteriorated polymer insulator at Loc.No.33 & 32 and other line maintenance work.
WAGHIVALI - DHARAVI 7	IntraState	09/10/2022	10:54	09/10/2022	11:28	T	TRIPPED ON DISTANCE PROTECTION.
KAMBA - VASAI	IntraState	09/10/2022	11:28	09/10/2022	13:44	HT	Due to heavy sparking observed at 89c isolator at vasai end
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33 kV 50 MVA PTR 1 @ VIRAJ	IntraState	08/10/2022	00:57	08/10/2022	04:09	T	TRIPPED ON DIFFERENTIAL PROTECTION
220/132 KV 200 MVA ICT - 2 @ CHINCHWAD 2	IntraState	08/10/2022	14:04	08/10/2022	19:01	T	B-PH LA Burst at Chinchwad-2
220/33kV 50MVA TF-2 @ KOPARGAON	IntraState	08/10/2022	16:05	08/10/2022	19:10	PO	For Diagnostic of 220/33 KV Trafo -2 and its associated equipment (Tan Delta, CRM, CBT) and attending the hotspot on Y phase LV bushing
220/33 KV 50 MVA PTR - 1 @ PHALTAN MIDC	IntraState	09/10/2022	08:08	09/10/2022	17:42	PO	Oil leakage attending work by Powerseal method & SFRA,DFRA testing work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 09/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	09/10/2022	11:04	09/10/2022	19:20	EO	Third Party work-Construction of 400KV Kharghar-Vikhroli Line by AEML: Loc. No: 56 (Un-installation of Crane used for Tower Erection and Shifting of Crane from site.)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage