

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Nov/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	96.050	725.249	1) Gujrat	3.045	25.798
2) Hydro	4.951	64.571	2) Madhya Pradesh	10.108	46.629
3) Gas	6.822	74.055	3) Chattisgarh	6.810	57.910
Total MSPGCL	107.823	863.875	4) Maharashtra	108.431	888.057
B) 1) APLM	71.205	578.682	5) Goa (Amona)	-0.594	-4.004
2) JSWEL	21.619	163.503	Total	127.800	1014.390
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.061	208.912
4) RPL(AMT)	10.164	33.277	b) Mumbai Drawl	29.730	235.753
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	26.796	180.902
6) Other IPP	8.016	66.713	Include PX	0.032	-7.300
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.061	208.912
C) 1) TPCL Thermal	12.862	106.184	Include PX	9.177	66.881
2) TPCL Hydro	5.000	33.558	Standby	0.000	0.000
3) TPCL Gas	3.836	33.495	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.107	77.121	1) MSEDCL	329.513	2582.837
D) STATE			2) Mumbai Discoms	60.535	486.106
1) Thermal	229.023	1750.729	TOTAL STATE	390.048	3068.943
(A1+C1+C4+(B1-B6))					
2) Hydro	9.951	98.129			
(A2+C2)					
3) Gas	10.658	107.550			
(A3+B7+C3)					
4) Wind	7.076	56.904			
6) SOLAR	5.540	41.246			
TOTAL STATE	262.248	2054.558			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	3779	4108	4450	3823
MSPGCL Hydro	154	163	666	96
MSPGCL Gas	281	285	284	287
MSPGCL Total Generation	4214	4556	5400	4206
Central Sector Receipt	6322	5459	5384	4003
WIND	257	142	242	569
CPP / IPP Thermal	4559	5094	5315	4115
CPP / IPP Gas	0	0	0	0
SOLAR	739	28	0	0
Exchange with Mumbai	-1720	-1360	-1095	-931
MSEDCL DEMAND MET	14371	13919	15246	11962
Load Shedding	0	0	0	0
MSEDCL DEMAND	14371	13919	15246	11962
TPCL GENERATION	912	1096	1212	680
AEML GENERATION	375	386	494	375
MUMBAI DEMAND	3007	2842	2801	1986
STATE DEMAND MET	17378	16761	18047	13948
STATE DEMAND	17378	16761	18047	13948
Frequency (Hz)	50.02	50.02	50.04	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.22 Hz at 04.02 Hrs	49.83 Hz at 09.07 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 08/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.59	85.70	557	440
Unit 9	10.92	90.27	540	330
Unit 10	1.01	69.59	295	0
Total	23.52	245.56		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.05	73.66	420	355
Unit 5	8.92	75.12	425	350
Total	17.97	148.78		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.96	17.46	183	141
Unit 4	0.00	0.00	0	0
Unit 5	8.74	40.14	390	303
Unit 6	9.30	45.36	465	350
Unit 7	0.00	0.00	0	0
Unit 8	9.56	78.07	500	360
Unit 9	9.30	68.47	461	352
Total	40.86	249.50		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	9.67	53.43	490	360
Total	9.67	53.43		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.04	23.07	193	155
Unit 5	0.00	4.91	0	0
Total	4.04	27.98		
Uran				
All Units	6.82	74.06	297	267
Total	6.82	74.06		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.09	3.77	27	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.09	3.77		
Koyna				
Stage 1-2	2.00	21.76	425	35
Stage 4	0.76	19.38	468	0
Stage 3	0.83	9.28	150	0
Total	3.60	50.41		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	1.54	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.31	2.48	80	0
RNGR+BHTSA	0.00	2.63	0	0
BHANDARDRA	0.01	0.01	11	0
ELDARY	0.52	2.06	23	20
SMLHY_PTN	0.32	2.97	14	12
GHATGHAR	0.19	2.46	125	0
Total	1.35	14.16		
Wind				
Total	7.08	56.90	0	0
Total	7.08	56.90		
CPP				
APML(Mus)	71.20	578.68	0	0
JSWEL(Mus)	21.62	163.50	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	10.16	33.28	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.02	66.71	0	0
Total	111.00	842.18		
SOLAR				
Total	5.54	41.25	0	0
Total	5.54	41.25		
Tata				
Trombay 5	8.10	68.17	479	284
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.38	21.23	117	87
Trombay 7B	1.45	12.27	66	56
Trombay 8	4.76	38.02	201	196
TATA Hydro	5.00	33.56	435	0
Total	21.70	173.24		
AEML				
DTPS U-1&2	9.11	77.12	500	134
Total	9.11	77.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	96.05	725.25	MSPGCL Total	107.82	863.88
			MSPGCL Thml+Gas	102.87	799.30	Koyna 1,2 & 4 Total	2.76	41.13
			MSPGCL Hydro	4.95	64.57	State Total	262.25	2054.56

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3908	105	285	4298	735	4084	0	0	4807	4642	-1159	12600	0	12600	2279	14879	50.03
2	3893	71	285	4249	697	4079	0	0	4642	4138	-1021	12142	0	12142	2109	14251	50.01
3	3823	96	287	4206	569	4115	0	0	4200	4003	-931	11962	0	11962	1986	13948	50.02
4	3669	215	287	4171	530	4099	0	0	4353	4498	-876	12422	0	12422	1914	14336	50.04
5	3754	85	286	4125	488	4162	0	0	4791	4825	-859	12741	0	12741	1898	14639	50.02
6	4105	80	286	4471	412	4674	0	0	5085	5232	-910	13879	0	13879	1960	15839	50.01
7	4452	220	297	4969	334	5137	0	8	5041	5041	-789	14700	0	14700	2049	16749	50.00
8	4466	539	286	5291	279	5185	0	147	5000	5104	-793	15213	0	15213	2197	17410	50.03
9	4384	171	288	4843	201	4954	0	369	5462	5297	-975	14689	0	14689	2485	17174	50.00
10	3789	155	285	4229	268	4739	0	545	5913	5931	-1355	14357	0	14357	2792	17149	49.99
11	3779	154	281	4214	257	4559	0	739	6377	6322	-1720	14371	0	14371	3007	17378	50.02
12	3766	230	280	4276	238	4131	0	812	6505	6504	-1827	14134	0	14134	3111	17245	50.00
13	3761	167	267	4195	158	4114	0	827	6237	6162	-1843	13613	0	13613	3079	16692	49.98
14	3759	195	278	4232	165	4104	0	762	5876	5957	-1720	13500	0	13500	2942	16442	50.02
15	3724	121	279	4124	176	4090	0	668	6187	6192	-1715	13535	0	13535	2946	16481	50.01
16	3704	110	278	4092	133	4288	0	421	5880	5832	-1500	13266	0	13266	2913	16179	49.97
17	3775	140	281	4196	120	4690	0	214	5551	5866	-1420	13666	0	13666	2888	16554	50.03
18	4108	163	285	4556	142	5094	0	28	5287	5459	-1360	13919	0	13919	2842	16761	50.02
19	4391	888	285	5564	199	5233	0	0	5202	5298	-1193	15101	0	15101	2900	18001	50.05
20	4450	666	284	5400	242	5315	0	0	5181	5384	-1095	15246	0	15246	2801	18047	50.04
21	4477	146	285	4908	261	5232	0	0	5062	5200	-1184	14417	0	14417	2660	17077	50.04
22	4331	74	285	4690	207	5118	0	0	4995	4985	-1150	13850	0	13850	2480	16330	50.05
23	3941	80	295	4316	133	5053	0	0	5096	5020	-1182	13340	0	13340	2217	15557	49.95
24	3841	80	287	4208	132	4755	0	0	5142	4908	-1153	12850	0	12850	2080	14930	50.03
MUs	96.05	4.95	6.82	107.82	7.08	111.00	0.00	5.54	127.87	127.80	-29.73	329.51	0.00	329.51	60.54	390.05	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Nov/2019

Position as on 6.30 Hrs of 09/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
MSPGCL	Khaparkheda Unit 4	210	22/10/2019	23.52		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 6	250	23/10/2019	03.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Parli Unit 7	250	23/10/2019	17.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Nov/2019

Position as on 6.30 Hrs of 09/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 4	210	31/10/2019	08.16		Continued.	Excessive Consumption of Hydrogen Cylinder.	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	
MSPGCL	Uran Unit 7	108	05/11/2019	00.17		Continued.	Internal Inspection	
MSPGCL	Uran Unit B0	120	06/11/2019	03.05		Continued.	Bearing vibration high	
MSPGCL	Uran Unit 8	108	06/11/2019	19.23		Continued.	Turbine Vibration	
MSPGCL	Koradi Unit 10	660	08/11/2019	02.42	08/11/2019	21.24	Fire On 11KV Switch Gear.	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 09/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT-II @ Koradi-III	IntraState	08/11/2019	09.54	08/11/2019	19.26	PO	Bay Maintenance Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	07/11/2019	19.22		Continued.	HT	Over Voltage
Akola Wardha I	InterState	08/11/2019	14.26	09/11/2019	15.30	T	Distance Protection
Alkud-Solapur(PG)	InterState	09/11/2019	15.29	09/11/2019	18.36	T	Distance Protection
Akola II - RPL(Rattania) Ckt I	IntraState	27/10/2019	14.07		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	06/11/2019	21.58		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/11/2019	10.24	08/11/2019	08.20	PO	RFC 19.38 Diagnostic Testing Work.
Khadka-Aurangabad (Waluj)	IntraState	07/11/2019	17.13	08/11/2019	11.46	HT	Over Voltage
Kala Kudus Ckt-I	IntraState	07/11/2019	17.23	08/11/2019	03.23	EO	To Attend Insulator For Flashover Work.
Jejuri- Koynastage-IV	IntraState	07/11/2019	22.08	08/11/2019	06.45	T	Distance Protection
Bhusawal-Aurangabad	IntraState	08/11/2019	19.58		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	09/11/2019	08.50	09/11/2019	13.11	PO	CVT Replacement Work.
Bus Coupler @ Padghe	IntraState	09/11/2019	12.35	09/11/2019	17.26	PO	Attending Hot Spot
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 KV 500MVA ICT II @ Nanded	IntraState	08/11/2019	09.58	08/11/2019	16.48	PO	ICT Tertiry Insulation Coating Work
400/220 KV 500MVA ICT II @ Nanded	IntraState	08/11/2019	17.33	08/11/2019	21.03	T	On Pressure Relief Valve , Oil Surge Relay.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	09/11/2019	10.13	09/11/2019	11.48	PO	Buchloz Relay Alaram Setting Work.
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	09/11/2019	11.25	09/11/2019	16.52	PO	Attending Hot Spot
400/220kv, 500 Mva ICT-1 @Deepnagar	IntraState	09/11/2019	11.29	09/11/2019	12.49	PO	Dc Lekage.
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	09/11/2019	11.52	09/11/2019	16.25	PO	Buchloz Relay Alaram Setting Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	06/11/2019	15.12		Continued.	T	Distance Protection, R-N, 15.5KM, 2.79KA.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Ranjangaon-Lonikand	IntraState	31/10/2019	15.29		Continued.	PO	Tower jumps opened.
220kv Halkarni- Tillary	IntraState	06/11/2019	18.06		Continued.	T	B PH PT Burst.
Trombay - Kalwa	IntraState	06/11/2019	20.13	08/11/2019	11.46	PO	Pilling Work At LOC NO 19.
Lonikand2-Lonikand1 (Interconector)	IntraState	08/11/2019	08.32	08/11/2019	17.23	PO	Twin Conductor Arrangement.
KORADI 2 - KAULEWADA CKT - II	IntraState	08/11/2019	09.32	08/11/2019	17.45	PO	SSN To DSN Conversion.
Karad(400kv) - Ogalewadi Ckt 1	IntraState	08/11/2019	09.46	08/11/2019	16.03	PO	LA Replacement.
Mahape - TIFIL	IntraState	08/11/2019	09.48	08/11/2019	19.05	PO	AT Mahape SS CB Timing,CRM & Bay Maint Work.
Adlabs - Pedambe	IntraState	08/11/2019	10.00	08/11/2019	17.18	PO	Bay RM Work.
Trombay - Mulund	IntraState	08/11/2019	10.09	08/11/2019	16.22	T	Y-PH Jumper Conductor Broken Tripped At Mulund End, Replaced

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 09/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							At Loc.3B.
Khadka-Chalisgaon-2	IntraState	08/11/2019	10.09	08/11/2019	17.52	PO	For Making LILO Arrangement At LOC No.238.
Kalwa - Mulund 1	IntraState	08/11/2019	10.09	08/11/2019	12.50	T	Tripped From Kalwa End.
Abhijeet-Wardha-Ii	IntraState	08/11/2019	10.10	08/11/2019	17.42	PO	For Shifting Of 220KV Wardha-Abhijit-1 Ckt From ERs Towers To Dverted/Hight Raised Towers.
Khadka-Chalisgaon-2	IntraState	08/11/2019	10.10	08/11/2019	17.07	PO	For Making LILO Arrangement At LOC No.238.
Vita Alkud	IntraState	08/11/2019	10.30	08/11/2019	12.32	PO	Tan Delta Testing Of CTS
Akola-Paras Ckt No-I	IntraState	08/11/2019	11.35	08/11/2019	16.15	EO	Attending Hot Spot
Bhigwan-Baramat Iagro	IntraState	08/11/2019	11.45	08/11/2019	17.00	PO	Daignostic Testing Work.
Nanded-Parbhani	IntraState	08/11/2019	12.15	08/11/2019	15.34	EO	Replacement Of Flash String At Loc 71
Ghatghar - Bapgaon	IntraState	08/11/2019	12.30	08/11/2019	16.25	T	Mock Drill Of Ghatghar balck-Start.
Taloja Ii - OCIL-II	IntraState	08/11/2019	13.50	08/11/2019	18.40	PO	Check Meter Installation At Consumer End.
Waluj- Padegaon Ii	IntraState	08/11/2019	13.56	08/11/2019	22.12	PO	220Kv Bus Section 2 Outage For Fixing Of Jumper For Newly Coannected 220Kv Sawangi CKT 2.
Theur-Phursungi ckt-2	IntraState	08/11/2019	16.06	08/11/2019	20.27	PO	Jumper Replacement LOC 18.
Kathapur-Ranjangaon	IntraState	08/11/2019	18.45	08/11/2019	14.40	PO	Taken In Service For 132Kv Theur Sanaswadi Outage Then Out At 18.45.
Taloja II - OCIL-I	IntraState	08/11/2019	20.11	08/11/2019	20.33	PO	Check Meter Installation At Consumer End.
Trombay - Kalwa	IntraState	08/11/2019	21.01		Continued.	PO	Pilling Work At LOC.NO.19
Nerle - Dasgaon	IntraState	09/11/2019	1.15	09/11/2019	02.52	T	Tripped At Dasgaon End Only.
Miraj-Ichalkaranji I	IntraState	09/11/2019	10.14	09/11/2019	16.23	PO	Routine Maintenance Work
Pophali - New Koyna	IntraState	09/11/2019	10.15	09/11/2019	15.10	PO	Routine Maintenance Work
MAHAPE - RELIANCE GIS	IntraState	09/11/2019	10.24	09/11/2019	17.55	PO	Safety Purpose.
Kharghar-Borivali ckt II	IntraState	09/11/2019	10.35	09/11/2019	17.30	PO	Cnstruction Work.
Chinchwad-Hinjewadi I	IntraState	09/11/2019	10.42	09/11/2019	18.38	PO	Load Management.
Sahara-Urse	IntraState	09/11/2019	10.45	09/11/2019	18.45	PO	Load Managment.
Urse - Talegaon (Ambi) Ckt 1	IntraState	09/11/2019	10.58	09/11/2019	18.20	PO	Line Maintenance work
Bableshtar - Alephata ckt I	IntraState	09/11/2019	11.43	09/11/2019	11.54	T	Distance Protection
Ghatghar - Bapgaon	IntraState	09/11/2019	13.10	09/11/2019	18.15	PO	Maintenance Of Bay Equipment.
Jejuri- Ismt- Lonand	IntraState	09/11/2019	21.53	09/11/2019	22.45	T	Distance Protection
Trombay - Mulund	IntraState	09/11/2019	22.59		Continued.	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	08/11/2019	09.16	08/11/2019	18.35	PO	Attending Oil Leakage
220/132 Kv 200 Mva Bbl Ict 4 @Padegaon	IntraState	08/11/2019	14.17	08/11/2019	22.14	PO	220Kv Bus Section 2 Outage For Fixing Of Jumper For Newly Coannected 220Kv Sawangi CKT 2.
220/132 Kv 100 Mva Bhel Ict 2 @Padegaon	IntraState	08/11/2019	14.31	08/11/2019	22.15	PO	220Kv Bus Section 2 Outage For Fixing Of Jumper For Newly Coannected 220Kv Sawangi CKT 2.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage