

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Dec/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	139.712	1180.401	1) Gujrat	-6.495	-40.335
2) Hydro	11.918	98.397	2) Madhya Pradesh	3.499	7.851
3) Gas	4.916	43.960	3) Chattisgarh	6.640	42.300
Total MSPGCL	156.546	1322.758	4) Maharashtra	168.551	1317.010
B) 1) APLM	74.603	590.407	5) Goa (Amona)	-1.309	-11.378
2) JSWEL	12.570	96.193	Total	170.886	1315.448
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.175	221.174
4) RPL(AMT)	25.432	229.383	b) Mumbai Drawl	33.054	260.370
5) SWPGPL	6.001	60.226			
6) Other IPP	46.841	362.279	c) MSEDCL Bilateral *	79.257	518.694
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	11.935	89.919	d) Mumbai Bilateral *	29.175	221.174
2) TPCL Hydro	3.862	29.929	Include PX	0.000	0.000
3) TPCL Gas	1.850	14.079	Standby	0.000	0.000
4) AEML Thermal	10.187	79.932			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	327.281	2688.740	1) MSEDCL	476.118	3789.712
2) Hydro (A2+C2)	15.780	128.326	2) Mumbai Discoms	60.889	474.227
3) Gas (A3+B7+C3)	6.766	58.039	3) Other Discoms	9.479	75.275
4) Wind	14.239	63.987			
6) SOLAR	11.533	84.676	TOTAL STATE	546.486	4339.214
TOTAL STATE	375.599	3023.768			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6365	5734	6341	4869
MSPGCL Hydro	887	274	1324	129
MSPGCL Gas	185	183	180	188
MSPGCL Total Generation	7437	6191	7845	5186
Central Sector Receipt	8800	8652	6859	5878
WIND	427	464	789	1199
CPP / IPP Thermal	6836	6843	6945	6300
CPP / IPP Gas	0	0	0	0
SOLAR	1511	1806	2	0
Exchange with Mumbai	-1759	-1755	-1406	-1368
MSEDCL DEMAND MET	22817	21792	20595	16804
Load Shedding	0	0	0	0
MSEDCL DEMAND	22817	21792	20595	16804
TPCL GENERATION	772	754	1029	588
AEML GENERATION	493	492	500	314
MUMBAI DEMAND	3024	3001	2935	2270
OTHER DISCOM DEMAND	435	409	439	391
STATE DEMAND MET	26276	25202	23969	19465
STATE DEMAND	26276	25202	23969	19465
Frequency (Hz)	50.05	50.00	50.01	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.36 Hz at 06:04 Hrs	49.62 Hz at 22:18 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.04	40.42	215	205
Unit 7	0.00	0.00	0	0
Unit 8	13.71	105.18	608	375
Unit 9	13.93	107.14	627	422
Unit 10	13.09	105.52	580	390
Total	45.77	358.26		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.38	78.48	495	275
Unit 5	10.75	81.09	495	280
Total	21.13	159.57		
Parli				
Unit 6	4.32	34.66	235	141
Unit 7	4.36	35.16	241	142
Unit 8	0.00	23.29	0	0
Total	8.68	93.11		
Chandrapur				
Unit 3	3.34	28.12	170	120
Unit 4	3.04	26.07	146	100
Unit 5	5.20	53.90	295	70
Unit 6	7.19	53.20	340	260
Unit 7	0.00	0.00	0	0
Unit 8	8.88	41.65	445	283
Unit 9	10.12	80.73	496	294
Total	37.76	283.68		
Paras				
Unit 3	5.00	40.52	215	200
Unit 4	5.03	41.16	219	193
Total	10.03	81.68		
Khaparkheda				
Unit 1	2.94	22.51	140	110
Unit 2	2.81	22.52	135	110
Unit 3	3.52	29.33	178	130
Unit 4	3.42	26.92	166	128
Unit 5	0.00	54.80	0	0
Total	12.69	156.07		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.32	24.39	157	122
Unit 5	0.33	0.33	136	0
Total	3.65	48.04		
Uran				
All Units	4.92	43.96	240	174
Total	4.92	43.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	1.06	56	0
Total	0.19	1.06		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.39	26.76	520	40
Stage 4	3.60	29.54	750	0
Stage 3	1.34	12.03	240	0
Total	8.34	68.33		
Hydro				
KDPH	0.43	3.46	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.41	4.06	58	0
BHIRA T.R.	0.30	1.66	77	0
SMLHY_PTN	1.81	16.08	81	71
GHATGHAR	0.44	3.75	125	0
Total	3.39	29.00		
Wind				
Total	14.24	63.99	0	0
Total	14.24	63.99		
CPP				
APML(Mus)	74.60	590.41	0	0
JSWEL(Mus)	12.57	96.19	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.43	229.38	0	0
SWPGPL-Mus	6.00	60.23	0	0
Other(Mus)	46.84	362.28	0	0
Total	165.45	1338.49		
SOLAR				
Total	11.53	84.68	0	0
Total	11.53	84.68		
Tata				
Trombay 5	8.17	60.41	460	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.99	7.68	49	36
Trombay 7B	0.86	6.40	41	32
TATA Hydro	3.86	29.93	326	10
Trombay 8	3.76	29.51	206	132
Total	17.65	133.93		
AEML				
DTPS U-1&2	10.19	79.93	500	311
Total	10.19	79.93		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	139.71	1180.40	MSPGCL Total	156.55	1322.76
			MSPGCL Thml+Gas	144.63	1224.36	Koyna 1,2 & 4 Total	6.99	56.30
			MSPGCL Hydro	11.92	98.40	State Total	375.60	3023.77

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 08/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5302	154	235	5691	547	6971	0	0	6161	5820	-1320	17356	0	17356	2204	353	19913	50.04
2	5416	139	237	5792	496	6911	0	0	6050	5928	-1157	17642	0	17642	2040	328	20010	49.95
3	5515	133	238	5886	492	6862	0	0	5987	5799	-1083	17655	0	17655	1920	301	19876	49.86
4	5658	134	239	6031	411	6912	0	0	5921	5951	-1016	17987	0	17987	1843	302	20132	49.96
5	5826	133	238	6197	371	6919	0	0	6358	6332	-1010	18483	0	18483	1835	326	20644	50.01
6	5892	163	240	6295	319	6979	0	0	7183	7352	-1111	19477	0	19477	1955	357	21789	50.05
7	6028	939	238	7205	326	6990	0	14	7191	7438	-1117	20467	0	20467	2114	389	22970	50.09
8	6055	1648	238	7941	220	7396	0	228	6591	7027	-959	21455	0	21455	2354	398	24207	49.99
9	6203	1588	240	8031	232	7377	0	618	6803	7053	-1150	21741	0	21741	2616	420	24777	50.07
10	6269	1346	216	7831	343	7045	0	1118	7636	7891	-1457	22338	0	22338	2841	433	25612	50.04
11	6365	887	185	7437	427	6836	0	1511	8563	8800	-1759	22817	0	22817	3024	435	26276	50.05
12	6074	270	184	6528	424	6800	0	1701	9203	9108	-1812	22315	0	22315	3062	434	25811	50.02
13	5734	274	183	6191	464	6843	0	1806	8774	8652	-1755	21792	0	21792	3001	409	25202	50.00
14	5608	206	181	5995	405	6842	0	1641	8348	8419	-1637	21259	0	21259	2881	406	24546	50.04
15	5877	189	180	6246	430	6842	0	1433	8864	8899	-1680	21751	0	21751	2920	419	25090	50.02
16	5882	194	174	6250	497	6907	0	953	8842	8852	-1607	21447	0	21447	2953	405	24805	50.01
17	5966	348	179	6493	503	6906	0	417	8135	8249	-1482	20654	0	20654	2939	432	24025	49.98
18	6318	647	182	7147	697	6942	0	91	7033	7106	-1450	20097	0	20097	2920	436	23453	49.99
19	6341	1324	180	7845	789	6945	0	2	6442	6859	-1406	20595	0	20595	2935	439	23969	50.01
20	6282	613	182	7077	1100	6971	0	0	6351	5890	-1247	19363	0	19363	2779	428	22570	50.05
21	5784	181	183	6148	1166	6850	0	0	6035	5959	-1478	18223	0	18223	2620	422	21265	50.00
22	5312	144	186	5642	1208	6709	0	0	5794	5843	-1537	17451	0	17451	2491	414	20356	49.99
23	5136	135	190	5461	1173	6392	0	0	5828	5781	-1456	16948	0	16948	2371	403	19722	49.89
24	4869	129	188	5186	1199	6300	0	0	5827	5878	-1368	16804	0	16804	2270	391	19465	50.02
MUs	139.71	11.92	4.92	156.55	14.24	165.45	0.00	11.53	169.92	170.89	-33.05	476.12	0.00	476.12	60.89	9.48	546.49	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 08/Dec/2022

Position as on 6.30 Hrs of 09/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	13/12/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20	08/12/2022	20:20	UNIT IS READY(UNIT UNDER TOLLING from 20.11.2022)	07/12/2022
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
IPP	RPL(AMT) U-3	270	05/12/2022	12:00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 5	500	06/12/2022	12:50	09/12/2022	12:12	Boiler Tube Leakage	09/12/2022
MSPGCL	Parli Unit 8	250	07/12/2022	13:28	09/12/2022	11:57	Boiler Tube Leakage	09/12/2022
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage	12/12/2022
MSPGCL	Uran Unit B0	120	08/12/2022	09:37	09/12/2022	09:18	tripped on Generator exciter end vibration high	
IPP	SWPGPL U-3	135	08/12/2022	09:56	09/12/2022	02:57	BOILER SSC CHAIN PROBLEM	
MSPGCL	Paras Unit 3	250	09/12/2022	18:28		Continued.	Boiler Tube Leakage	13/12/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 09/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BR Outages/Trippings							
BUS REACTOR (240 MVAR) @ EKTUNI	IntraState	08/12/2022	11:15	08/12/2022	20:02	PO	Diagnostic, Relay Testing & Routine Maintenance
400 KV TIEBAY Outages/Trippings							
TIE BAY (417) OF ST - 3 AND ST-5 @ TIRORA	IntraState	08/12/2022	09:00	08/12/2022	18:48	PO	For bay equipment maintenance and testing work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (415) OF PADGHE PG CKT - 1 @ KUDUS	InterState	08/12/2022	11:00	08/12/2022	16:04	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
MAIN BAY (406) OF LINE- 3 @ KORADI 3	IntraState	08/12/2022	08:54	08/12/2022	15:33	PO	Annual Maintenance of Bay Equipment
MAIN BAY (409) LINE - 2 OF KORADI-2 @ KORADI 3	IntraState	09/12/2022	08:59	09/12/2022	17:34	PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Trippings							
CHANDRAPUR - BHADRAVATI CKT - 1	InterState	09/12/2022	09:33	09/12/2022	16:33	PO	1. Replacement of faulty Phasor measurement unit (PMU) relay 2. Wiring and testing of PMU relay.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
JAIGAD - KARAD CKT - 1	IntraState	07/12/2022	19:25	08/12/2022	09:55	HT	to control overvoltage
PARLI-SOLAPUR (LAMBOTI)	IntraState	08/12/2022	08:06	08/12/2022	18:43	PO	Replacement of string
PARLI-SOLAPUR (LAMBOTI)	IntraState	08/12/2022	08:06	08/12/2022	18:43	PO	(1) C & Tan delta measurement of CTs (2) Bay maintenance work.
LONIKAND - JEJURI CKT - 1	IntraState	08/12/2022	08:47	08/12/2022	17:32	PO	DT and Line Maintenance
CHANDRAPUR 2 - WARORA CKT-2	IntraState	08/12/2022	08:48	08/12/2022	18:08	PO	Conductor & Earthwire Hardware tightening work
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/12/2022	08:48			PO	For attending SF6 gas leakage
JAIGAD - KARAD CKT - 2	IntraState	09/12/2022	01:36	09/12/2022	09:51	HT	H/T DUE TO O/V
CHANDRAPUR-PARLI CKT-3	IntraState	09/12/2022	11:25	09/12/2022	17:04	PO	1. Replacement of faulty Phasor measurement unit (PMU) relay 2. Wiring and testing of PMU relay.
NAGOTHANE - DABHOL CKT - 1	IntraState	09/12/2022	12:06	09/12/2022	19:16	PO	Cold washing work
JAIGAD - KARAD CKT - 1	IntraState	09/12/2022	20:57		Continued.	HT	Overvoltage
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	03/12/2022	09:20			PO	FOR CB replacemnt work
400/220/33 KV 500 MVA ICT - 2 @ DHULE	IntraState	06/12/2022	10:57	09/12/2022	18:02	PO	400/220/33kv 501MVA ICT 2 HV side 400kv Circuit breaker mechanism Overhauling & servicing work
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	07/12/2022	21:00	08/12/2022	04:11	PO	Oil pump replacement work and Bay maintenance and diagnostic work. chemical washing of equipment.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 09/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	08/12/2022	11:20	08/12/2022	18:59	PO	For Overhauling of Bus B 89B Rph, Yph, Bph and Bus C 89C Rph, Yph, Bph PG Isolators and Routine Testing and Maintenance Wodrk.
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	08/12/2022	13:09	08/12/2022	17:51	PO	SFRA, Tan-d of ICT-1 Unit-Y-ph Rouitne relay testing & Bay maintenance Works
400/220 KV 315MVA ICT - 2 @ KARAD	IntraState	09/12/2022	08:50	09/12/2022	12:11	T	R-ph Bucholz Protection
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	09/12/2022	09:45	09/12/2022	11:37	HT	Sparking observed on LA
400/220/33 KV 315MVA ICT - 1 @ CHAKAN	IntraState	09/12/2022	09:45	09/12/2022	11:02	T	Tripped
400/220/33 KV 315MVA ICT - 2 @ CHAKAN	IntraState	09/12/2022	09:45	09/12/2022	10:40	T	Tripped
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	07/12/2022	21:55	08/12/2022	07:37	HT	Attending hot spot work
NALASOPARA - BOISAR PG	InterState	08/12/2022	22:55	08/12/2022	07:37	EO	Attending hot spot work at loc. No.112 (B-Ph PGCIL Side Temp-121 ĆC & B-Ph Nalasopara Side Temp-76 ĆC), Loc No.136 (B-Ph Nalasopara side Temp-133 ĆC), 203 (Y-Ph Nalasopara Side Temp-134 ĆC), 204 (Y-Ph PGCIL Side Temp-85 ĆC , B-Ph PGCIL Side Temp-84 ĆC & Y-Ph Nalasopara Side Temp-92 ĆC),
NALASOPARA - BOISAR PG	InterState	08/12/2022	23:10	09/12/2022	08:00	EO	Attending hot spot work at loc. No.NSP Gantry (B-Ph PGCIL Side Temp-75ĆC), Loc No.80 (Y-PhNalasopara side Temp-73ĆC),84 (R-PhPGCIL Side Temp-94ĆC),87 (B-Ph NSP Side Temp-71ĆC) , Loc No.102 (Y-Ph PGCIL Side Temp-74ĆC&R-PhNalasopara Side Temp-72ĆC& B-PhNalasopara Side Temp-78ĆC),Loc No.106 (B-Ph PGCIL Side Temp-88ĆC& B-PhNalasopara Side Temp-77ĆC),Loc No.156 (R-Ph PGCIL Side Temp-101ĆC, B-Ph PGCIL Side Temp-86ĆC& Y-PhNalasopara Side Temp-78ĆC),Loc No.132 (B-PhNalasopara Side Temp-74ĆC),Loc No.13 (R-PhNalasopara Side Temp-71ĆC, Y-PhNalasopara Side Temp-89ĆC),Loc No.108 (Y-PhNalasopara Side Temp-
NALASOPARA - BOISAR PG	InterState	08/12/2022	23:10	09/12/2022	08:00	HT	Emergency outage availed to attend hot spot.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KALWA SALSETTE - 3	IntraState	01/12/2022	22:23			EO	Interchanging of BUS of 220KV Kalwa-Salshette-3 & 220KV Kalwa-Salshette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
KALWA SALSETTE - 4	IntraState	01/12/2022	22:42			EO	Interchanging of BUS of 220 kV Kalwa-Salsette-3 & 220 kV Kalwa-Salsette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 09/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - PADGHE	IntraState	06/12/2022	09:19		Continued.	HT	to control overloading
MHAISHAL - SHEDYAL	IntraState	08/12/2022	09:25	08/12/2022	18:16	PO	Cold line washing work
PAL DOMBIVALI - PALAVA	IntraState	08/12/2022	09:52	08/12/2022	15:09	EO	For replacement of 220kV P.T. Bus Jumper
MAIN BUS SECTION - 2 @ PAL-DOMBIVALI	IntraState	08/12/2022	10:05	08/12/2022	15:09	EO	Replacement of damaged jumper of Main Bus R-Ph
EKLAHARA(OCR)-RAYMOND	IntraState	08/12/2022	10:20	08/12/2022	21:57	PO	attending red hot at locn no. 4,7,1 & 2 of LIL0 of 220kV Raymond OCR line. temp at locn 1-Rph 83.4degC. locn 2 Rph 97.8DegC, locn no.4-70.8degC, locn no.7-80.4Deg C
BIDRI - SAWANTWADI	IntraState	08/12/2022	10:33	08/12/2022	16:18	PO	Replacement of flashover string at Loc. No.30 Y Ph & insulator cleaning at loc.No.29 & 31
BARAMATI- KALYANI	IntraState	08/12/2022	11:40	08/12/2022	12:37	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK.
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	IntraState	08/12/2022	12:26	08/12/2022	17:45	PO	Replacement of Jumper of B phase wavetrap
NEW KOYNA - LOTEPARSHURAM	IntraState	08/12/2022	16:05	08/12/2022	20:24	PO	For Cold washing of insulator strings
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	08/12/2022	19:41	08/12/2022	22:36	HT	To control overloading
BOISAR II - BOISAR (PG) CKT - 2	IntraState	08/12/2022	23:12	09/12/2022	03:15	EO	Outage is required for safety purpose to attend Hot spot on 220kv PGCIL 2 NALASOPARA LINE as both on same Ckt.
BOISAR II - BOISAR (PG) CKT - 2	IntraState	08/12/2022	23:12	09/12/2022	03:15	HT	Emergency outage availed for safety purpose only.
PADGHE - JAMBHUL 1	IntraState	09/12/2022	06:38	09/12/2022	18:37	PO	1.Stringing - 4Spans 2.Removal of Tower - 1 Nos OPGW shifting - 2Spans
CHEMBUR (AEML) - NERUL (M)	IntraState	09/12/2022	07:46	09/12/2022	08:14	PO	To check Non operation of Autorelclose of Nerul-Chembur(Adani) line by Testing Team , Kalwa at Nerul end & For Diagnostic and R.M. work.
TIFIL - KALWA	IntraState	09/12/2022	08:09	09/12/2022	19:07	PO	Diagnostic testing of Bay equipment & Bus maintenance work.
MHAISHAL - SHEDYAL	IntraState	09/12/2022	09:00	09/12/2022	17:40	PO	Cold line washing work
CHAKAN-MAHINDRA VEHICLE	IntraState	09/12/2022	09:45	09/12/2022	10:48	T	Tripped
CHAKAN-BHOSARI 1	IntraState	09/12/2022	09:45	09/12/2022	11:38	T	Tripped
CHAKAN - CHINCHWAD 2	IntraState	09/12/2022	09:45	09/12/2022	11:20	T	Tripped
URSE-CHINCHWAD	IntraState	09/12/2022	09:45	09/12/2022	10:01	T	Tripped on Overcurrent Back up protection
HINJAWADI I- CHINCHWAD	IntraState	09/12/2022	09:45	09/12/2022	16:45	T	Tripped on Overcurrent Back up Protection
PIRANGUT - HINJAWADI 2	IntraState	09/12/2022	09:45	09/12/2022	10:20	T	Tripped on Overcurrent Back up Protection
CHAKAN (400KV) - VOLKSWAGEN	IntraState	09/12/2022	09:45	09/12/2022	10:58	T	Tripped
TALANDGE - MUDSHINGI CKT - 1	IntraState	09/12/2022	10:27	09/12/2022	15:15	PO	For disc insulator string cleaning by chemical method at tower Lo. No. 1, 2 & 6 nos. Guid tower.
EKLAHARE (OCR) - PADGHE	IntraState	09/12/2022	11:09	09/12/2022	16:11	EO	1. To attend the damaged Jump& conductor of B-phase at loc.no.309.
EKLAHARE (OCR) - PADGHE	IntraState	09/12/2022	11:09	09/12/2022	16:11	EO	1. To attend the damaged Jump& conductor of B-phase at loc.no.309.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 09/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NEW KOYNA - NIWALI	IntraState	09/12/2022	13:04	09/12/2022	17:36	EO	For replacement of 03 flashover disc of loc no 169B - R phase New Koyna side
ALEPHATA-PARGAON(KATHAPUR)	IntraState	09/12/2022	18:13	09/12/2022	23:38	HT	For load management , ICT outage at 400 KV Lonikand
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	08/12/2022	10:00	09/12/2022	15:00	PO	220kV CB Mechanism Overhauling work
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	08/12/2022	12:04	08/12/2022	16:00	PO	Hot spots attending work
220/33kV 50MVA TF-1 @ KOPARGAON	IntraState	08/12/2022	17:39	08/12/2022	20:33	PO	For attending of Hot Spot on R PH LV Bushing
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	09/12/2022	07:33	09/12/2022	18:20	PO	1) 220kV Padghe Line & 220kV Bus Sectionaliser Bay Isolators Gear Box Replacement & Isolators Maintenance works. 2) Diagnostic Testing of 220kV Padghe Bay & 220kV Bus Sectionaliser Bay & ICT Bay
220/132 KV 200 MVA ICT 2 @ BOISAR-II	IntraState	09/12/2022	09:53	09/12/2022	14:36	PO	Diagnostic testing work (SFRA)
220/132 KV 100 MVA ICT 1 @ BHENDA	IntraState	09/12/2022	11:12	09/12/2022	15:38	PO	Work for replacement of faulty fire detector assembly of NIPS & FD rain guard. And Quarterly maintenance Activities.
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	09/12/2022	17:31	09/12/2022	21:16	PO	For diagnosing testing work
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	08/12/2022	10:46	08/12/2022	14:54	EO	FOR ATTENDING HOTSPOT AT LOC 111
KALYAN KALWA SALSETTE 1	IntraState	08/12/2022	10:46	08/12/2022	14:54	PO	AATTENDING HOT SPOT AT LOC -111
110 KV BR Outages/Trippings							
110KV GROUP BREAKER-2 @ TROMBAY	IntraState	09/12/2022	11:55		Continued.	PO	RPUF protection Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage