

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 09/Jan/2018 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 114.432        | 1112.740        | 1) Gujrat                      | 1.619          | 7.084           |
| 2) Hydro            | 7.069          | 80.989          | 2) Madhya Pradesh              | 15.399         | 124.290         |
| 3) Gas              | 9.339          | 87.628          | 3) Chattisgarh                 | 6.460          | 53.080          |
| <b>Total MSPGCL</b> | <b>130.840</b> | <b>1281.357</b> | 4) Maharashtra Net             | 110.376        | 918.360         |
| B) 1) APML          | 53.346         | 469.379         | 5) Goa (Amona)                 | -0.792         | -7.612          |
| 2) JSWEL            | 18.658         | 161.881         | <b>Total</b>                   | <b>133.062</b> | <b>1095.202</b> |
| 3) VIPL             | 12.126         | 109.024         | a) Mumbai Schedule             | 29.815         | 200.765         |
| 4) RPL(AMT)         | 15.901         | 87.339          | b) Mumbai Drawl                | 31.487         | 220.556         |
| 5) WPCL             | 4.371          | 36.167          | c) MSEDCL Bilateral *          | 18.120         | 140.574         |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -1.343         | -16.006         |
| 7) Other IPP        | 12.298         | 112.209         | d) Mumbai Bilateral *          | 29.815         | 199.460         |
| C) 1) TPCL Thermal  | 0.000          | 38.638          | Include PX                     | 8.228          | 33.992          |
| 2) TPCL Hydro       | 6.676          | 48.384          | Include Standby                | 0.000          | 1.305           |
| 3) TPCL Gas         | 3.682          | 34.856          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) R-INFRA Thermal  | 6.082          | 75.572          | 1) MSEDCL                      | 361.392        | 3198.249        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 47.927         | 418.010         |
| 1) Thermal          | 237.214        | 2202.949        | <b>TOTAL STATE</b>             | <b>409.319</b> | <b>3616.259</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro (A2+C2)    | 13.745         | 129.373         |                                |                |                 |
| 3) Gas (A3+B6+C3)   | 13.021         | 122.484         |                                |                |                 |
| 4) Wind             | 9.555          | 39.336          |                                |                |                 |
| 6) SOLAR            | 2.722          | 26.911          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>276.257</b> | <b>2521.053</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5282                      | 5273                  | 5009                      | 4043                      |
| MSPGCL Hydro             | 397                       | 328                   | 508                       | 122                       |
| MSPGCL Gas               | 380                       | 390                   | 393                       | 387                       |
| MSPGCL Total Generation  | 6059                      | 5991                  | 5910                      | 4552                      |
| Central Sector Receipt   | 6713                      | 6331                  | 5941                      | 4210                      |
| WIND                     | 419                       | 341                   | 318                       | 503                       |
| CPP / IPP Thermal        | 5544                      | 5505                  | 4777                      | 4203                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 397                       | 429                   | 0                         | 0                         |
| Exchange with Mumbai     | -1606                     | -1480                 | -1589                     | -872                      |
| <b>MSEDCL DEMAND MET</b> | <b>17526</b>              | <b>17117</b>          | <b>15357</b>              | <b>12596</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17526                     | 17117                 | 15357                     | 12596                     |
| TPCL GENERATION          | 629                       | 629                   | 597                       | 125                       |
| R-INFRA GENERATION       | 253                       | 253                   | 254                       | 253                       |
| <b>MUMBAI DEMAND</b>     | <b>2488</b>               | <b>2362</b>           | <b>2440</b>               | <b>1250</b>               |
| STATE DEMAND MET         | 20014                     | 19479                 | 17797                     | 13846                     |
| <b>STATE DEMAND</b>      | <b>20014</b>              | <b>19479</b>          | <b>17797</b>              | <b>13846</b>              |
| Frequency (Hz)           | 49.95                     | 49.98                 | 49.98                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 22.00 Hrs | 49.78 Hz at 11.06 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 09/Jan/2018

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 23.40         | 0        | 0        |
| Unit 8             | 10.02        | 104.08        | 554      | 358      |
| Unit 9             | 9.86         | 59.45         | 470      | 360      |
| Unit 10            | 9.64         | 96.06         | 480      | 320      |
| <b>Total</b>       | <b>29.51</b> | <b>282.99</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 4.00         | 24.82         | 180      | 120      |
| Unit 4             | 0.36         | 78.40         | 330      | 0        |
| Unit 5             | 10.12        | 88.73         | 500      | 345      |
| <b>Total</b>       | <b>14.48</b> | <b>191.96</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 5.12         | 38.41         | 243      | 184      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 20.17         | 0        | 0        |
| <b>Total</b>       | <b>5.12</b>  | <b>58.58</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 10.10        | 90.33         | 470      | 357      |
| Unit 6             | 0.00         | 22.82         | 0        | 0        |
| Unit 7             | 10.03        | 88.98         | 463      | 360      |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 9.72         | 87.64         | 465      | 350      |
| <b>Total</b>       | <b>29.85</b> | <b>289.76</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.67         | 3.67          | 245      | 0        |
| Unit 4             | 5.27         | 48.04         | 255      | 185      |
| <b>Total</b>       | <b>8.94</b>  | <b>51.71</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 5.84          | 0        | 0        |
| Unit 2             | 3.94         | 35.84         | 180      | 135      |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.03         | 35.65         | 180      | 160      |
| Unit 5             | 10.22        | 90.92         | 485      | 347      |
| <b>Total</b>       | <b>18.19</b> | <b>168.24</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.16         | 9.66          | 195      | 162      |
| Unit 4             | 4.18         | 37.77         | 197      | 163      |
| Unit 5             | 0.00         | 22.07         | 0        | 0        |
| <b>Total</b>       | <b>8.35</b>  | <b>69.50</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 9.34         | 87.63         | 411      | 365      |
| <b>Total</b>       | <b>9.34</b>  | <b>87.63</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.04         | 2.12          | 25       | 0        |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.04</b>   | <b>2.12</b>   |          |          |
| <b>Koyna</b>    |               |               |          |          |
| Stage 1-2       | 1.82          | 21.63         | 315      | 40       |
| Stage 4         | 0.26          | 11.89         | 200      | 0        |
| Stage 3         | 0.41          | 7.89          | 80       | 0        |
| <b>Total</b>    | <b>2.49</b>   | <b>41.41</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.88          | 6.22          | 37       | 36       |
| VTRNA           | 0.92          | 7.82          | 61       | 0        |
| TILLARI         | 0.22          | 3.53          | 62       | 0        |
| BHTGR/VEER      | 0.00          | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.40          | 2.55          | 80       | 0        |
| RNGR+BHTSA      | 0.37          | 3.31          | 16       | 15       |
| BHANDARDRA      | 0.00          | 0.01          | 0        | 0        |
| ELDARY          | 0.00          | 0.33          | 0        | 0        |
| SMLHY_PTN       | 0.74          | 6.74          | 41       | 28       |
| GHATGHAR        | 1.05          | 9.09          | 125      | 0        |
| <b>Total</b>    | <b>4.58</b>   | <b>39.58</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 9.56          | 39.34         | 0        | 0        |
| <b>Total</b>    | <b>9.56</b>   | <b>39.34</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 53.35         | 469.38        | 0        | 0        |
| JSWEL(Mus)      | 18.66         | 161.88        | 0        | 0        |
| VIPL(Mus)       | 12.13         | 109.02        | 0        | 0        |
| RPLAMT(Mus)     | 15.90         | 87.34         | 0        | 0        |
| WPCL(Mus)       | 4.37          | 36.17         | 0        | 0        |
| Other(Mus)      | 12.30         | 112.21        | 0        | 0        |
| <b>Total</b>    | <b>116.70</b> | <b>976.00</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 2.72          | 26.91         | 0        | 0        |
| <b>Total</b>    | <b>2.72</b>   | <b>26.91</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 0.00          | 16.69         | 0        | 0        |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 2.25          | 21.54         | 106      | 72       |
| Trombay 7B      | 1.44          | 13.32         | 64       | 53       |
| Trombay 8       | 0.00          | 21.95         | 0        | 0        |
| TATA Hydro      | 6.68          | 48.38         | 459      | 0        |
| <b>Total</b>    | <b>10.36</b>  | <b>121.88</b> |          |          |
| <b>R-INFRA</b>  |               |               |          |          |
| DTPS U-1&2      | 6.08          | 75.57         | 254      | 252      |
| <b>Total</b>    | <b>6.08</b>   | <b>75.57</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 114.43      | 1112.74       | MSPGCL Total        | 130.84      | 1281.36       |
|                |             |         | MSPGCL Thml+Gas | 123.77      | 1200.37       | Koyna 1,2 & 4 Total | 2.08        | 33.52         |
|                |             |         | MSPGCL Hydro    | 7.07        | 80.99         | State Total         | 276.26      | 2521.05       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 09/Jan/2018

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4315        | 127  | 366  | 4808   | 298  | 4207      | 0    | 0     | 4234        | 4286        | -1106                | 12493                 | 0                    | 12493                     | 1484             | 13977           | 50.02         |
| 2                  | 4044        | 122  | 375  | 4541   | 377  | 4202      | 0    | 0     | 4142        | 4445        | -975                 | 12590                 | 0                    | 12590                     | 1354             | 13944           | 50.02         |
| 3                  | 4018        | 127  | 366  | 4511   | 433  | 4198      | 0    | 0     | 4154        | 4347        | -911                 | 12578                 | 0                    | 12578                     | 1289             | 13867           | 50.00         |
| 4                  | 4043        | 122  | 387  | 4552   | 503  | 4203      | 0    | 0     | 4168        | 4210        | -872                 | 12596                 | 0                    | 12596                     | 1250             | 13846           | 50.00         |
| 5                  | 4077        | 132  | 365  | 4574   | 550  | 4210      | 0    | 0     | 4506        | 4655        | -835                 | 13154                 | 0                    | 13154                     | 1286             | 14440           | 49.99         |
| 6                  | 4368        | 127  | 376  | 4871   | 536  | 4326      | 0    | 0     | 5308        | 5435        | -956                 | 14212                 | 0                    | 14212                     | 1424             | 15636           | 50.01         |
| 7                  | 5050        | 122  | 382  | 5554   | 603  | 4902      | 0    | 1     | 5851        | 6102        | -1077                | 16085                 | 0                    | 16085                     | 1661             | 17746           | 50.00         |
| 8                  | 5211        | 166  | 411  | 5788   | 664  | 5483      | 0    | 18    | 6313        | 6523        | -1182                | 17294                 | 0                    | 17294                     | 1857             | 19151           | 49.92         |
| 9                  | 5287        | 391  | 408  | 6086   | 636  | 5609      | 0    | 115   | 6140        | 6143        | -1321                | 17268                 | 0                    | 17268                     | 2108             | 19376           | 49.93         |
| 10                 | 5275        | 535  | 393  | 6203   | 620  | 5630      | 0    | 243   | 6102        | 5974        | -1484                | 17186                 | 0                    | 17186                     | 2341             | 19527           | 49.97         |
| 11                 | 5276        | 413  | 399  | 6088   | 450  | 5582      | 0    | 345   | 6438        | 6464        | -1609                | 17320                 | 0                    | 17320                     | 2481             | 19801           | 49.93         |
| 12                 | 5282        | 397  | 380  | 6059   | 419  | 5544      | 0    | 397   | 6728        | 6713        | -1606                | 17526                 | 0                    | 17526                     | 2488             | 20014           | 49.95         |
| 13                 | 5273        | 328  | 390  | 5991   | 341  | 5505      | 0    | 429   | 6527        | 6331        | -1480                | 17117                 | 0                    | 17117                     | 2362             | 19479           | 49.98         |
| 14                 | 5191        | 310  | 389  | 5890   | 252  | 5293      | 0    | 413   | 6078        | 6403        | -1443                | 16808                 | 0                    | 16808                     | 2311             | 19119           | 50.00         |
| 15                 | 5229        | 580  | 390  | 6199   | 174  | 5456      | 0    | 346   | 5965        | 6056        | -1497                | 16734                 | 0                    | 16734                     | 2364             | 19098           | 49.94         |
| 16                 | 5243        | 480  | 390  | 6113   | 159  | 5539      | 0    | 255   | 5969        | 6181        | -1489                | 16758                 | 0                    | 16758                     | 2369             | 19127           | 49.97         |
| 17                 | 5243        | 227  | 405  | 5875   | 128  | 5427      | 0    | 138   | 5954        | 6120        | -1497                | 16191                 | 0                    | 16191                     | 2373             | 18564           | 50.00         |
| 18                 | 5083        | 340  | 393  | 5816   | 181  | 5169      | 0    | 22    | 5728        | 5554        | -1550                | 15192                 | 0                    | 15192                     | 2380             | 17572           | 50.01         |
| 19                 | 5009        | 508  | 393  | 5910   | 318  | 4777      | 0    | 0     | 5579        | 5941        | -1589                | 15357                 | 0                    | 15357                     | 2440             | 17797           | 49.98         |
| 20                 | 4825        | 474  | 404  | 5703   | 385  | 4551      | 0    | 0     | 5654        | 5586        | -1560                | 14665                 | 0                    | 14665                     | 2409             | 17074           | 49.99         |
| 21                 | 4328        | 324  | 392  | 5044   | 384  | 4340      | 0    | 0     | 5352        | 5545        | -1442                | 13871                 | 0                    | 13871                     | 2259             | 16130           | 49.97         |
| 22                 | 4286        | 315  | 392  | 4993   | 387  | 4187      | 0    | 0     | 4747        | 4944        | -1431                | 13080                 | 0                    | 13080                     | 2076             | 15156           | 50.04         |
| 23                 | 4244        | 222  | 390  | 4856   | 397  | 4188      | 0    | 0     | 4697        | 4808        | -1365                | 12884                 | 0                    | 12884                     | 1877             | 14761           | 49.99         |
| 24                 | 4232        | 180  | 403  | 4815   | 360  | 4172      | 0    | 0     | 4393        | 4296        | -1210                | 12433                 | 0                    | 12433                     | 1684             | 14117           | 49.98         |
| MUs                | 114.43      | 7.07 | 9.34 | 130.84 | 9.56 | 116.70    | 0.00 | 2.72  | 130.73      | 133.06      | -31.49               | 361.39                | 0.00                 | 361.39                    | 47.93            | 409.32          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL) Statement-VI

## Details of Generating Unit Outages/Trippings for 09/Jan/2018

Position as on 6.30 Hrs of 10/Jan/2018

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                   | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                    |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown.                                                                                                 |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 04/06/2017   | 19.09        |            | Continued. | 3 months outage for refuelling.                                                                                    |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 16/12/2017   | 00.16        |            | Continued. | Annual Overhaul                                                                                                    |               |
| TPC-G                 | Trombay 5               | 500      | 02/01/2018   | 23.48        |            | Continued. | Boiler Recertification Work.                                                                                       |               |
| RINFRA-G              | REL Unit 2              | 250      | 06/01/2018   | 00.46        |            | Continued. | Annual Overhaul                                                                                                    |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                    |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                                                                      |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                                                                       |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                                                                       |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                                                                     |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                            |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                                                             |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                  |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                  |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 14/06/2016   | 19.35        |            | Continued. | De-commissioned on dt. 01.04.2017                                                                                  |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |            | Continued. | Change Over.                                                                                                       |               |
| MSPGCL                | Koradi Unit 5           | 200      | 05/09/2016   | 00.21        |            | Continued. | De-commissioned on dt.02.03.2017                                                                                   |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                        |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                        |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 28/07/2017   | 00.00        |            | Continued. | due to common pressure shaft with unit 1.                                                                          |               |
| MSPGCL                | Khaparkheda Unit 3      | 210      | 12/09/2017   | 00.00        |            | Continued. | Coal Shortage                                                                                                      |               |
| IPP                   | RPL(AMT) U-5            | 270      | 17/09/2017   | 02.01        |            | Continued. | Coal Shortage                                                                                                      |               |
| IPP                   | Dhariwal                | 300      | 27/10/2017   | 17.31        |            | Continued. | Drum level Not Maintained                                                                                          |               |
| MSPGCL                | Paras Unit 3            | 250      | 29/11/2017   | 22.55        | 09/01/2018 | 03.29      | bunkering problem, Water shortage                                                                                  |               |
| IPP                   | JSW (J) U2              | 300      | 01/12/2017   | 24.00        |            | Continued. | no schedule.                                                                                                       |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 03/12/2017   | 01.35        |            | Continued. | Water Shortage                                                                                                     |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 03/12/2017   | 14.17        |            | Continued. | Water Shortage                                                                                                     |               |
| MSPGCL                | Parli Unit 7            | 250      | 03/12/2017   | 23.35        |            | Continued. | Poor Coal Receipt.                                                                                                 |               |
| IPP                   | RPL(AMT) U-1            | 270      | 12/12/2017   | 08.49        |            | Continued. | switch gear problem (Coal shortage from 17.12.2017, 00:00hrs)Converted to zero schedule w.e.f 01.01.2018, 00:00hrs |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 26/12/2017   | 10.51        |            | Continued. | commission of venting system.                                                                                      |               |
| CPP                   | IEPL Unit 1             | 270      | 30/12/2017   | 23.58        |            | Continued. | No Schedule                                                                                                        |               |
| IPP                   | Adani U-2               | 660      | 02/01/2018   | 15.26        |            | Continued. | HPBP Bonnet leakage                                                                                                |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 09/Jan/2018**

**Position as on 6.30 Hrs of 10/Jan/2018**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                              | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|-------------------------------------------------------------------------------|---------------|
| MSPGCL             | Chandrapur Unit 6       | 500      | 04/01/2018   | 13.30        |           | Continued. | Water Shortage                                                                |               |
| MSPGCL             | Khaparkhedda Unit 1     | 210      | 04/01/2018   | 16.42        |           | Continued. | Coal Shortage                                                                 |               |
| MSPGCL             | Uran Unit 8             | 108      | 04/01/2018   | 19.38        |           | Continued. | due to vibration.                                                             |               |
| TPC_G              | Trombay 8               | 250      | 05/01/2018   | 05.52        |           | Continued. | Turbine bearing temperature high.                                             |               |
| MSPGCL             | Nasik Unit 5            | 210      | 06/01/2018   | 06.30        |           | Continued. | PA Fan Problem (Not available due to Coal shortage from 07.01.2018, 14:00Hrs) |               |
| MSPGCL             | Parli Unit 8            | 250      | 06/01/2018   | 07.07        |           | Continued. | Coal bunkering problem                                                        |               |
| MSPGCL             | Koradi Unit 7           | 210      | 07/01/2018   | 17.00        |           | Continued. | Poor Coal Receipt.                                                            |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 09/01/2018   | 01.08        |           | Continued. | Boiler Tube Leakage                                                           |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 09/Jan/2018**

**Statement-VII**

**Position as on 6.30 Hrs of 10/Jan/2018**

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                      |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                       |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                                              |
| Dhule Sar'Sarovar I                    | InterState                | 08/01/2018   | 17.19        | 09/01/2018 | 08.27      | HT          | Over Voltage                                                                                                                          |
| Dhule Sar'Sarovar I                    | InterState                | 09/01/2018   | 08.37        | 09/01/2018 | 09.06      | T           | Tripped At SSP Mend On PDR.                                                                                                           |
| Dhule Sar'Sarovar I                    | InterState                | 09/01/2018   | 09.09        |            | Continued. | T           | CB Not Closed At SSNL End Trial Taken At 14:26HRS But BKR Problem Persist At SSNL End Code 1018, Work Permit 15:35/9.1.2018 Code 1041 |
| Chandrapur Bhadravati IV               | InterState                | 09/01/2018   | 09.20        | 09/01/2018 | 21.07      | PO          | Outage By WRLDC                                                                                                                       |
| Chandrapur-II - Nanded ckt I           | IntraState                | 08/01/2018   | 09.09        | 09/01/2018 | 07.36      | PO          | Testing Work                                                                                                                          |
| Ektuni-Bableshwar ckt II               | IntraState                | 08/01/2018   | 12.41        |            | Continued. | PO          | Work At BBSLR End.                                                                                                                    |
| Bhusawal-Aurangabad                    | IntraState                | 08/01/2018   | 17.29        | 09/01/2018 | 07.26      | HT          | Over Voltage                                                                                                                          |
| Karad-Jaigad - I                       | IntraState                | 08/01/2018   | 18.22        |            | Continued. | HT          | Over Voltage                                                                                                                          |
| Lonikand I - Koyna stage-IV            | IntraState                | 08/01/2018   | 23.55        | 09/01/2018 | 08.58      | HT          | Over Voltage                                                                                                                          |
| Karad-Jaigad - I                       | IntraState                | 09/01/2018   | 09.00        |            | Continued. | OO          | Bay Maint Work. RCF-17:41HRS.                                                                                                         |
| Chandrapur-Parali III                  | IntraState                | 09/01/2018   | 11.24        | 09/01/2018 | 18.22      | PO          | Line Maintenance work                                                                                                                 |
| Chandrapur - Parli                     | IntraState                | 09/01/2018   | 11.24        | 09/01/2018 | 18.22      | PO          | Tightening Of Hardware At LOC908.                                                                                                     |
| Khadka-Aurangabad (Waluj)              | IntraState                | 09/01/2018   | 18.01        |            | Continued. | HT          | Over Voltage                                                                                                                          |
| karad -kolhapur-I                      | IntraState                | 09/01/2018   | 20.03        |            | Continued. | HT          | Over Voltage                                                                                                                          |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                       |
| 400/220/33 Kv 500 Mva Ict-3 @Nagothane | IntraState                | 09/01/2018   | 09.28        | 09/01/2018 | 18.16      | PO          | Attending Oil Leakage                                                                                                                 |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                       |
| Talandage - Chikodi                    | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | NO SCHEDULE.                                                                                                                          |
| Mudshingi - Chikodi                    | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | NO SCHEDULE.                                                                                                                          |
| Chandrapur GCR - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.                  |
| Chandrapur GCR - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.                  |
| Mumewadi -Halkarni II                  | IntraState                | 17/11/2017   | 10.00        |            | Continued. | PO          | Tower erection work (temporarily line would be Mumewadi-Tillari)                                                                      |
| Halkarni - Tillari II                  | IntraState                | 17/11/2017   | 12.25        |            | Continued. | PO          | Tower erection work. (temporarily line would be Mumewadi-Tillari)                                                                     |
| Kharghar-Borivali ckt II               | IntraState                | 07/12/2017   | 12.23        |            | Continued. | T           | Distance Protection                                                                                                                   |
| Kandalgaon - Sona Alloys               | IntraState                | 08/01/2018   | 08.40        | 09/01/2018 | 19.50      | PO          | Conductor replacement work                                                                                                            |
| Kharghar - Nerul                       | IntraState                | 09/01/2018   | 06.27        | 09/01/2018 | 08.05      | PO          | Voltage surge Arrester Relay fixing work.                                                                                             |
| Kandalgaon - Sona Alloys               | IntraState                | 09/01/2018   | 08.15        | 09/01/2018 | 17.00      | PO          | Conductor Replacement.                                                                                                                |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                       |
| 220/100 Kv 200 MVA ICT III @Borivali   | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                                    |
| 220/100 Kv 200 MVA ICT-IV@Kalwa        | IntraState                | 24/11/2017   | 01.58        |            | Continued. | T           | Buchholz PRV Operated(Failed on Internal Fault)                                                                                       |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage