

**State Load Despatch Center,Airoli (MSETCL) Statement I**  
**Daily system Report for 09/Jan/2019 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 153.556        | 1309.253        | 1) Gujrat                      | 2.965          | 18.973          |
| 2) Hydro            | 6.923          | 55.428          | 2) Madhya Pradesh              | 8.308          | 61.840          |
| 3) Gas              | 7.376          | 62.717          | 3) Chattisgarh                 | 3.010          | 34.850          |
| <b>Total MSPGCL</b> | <b>167.855</b> | <b>1427.398</b> | 4) Maharashtra Net             | 86.725         | 778.230         |
| B) 1) APML          | 66.969         | 611.790         | 5) Goa (Amona)                 | -0.264         | -1.980          |
| 2) JSWEL            | 22.886         | 204.206         | <b>Total</b>                   | <b>100.744</b> | <b>891.913</b>  |
| 3) VIPL             | 5.334          | 48.100          | a) Mumbai Schedule             | 15.329         | 144.633         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 21.516         | 188.190         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 10.505         | 107.149         |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -4.752         | -48.486         |
| 7) Other IPP        | 15.739         | 142.668         | d) Mumbai Bilateral *          | 15.329         | 144.633         |
| C) 1) TPCL Thermal  | 12.568         | 115.559         | Include PX                     | -0.398         | 0.868           |
| 2) TPCL Hydro       | 3.980          | 28.737          | Include Standby                | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.418          | 39.074          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) R-INFRA Thermal  | 4.642          | 42.935          | 1) MSEDCL                      | 368.220        | 3245.266        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 47.124         | 414.495         |
| 1) Thermal          | 281.694        | 2474.511        | <b>TOTAL STATE</b>             | <b>415.344</b> | <b>3659.761</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 10.903         | 84.165          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.794         | 101.791         |                                |                |                 |
| (A3+B6+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 4.119          | 55.138          |                                |                |                 |
| 6) SOLAR            | 6.090          | 52.243          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>314.600</b> | <b>2767.848</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 7313                      | 6761                  | 6527                      | 5948                      |
| MSPGCL Hydro             | 451                       | 534                   | 476                       | 99                        |
| MSPGCL Gas               | 298                       | 290                   | 297                       | 319                       |
| MSPGCL Total Generation  | 8062                      | 7585                  | 7300                      | 6366                      |
| Central Sector Receipt   | 4922                      | 4882                  | 4227                      | 2880                      |
| WIND                     | 231                       | 209                   | 183                       | 139                       |
| CPP / IPP Thermal        | 5301                      | 4938                  | 4922                      | 3882                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 789                       | 901                   | 0                         | 0                         |
| Exchange with Mumbai     | -1213                     | -1190                 | -1051                     | -398                      |
| <b>MSEDCL DEMAND MET</b> | <b>18092</b>              | <b>17325</b>          | <b>15581</b>              | <b>12869</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18092                     | 17325                 | 15581                     | 12869                     |
| TPCL GENERATION          | 988                       | 1029                  | 1135                      | 687                       |
| R-INFRA GENERATION       | 234                       | 190                   | 190                       | 191                       |
| <b>MUMBAI DEMAND</b>     | <b>2435</b>               | <b>2409</b>           | <b>2376</b>               | <b>1276</b>               |
| STATE DEMAND MET         | 20527                     | 19734                 | 17957                     | 14145                     |
| <b>STATE DEMAND</b>      | <b>20527</b>              | <b>19734</b>          | <b>17957</b>              | <b>14145</b>              |
| Frequency (Hz)           | 49.96                     | 49.99                 | 50.00                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 13.00 Hrs | 49.76 Hz at 19.36 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 09/Jan/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.28         | 9.78          | 170      | 105      |
| Unit 7             | 3.60         | 33.10         | 160      | 125      |
| Unit 8             | 10.03        | 24.76         | 560      | 350      |
| Unit 9             | 8.82         | 99.98         | 552      | 0        |
| Unit 10            | 9.14         | 91.98         | 401      | 330      |
| <b>Total</b>       | <b>34.87</b> | <b>259.61</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.16         | 86.03         | 500      | 350      |
| Unit 5             | 9.16         | 85.94         | 500      | 350      |
| <b>Total</b>       | <b>18.32</b> | <b>171.98</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 4.94         | 43.81         | 250      | 198      |
| <b>Total</b>       | <b>4.94</b>  | <b>43.81</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.34         | 37.93         | 195      | 161      |
| Unit 4             | 4.21         | 33.88         | 185      | 164      |
| Unit 5             | 9.32         | 83.34         | 410      | 365      |
| Unit 6             | 9.87         | 86.04         | 460      | 360      |
| Unit 7             | 9.38         | 83.76         | 447      | 360      |
| Unit 8             | 10.67        | 92.97         | 485      | 360      |
| Unit 9             | 10.57        | 94.22         | 485      | 360      |
| <b>Total</b>       | <b>58.35</b> | <b>512.13</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 5.14         | 46.81         | 257      | 200      |
| <b>Total</b>       | <b>5.14</b>  | <b>46.81</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.80         | 32.54         | 170      | 145      |
| Unit 2             | 3.68         | 31.46         | 160      | 140      |
| Unit 3             | 3.90         | 32.99         | 175      | 159      |
| Unit 4             | 3.85         | 32.15         | 170      | 155      |
| Unit 5             | 9.32         | 86.48         | 425      | 373      |
| <b>Total</b>       | <b>24.56</b> | <b>215.62</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.29         | 22.11         | 193      | 0        |
| Unit 4             | 4.09         | 37.19         | 194      | 164      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>7.38</b>  | <b>59.30</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.38         | 62.72         | 323      | 286      |
| <b>Total</b>       | <b>7.38</b>  | <b>62.72</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.10         | 0.57          | 35       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.10</b>   | <b>0.57</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.15          | 16.60          | 360      | 40       |
| Stage 4         | 0.18          | 1.75           | 90       | 0        |
| Stage 3         | 0.37          | 4.10           | 80       | 0        |
| <b>Total</b>    | <b>2.70</b>   | <b>22.44</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.46          | 2.42           | 19       | 19       |
| VTRNA           | 0.53          | 4.30           | 60       | 0        |
| TILLARI         | 0.60          | 3.76           | 60       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.27          | 1.41           | 80       | 0        |
| RNGR+BHTSA      | 0.30          | 2.58           | 13       | 12       |
| BHANDARDRA      | 0.00          | 0.06           | 0        | 0        |
| ELDARY          | 0.21          | 2.00           | 9        | 8        |
| SMLHY_PTN       | 0.31          | 3.33           | 13       | 12       |
| GHATGHAR        | 1.55          | 13.12          | 203      | 0        |
| <b>Total</b>    | <b>4.23</b>   | <b>32.98</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 4.12          | 55.14          | 0        | 0        |
| <b>Total</b>    | <b>4.12</b>   | <b>55.14</b>   |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 66.97         | 611.79         | 0        | 0        |
| JSWEL(Mus)      | 22.89         | 204.21         | 0        | 0        |
| VIPL(Mus)       | 5.33          | 48.10          | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 0.00           | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 15.74         | 142.67         | 0        | 0        |
| <b>Total</b>    | <b>110.93</b> | <b>1006.76</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.09          | 52.24          | 0        | 0        |
| <b>Total</b>    | <b>6.09</b>   | <b>52.24</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.36          | 68.52          | 318      | 299      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.81          | 24.70          | 118      | 116      |
| Trombay 7B      | 1.61          | 14.38          | 68       | 66       |
| Trombay 8       | 5.21          | 47.04          | 226      | 201      |
| TATA Hydro      | 3.98          | 28.74          | 429      | 0        |
| <b>Total</b>    | <b>20.97</b>  | <b>183.37</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| DTPS U-1&2      | 4.64          | 42.94          | 234      | 189      |
| <b>Total</b>    | <b>4.64</b>   | <b>42.94</b>   |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 153.56      | 1309.25       | MSPGCL Total        | 167.86      | 1427.40       |
|                |             |         | MSPGCL Thml+Gas | 160.93      | 1371.97       | Koyna 1,2 & 4 Total | 2.33        | 18.35         |
|                |             |         | MSPGCL Hydro    | 6.92        | 55.43         | State Total         | 314.60      | 2767.85       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 09/Jan/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6040        | 199  | 317  | 6556   | 49   | 3940      | 0    | 0     | 2912        | 3063        | -585                 | 13023                 | 0                    | 13023                     | 1459             | 14482           | 50.00         |
| 2                  | 5955        | 139  | 319  | 6413   | 93   | 3874      | 0    | 0     | 3042        | 2983        | -465                 | 12898                 | 0                    | 12898                     | 1339             | 14237           | 49.98         |
| 3                  | 5948        | 99   | 319  | 6366   | 139  | 3882      | 0    | 0     | 3086        | 2880        | -398                 | 12869                 | 0                    | 12869                     | 1276             | 14145           | 50.00         |
| 4                  | 5943        | 99   | 319  | 6361   | 115  | 3884      | 0    | 0     | 2850        | 2992        | -359                 | 12993                 | 0                    | 12993                     | 1237             | 14230           | 49.96         |
| 5                  | 5931        | 94   | 323  | 6348   | 90   | 3885      | 0    | 0     | 3387        | 3283        | -378                 | 13228                 | 0                    | 13228                     | 1256             | 14484           | 50.00         |
| 6                  | 6084        | 94   | 321  | 6499   | 97   | 3911      | 0    | 0     | 4409        | 4705        | -535                 | 14677                 | 0                    | 14677                     | 1409             | 16086           | 49.96         |
| 7                  | 6600        | 209  | 319  | 7128   | 128  | 4669      | 0    | 4     | 4755        | 4725        | -760                 | 15894                 | 0                    | 15894                     | 1637             | 17531           | 49.93         |
| 8                  | 6981        | 544  | 322  | 7847   | 172  | 5202      | 0    | 73    | 4886        | 4870        | -809                 | 17355                 | 0                    | 17355                     | 1813             | 19168           | 49.94         |
| 9                  | 7077        | 393  | 320  | 7790   | 163  | 5354      | 0    | 331   | 5328        | 4826        | -945                 | 17519                 | 0                    | 17519                     | 2072             | 19591           | 50.02         |
| 10                 | 7244        | 289  | 315  | 7848   | 166  | 5286      | 0    | 588   | 5034        | 5198        | -1119                | 17967                 | 0                    | 17967                     | 2290             | 20257           | 50.02         |
| 11                 | 7313        | 451  | 298  | 8062   | 231  | 5301      | 0    | 789   | 5296        | 4922        | -1213                | 18092                 | 0                    | 18092                     | 2435             | 20527           | 49.96         |
| 12                 | 6922        | 494  | 304  | 7720   | 234  | 5144      | 0    | 873   | 5173        | 5056        | -1265                | 17762                 | 0                    | 17762                     | 2465             | 20227           | 50.00         |
| 13                 | 6761        | 534  | 290  | 7585   | 209  | 4938      | 0    | 901   | 4723        | 4882        | -1190                | 17325                 | 0                    | 17325                     | 2409             | 19734           | 49.99         |
| 14                 | 6749        | 285  | 287  | 7321   | 195  | 4881      | 0    | 861   | 4659        | 4973        | -1192                | 17039                 | 0                    | 17039                     | 2290             | 19329           | 50.01         |
| 15                 | 6605        | 288  | 286  | 7179   | 175  | 4881      | 0    | 763   | 4736        | 4777        | -1166                | 16609                 | 0                    | 16609                     | 2302             | 18911           | 49.93         |
| 16                 | 6471        | 373  | 287  | 7131   | 162  | 4908      | 0    | 564   | 4719        | 4983        | -1155                | 16593                 | 0                    | 16593                     | 2314             | 18907           | 49.90         |
| 17                 | 6545        | 408  | 289  | 7242   | 154  | 4888      | 0    | 290   | 4524        | 4463        | -1147                | 15890                 | 0                    | 15890                     | 2320             | 18210           | 49.93         |
| 18                 | 6550        | 306  | 294  | 7150   | 120  | 4920      | 0    | 53    | 4084        | 3867        | -1105                | 15005                 | 0                    | 15005                     | 2308             | 17313           | 50.01         |
| 19                 | 6527        | 476  | 297  | 7300   | 183  | 4922      | 0    | 0     | 4106        | 4227        | -1051                | 15581                 | 0                    | 15581                     | 2376             | 17957           | 50.00         |
| 20                 | 6298        | 410  | 307  | 7015   | 304  | 4692      | 0    | 0     | 4210        | 4213        | -1001                | 15223                 | 0                    | 15223                     | 2337             | 17560           | 49.94         |
| 21                 | 6056        | 301  | 311  | 6668   | 279  | 4553      | 0    | 0     | 4011        | 4083        | -961                 | 14622                 | 0                    | 14622                     | 2225             | 16847           | 50.01         |
| 22                 | 5776        | 209  | 302  | 6287   | 192  | 4560      | 0    | 0     | 3977        | 3777        | -1015                | 13801                 | 0                    | 13801                     | 2037             | 15838           | 50.00         |
| 23                 | 5637        | 133  | 314  | 6084   | 232  | 4357      | 0    | 0     | 3763        | 3417        | -943                 | 13147                 | 0                    | 13147                     | 1857             | 15004           | 49.98         |
| 24                 | 5543        | 96   | 316  | 5955   | 237  | 4097      | 0    | 0     | 3415        | 3579        | -759                 | 13109                 | 0                    | 13109                     | 1661             | 14770           | 50.01         |
| MUs                | 153.56      | 6.92 | 7.38 | 167.85 | 4.12 | 110.93    | 0.00 | 6.09  | 101.08      | 100.74      | -21.52               | 368.22                | 0.00                 | 368.22                    | 47.12            | 415.34          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 09/Jan/2019

Position as on 6.30 Hrs of 10/Jan/2019

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                         |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |           | Continued. | Annual Overhaul                                                                                                                                         |               |
| MSPGCL                | Nasik Unit 5            | 210      | 22/11/2018   | 03.50        |           | Continued. | Boiler Tube Leakage work completed on 24/11/2018. Available against case 4 from 25/11/2018. Converted to COH from 00:00 Hrs of 05/12/2018 (for 40 Days) |               |
| RINFRA-G              | REL Unit 1              | 250      | 23/12/2018   | 06.06        |           | Continued. | For COH.                                                                                                                                                |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                         |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |           | Continued. | Economic shutdown                                                                                                                                       |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                                                                                 |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                       |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                       |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                             |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                             |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |           | Continued. | Compressor & Turbine Blade Failure.                                                                                                                     |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | Poor Coal Receipt                                                                                                                                       |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |           | Continued. | Withdrawn due to B0 & U-7                                                                                                                               |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |           | Continued. | Stator Earth Fault                                                                                                                                      |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| MSPGCL                | Koyana Unit 1           | 70       | 26/11/2018   | 00.00        |           | Continued. | Oil Cooler Leakage.                                                                                                                                     |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |           | Continued. | No Schedule.                                                                                                                                            |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |           | Continued. | ZERO SCHEDULE.                                                                                                                                          |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |           | Continued. | ZERO SCHEDULE.                                                                                                                                          |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-1            | 270      | 14/12/2018   | 16.00        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-3            | 270      | 14/12/2018   | 16.30        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                                                                             |               |
| IPP                   | RPL(AMT) U-2            | 270      | 27/12/2018   | 19.30        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-5            | 270      | 28/12/2018   | 19.30        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                                                                                           |               |
| MSPGCL                | Nasik Unit 3            | 210      | 09/01/2019   | 19.30        |           | Continued. | Zero Schedule                                                                                                                                           |               |
| MSPGCL                | Koradi Unit 9           | 660      | 09/01/2019   | 20.55        |           | Continued. | Boiler Tube Leakage                                                                                                                                     |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 09/Jan/2019**

**Statement-VII**

Position as on 6.30 Hrs of 10/Jan/2019

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                       | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                                               |
| Dhule Sar'Sarovar II                     | InterState                | 24/12/2018   | 18.09        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Padghe - Nagothane - II                  | IntraState                | 03/01/2019   | 11.30        |            | Continued. | PO          | New Line Tower Erection work                                                                                                           |
| Padghe - Nagothane - I                   | IntraState                | 03/01/2019   | 11.30        |            | Continued. | PO          | New Line Tower Erection work                                                                                                           |
| Lonikand I - Koyna stage-IV              | IntraState                | 08/01/2019   | 22.08        | 09/01/2019 | 07.00      | HT          | Over Voltage                                                                                                                           |
| Akola II - RPL(Rattaniindia) Ckt-II      | IntraState                | 09/01/2019   | 08.37        | 09/01/2019 | 21.35      | PO          | Routine Maintenance Work                                                                                                               |
| New Koyna - Koyna Stage IV-II            | IntraState                | 09/01/2019   | 09.36        | 09/01/2019 | 17.45      | PO          | Routine Maintenance Work                                                                                                               |
| Khadka-Aurangabad (Waluj)                | IntraState                | 09/01/2019   | 17.49        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Karad - Jaigad - II                      | IntraState                | 09/01/2019   | 20.29        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe      | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential protection, Declared Faulty.                                                                                              |
| 400/220kV 315MVA ICT-I@Parly             | IntraState                | 24/12/2018   | 15.40        |            | Continued. | PO          | Replacement Of B-PH Unit By Re paired One.                                                                                             |
| 400/220/33kv, 500 Mva Ict-2 @Khaparkheda | IntraState                | 09/01/2019   | 11.30        | 09/01/2019 | 12.54      | PO          | REPLACEMENT OF N-2 CYLINDER OF CTR.                                                                                                    |
| <b>220 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                      | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                      | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Mahalakshmi Amona                        | InterState                | 09/01/2019   | 19.45        | 09/01/2019 | 20.58      | T           | Distance Protection                                                                                                                    |
| Nasik Navsari I                          | InterState                | 10/01/2019   | 00.00        |            | Continued. | T           | Distance Protection                                                                                                                    |
| Chandrapur GCR - Warora - I              | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.                   |
| Chandrapur GCR - Wani                    | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                          | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To control line loading.                                                                                                               |
| Kalwa-TIFIL                              | IntraState                | 27/11/2018   | 06.06        | 09/01/2019 | 12.05      | EO          | Tapping Of Tifil Substation On 220KV Kharghar-Borivali Line                                                                            |
| Kalwa - Siemens                          | IntraState                | 27/11/2018   | 13.13        | 09/01/2019 | 08.28      | HT          | To Shift Load On Kharghar ICT                                                                                                          |
| Goregaon Aarey Line 2                    | IntraState                | 09/01/2019   | 08.14        | 09/01/2019 | 18.49      | PO          | LINE DIVERSION WORK.                                                                                                                   |
| Dahanu Ghodbunder Line 1                 | IntraState                | 09/01/2019   | 08.22        | 09/01/2019 | 19.50      | PO          | LINE ISOLATOR MAINTENANCE WORK.                                                                                                        |
| Kharghar-Borivali ckt II                 | IntraState                | 09/01/2019   | 08.44        | 09/01/2019 | 13.07      | PO          | FOR REMOVING TAP ARRANGEMENT AND NORMALIZE KALWA TFIPL LINE.                                                                           |
| Kalmeshwar-Pandhurna                     | IntraState                | 09/01/2019   | 09.51        | 09/01/2019 | 19.15      | PO          | Line Maintenance work                                                                                                                  |
| Mudshingi-Wathar                         | IntraState                | 09/01/2019   | 10.40        | 09/01/2019 | 13.48      | PO          | Quarterly Maintenance Work                                                                                                             |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Kanhan Pench                             | InterState                | 09/01/2019   | 13.55        | 09/01/2019 | 15.19      | PO          | String Replacement work                                                                                                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage