

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 09/Jan/2021 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 138.600        | 1191.406        | 1) Gujrat                      | 0.672          | 19.300          |
| 2) Hydro            | 8.903          | 107.536         | 2) Madhya Pradesh              | 11.865         | 87.114          |
| 3) Gas              | 3.460          | 43.118          | 3) Chattisgarh                 | 6.030          | 58.530          |
| <b>Total MSPGCL</b> | <b>150.963</b> | <b>1342.060</b> | 4) Maharashtra                 | 143.761        | 1294.641        |
| B) 1) APLM          | 26.400         | 227.985         | 5) Goa (Amona)                 | -1.618         | -9.925          |
| 2) JSWEL            | 16.851         | 158.641         | <b>Total</b>                   | <b>160.710</b> | <b>1449.660</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 23.181         | 166.445         |
| 4) RPL(AMT)         | 25.929         | 249.365         | b) Mumbai Drawl                | 22.093         | 168.225         |
| 5) WPCL             | 7.599          | 70.706          | c) MSEDCL Bilateral *          | 40.789         | 430.139         |
| 6) Other IPP        | 17.590         | 159.345         | Include PX                     | 10.691         | 165.590         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 23.181         | 166.445         |
| C) 1) TPCL Thermal  | 14.145         | 119.968         | Include PX                     | 15.429         | 86.864          |
| 2) TPCL Hydro       | 2.830          | 36.228          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.692          | 7.463           | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 5.331          | 82.270          | 1) MSEDCL                      | 393.715        | 3609.511        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 47.091         | 414.156         |
| 1) Thermal          | 252.445        | 2259.686        | <b>TOTAL STATE</b>             | <b>440.806</b> | <b>4023.667</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 11.733         | 143.764         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 6.152          | 50.581          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 5.176          | 76.014          |                                |                |                 |
| 6) SOLAR            | 4.590          | 43.960          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>280.096</b> | <b>2574.005</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5897                      | 5927                  | 6140                      | 4662                      |
| MSPGCL Hydro             | 860                       | 358                   | 490                       | 300                       |
| MSPGCL Gas               | 140                       | 130                   | 244                       | 20                        |
| MSPGCL Total Generation  | 6898                      | 6416                  | 6874                      | 4982                      |
| Central Sector Receipt   | 7906                      | 7899                  | 6252                      | 5962                      |
| WIND                     | 168                       | 125                   | 170                       | 202                       |
| CPP / IPP Thermal        | 4440                      | 4471                  | 4414                      | 3371                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 660                       | 739                   | 0                         | 0                         |
| Exchange with Mumbai     | -1101                     | -1061                 | -992                      | -759                      |
| <b>MSEDCL DEMAND MET</b> | <b>18970</b>              | <b>18589</b>          | <b>16718</b>              | <b>13758</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18970                     | 18589                 | 16718                     | 13758                     |
| TPCL GENERATION          | 1049                      | 1049                  | 1012                      | 529                       |
| AEML GENERATION          | 248                       | 250                   | 251                       | 148                       |
| <b>MUMBAI DEMAND</b>     | <b>2398</b>               | <b>2360</b>           | <b>2255</b>               | <b>1436</b>               |
| STATE DEMAND MET         | 21368                     | 20949                 | 18974                     | 15194                     |
| <b>STATE DEMAND</b>      | <b>21368</b>              | <b>20949</b>          | <b>18974</b>              | <b>15194</b>              |
| Frequency (Hz)           | 49.92                     | 50.04                 | 49.98                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 06.32 Hrs | 49.74 Hz at 11.10 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 09/Jan/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.06         | 25.74         | 145      | 115      |
| Unit 7             | 0.00         | 17.25         | 0        | 0        |
| Unit 8             | 11.84        | 111.63        | 535      | 400      |
| Unit 9             | 10.84        | 109.05        | 550      | 370      |
| Unit 10            | 12.18        | 57.30         | 570      | 460      |
| <b>Total</b>       | <b>37.93</b> | <b>320.97</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.70         | 21.16         | 185      | 135      |
| Unit 4             | 10.73        | 72.87         | 475      | 325      |
| Unit 5             | 2.85         | 2.85          | 430      | 0        |
| <b>Total</b>       | <b>17.28</b> | <b>96.87</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 5.02         | 44.14         | 250      | 178      |
| Unit 7             | 4.90         | 45.27         | 249      | 155      |
| Unit 8             | 5.11         | 46.94         | 250      | 180      |
| <b>Total</b>       | <b>15.03</b> | <b>136.35</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.77         | 35.66         | 172      | 127      |
| Unit 4             | 0.00         | 29.69         | 0        | 0        |
| Unit 5             | 8.04         | 79.67         | 420      | 75       |
| Unit 6             | 9.61         | 67.25         | 430      | 285      |
| Unit 7             | 7.55         | 66.45         | 335      | 295      |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 11.54        | 104.03        | 494      | 462      |
| <b>Total</b>       | <b>40.50</b> | <b>382.75</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 2.68         | 32.55         | 238      | 0        |
| Unit 4             | 5.67         | 51.54         | 250      | 165      |
| <b>Total</b>       | <b>8.35</b>  | <b>84.09</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.56         | 28.34         | 165      | 115      |
| Unit 2             | 3.95         | 34.65         | 180      | 115      |
| Unit 3             | 4.49         | 28.96         | 200      | 140      |
| Unit 4             | 4.36         | 39.14         | 202      | 130      |
| Unit 5             | 0.00         | 8.74          | 0        | 0        |
| <b>Total</b>       | <b>16.35</b> | <b>139.83</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.15         | 30.54         | 181      | 121      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>3.15</b>  | <b>30.54</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 3.46         | 43.12         | 289      | 0        |
| <b>Total</b>       | <b>3.46</b>  | <b>43.12</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.29         | 3.12          | 25       | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.29</b>  | <b>3.12</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 2.71         | 27.52         | 325      | 40       |
| Stage 4         | 2.71         | 41.76         | 490      | 0        |
| Stage 3         | 0.76         | 14.37         | 160      | 0        |
| <b>Total</b>    | <b>6.18</b>  | <b>83.64</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.44         | 4.00          | 19       | 19       |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 0.00         | 0.00          | 0        | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.00         | 2.27          | 0        | 0        |
| RNGR+BHTSA      | 0.36         | 3.24          | 15       | 14       |
| BHANDARDRA      | 0.00         | 0.00          | 0        | 0        |
| ELDARY          | 0.36         | 3.24          | 16       | 15       |
| SMLHY_PTN       | 0.39         | 2.24          | 17       | 16       |
| GHATGHAR        | 1.17         | 8.91          | 250      | 0        |
| <b>Total</b>    | <b>2.72</b>  | <b>23.89</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 5.18         | 76.01         | 0        | 0        |
| <b>Total</b>    | <b>5.18</b>  | <b>76.01</b>  |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 26.40        | 227.98        | 0        | 0        |
| JSWEL(Mus)      | 16.85        | 158.64        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 25.93        | 249.36        | 0        | 0        |
| WPCL(Mus)       | 7.60         | 70.71         | 0        | 0        |
| Other(Mus)      | 17.59        | 159.34        | 0        | 0        |
| <b>Total</b>    | <b>94.37</b> | <b>866.04</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 4.59         | 43.96         | 0        | 0        |
| <b>Total</b>    | <b>4.59</b>  | <b>43.96</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 9.32         | 79.28         | 475      | 277      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 1.50         | 4.43          | 65       | 62       |
| Trombay 7B      | 1.19         | 3.03          | 51       | 49       |
| Trombay 8       | 4.82         | 40.69         | 233      | 139      |
| TATA Hydro      | 2.83         | 36.23         | 231      | 0        |
| <b>Total</b>    | <b>19.67</b> | <b>163.66</b> |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 5.33         | 82.27         | 251      | 147      |
| <b>Total</b>    | <b>5.33</b>  | <b>82.27</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 138.60      | 1191.41       | MSPGCL Total        | 150.96      | 1342.06       |
|                |             |         | MSPGCL Thml+Gas | 142.06      | 1234.52       | Koyna 1,2 & 4 Total | 5.42        | 69.28         |
|                |             |         | MSPGCL Hydro    | 8.90        | 107.54        | State Total         | 280.10      | 2574.00       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 09/Jan/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5673        | 126  | 0    | 5800   | 304  | 3541      | 0    | 0     | 5512        | 5544        | -843                 | 14346                 | 0                    | 14346                     | 1660             | 16006           | 49.96         |
| 2                  | 5327        | 106  | 0    | 5432   | 307  | 3410      | 0    | 0     | 5933        | 5735        | -862                 | 14022                 | 0                    | 14022                     | 1554             | 15576           | 50.00         |
| 3                  | 4888        | 110  | 21   | 5020   | 212  | 3398      | 0    | 0     | 5976        | 5911        | -805                 | 13735                 | 0                    | 13735                     | 1485             | 15220           | 50.00         |
| 4                  | 4662        | 300  | 20   | 4982   | 202  | 3371      | 0    | 0     | 5966        | 5962        | -759                 | 13758                 | 0                    | 13758                     | 1436             | 15194           | 50.00         |
| 5                  | 5128        | 116  | 60   | 5304   | 209  | 3320      | 0    | 0     | 6255        | 6179        | -770                 | 14242                 | 0                    | 14242                     | 1446             | 15688           | 49.98         |
| 6                  | 5458        | 120  | 85   | 5664   | 222  | 3350      | 0    | 0     | 6815        | 6966        | -838                 | 15363                 | 0                    | 15363                     | 1515             | 16878           | 50.00         |
| 7                  | 5744        | 120  | 135  | 6000   | 268  | 3543      | 0    | 0     | 7307        | 7344        | -875                 | 16279                 | 0                    | 16279                     | 1604             | 17883           | 50.03         |
| 8                  | 5826        | 548  | 140  | 6514   | 269  | 4186      | 0    | 54    | 7194        | 7126        | -748                 | 17401                 | 0                    | 17401                     | 1728             | 19129           | 50.02         |
| 9                  | 5865        | 962  | 140  | 6966   | 187  | 4387      | 0    | 194   | 6886        | 6823        | -831                 | 17727                 | 0                    | 17727                     | 1932             | 19659           | 50.01         |
| 10                 | 5861        | 1140 | 130  | 7132   | 240  | 4516      | 0    | 408   | 7118        | 7082        | -1014                | 18364                 | 0                    | 18364                     | 2169             | 20532           | 49.96         |
| 11                 | 5760        | 1156 | 140  | 7056   | 223  | 4533      | 0    | 524   | 7772        | 7471        | -1111                | 18696                 | 0                    | 18696                     | 2332             | 21028           | 49.92         |
| 12                 | 5897        | 860  | 140  | 6898   | 168  | 4440      | 0    | 660   | 7920        | 7906        | -1101                | 18970                 | 0                    | 18970                     | 2398             | 21368           | 49.92         |
| 13                 | 5927        | 358  | 130  | 6416   | 125  | 4471      | 0    | 739   | 7877        | 7899        | -1061                | 18589                 | 0                    | 18589                     | 2360             | 20949           | 50.04         |
| 14                 | 5783        | 204  | 140  | 6126   | 88   | 4267      | 0    | 734   | 8005        | 7724        | -973                 | 17966                 | 0                    | 17966                     | 2254             | 20220           | 50.06         |
| 15                 | 5831        | 294  | 130  | 6256   | 61   | 4002      | 0    | 596   | 7961        | 8002        | -964                 | 17953                 | 0                    | 17953                     | 2223             | 20176           | 50.01         |
| 16                 | 5981        | 562  | 130  | 6674   | 47   | 4163      | 0    | 405   | 8003        | 7609        | -903                 | 17994                 | 0                    | 17994                     | 2176             | 20170           | 50.00         |
| 17                 | 5994        | 312  | 152  | 6458   | 107  | 4217      | 0    | 228   | 7638        | 7387        | -880                 | 17518                 | 0                    | 17518                     | 2145             | 19662           | 50.00         |
| 18                 | 6152        | 260  | 174  | 6586   | 161  | 4234      | 0    | 48    | 6760        | 6665        | -882                 | 16811                 | 0                    | 16811                     | 2152             | 18963           | 50.00         |
| 19                 | 6140        | 490  | 244  | 6874   | 170  | 4414      | 0    | 0     | 6528        | 6252        | -992                 | 16718                 | 0                    | 16718                     | 2255             | 18974           | 49.98         |
| 20                 | 6010        | 270  | 289  | 6570   | 195  | 4453      | 0    | 0     | 6528        | 6189        | -1025                | 16382                 | 0                    | 16382                     | 2267             | 18648           | 50.01         |
| 21                 | 6094        | 110  | 270  | 6474   | 262  | 3817      | 0    | 0     | 6487        | 6196        | -978                 | 15771                 | 0                    | 15771                     | 2202             | 17973           | 49.99         |
| 22                 | 6189        | 108  | 270  | 6568   | 337  | 3512      | 0    | 0     | 5964        | 6045        | -945                 | 15516                 | 0                    | 15516                     | 2076             | 17592           | 50.00         |
| 23                 | 6269        | 104  | 260  | 6632   | 366  | 3428      | 0    | 0     | 5872        | 5369        | -929                 | 14866                 | 0                    | 14866                     | 1923             | 16790           | 49.98         |
| 24                 | 6141        | 164  | 260  | 6564   | 446  | 3396      | 0    | 0     | 5843        | 5324        | -1004                | 14726                 | 0                    | 14726                     | 1799             | 16526           | 49.92         |
| MUs                | 138.60      | 8.90 | 3.46 | 150.96 | 5.18 | 94.37     | 0.00 | 4.59  | 164.12      | 160.71      | -22.09               | 393.71                | 0.00                 | 393.71                    | 47.09            | 440.81          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 09/Jan/2021

Position as on 6.30 Hrs of 10/Jan/2021

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                     | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                      |               |
| MSPGCL                | Koyna STG-IV Unit-2     | 250      | 23/11/2020   | 08.00        |            | Continued. | Capital Overhaul                                                     |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 20/12/2020   | 00.00        |            | Continued. | Annual Overhaul                                                      |               |
| MSPGCL                | Khaparkhedha Unit 5     | 500      | 01/01/2021   | 23.13        |            | Continued. | Annual Overhaul                                                      |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                      |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                              |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                          |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                               |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                        |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                        |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)   |               |
| MSPGCL                | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |            | Continued. | Gas shortage                                                         |               |
| MSPGCL                | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                |               |
| IPP                   | JSW (J) U2              | 300      | 01/11/2020   | 04.44        |            | Continued. | No Schedule                                                          |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | Economizer Tube Leakage. (Zero Schedule from 18:45hrs of 05.12.2020) |               |
| IPP                   | Adani U-4               | 660      | 15/12/2020   | 23.48        |            | Continued. | Zero schedule.                                                       |               |
| IPP                   | Adani U-1               | 660      | 16/12/2020   | 10.58        |            | Continued. | Withdrawal For RSD.                                                  |               |
| IPP                   | Adani U-3               | 660      | 23/12/2020   | 23.59        |            | Continued. | Turbine Bearing Vibration.                                           |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 24/12/2020   | 21.15        | 09/01/2021 | 13.23      | Due to clinker formed inside the bottom ash hopper                   |               |
| MSPGCL                | Paras Unit 3            | 250      | 06/01/2021   | 12.07        | 09/01/2021 | 11.10      | Furnace Pressure High                                                |               |
| MSPGCL                | Koradi Unit 7           | 210      | 08/01/2021   | 09.48        |            | Continued. | Flame Failure                                                        |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 08/01/2021   | 20.43        |            | Continued. | Boiler Tube Leakage                                                  |               |
| MSPGCL                | Uran Unit A0            | 120      | 08/01/2021   | 22.24        | 09/01/2021 | 05.52      | Boiler protection operated.                                          |               |
| MSPGCL                | Uran Unit 6             | 108      | 08/01/2021   | 22.24        | 09/01/2021 | 02.03      | Boiler protection operated.                                          |               |
| MSPGCL                | Uran Unit 5             | 108      | 08/01/2021   | 22.24        | 09/01/2021 | 16.23      | Boiler protection operated.                                          |               |
| AEML                  | AEML Unit 1             | 250      | 09/01/2021   | 00.47        | 10/01/2021 | 19.39      | Boiler License Renewal.                                              |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 09/Jan/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 10/Jan/2021**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                         |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                          |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                                                 |
| Dhule Sar'Sarovar II                              | InterState                | 08/01/2021   | 16.11        |            | Continued. | HT          | Over Voltage                                                                                                                                                             |
| Lonikand 1 - Talegaon(Pgcil)                      | IntraState                | 31/12/2020   | 10.17        |            | Continued. | PO          | 1)Erection of 89A(N+27) & 90A(N+27); 2) loc no. 89A to 90A stringing; 3) loc no. 89A to 82 stringing;4) loc no. 90 to 92 stringing; 5)Dismentaling of old towers 89 & 90 |
| Bhusawal-Aurangabad                               | IntraState                | 08/01/2021   | 17.19        | 09/01/2021 | 09.17      | HT          | Over Voltage                                                                                                                                                             |
| Dhule - Bableshwar - II                           | IntraState                | 08/01/2021   | 22.20        | 09/01/2021 | 09.21      | HT          | Over Voltage                                                                                                                                                             |
| Dhule- Bableshwar - I                             | IntraState                | 09/01/2021   | 19.35        | 10/01/2021 | 10.32      | HT          | Over Voltage                                                                                                                                                             |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 09/01/2021   | 20.50        | 10/01/2021 | 09.48      | HT          | Over Voltage                                                                                                                                                             |
| Kala Kudus Ckt-I                                  | IntraState                | 10/01/2021   | 10.54        | 10/01/2021 | 14.08      | PO          | Annual Maintenance Work                                                                                                                                                  |
| Jejuri- Koynastage-IV                             | IntraState                | 10/01/2021   | 12.55        | 10/01/2021 | 19.24      | PO          | PID Faulty Disc Insulator replacement work                                                                                                                               |
| Chandrapur-Parali III                             | IntraState                | 10/01/2021   | 15.28        |            | Continued. | EO          | CB Safety valve problem(RFC 21.03Hrs)                                                                                                                                    |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 10/01/2021   | 20.01        |            | Continued. | HT          | Over Voltage                                                                                                                                                             |
| Dhule - Bableshwar - II                           | IntraState                | 10/01/2021   | 20.05        |            | Continued. | HT          | Over Voltage                                                                                                                                                             |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                                                                                                 |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                                                                                    |
| 400/220/33 Kv 315 Mva Ict 2 @Dhule                | IntraState                | 23/09/2020   | 09.12        |            | Continued. | PO          | Augmentation work of 400/220 315MVA ICT-II to 501MVA                                                                                                                     |
| 400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2        | IntraState                | 06/01/2021   | 08.30        | 09/01/2021 | 16.47      | PO          | applying high insulation resistance Coating on tertiary side Equipment of 501 MVA,400/220/30KV ICT 2Like 33KV PT,BPI,IPS Tube, LA & Tertiary Bushings.                   |
| 400/220 kv 500 MVA ICT III @ Jejuri               | IntraState                | 08/01/2021   | 19.35        | 09/01/2021 | 04.13      | T           | Differential protection                                                                                                                                                  |
| 400/220 Kv 500 MVA ICT-IV @Kalwa                  | IntraState                | 09/01/2021   | 09.12        | 09/01/2021 | 19.19      | PO          | Testing Work                                                                                                                                                             |
| 400/220 KV 300 MVA ICT- I @Koradi                 | IntraState                | 09/01/2021   | 11.09        | 09/01/2021 | 22.37      | PO          | Testing Work                                                                                                                                                             |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                          |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                                              |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                                                   |
| Solapur(PG)- Jeur                                 | InterState                | 08/01/2021   | 19.36        | 09/01/2021 | 21.44      | EO          | Insulator String replacement.                                                                                                                                            |
| Parli 3 (Old Gcr)-Girwali Ckt-3                   | IntraState                | 20/08/2020   | 13.05        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                                                                                |
| Parli 3(Old Gcr)- Girwali Ckt 4                   | IntraState                | 20/08/2020   | 13.06        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                                                                                |
| Trombay - Kalwa                                   | IntraState                | 16/12/2020   | 06.43        |            | Continued. | PO          | HTLS work.                                                                                                                                                               |
| Loteparshuram- Dasturi Line                       | IntraState                | 05/01/2021   | 10.50        |            | Continued. | T           | Cross arm bent at Loc. no.98,100 & 101.                                                                                                                                  |
| Malegaon-Satana                                   | IntraState                | 09/01/2021   | 00.59        | 09/01/2021 | 16.46      | T           | Insulator Decapping                                                                                                                                                      |
| Padghe - Jambhul 1                                | IntraState                | 09/01/2021   | 08.59        | 09/01/2021 | 19.17      | PO          | Fixing Additional jumper to cut point location                                                                                                                           |
| Halkarni-Mahalaxmi line                           | IntraState                | 09/01/2021   | 09.13        | 09/01/2021 | 17.56      | PO          | Insulator cleaning work                                                                                                                                                  |
| Pirangut - Hinjawadi 2                            | IntraState                | 09/01/2021   | 10.07        | 09/01/2021 | 10.38      | PO          | Removing Bird Nest                                                                                                                                                       |
| Bombay Dyeing - Sahara                            | IntraState                | 09/01/2021   | 16.10        | 09/01/2021 | 18.35      | EO          | Insulator string Replacement Work                                                                                                                                        |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 09/Jan/2021**

**Statement-VII**

Position as on 6.30 Hrs of 10/Jan/2021

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------|
| Chinchwad-Hinjewadi I                         | IntraState                | 09/01/2021   | 16.26        | 09/01/2021 | 19.19      | HT          | Load Management on Urse-Chinchwad               |
| Nagothane - Ipcl                              | IntraState                | 10/01/2021   | 01.03        | 10/01/2021 | 12.50      | T           | Distance Protection                             |
| Parli 3 (Old Gcr)-Girwali Ckt 2               | IntraState                | 10/01/2021   | 06.09        | 10/01/2021 | 11.56      | T           | Distance Protection                             |
| Kalwa-Salsette-IV                             | IntraState                | 10/01/2021   | 06.46        | 10/01/2021 | 09.36      | PO          | Tree Trimming                                   |
| Padghe - Jambhul 1                            | IntraState                | 10/01/2021   | 08.53        | 10/01/2021 | 18.24      | PO          | Fixing of Additional Jumper                     |
| Padghe - Nalasopara                           | IntraState                | 10/01/2021   | 09.38        | 10/01/2021 | 19.08      | PO          | Replacement of R and B Phase Stub Bus Conductor |
| Virur - Gadchiroli                            | IntraState                | 10/01/2021   | 13.05        | 10/01/2021 | 13.19      | T           | Distance Protection                             |
| <b>220 KV ICT Outages/Trippings</b>           |                           |              |              |            |            |             |                                                 |
| 220/22 KV 50MVA T/F-IV @ Mahape               | IntraState                | 09/01/2021   | 09.03        | 09/01/2021 | 11.23      | PO          | Attending Hot Spot                              |
| 220/22 Kv 50 Mva Ptr 1 @Chakan                | IntraState                | 09/01/2021   | 09.28        | 09/01/2021 | 18.11      | HT          | Y-Phase LV CT Burnt Then HV CT HandTripped      |
| 220/100 Kv 100 Mva Vijai Ict 1 @Jambhul       | IntraState                | 09/01/2021   | 09.30        | 09/01/2021 | 19.17      | PO          | Annual Maintenance Work                         |
| 220/132 Kv 200 Mva Vijai Ict 1 @Eklahre (Gcr) | IntraState                | 09/01/2021   | 10.30        | 09/01/2021 | 15.00      | PO          | OLTC Maintenance Work                           |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage