

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Jan/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	139.922	1250.596	1) Gujrat	-7.062	-43.023
2) Hydro	19.038	136.085	2) Madhya Pradesh	1.739	39.396
3) Gas	2.298	36.949	3) Chattisgarh	5.870	55.710
Total MSPGCL	161.258	1423.630	4) Maharashtra	174.397	1637.568
B) 1) APLM	53.560	453.090	5) Goa (Amona)	-1.941	-15.765
2) JSWEL	19.405	178.556	Total	173.003	1673.886
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.297	205.059
4) RPL(AMT)	19.710	168.919	b) Mumbai Drawl	27.123	238.117
5) SWPGPL	5.683	72.629	c) MSEDCL Bilateral *	70.595	713.839
6) Other IPP	46.255	415.581	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.297	205.059
C) 1) TPCL Thermal	12.315	100.487	Include PX	0.000	0.000
2) TPCL Hydro	4.094	30.773	Standby	0.000	0.000
3) TPCL Gas	2.762	22.912	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.482	79.242	1) MSEDCL	466.645	4236.285
D) STATE			2) Mumbai Discoms	55.776	471.531
1) Thermal	306.332	2719.100	3) Other Discoms	9.624	95.458
(A1+C1+C4+(B1-B6))			TOTAL STATE	532.045	4803.274
2) Hydro	23.132	166.858			
(A2+C2)					
3) Gas	5.060	59.861			
(A3+B7+C3)					
4) Wind	9.642	81.282			
6) SOLAR	14.876	102.287			
TOTAL STATE	359.042	3129.388			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6223	6251	6268	4797
MSPGCL Hydro	1483	761	1662	166
MSPGCL Gas	96	92	88	98
MSPGCL Total Generation	7802	7104	8018	5061
Central Sector Receipt	7924	8308	6442	6689
WIND	376	136	201	654
CPP / IPP Thermal	6524	6283	6472	5159
CPP / IPP Gas	0	0	0	0
SOLAR	1904	2127	0	0
Exchange with Mumbai	-1221	-1493	-1093	-1060
MSEDCL DEMAND MET	22894	22040	19596	16155
Load Shedding	0	0	0	0
MSEDCL DEMAND	22894	22040	19596	16155
TPCL GENERATION	1108	795	1234	491
AEML GENERATION	491	501	498	287
MUMBAI DEMAND	2820	2789	2825	1838
OTHER DISCOM DEMAND	415	425	444	348
STATE DEMAND MET	26129	25254	22865	18341
STATE DEMAND	26129	25254	22865	18341
Frequency (Hz)	49.99	49.74	49.90	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 05:02 Hrs	49.41 Hz at 14:45 Hrs	49.93	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.70	44.18	210	160
Unit 7	0.00	0.00	0	0
Unit 8	13.96	120.86	665	469
Unit 9	10.90	20.98	592	22
Unit 10	12.22	113.99	560	470
Total	41.78	300.02		
Bhusawal				
Unit 3	0.00	6.71	0	0
Unit 4	10.58	92.18	500	285
Unit 5	0.00	74.57	0	0
Total	10.58	173.46		
Parli				
Unit 6	2.04	38.91	223	0
Unit 7	0.00	13.70	0	0
Unit 8	3.84	34.91	182	136
Total	5.88	87.53		
Chandrapur				
Unit 3	3.12	29.66	150	115
Unit 4	3.00	15.89	140	114
Unit 5	7.04	52.93	310	270
Unit 6	8.98	77.62	425	292
Unit 7	0.00	0.00	0	0
Unit 8	10.50	96.38	489	277
Unit 9	10.65	97.81	500	314
Total	43.29	370.31		
Paras				
Unit 3	4.47	43.60	226	150
Unit 4	4.76	27.18	222	154
Total	9.23	70.78		
Khaparkheda				
Unit 1	2.80	22.77	140	100
Unit 2	2.91	22.36	139	105
Unit 3	3.66	28.96	180	129
Unit 4	3.19	24.07	144	121
Unit 5	9.58	90.41	450	273
Total	22.14	188.58		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.53	30.16	166	120
Unit 5	3.50	29.76	170	110
Total	7.02	59.92		
Uran				
All Units	2.30	36.95	99	88
Total	2.30	36.95		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.30	3.97	49	0
Total	0.30	3.97		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.36	41.46	565	40
Stage 4	7.45	44.91	750	0
Stage 3	2.94	18.57	320	0
Total	15.75	104.94		
Hydro				
KDPH	0.00	3.13	0	0
VTRNA	0.00	0.04	0	0
TILLARI	0.46	4.24	58	0
BHIRA T.R.	0.20	1.80	40	0
SMLHY_PTN	1.56	12.77	68	61
GHATGHAR	0.76	5.19	125	0
Total	2.99	27.17		
Wind				
Total	9.64	81.28	0	0
Total	9.64	81.28		
CPP				
APML(Mus)	53.56	453.09	0	0
JSWEL(Mus)	19.40	178.56	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.71	168.92	0	0
SWPGPL-Mus	5.68	72.63	0	0
Other(Mus)	46.26	415.58	0	0
Total	144.61	1288.78		
SOLAR				
Total	14.88	102.29	0	0
Total	14.88	102.29		
Tata				
Trombay 5	8.17	66.62	451	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.60	13.08	107	43
Trombay 7B	1.16	9.83	65	39
TATA Hydro	4.09	30.77	394	4
Trombay 8	4.14	33.86	239	130
Total	19.17	154.17		
AEML				
DTPS U-1&2	9.48	79.24	501	285
Total	9.48	79.24		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	139.92	1250.60	MSPGCL Total	161.26	1423.63
			MSPGCL Thml+Gas	142.22	1287.54	Koyna 1,2 & 4 Total	12.81	86.37
			MSPGCL Hydro	19.04	136.08	State Total	359.04	3129.39

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4797	166	98	5061	654	5159	0	0	7165	6689	-1060	16155	0	16155	1838	348	18341	49.99
2	4626	164	99	4889	681	5200	0	0	7199	6923	-935	16432	0	16432	1715	326	18473	50.00
3	4524	165	98	4787	740	5090	0	0	7044	6992	-838	16456	0	16456	1639	315	18410	50.00
4	4872	141	98	5111	736	5094	0	0	6942	6968	-809	16781	0	16781	1591	319	18691	50.08
5	5390	106	99	5595	606	5214	0	0	7064	6943	-826	17196	0	17196	1603	336	19135	50.04
6	5707	122	98	5927	519	5576	0	0	7357	7346	-950	18050	0	18050	1736	368	20154	49.97
7	5964	621	98	6683	478	6208	0	0	7249	7414	-1033	19364	0	19364	1932	386	21682	49.88
8	6151	1462	99	7712	477	6551	0	190	6957	7163	-882	20804	0	20804	2116	407	23327	49.99
9	6199	1361	99	7659	434	6539	0	840	6956	7206	-976	21293	0	21293	2415	409	24117	50.04
10	6174	1392	97	7663	408	6500	0	1488	7421	7648	-1126	22169	0	22169	2714	412	25295	49.99
11	6223	1483	96	7802	376	6524	0	1904	7858	7924	-1221	22894	0	22894	2820	415	26129	49.99
12	6215	1027	95	7337	226	6495	0	2094	8317	8357	-1468	22611	0	22611	2830	430	25871	49.77
13	6251	761	92	7104	136	6283	0	2127	8355	8308	-1493	22040	0	22040	2789	425	25254	49.74
14	6266	367	91	6724	107	6083	0	2064	8598	8869	-1614	21840	0	21840	2623	393	24856	49.78
15	6215	653	91	6959	93	6344	0	1829	8615	8438	-1657	21604	0	21604	2648	402	24654	49.58
16	6335	1326	91	7752	85	6394	0	1406	7939	7924	-1454	21673	0	21673	2669	434	24776	49.71
17	6319	1599	95	8013	90	6413	0	783	6938	7033	-1137	20742	0	20742	2776	453	23971	49.92
18	6264	1727	96	8087	138	6397	0	151	6445	6640	-1078	19877	0	19877	2812	458	23147	49.89
19	6268	1662	88	8018	201	6472	0	0	6327	6442	-1093	19596	0	19596	2825	444	22865	49.90
20	6194	1698	93	7985	280	6491	0	0	6205	6221	-1048	19473	0	19473	2776	456	22705	50.00
21	6117	520	96	6733	411	6454	0	0	6217	5986	-989	18147	0	18147	2572	448	21167	50.01
22	5972	190	97	6259	493	5962	0	0	6513	6415	-1044	17643	0	17643	2260	442	20345	50.05
23	5721	161	97	5979	634	5729	0	0	6631	6497	-1216	17212	0	17212	2107	411	19730	50.02
24	5158	164	97	5419	639	5441	0	0	6805	6657	-1176	16593	0	16593	1970	387	18950	49.97
MUs	139.92	19.04	2.30	161.26	9.64	144.61	0.00	14.88	173.12	173.00	-27.12	466.64	0.00	466.64	55.78	9.62	532.05	49.93

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Jan/2023

Position as on 6.30 Hrs of 10/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
IPP	JSW (J) U4	300	04/01/2023	23:45		Continued.	NO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	13/01/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	12/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
IPP	RPL(AMT) U-3	270	25/12/2022	17:45		Continued.	Bottom Ash evacuation problem	12/01/2023
IPP	SWPGPL U-4	135	28/12/2022	00:00		Continued.	BOTTOM ASH EVACUATION PROBLEM	12/01/2023
MSPGCL	Koradi Unit 9	660	01/01/2023	20:49	09/01/2023	00:29	Boiler Tube Leakage	09/01/2023
IPP	RPL(AMT) U-4	270	05/01/2023	00:00	09/01/2023	20:06	BOTTOM ASH PROBLEM. Now SYNchronised.	09/01/2023
MSPGCL	Bhusawal Unit 3	210	07/01/2023	12:47		Continued.	Boiler Tube Leakage	
IPP	SWPGPL U-1	135	08/01/2023	12:25	09/01/2023	17:49	PA Fan problem	
MSPGCL	Uran Unit B0	120	08/01/2023	14:25	10/01/2023	04:43	Gas shortage	
MSPGCL	Uran Unit 8	108	08/01/2023	14:25	10/01/2023	01:42	Gas shortage	
MSPGCL	Koyna Unit 10	80	08/01/2023	18:40	09/01/2023	10:50	Generator excitation problem	
MSPGCL	Bhusawal Unit 5	500	08/01/2023	19:14		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Jan/2023

Position as on 6.30 Hrs of 10/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 6	250	09/01/2023	01:38	09/01/2023	06:58	Furnace Pressure High	09/01/2023
MSPGCL	Koyna Unit 12	80	09/01/2023	06:30	09/01/2023	10:05	GOVENER RECEIVER OIL LEVEL PRESURE LOW	
MSPGCL	Parli Unit 6	250	09/01/2023	10:47		Continued.	Furnace Pressure High	12/01/2023
MSPGCL	Nasik Unit 5	210	10/01/2023	00:35	10/01/2023	07:38	Suspected seal oil system problem.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
MAIN BUS - 1 @ AKOLA 2	IntraState	09/01/2023	10:26	09/01/2023	18:38	PO	Annual maintenance of Bus-1 Equipments
765 KV BR Outages/Trippings							
706 Bus reactor @ Koradi - 3	IntraState	06/01/2023	10:59			PO	For Reactor changeover Activity as per CEA guideline B- Ph reactor taken into service in place of Spare Reactor.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (406) OF KORADI 3 CKT - 2 @ KORADI 2	IntraState	09/01/2023	11:17	09/01/2023	17:30	PO	Diagnostic Testing of CB and routine bay maintenance work
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
DHULE - KHANDWA CKT - 2	InterState	09/01/2023	11:12	09/01/2023	21:16	PO	Line Isolator arm retrofitting work and line amp works.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
JAIGAD - KARAD CKT - 1	IntraState	08/01/2023	23:26	09/01/2023	09:50	HT	H/T due to Over Voltage.
KHADKA- DEEPNAGAR CKT 2	IntraState	09/01/2023	08:32	09/01/2023	16:23	PO	for chemical washing of disc insulator in premises of deepnagar power plant
TBC @ PARLI	IntraState	09/01/2023	10:55	09/01/2023	16:36	PO	(1) Breaker testing work. (2) Bay maintenance work.
LONIKAND - JEJURI CKT - 1	IntraState	09/01/2023	13:40			PO	O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box.
JAIGAD - KARAD CKT - 2	IntraState	10/01/2023	00:18			HT	H/T Due to Over Voltage.
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	09/01/2023	12:12	09/01/2023	19:50	PO	Regular Maint work and Dignostic testing work
220 KV MAINBAY Outages/Trippings							
MAIN BUS @ NIWALI	IntraState	09/01/2023	10:18	09/01/2023	17:29	PO	Outage required in 220kV Main bus section-2 in which 220kV Niwali-Pawas line bay & 220/110kV, 100MVA ICT-1 is present. 220/110kV, 100MVA ICT 2 stub bus jumpering work(stub bus work location is above 220kV Main bus).
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
POPHALI - KDPH	IntraState	07/01/2023	10:32			PO	For Erection & stringing of In-line Multi circuit towers (Loc. No. 1 to 7) of new 220 KV Karad ꞑ Koyna line and restringing of existing 220 KV D/C KDPH LILO line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
WARDHA (PG) - BADNERA	IntraState	09/01/2023	08:40	09/01/2023	18:27	PO	1. For Replacement of Flashover Discs. 2. For Diagnostic Testing of Line Bay
TROMBAY - KALWA	IntraState	09/01/2023	09:23	09/01/2023	18:46	PO	For diagnostic testing of equipments & Bay maintenance work
MUDSHINGI - CHIKODI	IntraState	09/01/2023	09:42	09/01/2023	21:10	PO	For reconductoring of 400kV Kolhapur-Kolhapur ckt.-1 Moose conductor with HTLS conductor for sytem improvement by PGCIL, Kolhpaur. 400kV line crosses 220kV Mudshingi- Chikodi line at loc no. 266-267. For safety during work, outage is required on 220 KV Mudshingi-Chikodi line.
TALANDAGE - CHIKODI	IntraState	09/01/2023	09:44	09/01/2023	21:27	PO	For reconductoring of 400kV Kolhapur-Kolhapur ckt.-1 Moose conductor with HTLS conductor for sytem improvement by PGCIL, Kolhpaur. 400kV line crosses 220kV Talandge- Chikodi line at loc no. 266-267. For safety during work, outage is required on 220 KV Talandge-Chikodi line.
TALANDGE - ICHALKARANJI 1	IntraState	09/01/2023	09:50	09/01/2023	18:47	PO	For replacement of faulty insulator string found critical in P.I.D & Tightening of cut point jumperings.
ALKUD - VITA	IntraState	09/01/2023	12:11	09/01/2023	12:20	PO	Quarterly Maintenance Work & attending DC leakage from CR Panel.
PADGHE - TEMGHAR - 1	IntraState	09/01/2023	22:35	10/01/2023	01:03	EO	For attending Y-ph CT Oil leakage.
TILLARI - AMONA LINE	IntraState	09/01/2023	23:13	09/01/2023	23:51	T	A/R SUCCESSFUL ONLY AT TILLARI END. TRIPPED ONLY AT AMONA END
CHINCHWAD-2 - TELCO	IntraState	09/01/2023	23:43	10/01/2023	03:34	PO	1) Reconnection of jumpers at loc 14 & 25 on 220 kV Chinchwad-Chakan line 2) Removal of Jumpers at Loc 14 & 25 on 220 kV Chinchwad Telco Line so as to make portion from loc 14 to 25 in dead condition for balance stringing work for railway overbridge project by PCMC
CHAKAN - CHINCHWAD 2	IntraState	09/01/2023	23:46	10/01/2023	03:32	PO	1) Reconnection of jumpers at loc 14 & 25 on 220 kV Chinchwad-Chakan line 2) Removal of Jumpers at Loc 14 & 25 on 220 kV Chinchwad Telco Line so as to make portion from loc 14 to 25 in dead condition for balance stringing work for railway overbridge project by PCMC
DAHANU - VERSOVA	IntraState	10/01/2023	05:57			PO	DFCCIL PROJECT WORK-SHIFTING OF EXISTING LINES ON NEWELY CONSTRUCTED TOWER AT SS 234-235 & SS 230-231
MALEGAON-SATANA	IntraState	10/01/2023	06:25			HT	H/T TO CONTROL LINE LOADING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/110 KV 100 MVA PTR 3	IntraState	09/01/2023	10:18	09/01/2023	17:29	PO	Testing work.
110 KV LINE Outages/Trippings							
BHIRA (T) - DAVDI	IntraState	09/01/2023	08:11	09/01/2023	22:30	EO	Painting work in vicinity

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage