

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Feb/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	149.519	1331.497	1) Gujrat	-8.337	-80.011
2) Hydro	18.824	122.334	2) Madhya Pradesh	5.596	55.181
3) Gas	7.160	63.906	3) Chattisgarh	6.720	59.170
Total MSPGCL	175.503	1517.737	4) Maharashtra	136.429	1257.495
B) 1) APLM	68.030	619.882	5) Goa (Amona)	-1.548	-13.924
2) JSWEL	14.670	129.178	Total	138.860	1277.911
3) VIPL	0.000	0.000	a) Mumbai Schedule	18.579	159.269
4) RPL(AMT)	28.515	249.838	b) Mumbai Drawl	20.432	187.555
5) SWPGPL	8.054	72.594			
6) Other IPP	39.327	358.666	c) MSEDCL Bilateral *	66.902	603.803
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	10.538	78.735	d) Mumbai Bilateral *	18.579	159.049
2) TPCL Hydro	3.994	34.767	Include PX	0.000	0.000
3) TPCL Gas	3.478	28.750	Standby	0.000	0.220
4) AEML Thermal	9.376	90.026			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	328.029	2930.416	1) MSEDCL	459.656	4118.707
2) Hydro (A2+C2)	22.818	157.101	2) Mumbai Discoms	47.818	419.832
3) Gas (A3+B7+C3)	10.638	92.656	3) Other Discoms	10.009	89.114
4) Wind	8.602	91.627			
6) SOLAR	8.536	77.943	TOTAL STATE	517.483	4627.653
TOTAL STATE	378.623	3349.743			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6250	5981	6664	5916
MSPGCL Hydro	1519	1418	716	244
MSPGCL Gas	289	287	299	302
MSPGCL Total Generation	8058	7686	7679	6462
Central Sector Receipt	6969	7137	5536	5091
WIND	140	167	308	709
CPP / IPP Thermal	6647	6269	7046	5727
CPP / IPP Gas	0	0	0	0
SOLAR	1225	1252	0	0
Exchange with Mumbai	-904	-1262	-847	-718
MSEDCL DEMAND MET	21896	21018	19463	17048
Load Shedding	0	0	0	0
MSEDCL DEMAND	21896	21018	19463	17048
TPCL GENERATION	1120	817	1001	507
AEML GENERATION	492	335	474	314
MUMBAI DEMAND	2516	2414	2322	1539
OTHER DISCOM DEMAND	367	350	390	306
STATE DEMAND MET	24779	23782	22175	18893
STATE DEMAND	24779	23782	22175	18893
Frequency (Hz)	50.07	50.03	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 06:02 Hrs	49.84 Hz at 10:31 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Feb/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.67	31.78	170	120
Unit 7	0.00	0.00	0	0
Unit 8	13.51	124.62	609	510
Unit 9	12.98	119.11	570	426
Unit 10	11.90	112.96	516	475
Total	42.06	388.47		
Bhusawal				
Unit 3	3.04	28.89	150	110
Unit 4	0.00	0.00	0	0
Unit 5	9.52	86.00	440	285
Total	12.56	114.88		
Parli				
Unit 6	3.83	35.70	184	147
Unit 7	3.78	35.65	184	140
Unit 8	3.70	33.60	182	143
Total	11.32	104.96		
Chandrapur				
Unit 3	3.24	6.98	150	124
Unit 4	0.66	0.66	111	0
Unit 5	6.93	72.31	370	215
Unit 6	7.52	69.92	340	275
Unit 7	8.53	72.45	420	284
Unit 8	10.51	92.48	460	415
Unit 9	10.61	90.56	457	421
Total	47.99	405.35		
Paras				
Unit 3	4.16	40.81	249	135
Unit 4	4.07	39.12	228	142
Total	8.23	79.93		
Khaparkheda				
Unit 1	3.11	28.99	150	115
Unit 2	0.00	0.00	0	0
Unit 3	3.69	34.36	196	128
Unit 4	3.63	25.81	190	125
Unit 5	10.65	95.50	465	420
Total	21.08	184.66		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.20	29.61	170	119
Unit 5	3.08	23.63	164	116
Total	6.28	53.24		
Uran				
All Units	7.16	63.91	323	276
Total	7.16	63.91		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	1.32	24	0
Total	0.15	1.32		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.50	22.52	270	35
Stage 4	8.13	22.95	1005	0
Stage 3	1.99	10.04	240	0
Total	11.62	55.51		
Hydro				
KDPH	0.86	5.60	36	36
VTRNA	0.77	6.62	60	0
TILLARI	0.52	4.64	58	0
BHIRA T.R.	0.20	1.98	80	0
SMLHY_PTN	4.47	42.94	227	161
GHATGHAR	0.38	5.04	125	0
Total	7.20	66.83		
Wind				
Total	8.60	91.63	0	0
Total	8.60	91.63		
CPP				
APML(Mus)	68.03	619.88	0	0
JSWEL(Mus)	14.67	129.18	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	28.52	249.84	0	0
SWPGPL-Mus	8.05	72.59	0	0
Other(Mus)	39.33	358.67	0	0
Total	158.60	1430.16		
SOLAR				
Total	8.54	77.94	0	0
Total	8.54	77.94		
Tata				
Trombay 5	6.88	45.56	477	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.09	17.11	116	63
Trombay 7B	1.39	11.64	67	50
TATA Hydro	3.99	34.77	386	0
Trombay 8	3.66	33.17	220	130
Total	18.01	142.25		
AEMIL				
DTPS U-1&2	9.38	90.03	498	297
Total	9.38	90.03		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	149.52	1331.50	MSPGCL Total	175.50	1517.74
			MSPGCL Thml+Gas	156.68	1395.40	Koyna 1,2 & 4 Total	9.63	45.47
			MSPGCL Hydro	18.82	122.33	State Total	378.62	3349.74

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Feb/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5916	244	302	6462	709	5810	0	0	5268	5091	-718	17048	0	17048	1539	306	18893	49.99
2	5932	253	313	6498	694	5864	0	0	5338	5445	-620	17593	0	17593	1442	288	19323	49.98
3	6052	244	303	6599	732	6368	0	0	5267	4919	-567	17782	0	17782	1380	269	19431	50.00
4	6027	250	303	6580	646	6538	0	0	5234	4908	-540	17858	0	17858	1347	274	19479	50.02
5	6191	247	293	6731	521	6592	0	0	5224	5119	-540	18138	0	18138	1355	285	19778	50.04
6	6518	249	323	7090	485	6935	0	0	5280	5393	-631	18961	0	18961	1476	311	20748	50.04
7	6713	849	293	7855	475	6969	0	3	5527	4934	-629	19263	0	19263	1654	344	21261	50.05
8	6722	909	323	7954	384	7062	0	120	5479	4547	-534	19172	0	19172	1864	361	21397	50.00
9	6623	561	293	7477	286	7030	0	423	5965	5519	-761	19605	0	19605	2143	369	22117	50.01
10	6248	844	311	7403	232	6886	0	815	6676	6019	-782	20200	0	20200	2364	373	22937	50.02
11	6155	1175	300	7630	218	6529	0	1038	7222	7176	-789	21434	0	21434	2522	368	24324	50.02
12	6250	1519	289	8058	140	6775	0	1225	7279	6969	-904	21896	0	21896	2516	367	24779	50.07
13	5981	1418	287	7686	167	6388	0	1252	7332	7137	-1262	21018	0	21018	2414	350	23782	50.03
14	5824	1581	276	7681	182	5943	0	1200	7034	7420	-1254	20823	0	20823	2292	349	23464	50.03
15	5813	1650	297	7760	222	6046	0	1038	7279	7400	-1259	20860	0	20860	2269	347	23476	49.97
16	5944	1857	297	8098	213	6368	0	803	7072	6825	-1251	20707	0	20707	2266	349	23322	50.01
17	6433	1328	277	8038	199	6944	0	480	6497	6291	-1196	20387	0	20387	2276	369	23032	50.02
18	6582	774	298	7654	196	7167	0	138	6074	5818	-965	19614	0	19614	2292	394	22300	50.02
19	6350	866	279	7495	270	7042	0	1	5808	5843	-888	19368	0	19368	2312	395	22075	50.03
20	6664	716	299	7679	308	7177	0	0	5560	5536	-847	19463	0	19463	2322	390	22175	50.03
21	6454	370	300	7124	312	6957	0	0	5221	4885	-855	18029	0	18029	2201	394	20624	50.01
22	6114	333	290	6737	351	6569	0	0	5444	5304	-919	17670	0	17670	2028	372	20070	50.02
23	5988	313	312	6613	294	6327	0	0	5476	5311	-931	17249	0	17249	1857	365	19471	50.01
24	6025	274	302	6601	366	6310	0	0	5365	5051	-790	17196	0	17196	1687	342	19225	50.01
MUs	149.52	18.82	7.16	175.50	8.60	158.60	0.00	8.54	143.92	138.86	-20.43	461.33	0.00	461.33	47.82	8.33	517.48	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Feb/2022

Position as on 6.30 Hrs of 10/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49	10/02/2022	03:55	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
MSPGCL	Chandrapur Unit 4	210	18/01/2022	23:47	09/02/2022	15:37	Coal Shortage	09/02/2022
MSPGCL	Uran Unit 5	108	03/02/2022	16:54		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 10/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV TBC Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	09/02/2022	22:36	10/02/2022	03:25	EO	for urgent attending hotspot of temprature 240 deg and hotspot having temprature in between 100 -150 deg.
400 KV TIEBAY Outages/Trippings							
TIE BAY (412) OF BABHALESHWAR CKT - 1 @ EKTUNI	IntraState	10/02/2022	11:00	10/02/2022	17:01	PO	"Daignostic Testing & Routine Maintainence "
400 KV LR Outages/Trippings							
400KV Parli- LONIKAND ii 2 (Lonikand II end)	IntraState	09/02/2022	05:24	09/02/2022	15:42	T	tripped to heavy fog
400KV Parli- LONIKAND-II 1 (LONIKAND-II end)	IntraState	09/02/2022	05:52	09/02/2022	14:57	T	tripped due heavy fog
400 KV LINE Outages/Trippings							
CHAKAN - TALEGAON(PG)	InterState	09/02/2022	03:39	09/02/2022	12:04	T	Chakan end-Zone-1 B-ph 6.5 Km, 8.6 KA Talegaon end 9.2 Km B-ph 14.03 KA
SOLAPUR PG - ALKUD	InterState	09/02/2022	15:48	09/02/2022	21:22	T	Tripping due to isolator problem at PG end
DHULE - SSNNL CKT - 2	InterState	10/02/2022	12:49	10/02/2022	17:55	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
PARLI(MS) - PARLI (PG) CKT -2	InterState	10/02/2022	14:52	10/02/2022	18:24	HT	Hotspot in Line Isolator at Parli PG end
THAPTI TANDA - WALUJ	IntraState	01/02/2022	13:01			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
DEEPNAGAR - THAPTI TANDA	IntraState	01/02/2022	13:11			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	04/02/2022	14:43			HT	H/T TO CONTROL 400KV TALEGAON PG -CHAKAN LINE LOADING.
LONIKAND I - CHAKAN	IntraState	09/02/2022	04:31	09/02/2022	15:42	T	Distance Protection
KARAD - LONIKAND I	IntraState	09/02/2022	06:02	09/02/2022	18:10	T	Tripped on Distance Protection
PADGHE - NAGOTHANE CKT - 2	IntraState	10/02/2022	11:06			EO	Attending problem of R & Y ph A bus PG isolator . Yph A bus PG isolator Rotary found broken , hence Hot line work for opening of Isolator .
PADGHE - NAGOTHANE CKT - 2	IntraState	10/02/2022	11:06	10/02/2022	17:32	HT	Isolator Problem at Padghe end
PARLI-SOLAPUR (LAMBOTI)	IntraState	10/02/2022	14:12	10/02/2022	18:07	PO	Hardware Tightening & Fitting work
400 KV ICT Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 09/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 10/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/11KV STN-4B @ DEEPNAGAR	IntraState	03/02/2022	12:57			PO	Oil Filtration and other allied works of STN - 4B at 2 x 500MW , BTPS, Deepnagar, MSPGCL
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	10/02/2022	09:18	10/02/2022	19:21	PO	33kV BPI excavation work associated with rapid restoration scheme near 33KV Side of ICT1.
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	10/02/2022	09:56	10/02/2022	15:28	PO	For REF & Backup Relay Testing
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	10/02/2022	12:08	10/02/2022	21:08	PO	Half yearly DT & Maintenance
400 KV BR Outages/Tripping							
BUS REACTOR AT 400 KV KORADI S/S	IntraState	10/02/2022	10:39	10/02/2022	18:34	PO	retrofitting of bus reactor trip Relay under MTAMC project
220 KV TIEBAY Outages/Tripping							
BUS SECTION BREAKER @ SHIRSUPHAL	IntraState	09/02/2022	10:00	09/02/2022	13:00	PO	Diagnostic testing work
220 KV LINE Outages/Tripping							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	CABLE FAULT
BOISAR II - BOISAR (PG) CKT - 1	IntraState	02/02/2022	10:47	09/02/2022	09:27	PO	Replacement of existing 0.4ACSR Zebra Conductor of BSR-PGCIL line no. 01 at loc. No. 07-08, 06-07, 05-06, 04-05, 03-04, 02-03, 01-02, 01-Boisar Gantry
GHODBUNDER - MSETCL BOISAR	IntraState	04/02/2022	13:40			T	TRIPPED ON DIST.PROTN.
KARAD - VITA CKT- 1	IntraState	07/02/2022	08:36			PO	For tower erection of Loc.no.23-24 and stringing work between Loc.no.22-23-24-25 in respect of modification of EHV lines crossing Pune � Miraj Railway electrification work
KARAD - VITA CKT- 2	IntraState	07/02/2022	08:40			PO	For tower erection of Loc.no.23-24 and stringing work between Loc.no.22-23-24-25 in respect of modification of EHV lines crossing Pune � Miraj Railway electrification work
TAMBATI - ADLABS	IntraState	08/02/2022	10:32			PO	CB Pole overhauling work by agency and attending B ph CT oil leakage at 220KV Tambati substation end and attending Y ph CT oil leakage at 220KV Adlab substation
URSE - TALEGAON (AMBI) CKT 1	IntraState	08/02/2022	20:44	09/02/2022	11:24	T	loc no 4 R ph decapping
CHAKAN - CHINCHWAD 2	IntraState	09/02/2022	01:22	09/02/2022	01:45	T	Tripped from Chinchwad end only
CHAKAN - CHINCHWAD 2	IntraState	09/02/2022	03:11	09/02/2022	15:10	T	AR success at Chakan end but PDR operated at Chinchwad Phase-2
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/02/2022	04:21	09/02/2022	04:27	T	AR Success from Eklahre GCR end
URSE-CHINCHWAD	IntraState	09/02/2022	05:17	09/02/2022	05:17	T	AR Success at both end, z-2, z-3 , y-Ph, d-15 KM
BOISAR II - BOISAR (PG) CKT - 1	IntraState	09/02/2022	09:35	09/02/2022	17:40	HT	Abnormal sound in R ph CC at boisar M end
CHAKAN-BHOSARI 1	IntraState	09/02/2022	12:17	09/02/2022	18:37	T	Y PH,Z-1,6.56 KM
URSE - TALEGAON (AMBI) CKT 1	IntraState	09/02/2022	12:22	09/02/2022	17:06	T	Y PH,Z-1,SOTF,3.11 KM,5.62 KA
URSE-CHINCHWAD	IntraState	09/02/2022	19:55	09/02/2022	22:44	EO	For replacement of F/O string at loc.13(R,Y-ph)
HINJAWADI I- CHINCHWAD	IntraState	10/02/2022	11:44	10/02/2022	21:18	PO	220KV Bus post insulator replacement work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 10/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BHOSARI- BHOSARI 2	IntraState	10/02/2022	11:57	10/02/2022	20:11	PO	Due to high Tan delta values of CT replacement work as per LE Scheme
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	10/02/2022	12:07	10/02/2022	19:10	PO	UNLOADING 220 KV GIS BAYS IN VICINITY
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	28/01/2022	12:10			PO	Dismantling of bus post insulator jump of 220kV Main bus by hot line unit for erection of new bus post isolator
220/22 KV 50 MVA PTR 3 @ MAHAPE	IntraState	09/02/2022	12:01	09/02/2022	17:23	EO	To attend HV Breaker mechanism stuck up issue & overhauling of Areva Make GL 314 work by agency.
220/100 KV 200 MVA ICT 2 @ PAL- DOMBIVALI	IntraState	09/02/2022	14:06	09/02/2022	19:41	PO	Carrying out IR test of CFT point of ICT.
220/22 KV 50 MVA PTR 3 @ MAHAPE	IntraState	10/02/2022	09:39	10/02/2022	16:22	PO	HV Breaker mechanism overhauling of Areva Make GL 314 work by agency.
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	10/02/2022	10:11	10/02/2022	19:54	PO	For Attending oil leakage by Goodwill agency and commissioning of REC670 relay by testing unit.
220/33 KV 50 MVA 1 PTR @ SHIRSUPHAL	IntraState	10/02/2022	10:35	10/02/2022	14:01	PO	DIAGNOSTIC TESTING WORK
220/33 KV 50 MVA 2 PTR @ SHIRSUPHAL	IntraState	10/02/2022	14:50	10/02/2022	17:16	PO	DIAGNOSTIC TESTING WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage