

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Feb/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.184	1357.321	1) Gujrat	-4.179	-57.113
2) Hydro	18.934	106.621	2) Madhya Pradesh	5.533	48.136
3) Gas	5.153	47.603	3) Chattisgarh	4.410	41.500
Total MSPGCL	179.271	1511.545	4) Maharashtra	176.673	1607.858
B) 1) APLM	75.986	639.309	5) Goa (Amona)	-1.059	-13.776
2) JSWEL	18.915	161.121	Total	181.378	1626.605
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.520	274.172
4) RPL(AMT)	25.614	265.373	b) Mumbai Drawl	36.128	315.211
5) SWPGPL	7.338	81.890	c) MSEDCL Bilateral *	71.377	648.848
6) Other IPP	41.127	392.694	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.436	273.925
C) 1) TPCL Thermal	4.101	35.482	Include PX	0.000	0.000
2) TPCL Hydro	5.397	40.926	Standby	0.084	0.247
3) TPCL Gas	2.341	19.810	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.599	86.979	1) MSEDCL	505.709	4489.635
D) STATE			2) Mumbai Discoms	57.566	498.408
1) Thermal	337.864	3020.169	3) Other Discoms	10.091	89.503
(A1+C1+C4+(B1-B6))			TOTAL STATE	573.366	5077.546
2) Hydro (A2+C2)	24.331	147.547			
3) Gas (A3+B7+C3)	7.494	67.413			
4) Wind	6.507	81.905			
6) SOLAR	15.792	133.907			
TOTAL STATE	391.988	3450.941			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6566	6590	6584	6281
MSPGCL Hydro	1470	686	1695	235
MSPGCL Gas	231	220	224	70
MSPGCL Total Generation	8267	7496	8503	6586
Central Sector Receipt	9202	8511	7017	6273
WIND	154	72	279	508
CPP / IPP Thermal	7094	6979	7055	7022
CPP / IPP Gas	0	0	0	0
SOLAR	1954	2164	0	0
Exchange with Mumbai	-1803	-1904	-1398	-1379
MSEDCL DEMAND MET	24410	22875	21002	18624
Load Shedding	0	0	0	0
MSEDCL DEMAND	24410	22875	21002	18624
TPCL GENERATION	621	521	818	234
AEML GENERATION	497	500	478	336
MUMBAI DEMAND	2921	2925	2694	1949
OTHER DISCOM DEMAND	458	443	454	386
STATE DEMAND MET	27789	26243	24150	20959
STATE DEMAND	27789	26243	24150	20959
Frequency (Hz)	49.99	49.92	50.06	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.36 Hz at 17.03 Hrs	49.51 Hz at 11.46 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.88	43.40	215	165
Unit 8	13.90	123.20	618	542
Unit 9	13.36	121.85	617	500
Unit 10	13.20	102.51	596	515
Total	45.34	390.95		
Bhusawal				
Unit 3	3.38	28.75	160	120
Unit 4	10.64	90.70	475	400
Unit 5	10.70	88.40	470	410
Total	24.72	207.85		
Parli				
Unit 6	4.77	39.66	239	125
Unit 7	2.79	22.38	166	0
Unit 8	3.89	34.28	186	132
Total	11.44	96.32		
Chandrapur				
Unit 3	3.71	30.72	166	130
Unit 4	2.91	26.71	131	116
Unit 5	6.98	62.52	305	280
Unit 6	9.23	74.95	420	290
Unit 7	0.00	0.00	0	0
Unit 8	11.85	98.86	500	477
Unit 9	0.00	24.01	0	0
Total	34.67	317.77		
Paras				
Unit 3	5.27	41.88	231	208
Unit 4	5.81	51.08	250	232
Total	11.08	92.96		
Khaparkheda				
Unit 1	2.36	23.40	125	80
Unit 2	2.93	23.77	135	103
Unit 3	4.08	32.14	182	137
Unit 4	0.00	22.38	0	0
Unit 5	11.04	94.14	480	425
Total	20.41	195.83		
Nasik				
Unit 3	3.81	32.47	176	122
Unit 4	0.00	2.54	0	0
Unit 5	3.71	20.63	173	114
Total	7.53	55.64		
Uran				
All Units	5.15	47.60	240	70
Total	5.15	47.60		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.79	5.47	43	22
Total	0.79	5.47		
Koyna				
Stage 1-2	4.61	26.62	495	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.35	21.40	750	0
Stage 3	2.37	10.60	320	0
Total	13.33	58.61		
Hydro				
KDPH	0.86	6.20	36	36
VTRNA	0.47	4.25	61	0
TILLARI	0.46	3.02	58	0
BHIRA T.R.	0.32	2.54	80	0
SMLHY_PTN	2.70	21.90	116	104
GHATGHAR	0.00	4.64	0	0
Total	4.82	42.54		
Wind				
Total	6.51	81.90	0	0
Total	6.51	81.90		
CPP				
APML(Mus)	75.99	639.31	0	0
JSWEL(Mus)	18.92	161.12	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.61	265.37	0	0
SWPGPL-Mus	7.34	81.89	0	0
Dhariwal	0.00	18.40	0	0
IEPL	5.10	43.34	263	195
Other(Mus)	36.03	330.96	0	0
Total	168.98	1540.39		
SOLAR				
Total	15.79	133.91	0	0
Total	15.79	133.91		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.30	10.92	95	35
Trombay 7B	1.05	8.89	61	33
TATA Hydro	5.40	40.93	442	2
Trombay 8	4.10	35.48	235	131
Total	11.84	96.22		
AEML				
DTPS U-1&2	9.60	86.98	500	316
Total	9.60	86.98		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	155.18	1357.32	MSPGCL Total	179.27	1511.54
			MSPGCL Thml+Gas	160.34	1404.92	Koyna 1,2 & 4 Total	10.96	48.01
			MSPGCL Hydro	18.93	106.62	State Total	391.99	3450.94

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6281	235	70	6586	508	7022	0	0	6628	6273	-1379	18624	0	18624	1949	386	20959	49.99
2	6327	235	92	6654	503	7004	0	0	6713	6559	-1235	19126	0	19126	1809	359	21294	50.02
3	6339	217	198	6754	538	7016	0	0	6803	6247	-1152	19072	0	19072	1718	331	21121	50.01
4	6287	216	229	6732	522	7014	0	0	6709	6422	-1105	19259	0	19259	1663	326	21248	50.02
5	6453	213	233	6899	531	6977	0	0	6867	7120	-1111	20070	0	20070	1678	346	22094	50.09
6	6587	643	235	7465	499	7159	0	0	7075	6742	-1224	20270	0	20270	1809	371	22450	50.04
7	6473	1584	233	8290	481	7170	0	1	6644	6990	-1102	21427	0	21427	1983	403	23813	49.94
8	6468	1655	240	8363	373	7189	0	261	7613	7757	-1129	22380	0	22380	2175	434	24989	49.99
9	6519	1458	239	8216	262	7200	0	881	8023	8008	-1416	22694	0	22694	2458	457	25609	50.06
10	6504	1588	237	8329	198	7100	0	1493	8318	8527	-1534	23674	0	23674	2721	439	26834	50.01
11	6566	1470	231	8267	154	7094	0	1954	8977	9202	-1803	24410	0	24410	2921	458	27789	49.99
12	6530	1018	225	7773	104	7036	0	2120	9320	9269	-1879	23982	0	23982	2948	441	27371	49.95
13	6590	686	220	7496	72	6979	0	2164	8180	8511	-1904	22875	0	22875	2925	443	26243	49.92
14	6323	948	219	7490	73	6849	0	2124	7699	8346	-1734	22726	0	22726	2812	422	25960	50.10
15	6599	902	220	7721	80	6945	0	1965	7915	8262	-1899	22632	0	22632	2854	442	25928	50.01
16	6661	687	217	7565	72	6991	0	1536	8502	8773	-1878	22604	0	22604	2867	455	25926	50.00
17	6615	453	214	7282	75	6991	0	966	9129	8728	-1875	21696	0	21696	2818	471	24985	50.00
18	6611	542	221	7374	120	7029	0	314	8300	8029	-1768	20607	0	20607	2761	491	23859	50.08
19	6583	1306	224	8113	275	7070	0	13	6794	6893	-1463	20428	0	20428	2746	473	23647	49.98
20	6584	1695	224	8503	279	7055	0	0	6734	7017	-1398	21002	0	21002	2694	454	24150	50.06
21	6485	405	230	7120	252	7042	0	0	7193	7227	-1455	19748	0	19748	2517	438	22703	50.04
22	6142	211	231	6584	217	6965	0	0	7094	7071	-1529	18875	0	18875	2382	433	21690	50.01
23	6229	342	235	6806	160	7009	0	0	6861	6958	-1625	18895	0	18895	2239	413	21547	49.96
24	6428	225	236	6889	159	7074	0	0	6902	6447	-1531	18645	0	18645	2119	393	21157	50.01
MUs	155.18	18.93	5.15	179.27	6.51	168.98	0.00	15.79	180.99	181.38	-36.13	505.72	0.00	505.72	57.57	10.08	573.37	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Feb/2023

Position as on 6.30 Hrs of 10/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	22/02/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
IPP	Dhariwal	300	05/02/2023	00:00		Continued.	Annual Overhaul	22/02/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/02/2023
IPP	JSW (J) U3	300	28/01/2023	06:38		Continued.	Non availability of load schedule	
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24		Continued.	NASHIK TPS U#4 TOLLING FROM DATED 02.02.2023 at 03.43 A.M	
MSPGCL	Chandrapur Unit 9	500	07/02/2023	00:26	10/02/2023	03:56	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	07/02/2023	09:56	10/02/2023	03:37	Boiler Tube Leakage	
IPP	RPL(AMT) U-5	270	07/02/2023	21:58		Continued.	Bottom Ash Problem	10/02/2023
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	09/02/2023
MSPGCL	Parli Unit 7	250	09/02/2023	05:42	09/02/2023	10:53	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 10/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-1 @ KORADI 3	IntraState	09/02/2023	09:12	09/02/2023	19:29	PO	For ICT changeover Activity as per CEA guideline Spare Ph. ICT taken into service in place of R-Ph.
400 KV TIEBAY Outages/Trippings							
TIE BAY (418) OF ICT - 1 & ST 4B @ DEEPNAGAR	IntraState	09/02/2023	10:47			PO	For servicing & overhauling of 400kV AREVA make STN-4B Tie C.B. Mechanism
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
PARLI - KARJAT CKT - 2	IntraState	08/02/2023	23:04	09/02/2023	01:07	EO	To attend hotspot of 29C R Ph Isolator
KHADKA-AURANGABAD (WALUJ)	IntraState	09/02/2023	06:51	09/02/2023	16:34	PO	Replacement of faulty disc insulator strings found during Monkey Patrolling and PID Testing.
LONIKAND I - KOYNA STAGE-IV	IntraState	09/02/2023	08:35	09/02/2023	16:26	PO	PID Faulty disc insulator replacement work & Cold line washing work
NEW KOYNA-KARAD CKT - 1	IntraState	10/02/2023	08:13			PO	PID Faulty disc insulator replacement work & Cold line washing work
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	09/02/2023	11:17	09/02/2023	18:46	PO	Routine Diagnostic Testing as per test Frequency
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	09/02/2023	11:26	09/02/2023	13:55	PO	Annual testing & maintenance.
400 KV BUSBAR Outages/Trippings							
KUDUS - 400KV - BUS 2	IntraState	09/02/2023	10:45			PO	Maintenance of 400kV Bus-2 at Kudus substation.
220 KV TIEBAY Outages/Trippings							
TBC @ MAGARPATTA	IntraState	09/02/2023	09:00	09/02/2023	13:25	PO	Diagnostic Testing work and routine Maintenance.
BUS SECTIONALIZER @ NANDED CITY	IntraState	09/02/2023	14:54	09/02/2023	17:28	EO	For attending R Ph CT oil leakage by cold welding
220 KV TBC Outages/Trippings							
BUS COUPLER @ MULUND	IntraState	07/02/2023	11:45			EO	CB Overhauling work due to SF6 gas leakage.
TBC @ CHAKAN	IntraState	10/02/2023	10:10			PO	For replacement of R, Y and B phase 220kV CT due to Higher Tan Delta.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	04/02/2023	18:33	10/02/2023	09:42	HT	For load management
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/02/2023	05:25			PO	1.Bunching at Loc No.329. 2.Erection - 4 Nos. Of Monopole and 1 No. Of Lattice Pole. 3.Stringing- 6 spans. 4.Dismantling - 3 Nos. Of lattice tower. 5.Destringing- 4 Spans

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 10/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GHATGHAR - BAPGAON	IntraState	06/02/2023	05:41			PO	1.Bunching at Loc No.329. 2.Erection - 4 Nos. Of Monopole and 1 No. Of Lattice Pole. 3.Stringing- 6 spans. 4.Dismantling - 3 Nos. Of lattice tower. 5.Destringing- 4 Spans
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	09/02/2023	02:50	09/02/2023	06:27	EO	Foremergency outage on 220 KvBabhaleshwar NASIK Ckt 2 (DC LINE) for replacement of the burned jumper nut bolts due to hot spot (there is no hot spot temperature on this loc) at loc no 147 cut point detected in monkey patrolling of the line , outage on 07.02.2023 from 03.00 hrs. to 05.00 hrs.
URAN - APTA 3	IntraState	09/02/2023	09:06	09/02/2023	19:37	PO	For disc insulator string replacement work & Diagonstic testing and bay maint's work.
PUSAD - WARDHA (PG)	IntraState	09/02/2023	09:55	09/02/2023	15:01	PO	Routine line maintenance work. and A/R in N/A.
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	09/02/2023	10:20	09/02/2023	17:55		Outage is required for Replacement of Faulty String found in PID at TL 151 Y ph, 155 B ph, 156 Y and Insulator cleaning
BHOSARI 2 - TELCO	IntraState	09/02/2023	10:21	09/02/2023	14:33	PO	Replacement of 220 KV R PH CT in view of oil leakage.
VANKUSWADE - AJINKYATARA	IntraState	09/02/2023	11:36	09/02/2023	18:40	PO	Diagnostic testing and quarterly maintenance work
KHAREPATAN -PAWAS LINE	IntraState	09/02/2023	13:11	09/02/2023	14:28	T	Tripped on distance protection
KALYANI - BARAMATI AGRO	IntraState	09/02/2023	13:55	09/02/2023	18:45	PO	RELAY TESTING , SCADA TESTING & JUMPER REPLACEMENT WORK.
JEJURI (400 KV)-JEJURI- I	IntraState	09/02/2023	17:21	09/02/2023	19:31	PO	CT tan delta testing work
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	09/02/2023	22:08	10/02/2023	00:10	EO	To attend red hotspot on middle ph bushing terminal at CTT 1. 217 deg. C temperature observed on bushing terminal. (The line is now 220KV APK-Bapgaon line)
TROMBAY SALSETTE LINE-2	IntraState	10/02/2023	00:06	10/02/2023	03:40	PO	Project work for work in vicinity of 110 KV Three terminal Salsette Vikhroli Powai line normalisation.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	10/02/2023	00:10	10/02/2023	06:02	HT	E/O availed to replace burned jumper nut-bolts at loc. no.147
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	10/02/2023	01:59	10/02/2023	06:02	EO	For outage on 220 KvBabhaleshwar NASIK Ckt 1 (DC LINE) for replacement of the burned jumper nut bolts loc no 147 cut point detected in monkey patrolling of the line , outage on dated 10.02.2023 from 03.00 hrs. to 06.00 hrs.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA ICT 1@ RANJANGAON	IntraState	09/02/2023	11:00			PO	220kV A& B- Bus Isolator Maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 10/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 3 @ APTA	IntraState	09/02/2023	11:40	09/02/2023	18:23	PO	Diagnostic testing work(CT,winding,bushing C & Tan delta testing, IR testing) & maintenance work
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	09/02/2023	13:51	09/02/2023	18:35	PO	SFRA & DFRA of ICT-4.
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	09/02/2023	09:35	09/02/2023	17:05	PO	For MAIN BUS 2 insulator string replacement work.
132 KV LINE Outages/Trippings							
DHARANI - NEPANAGAR	InterState	09/02/2023	11:37	09/02/2023	18:47		Replacement of R-ph & Y-ph metering PT of 132kv Nepanagar line bay
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	09/02/2023	00:06	09/02/2023	04:27	PO	Work in vicinity of new tower erection.
BHIRA (T) - DAVDI	IntraState	09/02/2023	09:30	09/02/2023	19:19	PO	Jumper connection to bus 1 of bus section breaker

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage