

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Mar/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	158.439	1475.155	1) Gujrat	3.655	33.645
2) Hydro	5.786	78.187	2) Madhya Pradesh	6.390	37.054
3) Gas	2.772	37.335	3) Chattisgarh	4.330	33.900
Total MSPGCL	166.997	1590.677	4) Maharashtra	162.329	1435.531
B) 1) APLM	74.865	599.419	5) Goa (Amona)	-1.898	-12.098
2) JSWEL	22.355	225.486	Total	174.806	1528.032
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.381	269.743
4) RPL(AMT)	31.220	264.001	b) Mumbai Drawl	37.222	327.795
5) SWPGPL	10.256	89.620	c) MSEDCL Bilateral *	84.760	774.881
6) Other IPP	40.425	384.914	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.381	269.743
C) 1) TPCL Thermal	10.536	99.457	Include PX	0.000	0.000
2) TPCL Hydro	3.034	24.300	Standby	0.000	0.000
3) TPCL Gas	2.897	22.277	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.568	99.086	1) MSEDCL	497.425	4500.898
D) STATE			2) Mumbai Discoms	64.257	572.915
1) Thermal	358.664	3237.138	3) Other Discoms	10.064	90.226
(A1+C1+C4+(B1-B6))			TOTAL STATE	571.746	5164.039
2) Hydro (A2+C2)	8.820	102.487			
3) Gas (A3+B7+C3)	5.669	59.612			
4) Wind	8.807	116.460			
6) SOLAR	14.980	120.310			
TOTAL STATE	396.940	3636.007			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6760	5942	7195	6284
MSPGCL Hydro	281	271	331	152
MSPGCL Gas	82	111	116	128
MSPGCL Total Generation	7123	6324	7642	6564
Central Sector Receipt	8698	8866	7166	5515
WIND	343	285	274	677
CPP / IPP Thermal	7404	7361	7815	7276
CPP / IPP Gas	0	0	0	0
SOLAR	1832	2173	0	0
Exchange with Mumbai	-1785	-1930	-1511	-1256
MSEDCL DEMAND MET	23154	22611	20947	18432
Load Shedding	0	0	0	0
MSEDCL DEMAND	23154	22611	20947	18432
TPCL GENERATION	847	771	933	523
AEML GENERATION	499	470	482	304
MUMBAI DEMAND	3131	3171	2926	2083
OTHER DISCOM DEMAND	461	468	439	344
STATE DEMAND MET	26746	26250	24312	20859
STATE DEMAND	26746	26250	24312	20859
Frequency (Hz)	50.01	50.01	50.00	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 22:00 Hrs	49.8 Hz at 09:39 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.74	41.15	210	145
Unit 8	14.49	117.94	642	476
Unit 9	14.00	117.00	615	442
Unit 10	6.03	102.93	604	0
Total	39.26	379.02		
Bhusawal				
Unit 3	2.98	29.60	150	115
Unit 4	9.14	84.07	475	280
Unit 5	8.84	89.16	500	280
Total	20.96	202.82		
Parli				
Unit 6	3.90	40.01	247	144
Unit 7	3.16	39.25	234	0
Unit 8	2.96	29.63	131	112
Total	10.02	108.89		
Chandrapur				
Unit 3	3.26	32.06	165	120
Unit 4	3.07	28.86	144	120
Unit 5	7.41	25.60	395	285
Unit 6	7.37	75.65	385	275
Unit 7	7.54	72.68	423	268
Unit 8	9.93	93.38	494	270
Unit 9	10.15	95.70	500	320
Total	48.72	423.94		
Paras				
Unit 3	5.22	42.92	225	200
Unit 4	5.78	46.72	248	212
Total	11.00	89.64		
Khaparkheda				
Unit 1	2.66	25.38	120	100
Unit 2	2.91	27.91	132	110
Unit 3	3.40	34.25	180	130
Unit 4	3.68	33.84	185	132
Unit 5	10.38	88.88	490	280
Total	23.05	210.26		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	2.03	29.97	169	0
Unit 5	3.39	30.61	182	119
Total	5.42	60.58		
Uran				
All Units	2.77	37.34	128	82
Total	2.77	37.34		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	1.28	25	0
Total	0.13	1.28		
Koyna				
Stage 1-2	1.28	20.22	200	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	13.09	0	0
Stage 3	0.29	7.27	80	0
Total	1.57	40.58		
Hydro				
KDPH	0.86	7.33	36	36
VTRNA	0.89	8.90	61	0
TILLARI	0.35	0.64	58	0
BHIRA T.R.	0.10	1.21	40	0
SMLHY_PTN	1.88	18.25	84	74
GHATGHAR	0.00	0.00	0	0
Total	4.09	36.33		
Wind				
Total	8.81	116.46	0	0
Total	8.81	116.46		
CPP				
APML(Mus)	74.86	599.42	0	0
JSWEL(Mus)	22.36	225.49	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.22	264.00	0	0
SWPGPL-Mus	10.26	89.62	0	0
Dhariwal	5.99	53.46	281	234
IEPL	4.55	46.27	213	150
Other(Mus)	29.89	285.19	0	0
Total	179.12	1563.44		
SOLAR				
Total	14.98	120.31	0	0
Total	14.98	120.31		
Tata				
Trombay 5	7.03	65.63	401	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.64	13.08	107	44
Trombay 7B	1.26	9.20	65	40
TATA Hydro	3.03	24.30	353	6
Trombay 8	3.50	33.82	222	130
Total	16.47	146.03		
AEML				
DTPS U-1&2	10.57	99.09	499	304
Total	10.57	99.09		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	158.44	1475.16	MSPGCL Total	167.00	1590.68
			MSPGCL Thml+Gas	161.21	1512.49	Koyna 1,2 & 4 Total	1.28	33.31
			MSPGCL Hydro	5.79	78.19	State Total	396.94	3636.01

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6011	218	123	6352	724	7484	0	0	5919	5671	-1371	18472	0	18472	2398	388	21258	50.07
2	6128	213	126	6467	677	7374	0	0	5848	5635	-1285	18518	0	18518	2221	350	21089	49.98
3	6284	152	128	6564	677	7276	0	0	5963	5515	-1256	18432	0	18432	2083	344	20859	49.97
4	6195	150	128	6473	669	7313	0	0	5993	5765	-1178	18717	0	18717	1993	325	21035	50.00
5	6387	153	128	6668	603	7336	0	0	6057	5946	-1141	19067	0	19067	1967	345	21379	50.03
6	6822	160	127	7109	568	7345	0	0	6095	6288	-1159	19779	0	19779	2042	372	22193	49.98
7	7218	292	124	7634	483	7450	0	9	6684	6896	-1147	20912	0	20912	2182	413	23507	50.01
8	7660	331	123	8114	360	7448	0	270	6995	7280	-1258	21792	0	21792	2327	422	24541	50.01
9	7393	260	119	7772	262	7302	0	863	7696	7808	-1545	22007	0	22007	2624	455	25086	50.04
10	6577	312	104	6993	258	7380	0	1478	8165	8287	-1565	22369	0	22369	2920	462	25751	49.96
11	6760	281	82	7123	343	7404	0	1832	8512	8698	-1785	23154	0	23154	3131	461	26746	50.01
12	6659	269	108	7036	352	7404	0	2058	9090	8539	-1922	23002	0	23002	3196	465	26663	50.04
13	5942	271	111	6324	285	7361	0	2173	8921	8866	-1930	22611	0	22611	3171	468	26250	50.01
14	5386	287	109	5782	192	7342	0	2019	8552	8953	-1815	22013	0	22013	3074	460	25547	50.00
15	5975	433	108	6516	130	7365	0	1744	8758	9092	-2096	22320	0	22320	3121	431	25872	49.93
16	6495	263	111	6869	145	7456	0	1358	8950	8806	-2101	22093	0	22093	3192	440	25725	50.00
17	6703	222	112	7037	130	7464	0	844	8359	8188	-1858	21359	0	21359	3163	446	24968	50.03
18	6727	213	113	7053	178	7453	0	324	7845	7809	-1684	20686	0	20686	3062	447	24195	49.99
19	7112	246	113	7471	253	7650	0	8	7324	7144	-1616	20455	0	20455	2964	455	23874	50.02
20	7195	331	116	7642	274	7815	0	0	7217	7166	-1511	20947	0	20947	2926	439	24312	50.00
21	7111	238	115	7464	296	7711	0	0	6827	6531	-1497	20065	0	20065	2778	440	23283	50.02
22	6709	174	113	6996	284	7638	0	0	6657	6489	-1504	19466	0	19466	2635	437	22538	50.00
23	6375	160	114	6649	249	7665	0	0	6730	6765	-1515	19398	0	19398	2558	415	22371	50.00
24	6615	157	117	6889	415	7685	0	0	6542	6669	-1483	19790	0	19790	2529	385	22704	49.99
MUs	158.44	5.79	2.77	167.00	8.81	179.12	0.00	14.98	175.70	174.81	-37.22	497.43	0.00	497.43	64.26	10.06	571.75	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Mar/2023

Position as on 6.30 Hrs of 10/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 6	108	08/03/2023	13:13		Continued.	zero schedule by msedcl	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00	10/03/2023	04:05	boiler tube leakage (under tooling from dtd-27.2.2023 @ 16:00 hrs	
IPP	JSW (J) U1	300	09/03/2023	00:14	09/03/2023	09:14	Generator Protection operated	
MSPGCL	Parli Unit 7	250	09/03/2023	01:16	09/03/2023	05:05	tripped	
MSPGCL	Uran Unit B0	120	09/03/2023	09:42	09/03/2023	10:27	Bearing vibration high	09/03/2023
MSPGCL	Koradi Unit-10	660	09/03/2023	11:11		Continued.	Boiler Tube Leakage	12/03/2023
MSPGCL	Nasik Unit 4	210	09/03/2023	15:55		Continued.	FD Fan Problem.	10/03/2023
MSPGCL	Nasik Unit 3	210	10/03/2023	05:00	10/03/2023	06:55	Due to suspected Stuck up of I/L Valve of Hydrogen Cooler.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 10/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
MAIN BUS - 1 @ AKOLA 2	IntraState	09/03/2023	09:59	09/03/2023	16:30	PO	Maintenance of Bus equipment's
400 KV LR Outages/Trippings							
AURANGABAD (WALUJ) - PUNE GIS CKT - 2 L/R @ WALUJ	IntraState	09/03/2023	10:57	09/03/2023	18:31	PO	401LR AMP Work and Relay Testing works.
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
KHADKA-AURANGABAD (WALUJ)	IntraState	08/03/2023	20:56	09/03/2023	06:33	HT	Over Voltage.
PADGHE - NAGOTHANE CKT - 1	IntraState	09/03/2023	09:30			PO	CB replacement work
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	09/03/2023	10:57	09/03/2023	18:31	PO	For taking LR in and out of service
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	09/03/2023	13:09	09/03/2023	20:46	PO	Diagnostic testing and allied bay maintenance work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	IntraState	08/03/2023	10:52	09/03/2023	22:02	PO	for replacement of 36 kV HV Neutral bushing (Tertiary) of 2B2 ph. unit of 400/220kV ICT-2 from external agency as detected oil leakage
400/220/33 KV 500 MVA ICT - 1 @ JEJURI	IntraState	09/03/2023	15:29	09/03/2023	22:16	PO	For Y ph oil filtration work
220 KV TIEBAY Outages/Trippings							
MAIN BUS SECTIONALIZER -1 @ GHODBUNDER (GIS)	IntraState	09/03/2023	10:21	09/03/2023	13:15	PO	Preventive maintenance of Bay equipment
MAIN BUS SECTIONALIZER -2 @ GHODBUNDER (GIS)	IntraState	09/03/2023	14:22	09/03/2023	16:42	PO	Preventive maintenance of Bay equipment
220 KV MAINBAY Outages/Trippings							
MAIN BUS - 1 @ NEW KOYNA	IntraState	08/03/2023	11:15			PO	A) Bus isolator Routine maint. Works following bay will be transfer on A Bus by TBC Shifting 1) 220KV side ICT-II 2)220KV Pophali 3)220KV Lote 4) 220KV side 25 MVA T/F-I B) Jumper works for ICT-3 New Bay
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 10/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
CTRLS - NET MAGIC GIS	IntraState	07/03/2023	12:43			T	Distance Protection.
GHATGHAR - BAPGAON	IntraState	09/03/2023	02:00	09/03/2023	04:09	T	Tripped from Ghatghar end
BUS COUPLER @ TALEGAON	IntraState	09/03/2023	07:28	09/03/2023	10:37	PO	Diagnostic Testing and Half yearly maintenance work.
SADAWAGHAPUR KARAD CKT 2	IntraState	09/03/2023	09:31	09/03/2023	18:23	PO	Cold washing of insulator
MIRAJ - MHAISHAL	IntraState	09/03/2023	10:02	09/03/2023	19:00	PO	Cold washing of Insulator
LAMBOTI - SOLAPUR 2(BALE) CKT-2	IntraState	09/03/2023	10:07	09/03/2023	16:01	PO	For erection and commissioning of coupling capacitor.
VSNL- KHADKI	IntraState	09/03/2023	10:27	09/03/2023	16:09		For replacement of B Ph LA work
220 KV GHATODI - HINGOLI	IntraState	09/03/2023	10:29	09/03/2023	13:15	PO	Diagnostic testing Work.
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT I	IntraState	09/03/2023	11:12	09/03/2023	13:14	PO	Flashover disc replacement work at location no. 41R-phase.
PEDAMBE-KALAMBANI(TSS)	IntraState	09/03/2023	11:12	09/03/2023	17:30	PO	Urgent Testing of Distance Protection Relay of 220KV Pedhambe line Bay at Kalambani TSS end & Maintenance work.
LAMBOTI - TULJAPUR CKT - 2	IntraState	09/03/2023	11:38	09/03/2023	15:23	PO	Conductor repair sleeve Work at loc-99,100.
220KV TULJAPUR-LAMBOTI(400KV)CKT 1	IntraState	09/03/2023	11:38	09/03/2023	15:23	PO	Conductor repair sleeve work at location 99-100
BORIVALI - TARAPUR	IntraState	09/03/2023	11:43	09/03/2023	17:20	PO	Replacement of Rusted Hardware, conductor & old earthwire.
220KV SHIRSHUPHAL-SHIRSAI TSS CKT-1	IntraState	09/03/2023	12:42	09/03/2023	16:53	PO	Outage is proposed for testing of line differential relay, line backup relay & annual bay maintenance work.
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT II	IntraState	09/03/2023	13:27	09/03/2023	16:35	PO	Line maintenance work.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/03/2023	14:33	09/03/2023	14:42	T	Tripped on Dist. Protection.
PEDHAMBE ONI LINE	IntraState	09/03/2023	15:11	09/03/2023	16:36	T	Tripped on Dist. Protection.
NEW KOYNA - NIWALI	IntraState	09/03/2023	15:11	09/03/2023	16:03	T	Tripped on Dist. Protection.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/03/2023	15:21	09/03/2023	17:50	T	Tripped on Dist. Protection.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	09/03/2023	15:27			HT	H/T Due to load management.
MAHAD-KALAMBANI(TSS)	IntraState	09/03/2023	17:55	09/03/2023	19:35	PO	Urgent Testing of Distance Protection Relay of 220KV Mahad line Bay at Kalambani TSS end & Maintenance work.
TROMBAY SALSETTE LINE-2	IntraState	10/03/2023	00:21	10/03/2023	03:12	PO	Project work - Work in vicinity of line of Salsette Vikhroli line for connecting to New 110 KV Vikhroli GIS
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/03/2023	07:19			EO	To attend Hot Spot at Loc no. 6 (R-Ph towards Boisar- side. Temp. 137 deg C.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 10/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	09/03/2023	10:36	10/03/2023	02:57	PO	For air cell commissioning , attending oil leakage, replacement of OSR
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	09/03/2023	11:06	09/03/2023	16:23	PO	Demo of Winding Resistance Measurement Meter (Make: D. V. Power)
220 KV BUSBAR Outages/Trippings							
MAIN BUS -2 @ RANJANGAON-220 KV	IntraState	09/03/2023	10:45	09/03/2023	19:35	PO	B-Bus PT Diagnostic Testing, B-Bus PT Isolator Overhauling & General maintenance of Bus equipment's.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
WAGHIVALI - MANKHURD	IntraState	08/03/2023	22:30	09/03/2023	00:20	PO	PROJECT WORK-MOVEMENT OF JACK UP BARGE IN VICINITY
WAGHIVALI - MANKHURD	IntraState	10/03/2023	00:02	10/03/2023	04:20	PO	PROJECT WORK-MOVEMENT OF JACK UP BARGE IN VICINITY OF LINE.
100 KV LINE Outages/Trippings							
SHAHAPUR - BHATSA	IntraState	05/03/2023	14:24			PO	1. Restoration of the line from ERS system to newly erected tower between Pillar No.10-1 1.of 100KV Bhatsa-Shahapur @Ch.No.667 +197 2) Shifting of the line to ERS system on 100KV Bhatsa - Salambe (Phutali) between Pillar No. 19-20.LILO line @ Ch.No 667+298.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage