

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Mar/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	164.901	1442.769	1) Gujrat	5.504	42.441
2) Hydro	11.101	69.332	2) Madhya Pradesh	12.487	111.736
3) Gas	6.912	60.289	3) Chattisgarh	3.800	38.430
Total MSPGCL	182.914	1572.390	4) Maharashtra	166.739	1534.888
B) 1) APMIL	54.739	492.133	5) Goa (Amona)	-1.957	-17.285
2) JSWEL	27.194	230.028	Total	186.573	1710.210
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.230	263.196
4) RPL(AMT)	31.342	279.693	b) Mumbai Drawl	31.050	293.304
5) SWPGPL	10.676	100.501	c) MSEDCL Bilateral *	94.291	881.369
6) Other IPP	46.499	420.935	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.230	263.196
C) 1) TPCL Thermal	10.295	96.937	Include PX	0.000	0.000
2) TPCL Hydro	4.097	31.481	Standby	0.000	0.000
3) TPCL Gas	3.440	31.976	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.138	76.003	1) MSEDCL	528.581	4689.276
D) STATE			2) Mumbai Discoms	58.020	529.697
1) Thermal	354.784	3138.999	3) Other Discoms	10.626	96.899
(A1+C1+C4+(B1-B6))			TOTAL STATE	597.227	5315.872
2) Hydro	15.198	100.813			
(A2+C2)					
3) Gas	10.352	92.265			
(A3+B7+C3)					
4) Wind	12.599	117.750			
6) SOLAR	17.721	155.839			
TOTAL STATE	410.654	3605.666			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6936	6562	6726	6897
MSPGCL Hydro	388	277	1906	195
MSPGCL Gas	283	276	288	296
MSPGCL Total Generation	7607	7115	8920	7388
Central Sector Receipt	9072	8902	7047	6713
WIND	348	149	525	838
CPP / IPP Thermal	6764	6660	7631	6818
CPP / IPP Gas	0	0	0	0
SOLAR	2200	2372	0	0
Exchange with Mumbai	-1694	-1851	-1225	-808
MSEDCL DEMAND MET	23838	22885	22412	20609
Load Shedding	0	0	0	0
MSEDCL DEMAND	23838	22885	22412	20609
TPCL GENERATION	670	703	1020	601
AEML GENERATION	452	325	497	396
MUMBAI DEMAND	2816	2879	2742	1805
OTHER DISCOM DEMAND	459	462	486	340
STATE DEMAND MET	27113	26226	25640	22754
STATE DEMAND	27113	26226	25640	22754
Frequency (Hz)	50.00	50.02	49.95	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 13.01 Hrs	49.62 Hz at 15.54 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.38	38.18	190	170
Unit 8	13.77	125.24	616	514
Unit 9	7.05	105.92	537	0
Unit 10	10.77	107.40	465	405
Total	35.97	376.73		
Bhusawal				
Unit 3	3.65	28.28	180	120
Unit 4	11.55	84.18	500	370
Unit 5	9.50	82.11	500	0
Total	24.70	194.57		
Parli				
Unit 6	4.60	33.89	250	144
Unit 7	4.41	33.20	249	140
Unit 8	0.00	21.87	0	0
Total	9.02	88.96		
Chandrapur				
Unit 3	3.32	27.75	150	123
Unit 4	0.00	23.33	0	0
Unit 5	9.00	69.79	435	280
Unit 6	8.91	69.21	445	280
Unit 7	8.57	70.31	422	285
Unit 8	9.87	80.02	422	395
Unit 9	11.00	76.30	480	442
Total	50.68	416.71		
Paras				
Unit 3	5.54	48.96	243	158
Unit 4	5.60	50.63	253	156
Total	11.14	99.59		
Khaparkheda				
Unit 1	3.50	30.93	170	115
Unit 2	3.59	32.82	182	96
Unit 3	3.68	32.71	172	133
Unit 4	3.66	34.03	169	132
Unit 5	11.83	82.32	500	479
Total	26.26	212.81		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.70	30.79	188	125
Unit 5	3.42	22.61	165	117
Total	7.12	53.40		
Uran				
All Units	6.91	60.29	302	271
Total	6.91	60.29		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	0.77	45	0
Total	0.06	0.77		
Koyna				
Stage 1-2	2.46	13.69	525	45

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.10	7.13	750	0
Stage 3	1.17	4.97	232	0
Total	5.74	25.79		
Hydro				
KDPH	0.86	7.78	36	36
VTRNA	0.65	5.78	61	0
TILLARI	0.50	4.25	63	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.72	22.32	116	110
GHATGHAR	0.56	2.65	125	0
Total	5.29	42.77		
Wind				
Total	12.60	117.75	0	0
Total	12.60	117.75		
CPP				
APML(Mus)	54.74	492.13	0	0
JSWEL(Mus)	27.19	230.03	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.34	279.69	0	0
SWPGPL-Mus	10.68	100.50	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.14	52.76	267	247
Other(Mus)	35.87	330.65	0	0
JPL	4.48	37.52	241	168
Total	170.45	1523.29		
SOLAR				
Total	17.72	155.84	0	0
Total	17.72	155.84		
Tata				
Trombay 5	6.55	64.33	379	201
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.08	19.47	108	39
Trombay 7B	1.36	12.51	65	37
TATA Hydro	4.10	31.48	422	17
Trombay 8	3.74	32.61	222	133
Total	17.83	160.39		
AEML				
DTPS U-1&2	9.14	76.00	500	300
Total	9.14	76.00		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	164.90	1442.77	MSPGCL Total	182.91	1572.39
			MSPGCL Thml+Gas	171.81	1503.06	Koyna 1,2 & 4 Total	4.57	20.82
			MSPGCL Hydro	11.10	69.33	State Total	410.65	3605.67

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7287	197	295	7779	710	6849	0	0	7142	6846	-1063	20708	0	0	20708	2116	413	23237	49.98
2	7133	195	295	7623	740	6843	0	0	7239	6980	-883	20923	0	0	20923	1990	380	23293	50.01
3	6878	196	295	7369	845	6760	0	0	7163	6899	-870	20642	0	0	20642	1883	361	22886	49.98
4	6897	195	296	7388	838	6818	0	0	7130	6713	-808	20609	0	0	20609	1805	340	22754	50.00
5	6914	266	298	7478	773	6798	0	0	7149	7133	-810	21025	0	0	21025	1795	347	23167	49.98
6	7358	245	300	7903	746	7034	0	0	7533	7529	-871	21957	0	0	21957	1888	384	24229	49.98
7	7557	506	302	8365	755	7451	0	24	7632	7411	-816	22783	0	0	22783	1989	407	25179	49.99
8	7547	673	300	8520	560	7455	0	367	7499	7185	-828	22802	0	1	22802	2121	457	25380	50.06
9	7105	353	295	7753	440	6999	0	1081	7896	8192	-983	23012	0	0	23012	2354	470	25836	50.02
10	6812	416	292	7520	435	6779	0	1731	8461	8904	-1427	23468	0	0	23468	2607	474	26549	50.01
11	6936	388	283	7607	348	6764	0	2200	9191	9072	-1694	23838	0	20	23838	2816	459	27113	50.00
12	6871	288	278	7437	222	6682	0	2355	9055	9129	-1849	23514	0	76	23514	2898	462	26874	50.01
13	6562	277	276	7115	149	6660	0	2372	8923	8902	-1851	22885	0	74	22885	2879	462	26226	50.02
14	6360	251	271	6882	153	6686	0	2309	8684	8732	-1769	22518	0	27	22518	2762	475	25755	50.03
15	6456	252	273	6981	254	6745	0	2091	9073	8781	-1756	22639	0	8	22639	2749	457	25845	49.92
16	6767	323	271	7361	342	6893	0	1655	9248	8626	-1752	22652	0	1	22652	2778	473	25903	49.85
17	6872	273	279	7424	477	7342	0	1100	8808	8128	-1612	22361	0	0	22361	2748	498	25607	49.96
18	6831	356	281	7468	507	7477	0	418	8374	8172	-1574	21978	0	4	21978	2703	490	25171	50.01
19	6785	1195	280	8260	443	7599	0	18	7438	7450	-1429	21846	0	0	21846	2698	495	25039	49.95
20	6726	1906	288	8920	525	7631	0	0	7010	7047	-1225	22412	0	0	22412	2742	486	25640	49.95
21	6693	1260	288	8241	547	7549	0	0	7115	6872	-1270	21464	0	0	21464	2615	475	24554	50.03
22	6675	676	292	7643	572	7544	0	0	7152	6939	-1348	20869	0	0	20869	2479	481	23829	50.04
23	6445	220	291	6956	596	7539	0	0	7505	7390	-1315	20711	0	0	20711	2347	455	23513	49.98
24	6434	194	293	6921	622	7553	0	0	7426	7541	-1247	20963	0	0	20963	2258	427	23648	49.97
MUs	164.90	11.10	6.91	182.91	12.60	170.45	0.00	17.72	189.85	186.57	-31.05	528.58	0.00	0.21	528.58	58.02	10.63	597.23	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR carried out due to 132KV BBLSR-Rahuri line overload and 50MVA T/F overload at Kopargaon S/stn.2)ELR carried out due to overloading of Chakan-Talegaon PGCIL Line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Mar/2024

Position as on 6.30 Hrs of 10/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Parli Unit 8	250	07/03/2024	03:06		Continued.	Air heater problem	11/03/2024
MSPGCL	Chandrapur Unit 4	210	08/03/2024	10:00		Continued.	SUSPECTED BTL	11/03/2024
MSPGCL	Koradi Unit 9	660	09/03/2024	13:49		Continued.	SUSPECTED BTL	12/03/2024
MSPGCL	Ghatghar Unit-1	125	09/03/2024	18:00	10/03/2024	10:30	GM Link Fault	10/03/2024
MSPGCL	Koyna STG-IV Unit-4	250	09/03/2024	18:45	10/03/2024	02:25	Ruptured bolt	
MSPGCL	Bhusawal Unit 5	500	09/03/2024	22:00		Continued.	Boiler Tube Leakage	12/03/2024
MSPGCL	Uran Unit 7	108	10/03/2024	00:24	10/03/2024	18:20	Air Filter Replacement work	10/03/2024
MSPGCL	Chandrapur Unit 5	500	10/03/2024	02:20	10/03/2024	05:53	Drum level low	10/03/2024
Total Capacity MSPGCL		2831						
IPP								
IPP	SWPGPL U-1	135	06/03/2024	14:40	09/03/2024	08:32	Boiler Tube Leakage	09/03/2024
IPP	Adani U-5	660	08/03/2024	06:27		Continued.	Mill inlet bellow leakage	11/03/2024
IPP	JPL Unit 2	150	10/03/2024	17:55	10/03/2024	20:16	Flame Failure	
Total Capacity IPP		945						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		4096						

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Mar/2024

Position as on 6.30 Hrs of 10/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 09/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 10/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TBC @ PADGHE	IntraState	06/03/2024	12:01			PO	1. Replacement of CT with New ratio of 3000/1 Amp. 2. Diagnostic Testing work. 3. Bay Maintenance Work.
TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	IntraState	08/03/2024	09:56			PO	Replacement of non-PIR CB by with PIR CB
400 KV MAINBAY Outages/Trippings							
MAIN BAY (409) OF CHANDRAPUR GCR CKT - 2 @ CHANDRAPUR 2	IntraState	09/03/2024	10:35	09/03/2024	17:36	PO	Diagnostic testing & allied bay maintenance work
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar-Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
KHADKA- DEEPNAGAR CKT 2	IntraState	09/03/2024	09:58	09/03/2024	13:04	PO	For CVT, Capacitance and delta testing and maintenance works.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	09/03/2024	14:05	09/03/2024	17:04	PO	For attending oil leakage & oil top up work.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	10/03/2024	04:03	10/03/2024	12:52	T	Differential Protection
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	10/03/2024	09:15	10/03/2024	19:22	PO	To attend oil leakage of conservator Y Phase unit, ICT routine diagnostic testing and maintenance activity and Line CT diagnostic work.
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
BUS REACTOR (80 MVAR) - 1 @ KOLHAPUR (TALANDGE)	IntraState	09/03/2024	10:53	10/03/2024	12:46	PO	Bay AMP
220 KV TIEBAY Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 10/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS COUPLER @ ULWE GIS	IntraState	08/03/2024	15:21	10/03/2024	12:13	PO	For attending SF6 Gas Leakage in GIS GC-Y1(Need to replace GD gas valve)
220 KV MAINBAY Outages/Trippings							
220KV TATA Motors bay 1 (EHV Consumer Bay) TELCO-220 KV	IntraState	10/03/2024	08:50	10/03/2024	14:00	PO	Maintenanace work at 220KV Tata Motors yard.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
MAHALAXMI - AMONA	IntraState	06/03/2024	17:14	10/03/2024	17:50	T	Tripped on distance protection.
GIS BHANDUP - BORIVALI	IntraState	09/03/2024	00:26	09/03/2024	08:47	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
BORIVALI - CTRLS CKT	IntraState	09/03/2024	00:32	09/03/2024	08:40	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KALWA - BORIVALI	IntraState	09/03/2024	00:41	09/03/2024	08:34	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KHARGHAR - BORIVALI CKT - 2	IntraState	09/03/2024	00:52	09/03/2024	08:43	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
EKLAHARE (OCR) - PADGHE	IntraState	09/03/2024	08:13	09/03/2024	20:52	PO	. For the conversion of STN into DTN towards highway side due to crossing of National Highway (Mumbai Agra Highway) at loc.no.317 & 318.
BABHALESHWAR - DEOGAON RANGARI	IntraState	09/03/2024	09:02	09/03/2024	20:01	PO	Replacement of old disc insulator with long rod .
POPHLI PEDHMBE LINE- 2	IntraState	09/03/2024	09:15	09/03/2024	12:10	PO	220KV Pophali-II line CT Testing, Ta delta measurement & meggering work.
SALSETTE - VIKHROLI (GIS) CKT - 3	IntraState	09/03/2024	09:32	09/03/2024	16:22	PO	Closer inspection.
MALEGAON - KALWAN CKT-1	IntraState	09/03/2024	10:12	09/03/2024	16:18	PO	For relay testing work by PAC unit Malegaon
BHIRA - KARANJADE 7	IntraState	09/03/2024	11:51	09/03/2024	17:04	PO	Closer inspection
GCR CHANDRAPUR - GRACE LTD	IntraState	09/03/2024	13:14	09/03/2024	17:58	T	Distance Protection
PEDAMBE-KALAMBANI(TSS)	IntraState	09/03/2024	13:59	09/03/2024	17:53	T	Tripped on distance protection
220 KV DHULE(400 KV) - AMALNER	IntraState	09/03/2024	16:09	09/03/2024	20:13	PO	To attend Red Hot
MALEGAON - KALWAN CKT-2	IntraState	09/03/2024	17:35	09/03/2024	19:20	PO	For relay testing work by PAC unit Malegaon.
BABHALESHWAR - DEOGAON RANGARI	IntraState	10/03/2024	08:47	10/03/2024	20:29	PO	Replacement of old disc insulator with long rod .
KANDALGAON - PIRANGUT	IntraState	10/03/2024	09:11	10/03/2024	18:20	PO	For fixing of conductor vibration damper & cold line washing of insulators.
220KV BADNERA -NER CKT	IntraState	10/03/2024	12:25	10/03/2024	13:12	T	TRIPPED AT BADNERA AND AVADA END.
220 KV ICT Outages/Trippings							
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 10/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	05/03/2024	07:40			PO	ICI 1 overhauling ,Testing ,CRP replacement of CPLR 1-2 ,ICT 1
STATION TRANSFORMER - 3 @ EKLAHARE (GCR)	IntraState	09/03/2024	09:50	09/03/2024	17:11	PO	Routine maintenance, Diagnostic testing work.
220/33 KV 25 MVA PTR @ RAYMOND	IntraState	09/03/2024	09:55	09/03/2024	19:30	PO	1. Replacement 3 Nos of 220kV CTs due to high tan delta CTs 2. Attending oil leakages of PTR 3. Overhauling of 220kV Breaker 4. Replacement of B ph 220kV LA
220/110 KV 250 MVA ICT - 2 @ VERSOVA (TATA)	IntraState	09/03/2024	10:21	09/03/2024	17:36	PO	Protection trials
250 MVA ICT-5 @ TROMBAY	IntraState	10/03/2024	10:54	10/03/2024	17:02	PO	R/M of 110KV breaker
220 KV BUSBAR Outages/Trippings							
BUS SECTION - 1 @ ULWE GIS	IntraState	08/03/2024	15:21	10/03/2024	12:13	PO	For attending SF6 Gas Leakage in GIS GC-Y1(Need to replace GD gas valve)
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	09/03/2024	09:31	09/03/2024	15:13	PO	For earthwire replacement & other Routine Maint. Work
KANHAN-PENCH	IntraState	10/03/2024	09:46	10/03/2024	17:49	PO	For earthwire replacement & other Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
AMBERNATH - KALYAN CKT - 2	IntraState	09/03/2024	10:10	09/03/2024	12:27	PO	Opening loops at loc. 10 OFA North side for erection of gantry structure with conductor stringing at OFA North GOD Structure.
AMBERNATH - KALYAN CKT - 1	IntraState	09/03/2024	13:27	09/03/2024	15:26	PO	Opening loops at loc. 10 OFA North side for erection of gantry structure with conductor stringing at OFA North GOD Structure.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage