

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Apr/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	147.591	1320.827	1) Gujrat	2.316	9.885
2) Hydro	17.829	130.173	2) Madhya Pradesh	14.615	143.470
3) Gas	6.962	59.096	3) Chattisgarh	4.450	39.370
Total MSPGCL	172.382	1510.096	4) Maharashtra	119.274	1039.743
B) 1) APML	76.459	678.977	5) Goa (Amona)	-0.330	-4.532
2) JSWEL	21.009	207.320	Total	140.325	1227.936
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.457	252.692
4) RPL(AMT)	12.052	104.385	b) Mumbai Drawl	29.906	274.884
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	13.983	118.233
6) Other IPP	12.804	122.475	Include PX	-5.886	-75.701
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.457	252.692
C) 1) TPCL Thermal	15.685	128.246	Include PX	20.269	176.001
2) TPCL Hydro	4.530	31.628	Standby	0.000	0.000
3) TPCL Gas	4.252	37.102	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.874	91.306	1) MSEDCL	434.636	3802.769
D) STATE			2) Mumbai Discoms	65.250	563.170
1) Thermal	296.474	2653.536	TOTAL STATE	499.886	4365.939
(A1+C1+C4+(B1-B6))					
2) Hydro	22.359	161.801			
(A2+C2)					
3) Gas	11.214	96.198			
(A3+B7+C3)					
4) Wind	22.083	162.725			
6) SOLAR	7.428	63.739			
TOTAL STATE	359.558	3137.999			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6320	6360	5890	6027
MSPGCL Hydro	952	545	1352	423
MSPGCL Gas	284	281	288	305
MSPGCL Total Generation	7556	7186	7530	6755
Central Sector Receipt	6531	6465	5188	5520
WIND	489	1002	1138	1050
CPP / IPP Thermal	5051	5041	5130	5043
CPP / IPP Gas	0	0	0	0
SOLAR	969	675	0	0
Exchange with Mumbai	-1553	-1410	-1290	-1000
MSEDCL DEMAND MET	19043	18959	17696	17368
Load Shedding	0	0	0	0
MSEDCL DEMAND	19043	18959	17696	17368
TPCL GENERATION	1252	1270	1156	660
AEML GENERATION	499	501	499	373
MUMBAI DEMAND	3304	3181	2945	2033
STATE DEMAND MET	22347	22140	20641	19401
STATE DEMAND	22347	22140	20641	19401
Frequency (Hz)	50.01	49.97	49.95	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.13 Hz at 16.48 Hrs	49.8 Hz at 23.14 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 09/Apr/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.06	34.89	180	145
Unit 7	0.00	0.00	0	0
Unit 8	9.53	77.75	433	313
Unit 9	0.00	0.00	0	0
Unit 10	10.62	92.42	460	398
Total	24.22	205.06		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.84	97.16	505	400
Unit 5	11.79	96.80	500	415
Total	23.64	193.97		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.70	48.36	248	203
Total	5.70	48.36		
Chandrapur				
Unit 3	3.44	36.88	191	0
Unit 4	4.28	39.37	183	172
Unit 5	9.88	89.59	420	405
Unit 6	0.00	0.00	0	0
Unit 7	10.60	95.02	450	428
Unit 8	9.86	96.62	479	191
Unit 9	11.43	101.18	485	465
Total	49.49	458.65		
Paras				
Unit 3	6.03	51.00	255	250
Unit 4	5.36	53.40	248	150
Total	11.39	104.40		
Khaparkheda				
Unit 1	4.26	34.22	195	150
Unit 2	0.00	22.81	0	0
Unit 3	4.41	38.98	190	160
Unit 4	4.45	38.22	190	178
Unit 5	10.96	97.98	475	443
Total	24.08	232.21		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.58	39.33	210	160
Unit 5	4.51	38.86	206	161
Total	9.09	78.18		
Uran				
All Units	6.96	59.10	306	271
Total	6.96	59.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	1.29	36	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.07	1.29		
Koyna				
Stage 1-2	5.83	46.66	520	70
Stage 4	6.13	36.11	799	0
Stage 3	2.74	18.23	160	80
Total	14.70	100.99		
Hydro				
KDPH	0.71	7.78	36	18
VTRNA	0.91	8.45	61	0
TILLARI	0.48	4.06	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.25	1.59	40	0
RNGR+BHTSA	0.28	2.56	12	11
BHANDARDRA	0.00	0.62	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.50	3.51	21	20
GHATGHAR	0.00	0.63	0	0
Total	3.13	29.19		
Wind				
Total	22.08	162.72	0	0
Total	22.08	162.72		
CPP				
APML(Mus)	76.46	678.98	0	0
JSWEL(Mus)	21.01	207.32	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	12.05	104.38	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	12.80	122.48	0	0
Total	122.32	1113.16		
SOLAR				
Total	7.43	63.74	0	0
Total	7.43	63.74		
Tata				
Trombay 5	10.45	82.60	477	302
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.70	23.44	116	83
Trombay 7B	1.55	13.66	67	56
Trombay 8	5.24	45.64	230	200
TATA Hydro	4.53	31.63	422	0
Total	24.47	196.98		
AEML				
DTPS U-1&2	10.87	91.31	502	372
Total	10.87	91.31		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	147.59	1320.83	MSPGCL Total	172.38	1510.10
			MSPGCL Thml+Gas	154.55	1379.92	Koyna 1,2 & 4 Total	11.96	82.76
			MSPGCL Hydro	17.83	130.17	State Total	359.56	3138.00

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Apr/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6151	543	301	6995	1008	5103	0	0	6003	5943	-1226	17823	0	17823	2493	20316	49.95
2	6132	533	294	6959	1057	5041	0	0	5869	5646	-1089	17614	0	17614	2275	19889	49.99
3	6085	363	294	6742	1206	5029	0	0	5734	5694	-1042	17629	0	17629	2115	19744	49.99
4	6027	423	305	6755	1050	5043	0	0	5734	5520	-1000	17368	0	17368	2033	19401	49.94
5	6043	523	295	6861	1073	5074	0	0	5714	5614	-977	17645	0	17645	1996	19641	49.99
6	6218	701	306	7225	1064	5083	0	0	5735	5671	-997	18046	0	18046	2065	20111	49.99
7	6321	932	297	7550	818	5269	0	26	5897	5904	-812	18755	0	18755	2164	20919	50.00
8	6411	722	295	7428	661	5296	0	212	5958	5893	-911	18579	0	18579	2296	20875	50.04
9	6386	584	291	7261	498	5118	0	515	6105	6159	-1241	18310	0	18310	2607	20917	49.96
10	6382	829	287	7498	522	4979	0	749	6285	6312	-1422	18638	0	18638	2939	21577	49.98
11	6343	625	284	7252	503	5030	0	905	6475	6278	-1570	18398	0	18398	3217	21615	50.04
12	6320	952	284	7556	489	5051	0	969	6553	6531	-1553	19043	0	19043	3304	22347	50.01
13	6345	644	282	7271	611	5012	0	933	6539	6276	-1485	18618	0	18618	3248	21866	50.01
14	6336	512	281	7129	589	4941	0	927	6437	6226	-1390	18422	0	18422	3122	21544	49.99
15	6363	485	271	7119	860	4975	0	853	6470	6475	-1377	18905	0	18905	3163	22068	49.96
16	6360	545	281	7186	1002	5041	0	675	6504	6465	-1410	18959	0	18959	3181	22140	49.97
17	6213	688	282	7183	1052	5058	0	467	6370	6415	-1374	18801	0	18801	3170	21971	50.03
18	6105	696	285	7086	1166	4975	0	185	6050	5990	-1317	18085	0	18085	3067	21152	50.04
19	5801	397	287	6485	1226	4885	0	12	5841	5872	-1279	17201	0	17201	2951	20152	50.04
20	5890	1352	288	7530	1138	5130	0	0	5080	5188	-1290	17696	0	17696	2945	20641	49.95
21	5947	1097	289	7333	1159	5176	0	0	5229	4923	-1234	17357	0	17357	2848	20205	49.97
22	5870	823	290	6983	1018	5247	0	0	5366	5208	-1317	17139	0	17139	2705	19844	49.95
23	5725	1568	300	7593	1130	5277	0	0	4978	5040	-1367	17673	0	17673	2688	20361	49.93
24	5817	1292	293	7402	1183	5491	0	0	5060	5082	-1226	17932	0	17932	2655	20587	49.95
MUs	147.59	17.83	6.96	172.38	22.08	122.32	0.00	7.43	141.99	140.32	-29.91	434.64	0.00	434.64	65.25	499.88	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Apr/2019

Position as on 6.30 Hrs of 10/Apr/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 6	500	20/02/2019	22.07		Continued.	Rotor Earth Fault	
MSPGCL	Koradi Unit 9	660	31/03/2019	15.13		Continued.	Furnace Pressure High	
IPP	RPL(AMT) U-1	270	06/04/2019	00.00		Continued.	No Schedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 2	210	07/04/2019	03.20	10/04/2019	00.32	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 3	210	08/04/2019	22.14	09/04/2019	04.48	Attending Pressure Sensing Line Heavy Leakage.	
MSPGCL	Khaparkheda Unit 4	210	10/04/2019	07.15	10/04/2019	10.55	Drum level low	
MSPGCL	Bhusawal Unit 4	500	10/04/2019	12.44		Continued.	Boiler Tube Leakage	
MSPGCL	Paras Unit 4	250	10/04/2019	22.16		Continued.	Drum Level High Protection.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 10/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Ektuni-Akola II Ckt 2	IntraState	10/04/2019	09.43	10/04/2019	12.45	EO	Remove Hanging Nylon Net On Line.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	08/04/2019	17.52	09/04/2019	10.42	HT	Over Voltage
Parli(MS)-Parli (PG) I	InterState	08/04/2019	21.29	09/04/2019	00.03	PO	IR Value of CT Secondary Cable Upto Relay Panel.
Dabhol Nagothane I	InterState	09/04/2019	10.00	09/04/2019	17.34	PO	LE Scheme for Insulator String Replacement
Dhule Sar'Sarovar II	InterState	09/04/2019	17.50	10/04/2019	07.55	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	10/04/2019	17.54		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	08/04/2019	21.12	09/04/2019	14.22	HT	Over Voltage
Deepnagar Taptitanda	IntraState	09/04/2019	06.30	09/04/2019	19.06	PO	Replacement of Faulty Dead end and Mid span joint
N.Koyna-Karad -Ckt I	IntraState	09/04/2019	07.27	09/04/2019	18.51	PO	Replacement of Faulty String
Chandrapur-Parali III	IntraState	09/04/2019	10.12	09/04/2019	15.28	PO	Replacement of Broken Spacer Cum Vibration Damper
Koradi-RattanIndia	IntraState	09/04/2019	15.32	09/04/2019	16.40	T	Distance Protection R Phase
Padghe - Kalwa- I	IntraState	09/04/2019	16.49	10/04/2019	03.11	EO	String Replacement work
Khadka-Aurangabad (Waluj)	IntraState	09/04/2019	19.01	10/04/2019	08.29	HT	Over Voltage
Deepnagar Taptitanda	IntraState	10/04/2019	06.37	10/04/2019	18.09	PO	Replacement of Faulty Dead End & Mid Span Joint.
Main Bus I @ Chandrapur Sw	IntraState	10/04/2019	07.15	10/04/2019	18.30	PO	Extension of Main Bus 1 By Hotline Method.
Akola-Nandgaonpeth (RPL)	IntraState	10/04/2019	08.15	10/04/2019	08.40	PO	Routine Annual Line Maintenance.
N.Koyna-Karad -Ckt I	IntraState	10/04/2019	08.32	10/04/2019	17.57	PO	Replacement of Faulty Insulator.
Akola II - RPL(Rattanindia) Ckt I	IntraState	10/04/2019	13.02	10/04/2019	21.02	PO	Routine Maintenance Work
Padghe - Kalwa- I	IntraState	10/04/2019	14.49	10/04/2019	20.03	EO	String Replacement At Location No 1121.
Khadka-Aurangabad (Waluj)	IntraState	10/04/2019	18.16		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	26/03/2019	11.02		Continued.	PO	Overhauling work
400/220kv 315 Mva ICT II @Karad	IntraState	08/04/2019	09.03		Continued.	PO	OLTC Overhauling Work.
400/220KV 500MVA ICT1@koradi 2	IntraState	09/04/2019	06.42	09/04/2019	13.37	PO	Testing Work
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Mahalakshmi Amona	InterState	10/04/2019	09.45	10/04/2019	17.31	PO	Routine Maintenance & Diagnostic Testing Work.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Adlabs - Pedambe	IntraState	08/04/2019	10.25		Continued.	PO	Preventive Maintenance Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 10/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PANDHARPUR BHALVANI	IntraState	08/04/2019	17.05	09/04/2019	16:45	EO	Attending Hot Spot
Lamboti -Solapur li(Bale) Ckt- li	IntraState	09/04/2019	06.25	09/04/2019	14.43	T	Bus Bar Protection Operated due to B Phase PT Burst
Osmanabad - Solapur (Bale)	IntraState	09/04/2019	06.25	09/04/2019	22.20	T	Bus Bar Protection Operated due to B Phase PT Burst
Solapur(Bale) - Tuljapur	IntraState	09/04/2019	06.25	09/04/2019	22.15	T	Bus Bar Protection Operated due to B Phase PT Burst
Lamboti - Solapur li(Bale) Ckt- I	IntraState	09/04/2019	06.25	09/04/2019	06.51	T	Taken in service by Bypassing Distance Relay
Mahad - Pedambe	IntraState	09/04/2019	08.10	09/04/2019	15.15	PO	Washing of Insulator String
Deepnagar Bambhori	IntraState	09/04/2019	08.29	09/04/2019	14.41	PO	Line Maintenance work
Koradi-Ambazari-li	IntraState	09/04/2019	09.35	09/04/2019	14.36	PO	Testing Work
Hingoli- Girawali	IntraState	09/04/2019	11.04	09/04/2019	15.38	EO	To attend Hot Spot
Uran - Kharghar 2	IntraState	09/04/2019	11.08		Continued.	PO	Carrying out Reorientation of said line
Nagothane-Wadkhal II	IntraState	09/04/2019	11.28	09/04/2019	22.23	PO	Replacement of CT at Nagothane end
Dahanu Ghodbunder Line 1	IntraState	09/04/2019	14.28	09/04/2019	17.34	EO	To attend Hot Spot
Lamboti - Solapur li(Bale) Ckt- I	IntraState	09/04/2019	14.33	09/04/2019	22.00	T	Distance Protection Zone 1
Alkud Miraj	IntraState	09/04/2019	15.07	09/04/2019	19.51	PO	Replacement of Jumper
IPCL - SPCL	IntraState	10/04/2019	07.20	10/04/2019	18.52	T	Distance Protection B-PH,LA, Blast At Spcl.
Dhule-Amalner(220kv)	IntraState	10/04/2019	09.32	10/04/2019	14.00	EO	Attending Hot Spot
Lamboti - Solapur li(Bale) Ckt- I	IntraState	10/04/2019	09.57	10/04/2019	12.57	PO	Distance Relay Testing Work
Mudshingi-Wathar	IntraState	10/04/2019	10.20	10/04/2019	14.23	PO	Quarterly Maintenance Work
TPC Borivali Aarey Line 1	IntraState	10/04/2019	10.28	10/04/2019	17.12	PO	Annual Maintenance Work
Taptitanda-Jalna ckt II	IntraState	10/04/2019	10.46	10/04/2019	15.05	PO	Diagnostic Testing Work.
Vita-Hiwarwadi	IntraState	10/04/2019	12.03	10/04/2019	16.29	PO	Replacement of Y-PH Flashover String.
Nanded-Ghatodi	IntraState	10/04/2019	12.57	10/04/2019	16.27	T	Distance Protection
Koradi - Kawlewada II	IntraState	10/04/2019	16.05	10/04/2019	16.26	T	Distance Protection
Aurangabad (Waluj)-Bhenda	IntraState	10/04/2019	18.20	10/04/2019	22.05	PO	Quarterly Maintenance Work
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Buccholz Trip.
220/110 Kv 200 MVA ICT-III @Kolhapur-II (Mudshingi)	IntraState	05/04/2019	10.03		Continued.	PO	Quarterly Maintainance Work
220/132 KV ICT-2 @Nagar	IntraState	05/04/2019	10.45		Continued.	PO	oil Filtration.
220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded	IntraState	09/04/2019	06.20	09/04/2019	09.12	EO	To attend Hot Spot
220/132 Kv 100 Mva Ict 2 @Paranda	IntraState	09/04/2019	10.35	09/04/2019	11.15	PO	Pre Monsoon maintenance work
220/132 Kv 100 Mva Emco Ict @Bhenda	IntraState	10/04/2019	18.02	10/04/2019	21.17	HT	HT For Above Outage.
132 KV LINE Outages/Trippings							
Mansar Pench	InterState	07/03/2019	15.40		Continued.	HT	Hand trip Form Pench end for system requirment.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage