

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/May/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	83.113	642.987	1) Gujrat	7.621	64.716
2) Hydro	25.583	164.718	2) Madhya Pradesh	11.223	123.904
3) Gas	6.723	60.548	3) Chattisgarh	8.330	78.300
Total MSPGCL	115.419	868.253	4) Maharashtra	146.680	1320.099
B) 1) APLM	71.086	635.645	5) Goa (Amona)	-0.462	-3.410
2) JSWEL	16.181	140.052	Total	173.392	1583.609
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.077	211.032
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.092	224.902
5) WPCL	2.698	24.240	c) MSEDCL Bilateral *	63.109	587.672
6) Other IPP	7.558	64.260	Include PX	39.596	379.216
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.077	211.032
C) 1) TPCL Thermal	6.487	58.001	Include PX	16.193	150.447
2) TPCL Hydro	5.004	42.072	Standby	0.000	0.000
3) TPCL Gas	4.401	39.475	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.985	81.546	1) MSEDCL	383.088	3334.087
D) STATE			2) Mumbai Discoms	48.969	445.997
1) Thermal	196.108	1646.731	TOTAL STATE	432.057	3780.084
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	30.587	206.790			
3) Gas (A3+B7+C3)	11.124	100.023			
4) Wind	13.393	173.948			
6) SOLAR	7.453	68.982			
TOTAL STATE	258.665	2196.474			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3219	3523	3519	3545
MSPGCL Hydro	530	1024	1766	970
MSPGCL Gas	287	265	272	285
MSPGCL Total Generation	4036	4812	5556	4800
Central Sector Receipt	7569	8719	5660	6917
WIND	485	291	725	794
CPP / IPP Thermal	4015	4199	4143	4002
CPP / IPP Gas	0	0	0	0
SOLAR	947	565	0	0
Exchange with Mumbai	-1034	-994	-996	-911
MSEDCL DEMAND MET	16018	17592	15088	15602
Load Shedding	0	0	0	0
MSEDCL DEMAND	16018	17592	15088	15602
TPCL GENERATION	522	677	906	723
AEML GENERATION	375	374	375	373
MUMBAI DEMAND	1931	2045	2277	2007
STATE DEMAND MET	17950	19636	17366	17608
STATE DEMAND	17950	19636	17366	17608
Frequency (Hz)	49.98	49.89	49.90	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 18.01 Hrs	49.72 Hz at 22.19 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 09/May/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	0.00	0.00	0	0
Total	0.00	0.00		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.41	33.25	242	199
Total	5.41	33.25		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	10.40	91.91	475	365
Unit 7	10.23	61.07	462	360
Unit 8	11.45	101.82	495	385
Unit 9	10.50	91.73	450	370
Total	42.58	346.53		
Paras				
Unit 3	5.18	35.36	250	164
Unit 4	5.97	50.77	254	211
Total	11.15	86.14		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	4.34	22.42	190	160
Unit 3	4.45	21.12	195	160
Unit 4	4.34	38.06	190	160
Unit 5	10.86	95.48	490	365
Total	23.98	177.07		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.72	60.55	293	265
Total	6.72	60.55		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	1.07	37	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.13	1.07		
Koyna				
Stage 1-2	7.23	48.27	555	40
Stage 4	11.94	69.65	996	0
Stage 3	4.02	24.93	320	0
Total	23.19	142.84		
Hydro				
KDPH	0.80	7.09	34	34
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.28	2.41	80	0
RNGR+BHTSA	0.27	2.61	12	11
BHANDARDRA	0.48	4.23	36	12
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.56	5.53	33	20
GHATGHAR	0.00	0.00	0	0
Total	2.39	21.88		
Wind				
Total	13.39	173.95	0	0
Total	13.39	173.95		
CPP				
APML(Mus)	71.09	635.64	0	0
JSWEL(Mus)	16.18	140.05	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.70	24.24	0	0
Other(Mus)	7.56	64.26	0	0
Total	97.52	864.20		
SOLAR				
Total	7.45	68.98	0	0
Total	7.45	68.98		
Tata				
Trombay 5	6.49	58.00	275	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	25.23	117	117
Trombay 7B	1.59	14.24	67	66
Trombay 8	0.00	0.00	0	0
TATA Hydro	5.00	42.07	452	8
Total	15.89	139.55		
AEML				
DTPS U-1&2	8.98	81.55	377	373
Total	8.98	81.55		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	83.11	642.99	MSPGCL Total	115.42	868.25
			MSPGCL Thml+Gas	89.84	703.54	Koyna 1,2 & 4 Total	19.17	117.92
			MSPGCL Hydro	25.58	164.72	State Total	258.66	2196.47

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/May/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3537	1674	285	5496	669	4001	0	0	6814	6765	-1190	15742	0	15742	2358	18100	50.00
2	3531	1546	285	5362	663	3987	0	0	6876	6534	-1075	15470	0	15470	2230	17700	50.00
3	3523	1146	285	4954	744	4031	0	0	6975	6879	-972	15636	0	15636	2106	17742	49.94
4	3545	970	285	4800	794	4002	0	0	6840	6917	-911	15602	0	15602	2007	17608	49.97
5	3571	1230	287	5088	852	4007	0	0	6866	6743	-859	15830	0	15830	1959	17790	49.97
6	3581	1142	288	5012	643	4010	0	0	7754	7453	-834	16284	0	16284	1963	18246	49.98
7	3571	774	287	4632	642	4085	0	50	8362	8006	-756	16660	0	16660	1876	18536	50.00
8	3535	398	288	4222	602	4080	0	249	8161	8204	-842	16514	0	16514	1840	18354	49.99
9	3578	370	286	4234	422	4085	0	520	7666	7624	-1023	15862	0	15862	1877	17740	50.04
10	3427	574	271	4272	424	4057	0	774	7453	7152	-922	15756	0	15756	1905	17662	49.99
11	3219	530	287	4036	485	4015	0	947	7838	7569	-1034	16018	0	16018	1931	17950	49.98
12	3021	502	267	3790	448	3795	0	956	8465	7916	-1105	15800	0	15800	1951	17750	49.98
13	3136	728	277	4140	450	3766	0	984	8603	8907	-1100	17148	0	17148	1956	19104	49.95
14	3200	658	267	4124	276	3993	0	912	8548	8477	-1127	16656	0	16656	1964	18620	49.97
15	3523	968	285	4776	318	4179	0	802	8626	8289	-1064	17300	0	17300	2016	19316	49.91
16	3523	1024	265	4812	291	4199	0	565	8578	8719	-994	17592	0	17592	2045	19636	49.89
17	3503	1078	277	4858	460	4120	0	410	8150	8055	-948	16956	0	16956	1995	18950	50.01
18	3525	1040	269	4834	393	4174	0	264	7473	7196	-1064	15798	0	15798	1914	17712	50.02
19	3510	1090	281	4882	395	4191	0	20	6232	6140	-1033	14594	0	14594	1881	16476	50.02
20	3521	1348	281	5150	489	4108	0	0	5918	5972	-1028	14690	0	14690	2034	16724	49.94
21	3496	1392	282	5170	574	4120	0	0	5655	5877	-931	14810	0	14810	2117	16928	50.01
22	3519	1766	272	5556	725	4143	0	0	5644	5660	-996	15088	0	15088	2277	17366	49.90
23	3482	1938	293	5714	808	4168	0	0	6121	5973	-1090	15572	0	15572	2350	17922	49.92
24	3536	1696	273	5504	826	4207	0	0	6512	6365	-1194	15708	0	15708	2417	18126	49.98
MUs	83.11	25.58	6.72	115.42	13.39	97.52	0.00	7.45	176.13	173.39	-24.09	383.09	0.00	383.09	48.97	432.06	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/May/2020

Position as on 6.30 Hrs of 10/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/May/2020

Position as on 6.30 Hrs of 10/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	22/04/2020	20.45		Continued.	Zero Schedule By MSEDCL	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Paras Unit 3	250	10/05/2020	01.27	10/05/2020	09.14	Clinker formation removal work	
MSPGCL	Parli Unit 8	250	10/05/2020	13.03		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/May/2020

Statement-VII

Position as on 6.30 Hrs of 10/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi III - Akola II- ckt-II	IntraState	10/05/2020	09.53	10/05/2020	18.22	T	B PH UNIT Differential.
Ektuni-Akola II Ckt 2	IntraState	10/05/2020	16.05	10/05/2020	19.09	T	Distance Protection
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	09/05/2020	13.09	10/05/2020	08.25	EO	Earth Electrode station problem
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/04/2020	17.40		Continued.	HT	Over Voltage
Chakan Talegaon(Pg)	InterState	09/05/2020	21.48	10/05/2020	08.09	EO	CVT Replacement.
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Girwali- Lonikand 2	IntraState	03/05/2020	17.48		Continued.	HT	Controlling loading of Parli Parli (PG) D/C.
Babhaleshwar - Padghe-I	IntraState	04/05/2020	11.56	09/05/2020	12.36	HT	Over Voltage
Dhule - Bableshwar - II	IntraState	06/05/2020	21.26		Continued.	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	09/05/2020	10.19	09/05/2020	11.21	T	Tripped while shifting on TBC
Khadka-Aurangabad (Waluj)	IntraState	09/05/2020	18.17		Continued.	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	10/05/2020	18.01		Continued.	HT	Over Voltage
Koradi-Bhusawal	IntraState	10/05/2020	18.05		Continued.	T	Distance Protection
Koradi-Khaperkheda I	IntraState	10/05/2020	18.06		Continued.	T	Over Voltage
Koradi-RattanIndia	IntraState	10/05/2020	18.08		Continued.	T	Distance Protection
Akola II - RPL(Rattanindia) Ckt-II	IntraState	10/05/2020	18.13	10/05/2020	23.10	T	Distance Protection
karad -kolhapur-II	IntraState	10/05/2020	18.39		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19		Continued.	PO	Attending Hot Spot
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	10/05/2020	08.31	10/05/2020	13.10	EO	Attending Oil Leakage
400/220/33 Kv 315 MVA ICT II @Babhleshwar	IntraState	10/05/2020	08.52	10/05/2020	13.02	PO	Y PH UNIT Temp. meter Replacement.
400/220 Kv 315 Mva Ict 1 @Chakan	IntraState	10/05/2020	14.13	10/05/2020	16.41	EO	Oil Top UP .
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Boiser(M)-Boiser(PG) -III	InterState	10/05/2020	09.37	10/05/2020	15.23	PO	B BUS Outage.
Vasai Boiser(PG)	InterState	10/05/2020	09.51	10/05/2020	09.56	HT	Shifting From B-BUS To A BUS.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Sawantwadi-Bidri	IntraState	08/05/2020	20.42	09/05/2020	09.00	HT	Over Voltage
Bhambori Amalner	IntraState	09/05/2020	06.15	09/05/2020	17.13	PO	Disc Insulator replacement

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/May/2020

Statement-VII

Position as on 6.30 Hrs of 10/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KORADI 2 - KAULEWADA CKT - I	IntraState	09/05/2020	09.07	09/05/2020	18.16	PO	Tightening of Nut Bolts and String replacement work
Bus B @ Padaghe	IntraState	09/05/2020	09.30	10/05/2020	20.08	PO	Isolator Maintenance work.
512 Khadki- Century Enka	IntraState	09/05/2020	09.35	09/05/2020	11.35	PO	Testing Work
Parli 2-(Girwali) -Murud	IntraState	09/05/2020	19.47	09/05/2020	21.45	EO	To attend Hot Spot
Chakan-Chinchwad	IntraState	09/05/2020	21.17	10/05/2020	08.32	PO	To Manage Load.
Virur - Gadchiroli	IntraState	10/05/2020	05.00	10/05/2020	05.12	T	Distance Protection
Boisar II - Boisar PG II	IntraState	10/05/2020	08.51	10/05/2020	15.08	PO	B BUS OUTAGE.
Tata Borivli MSETCL Borivli 4	IntraState	10/05/2020	10.42		Continued.	PO	LA replacement.
Nanded- Bhokar I	IntraState	10/05/2020	15.14	10/05/2020	19.36	PO	Disc Replacement work.
Balapur-Malegaon	IntraState	10/05/2020	17.46	10/05/2020	18.54	T	Distance Protection
Karad - Kadegaon	IntraState	10/05/2020	18.11		Continued.	T	Distance Protection
AKOLA ANJANGAON (VIHIGAON) CKT-II	IntraState	10/05/2020	18.22	10/05/2020	20.12	T	Distance Protection
Pusad-WardhaPG(Deoli)	IntraState	10/05/2020	19.10	10/05/2020	21.39	T	Distance Protection
Badnera-Akola li	IntraState	10/05/2020	20.00		Continued.	T	Distance Protection
Badnera-Akola I	IntraState	10/05/2020	22.54	10/05/2020	23.25	HT	ST LOC No.16 Sparking Observed.
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	27/04/2020	17.15		Continued.	HT	Over Voltage
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/132kv 200mva Vijai Ptr 1 @Lonand	IntraState	09/05/2020	08.43	09/05/2020	18.52	PO	Routine Maintenance Work
220/132Kv 200MVA ICT-I @ Chikhali	IntraState	09/05/2020	14.06		Continued.	PO	Oil Filtration work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage