

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Jun/2019 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	156.381	1462.578	1) Gujrat	-1.779	-14.325
2) Hydro	3.711	38.021	2) Madhya Pradesh	5.113	65.327
3) Gas	3.409	53.831	3) Chattisgarh	3.050	31.450
Total MSPGCL	163.501	1554.430	4) Maharashtra	112.131	1018.386
B) 1) APML	69.739	646.309	5) Goa (Amona)	-0.330	-3.366
2) JSWEL	23.189	217.251	Total	118.185	1097.472
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.771	275.595
4) RPL(AMT)	23.690	221.820	b) Mumbai Drawl	35.407	348.238
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	10.358	96.022
6) Other IPP	6.577	64.827	Include PX	-4.968	-35.081
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.771	275.595
C) 1) TPCL Thermal	12.855	119.930	Include PX	10.388	121.432
2) TPCL Hydro	0.998	24.271	Standby	0.000	0.000
3) TPCL Gas	4.358	38.942	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.325	86.182	1) MSEDCL	397.664	3775.428
D) STATE			2) Mumbai Discoms	63.943	617.564
1) Thermal	302.756	2818.897	TOTAL STATE	461.607	4392.992
(A1+C1+C4+(B1-B6))					
2) Hydro	4.709	62.292			
(A2+C2)					
3) Gas	7.767	92.773			
(A3+B7+C3)					
4) Wind	21.991	266.255			
6) SOLAR	6.199	55.302			
TOTAL STATE	343.422	3295.519			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6550	6707	6511	6619
MSPGCL Hydro	163	148	309	339
MSPGCL Gas	142	142	145	147
MSPGCL Total Generation	6855	6997	6965	7105
Central Sector Receipt	5336	5641	4479	4726
WIND	884	811	1037	802
CPP / IPP Thermal	4932	5377	4876	5162
CPP / IPP Gas	0	0	0	0
SOLAR	823	702	0	0
Exchange with Mumbai	-1425	-1608	-1625	-1822
MSEDCL DEMAND MET	17405	17920	15732	15973
Load Shedding	0	0	0	0
MSEDCL DEMAND	17405	17920	15732	15973
TPCL GENERATION	697	728	826	780
AEML GENERATION	496	497	376	376
MUMBAI DEMAND	2618	2833	2827	2978
STATE DEMAND MET	20023	20753	18559	18951
STATE DEMAND	20023	20753	18559	18951
Frequency (Hz)	49.92	49.95	49.96	49.92

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 19.02 Hrs	49.73 Hz at 00.06 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 09/Jun/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.44	33.91	180	0
Unit 7	3.21	25.28	156	110
Unit 8	9.76	78.52	450	345
Unit 9	8.93	92.48	460	295
Unit 10	8.83	92.17	400	306
Total	33.17	322.36		
Bhusawal				
Unit 3	0.00	12.44	0	0
Unit 4	9.38	89.85	485	350
Unit 5	8.34	69.89	455	95
Total	17.72	172.18		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	11.77	0	0
Total	0.00	11.77		
Chandrapur				
Unit 3	4.42	38.88	195	163
Unit 4	3.95	35.21	167	158
Unit 5	9.45	85.79	427	370
Unit 6	9.74	89.86	460	330
Unit 7	9.48	86.48	432	340
Unit 8	10.92	99.25	496	360
Unit 9	10.80	94.91	485	365
Total	58.76	530.40		
Paras				
Unit 3	5.76	52.53	258	178
Unit 4	5.38	49.63	240	198
Total	11.14	102.16		
Khaparkheda				
Unit 1	3.38	28.92	145	140
Unit 2	2.18	26.24	140	60
Unit 3	3.37	30.15	150	133
Unit 4	3.37	30.13	142	140
Unit 5	11.33	99.48	495	385
Total	23.63	214.92		
Nasik				
Unit 3	3.97	37.01	196	157
Unit 4	4.03	35.06	204	158
Unit 5	3.97	36.74	188	158
Total	11.97	108.81		
Uran				
All Units	3.41	53.83	147	132
Total	3.41	53.83		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.01	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.01		
Koyna				
Stage 1-2	1.54	11.72	180	40
Stage 4	0.00	0.00	0	0
Stage 3	0.63	2.79	152	0
Total	2.16	14.51		
Hydro				
KDPH	0.43	3.89	18	18
VTRNA	0.76	8.53	61	0
TILLARI	0.00	0.97	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.14	1.32	40	0
RNGR+BHTSA	0.00	1.71	0	0
BHANDARDRA	0.00	1.07	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.10	1.56	5	4
GHATGHAR	0.12	4.46	116	0
Total	1.55	23.51		
Wind				
Total	21.99	266.26	0	0
Total	21.99	266.26		
CPP				
APML(Mus)	69.74	646.31	0	0
JSWEL(Mus)	23.19	217.25	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	23.69	221.82	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	6.58	64.83	0	0
Total	123.20	1150.21		
SOLAR				
Total	6.20	55.30	0	0
Total	6.20	55.30		
Tata				
Trombay 5	8.01	75.55	480	315
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	24.85	117	114
Trombay 7B	1.58	14.09	67	65
Trombay 8	4.85	44.38	231	198
TATA Hydro	1.00	24.27	132	2
Total	18.21	183.14		
AEML				
DTPS U-1&2	10.32	86.18	499	374
Total	10.32	86.18		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	156.38	1462.58	MSPGCL Total	163.50	1554.43
			MSPGCL Thml+Gas	159.79	1516.41	Koyna 1,2 & 4 Total	1.54	11.72
			MSPGCL Hydro	3.71	38.02	State Total	343.42	3295.52

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Jun/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6717	384	136	7237	868	5974	0	0	5213	5343	-1655	17767	0	17767	3065	20832	49.87
2	6757	127	145	7029	783	5917	0	0	5399	5465	-1499	17695	0	17695	2871	20566	49.88
3	6720	68	146	6934	893	5493	0	0	5476	5254	-1522	17052	0	17052	2691	19743	49.97
4	6671	68	146	6885	1029	5380	0	0	5567	5290	-1484	17100	0	17100	2562	19662	50.00
5	6501	67	146	6714	961	5117	0	0	5215	5140	-1404	16528	0	16528	2479	19007	49.97
6	6738	62	136	6936	774	5328	0	0	5520	5755	-1381	17412	0	17412	2456	19868	50.00
7	6821	62	146	7029	527	5434	0	33	5513	5338	-1262	17099	0	17099	2335	19434	50.00
8	6686	108	146	6940	631	5257	0	169	5213	5000	-1217	16780	0	16780	2290	19070	50.03
9	6177	128	146	6451	435	4902	0	362	5194	5013	-1260	15903	0	15903	2332	18235	50.04
10	6343	133	145	6621	483	4860	0	566	5259	5191	-1267	16454	0	16454	2423	18877	50.06
11	6536	123	133	6792	645	4930	0	765	5344	4991	-1338	16785	0	16785	2535	19320	50.00
12	6550	163	142	6855	884	4932	0	823	5631	5336	-1425	17405	0	17405	2618	20023	49.92
13	6594	203	141	6938	646	5004	0	915	5483	5061	-1487	17077	0	17077	2679	19756	49.95
14	6651	168	132	6951	699	5193	0	792	5456	5191	-1530	17296	0	17296	2723	20019	50.01
15	6707	148	142	6997	811	5377	0	702	5625	5641	-1608	17920	0	17920	2833	20753	49.95
16	6724	138	142	7004	780	5368	0	541	5702	5601	-1629	17665	0	17665	2882	20547	49.94
17	6314	123	132	6569	1110	5017	0	326	5442	4976	-1480	16518	0	16518	2794	19312	50.00
18	6085	128	144	6357	1316	4518	0	177	4521	4409	-1345	15432	0	15432	2655	18087	50.02
19	6109	102	145	6356	1733	4472	0	28	3617	2973	-1319	14243	0	14243	2545	16788	50.02
20	6100	206	145	6451	1596	4527	0	0	3653	3645	-1442	14777	0	14777	2647	17424	50.00
21	6114	242	135	6491	1414	4786	0	0	4284	3843	-1533	15001	0	15001	2732	17733	49.92
22	6511	309	145	6965	1037	4876	0	0	4237	4479	-1625	15732	0	15732	2827	18559	49.96
23	6619	339	147	7105	802	5162	0	0	4675	4726	-1822	15973	0	15973	2978	18951	49.92
24	6636	112	146	6894	1134	5371	0	0	5005	4524	-1873	16050	0	16050	2991	19041	49.94
MUs	156.38	3.71	3.41	163.50	21.99	123.20	0.00	6.20	122.24	118.18	-35.41	397.66	0.00	397.66	63.94	461.61	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Jun/2019

Position as on 6.30 Hrs of 10/Jun/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	20/05/2019	16.01		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 3	210	04/06/2019	20.15		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 5	500	07/06/2019	06.17	09/06/2019	00.10	Ash Feed Gate replacement work	
MSPGCL	Koyana STG-IV Unit-3	250	07/06/2019	10.00		Continued.	Stepup T/F Oil Leakage and Shaft Seal replacement	
MSPGCL	Uran Unit 5	108	07/06/2019	23.45		Continued.	Air Filter Replacement & Allied Work.	
MSPGCL	Koradi Unit 6	210	09/06/2019	08.24	09/06/2019	14.50	Flame Failure	
MSPGCL	Koradi Unit 7	210	10/06/2019	17.06		Continued.	ID Fan Problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 1	IntraState	09/06/2019	15.09	09/06/2019	21.31	PO	CHEMICAL WASHING OF INSULATORS.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	04/06/2019	18.55		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	10/06/2019	10.55	10/06/2019	14.32	EO	TBC SHIFTING AT KOLHAPUR END HOT SPOT ATTENDING WORK.
Akola Wardha li	InterState	10/06/2019	14.24	10/06/2019	19.40	HT	H/T FROM WARDHA PG END WORK BY PGCIL.
Chakan Talegaon(Pg)	InterState	10/06/2019	17.50		Continued.	T	Distance Protection
Khadka-Aurangabad (Waluj)	IntraState	07/06/2019	21.13	10/06/2019	08.20	HT	Over Voltage
New Koyna - Dabhol - II	IntraState	09/06/2019	03.34	09/06/2019	04.05	T	Distance Protection tripped at Dabhol end only.
New Koyna - Dabhol - II	IntraState	09/06/2019	04.30	09/06/2019	09.45	T	Distance Protection tripped at Dabhol end only.
Lonikand I - Koyna stage-IV	IntraState	09/06/2019	05.13	09/06/2019	14.42	T	Distance Protection
Padghe - Kalwa-II	IntraState	09/06/2019	05.26	09/06/2019	10.28	EO	Replacement of decapped insulator string at location number 1029.
Nagothane - Dabhol I	IntraState	09/06/2019	06.02	09/06/2019	11.22	T	Distance Protection tripped at Dabhol end only.
N.Koyna-Karad -Ckt I	IntraState	09/06/2019	06.07	09/06/2019	14.40	T	Distance Protection
Chakan-Talegaon (Pgcil)	IntraState	09/06/2019	20.03	10/06/2019	07.32	T	TRIPPED FROM CHAKAN END Z1,Y-E,4KM,20KA FROM TALEGAON PG 1.03KM,18.70KAMP.
Karad - Jaigad - II	IntraState	10/06/2019	09.16	10/06/2019	19.15	PO	ATTENDING DECAPPING.
Lonikand I - Koyna stage-IV	IntraState	10/06/2019	09.54	10/06/2019	18.14	PO	CHEMICAL CLEANING OF DISC INSULATOR.
Deepnagar Taptitanda	IntraState	10/06/2019	09.57	10/06/2019	15.03	PO	DISTANCE RELAY REPLACEMENT WORK.
Akola II - RPL(Rattaniindia) Ckt-II	IntraState	10/06/2019	14.24	10/06/2019	19.49	HT	EMERGENCY OUTAGE AT WARDHA PG END.
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	10/06/2019	17.42	10/06/2019	19.40	T	Distance Protection
Bhusawal-Aurangabad	IntraState	10/06/2019	18.18		Continued.	HT	Over Voltage
Akola II - RPL(Rattaniindia) Ckt I	IntraState	10/06/2019	19.38	10/06/2019	19.52	PO	DUE TO EMERGENCY O/G ON WARDHA PG-AKOLA CKT 2.
Padghe - Nagothane - I	IntraState	10/06/2019	19.43		Continued.	T	Distance Protection
Padghe - Nagothane - II	IntraState	10/06/2019	19.44		Continued.	T	Distance Protection
Padghe - Kalwa-II	IntraState	10/06/2019	21.25		Continued.	T	Distance Protection
Kharghar-Talegaon(PG)	IntraState	10/06/2019	22.31		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	09/06/2019	09.08	09/06/2019	17.3	PO	OLTC Overhauling.
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	10/06/2019	12.50	10/06/2019	13.50	T	TRIPPED ON PDR.
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	10/06/2019	14.50	10/06/2019	15.22	T	TRIPPED ON PDR.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	10/06/2019	21.24		Continued.	T	Buccholz Protection Optd
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Boiser(M)-Boiser(PG) -III	InterState	09/06/2019	09.21	09/06/2019	21.25	PO	Construction work
Khaparkheda-Butibori 3	InterState	09/06/2019	10.47	09/06/2019	12.54	EO	Removal of Earthwire.
Boisar(MS) - Boisar (PG) - I	InterState	09/06/2019	12.02	09/06/2019	17.16	PO	CONSTRUCTION WORK.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Warora - Hinganghat	IntraState	07/06/2019	17.16		Continued.	T	Tower Collapsed At Location No.327, RYB 3.94KA, 4.41KA, 4.11KA.
Warora - Wardha	IntraState	07/06/2019	17.16		Continued.	T	Wrora-Y PH Pick, B PH Pick Up,Z1.Wardha-Y PH B PH, Z1-B 91.8 KM.3.31KAMP.3.24KAMP.
Kandalgaon - Koyna (Pophali)	IntraState	09/06/2019	06.50	09/06/2019	07.50	T	Distance Protection
Midc Chandrapur-Gadchandur	IntraState	09/06/2019	07.46	09/06/2019	16.50	PO	FOR CRIMPING OF CONDUCTOR WITH REPAIR SLEEVES AT LOC.123&124 AND SIGNATURE TEST.
Boisar(M) - Ghodbunder	IntraState	09/06/2019	08.56	09/06/2019	09.43	HT	LOAD MANAGEMENT ON BOISAR-BOISAR-PG OUTAGE.
Boisar Versova Line	IntraState	09/06/2019	09.05	09/06/2019	09.41	HT	Load Management On Boisar-PG Outage.
Balapur-Akola I	IntraState	09/06/2019	10.35	09/06/2019	13.33	PO	Line Maintenance work
Khaparkheda-Ambazari-Ii	IntraState	09/06/2019	10.42	09/06/2019	12.25	PO	REMOVAL OF EARTHWIRE FROM LOCATION NO.29-30 OF 220KV NEW KHAPERKHEDA-AMBAZARI-1&220KV KHAPERKHEDA-BUTTIBORI 3CKT.
Boisar-Viraj	IntraState	09/06/2019	11.27	09/06/2019	17.25	HT	LOAD MANAGMENT ON BOISAR-BOISAR-PG OUTAGE.
Lonikand-VSNL	IntraState	09/06/2019	17.27	10/06/2019	06.07	T	Distance Protection
Loteparshuram- Dasturi Line	IntraState	09/06/2019	18.06	10/06/2019	13.48	T	INSULATOR BROKEN AT LOC. NO.97.
Kandalgaon - Koyna (Pophali)	IntraState	09/06/2019	18.55	09/06/2019	21.05	T	TRIPPED FROM POPHALI END ONLY.
Parly-Parly Extn.-II	IntraState	09/06/2019	19.48	09/06/2019	21.25	T	Y-PHASE CT BRUST: ALL 220KV LINE AFFECTED.
Trombay Salsette 1 Backbay	IntraState	09/06/2019	23.22	09/06/2019	23.53	T	Distance Protection
Pusad-Ghatodi	IntraState	10/06/2019	08.01	10/06/2019	10.35	PO	ARRESTING MINOR LEAKAGE PF R-PH. CT. ROUTINE MAINTENANCE WORK.
Nagothane-Wadkhal II	IntraState	10/06/2019	09.08	10/06/2019	19.38	PO	PROVIDING EART WIRE AT MISSING SPAN LOC. NO.56 TO 60.
Oni Kharepatan Line	IntraState	10/06/2019	09.15	10/06/2019	16.43	PO	BUS OUTAGE AT ONI.
Mudshingi-Wathar	IntraState	10/06/2019	10.00	10/06/2019	16.40	PO	INSULATOR CLEANING WORK.
Raymond - Washala	IntraState	10/06/2019	11.05	10/06/2019	12.35	PO	EO-HOT SPOT ATTENDING WORK AT WAVE TRAP.
Kandalgaon - ONGC Panvel	IntraState	10/06/2019	11.23	10/06/2019	15.25	PO	INSULATOR CHATTERING WORK.
Miraj - Mhaishal	IntraState	10/06/2019	11.47	10/06/2019	13.52	PO	Quarterly Maintainance Work
CHAKAN (400 KV)- Chinchwad2	IntraState	10/06/2019	18.00		Continued.	T	Distance Protection
Chinchwad-Hinjewadi I	IntraState	10/06/2019	18.01		Continued.	HT	TO CONTROL OVERLOADING.
Raymond - Washala	IntraState	10/06/2019	18.30	10/06/2019	19.09	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Eklahara(Gcr)(Nasik)- Bableshtar-I	IntraState	10/06/2019	18.44		Continued.	T	Distance Protection
Ghatghar - Jindal	IntraState	10/06/2019	18.50	10/06/2019	19.34	T	Distance Protection
Bombay Dyeing - Sahara	IntraState	10/06/2019	20.29		Continued.	T	Distance Protection
Uran - Kharghar 2	IntraState	10/06/2019	21.13	10/06/2019	21.30	T	Distance Protection
Uran - Ongc Uran	IntraState	10/06/2019	21.22		Continued.	T	Distance Protection
Colourchem - Temghar	IntraState	10/06/2019	21.34		Continued.	T	Distance Protection
Roma-Bhavegar	IntraState	10/06/2019	21.39		Continued.	T	Distance Protection
ANANDNAGAR - PALAVA	IntraState	10/06/2019	21.42		Continued.	T	TRIPPED FROM PALAVA END.
Dahanu Versova	IntraState	10/06/2019	21.51	10/06/2019	22.14	T	Distance Protection
Mulund - GIS Bhandup	IntraState	10/06/2019	21.52	10/06/2019	23.08	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Bucchoz Trip.
220/100 Kv 100 MVA ICT II @Kandalgaon	IntraState	01/06/2019	11.30		Continued.	PO	Oil Filtration Work.(Charged On Humming).
220/132 Kv 200 Mva Cgl Ict @Satana	IntraState	10/06/2019	09.10	10/06/2019	10.30	PO	PRE MONSOON MAINTENANCE WORK.
220/33kv 125 Mva Transformer 2 @Aarey R/S	IntraState	10/06/2019	09.10	10/06/2019	17.58	PO	Annual Maintenance Work
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	10/06/2019	10.24	10/06/2019	16.30	PO	Quarterly Maintainance Work
220/132Kv 200MVA ICT-I @ Akola	IntraState	10/06/2019	10.39	10/06/2019	19.03	PO	ROUTINE BAY MAINTENANCE AND DIAGNOSTIC TESTING WORK.
220/33kv 125 MVA T/F-III @ Goregaon	IntraState	10/06/2019	10.44	10/06/2019	17.20	PO	PRE MONSOON MAINTENANCE WORK.
220/100 KV 200MVA ICT II @ Pal	IntraState	10/06/2019	22.10		Continued.	T	INTERNAL FAULT.
110 KV LINE Outages/Trippings							
Kalyan Kalwa Salsette 1	IntraState	10/06/2019	10.23	10/06/2019	12.42	PO	TREE TRIMMING.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage