

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 09/Jun/2022 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 161.656        | 1535.773        | 1) Gujrat                      | -5.106         | -53.296         |
| 2) Hydro            | 12.439         | 124.083         | 2) Madhya Pradesh              | 1.283          | 32.550          |
| 3) Gas              | 6.471          | 38.588          | 3) Chattisgarh                 | 2.220          | 18.720          |
| <b>Total MSPGCL</b> | <b>180.566</b> | <b>1698.444</b> | 4) Maharashtra                 | 170.628        | 1582.526        |
| B) 1) APMIL         | 66.941         | 650.488         | 5) Goa (Amona)                 | -1.741         | -9.235          |
| 2) JSWEL            | 16.446         | 151.886         | <b>Total</b>                   | <b>167.284</b> | <b>1571.265</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 37.458         | 316.079         |
| 4) RPL(AMT)         | 25.525         | 222.814         | b) Mumbai Drawl                | 41.040         | 348.721         |
| 5) SWPGPL           | 9.283          | 77.282          | c) MSEDCL Bilateral *          | 67.546         | 686.864         |
| 6) Other IPP        | 14.284         | 137.678         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 37.447         | 315.880         |
| C) 1) TPCL Thermal  | 14.990         | 138.106         | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 5.613          | 48.130          | Standby                        | 0.011          | 0.199           |
| 3) TPCL Gas         | 1.991          | 12.678          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.999         | 102.328         | 1) MSEDCL                      | 459.146        | 4416.039        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 74.634         | 649.962         |
| 1) Thermal          | 320.124        | 3016.355        | 3) Other Discoms               | 9.571          | 85.625          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>543.351</b> | <b>5151.626</b> |
| 2) Hydro (A2+C2)    | 18.052         | 172.213         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 8.462          | 51.266          |                                |                |                 |
| 4) Wind             | 19.904         | 252.891         |                                |                |                 |
| 6) SOLAR            | 9.524          | 87.637          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>376.066</b> | <b>3580.362</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 23 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 6609                      | 6784                  | 6719                      | 6803                       |
| MSPGCL Hydro               | 920                       | 706                   | 428                       | 1034                       |
| MSPGCL Gas                 | 266                       | 276                   | 267                       | 269                        |
| MSPGCL Total Generation    | 7796                      | 7766                  | 7414                      | 8106                       |
| Central Sector Receipt     | 8819                      | 8819                  | 6050                      | 4846                       |
| WIND                       | 375                       | 389                   | 1234                      | 1030                       |
| CPP / IPP Thermal          | 5239                      | 5572                  | 5453                      | 5802                       |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                          |
| SOLAR                      | 1276                      | 1109                  | 38                        | 0                          |
| Exchange with Mumbai       | -2204                     | -2215                 | -1660                     | -1364                      |
| <b>MSEDCL DEMAND MET</b>   | <b>20860</b>              | <b>21033</b>          | <b>18071</b>              | <b>18023</b>               |
| Load Shedding              | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 20860                     | 21033                 | 18071                     | 18023                      |
| TPCL GENERATION            | 920                       | 970                   | 1141                      | 1067                       |
| AEML GENERATION            | 477                       | 477                   | 497                       | 395                        |
| <b>MUMBAI DEMAND</b>       | <b>3601</b>               | <b>3662</b>           | <b>3298</b>               | <b>2826</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>441</b>                | <b>408</b>            | <b>458</b>                | <b>397</b>                 |
| STATE DEMAND MET           | 24902                     | 25102                 | 21828                     | 21246                      |
| <b>STATE DEMAND</b>        | <b>24902</b>              | <b>25102</b>          | <b>21828</b>              | <b>21246</b>               |
| Frequency (Hz)             | 49.99                     | 49.97                 | 50.03                     | 49.83                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.24 Hz at 16.02 Hrs | 49.57 Hz at 22.15 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 09/Jun/2022

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.40         | 39.23         | 195      | 155      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 13.46        | 118.98        | 575      | 501      |
| Unit 9             | 11.18        | 109.71        | 494      | 427      |
| Unit 10            | 11.03        | 110.52        | 537      | 392      |
| <b>Total</b>       | <b>40.07</b> | <b>378.44</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.14         | 30.60         | 150      | 115      |
| Unit 4             | 10.69        | 93.16         | 470      | 375      |
| Unit 5             | 10.30        | 76.51         | 450      | 400      |
| <b>Total</b>       | <b>24.13</b> | <b>200.27</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.34         | 43.84         | 240      | 150      |
| Unit 7             | 3.93         | 37.71         | 199      | 126      |
| Unit 8             | 3.17         | 28.00         | 142      | 126      |
| <b>Total</b>       | <b>11.43</b> | <b>109.55</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.92         | 24.72         | 130      | 120      |
| Unit 4             | 2.85         | 27.42         | 123      | 115      |
| Unit 5             | 8.71         | 77.03         | 375      | 300      |
| Unit 6             | 9.10         | 82.82         | 400      | 295      |
| Unit 7             | 9.10         | 78.21         | 414      | 295      |
| Unit 8             | 10.96        | 96.93         | 472      | 446      |
| Unit 9             | 3.16         | 84.83         | 435      | 0        |
| <b>Total</b>       | <b>46.80</b> | <b>471.97</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.36         | 45.28         | 225      | 132      |
| Unit 4             | 4.50         | 39.53         | 218      | 142      |
| <b>Total</b>       | <b>8.86</b>  | <b>84.81</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.42         | 29.06         | 155      | 130      |
| Unit 2             | 3.72         | 32.00         | 160      | 150      |
| Unit 3             | 4.28         | 37.56         | 184      | 165      |
| Unit 4             | 0.00         | 13.16         | 0        | 0        |
| Unit 5             | 10.98        | 98.67         | 476      | 430      |
| <b>Total</b>       | <b>22.40</b> | <b>210.46</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.93         | 34.42         | 184      | 130      |
| Unit 4             | 4.02         | 20.67         | 191      | 115      |
| Unit 5             | 0.00         | 25.17         | 0        | 0        |
| <b>Total</b>       | <b>7.95</b>  | <b>80.27</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.47         | 38.59         | 279      | 255      |
| <b>Total</b>       | <b>6.47</b>  | <b>38.59</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.30         | 3.01          | 31       | 0        |
| <b>Total</b>       | <b>0.30</b>  | <b>3.01</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 2.04          | 28.70          | 440      | 35       |
| Stage 4         | 2.81          | 27.01          | 500      | 0        |
| Stage 3         | 0.99          | 13.50          | 152      | 0        |
| <b>Total</b>    | <b>5.84</b>   | <b>69.20</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.49          | 4.63           | 21       | 21       |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.00          | 0.54           | 0        | 0        |
| BHIRA T.R.      | 0.31          | 2.81           | 80       | 0        |
| SMLHY_PTN       | 4.95          | 42.87          | 220      | 169      |
| GHATGHAR        | 0.54          | 1.01           | 125      | 0        |
| <b>Total</b>    | <b>6.30</b>   | <b>51.87</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 19.90         | 252.89         | 0        | 0        |
| <b>Total</b>    | <b>19.90</b>  | <b>252.89</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 66.94         | 650.49         | 0        | 0        |
| JSWEL(Mus)      | 16.45         | 151.89         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 25.52         | 222.81         | 0        | 0        |
| SWPGPL-Mus      | 9.28          | 77.28          | 0        | 0        |
| Other(Mus)      | 14.28         | 137.68         | 0        | 0        |
| <b>Total</b>    | <b>132.48</b> | <b>1240.15</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 9.52          | 87.64          | 0        | 0        |
| <b>Total</b>    | <b>9.52</b>   | <b>87.64</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.55          | 90.03          | 447      | 270      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.07          | 8.81           | 47       | 43       |
| Trombay 7B      | 0.92          | 3.86           | 40       | 37       |
| TATA Hydro      | 5.61          | 48.13          | 441      | 5        |
| Trombay 8       | 5.44          | 48.08          | 242      | 199      |
| <b>Total</b>    | <b>22.59</b>  | <b>198.91</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.00         | 102.33         | 499      | 359      |
| <b>Total</b>    | <b>11.00</b>  | <b>102.33</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 161.66      | 1535.77       | MSPGCL Total        | 180.57      | 1698.44       |
|                |             |         | MSPGCL Thml+Gas | 168.13      | 1574.36       | Koyna 1,2 & 4 Total | 4.85        | 55.70         |
|                |             |         | MSPGCL Hydro    | 12.44       | 124.08        | State Total         | 376.07      | 3580.36       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 09/Jun/2022

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | LOAD<br>SHED<br>DING | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        |                      |                               |                      |                               |                 |               |
| 1                  | 7010        | 440   | 278  | 7728   | 589   | 6045      | 0    | 0     | 7392        | 6363        | -1508                | 18869                  | 0                    | 18869                         | 3185                 | 349                           | 22402           | 50.02         |
| 2                  | 7107        | 426   | 269  | 7802   | 777   | 5561      | 0    | 0     | 7142        | 6494        | -1308                | 19002                  | 0                    | 19002                         | 2968                 | 324                           | 22294           | 50.04         |
| 3                  | 7068        | 362   | 267  | 7698   | 855   | 5789      | 0    | 0     | 5974        | 5826        | -1352                | 18502                  | 0                    | 18502                         | 2767                 | 314                           | 21582           | 50.03         |
| 4                  | 6988        | 294   | 277  | 7560   | 779   | 5735      | 0    | 0     | 6293        | 6149        | -1437                | 18496                  | 0                    | 18496                         | 2604                 | 290                           | 21390           | 50.02         |
| 5                  | 6947        | 288   | 277  | 7512   | 709   | 5433      | 0    | 0     | 6401        | 6673        | -1511                | 18506                  | 0                    | 18506                         | 2529                 | 310                           | 21344           | 49.97         |
| 6                  | 7015        | 462   | 268  | 7744   | 691   | 5785      | 0    | 1     | 6438        | 6400        | -1579                | 18667                  | 0                    | 18667                         | 2539                 | 376                           | 21582           | 49.88         |
| 7                  | 7041        | 516   | 279  | 7836   | 749   | 5771      | 0    | 68    | 6792        | 6676        | -1501                | 19199                  | 0                    | 19199                         | 2504                 | 401                           | 22104           | 49.91         |
| 8                  | 6774        | 364   | 266  | 7404   | 901   | 5554      | 0    | 293   | 6752        | 7019        | -1657                | 19087                  | 0                    | 19087                         | 2619                 | 426                           | 22132           | 50.09         |
| 9                  | 6439        | 310   | 277  | 7026   | 899   | 5114      | 0    | 597   | 7573        | 7806        | -1893                | 19101                  | 0                    | 19101                         | 2907                 | 448                           | 22456           | 50.04         |
| 10                 | 6118        | 454   | 267  | 6840   | 591   | 5063      | 0    | 961   | 8037        | 8201        | -2007                | 19201                  | 0                    | 19201                         | 3248                 | 447                           | 22896           | 50.00         |
| 11                 | 6242        | 708   | 266  | 7216   | 439   | 5075      | 0    | 1166  | 8856        | 8706        | -2227                | 19946                  | 0                    | 19946                         | 3490                 | 429                           | 23866           | 49.98         |
| 12                 | 6609        | 920   | 266  | 7796   | 375   | 5239      | 0    | 1276  | 9088        | 8819        | -2204                | 20860                  | 0                    | 20860                         | 3601                 | 441                           | 24902           | 49.99         |
| 13                 | 6482        | 882   | 265  | 7630   | 371   | 5156      | 0    | 1298  | 8927        | 8721        | -2140                | 20611                  | 0                    | 20611                         | 3598                 | 425                           | 24634           | 49.98         |
| 14                 | 6605        | 840   | 255  | 7700   | 511   | 5124      | 0    | 1181  | 8812        | 8999        | -2109                | 20999                  | 0                    | 20999                         | 3556                 | 407                           | 24962           | 49.98         |
| 15                 | 6784        | 706   | 276  | 7766   | 389   | 5572      | 0    | 1109  | 8794        | 8819        | -2215                | 21033                  | 0                    | 21033                         | 3662                 | 408                           | 25102           | 49.97         |
| 16                 | 6834        | 536   | 256  | 7626   | 650   | 5801      | 0    | 820   | 9070        | 8549        | -2161                | 20854                  | 0                    | 20854                         | 3738                 | 431                           | 25023           | 50.06         |
| 17                 | 6648        | 370   | 265  | 7284   | 811   | 5627      | 0    | 533   | 9108        | 8301        | -2024                | 20079                  | 0                    | 20079                         | 3649                 | 453                           | 24180           | 50.01         |
| 18                 | 6510        | 422   | 277  | 7208   | 1049  | 5233      | 0    | 180   | 8291        | 7144        | -1798                | 18575                  | 0                    | 18575                         | 3493                 | 441                           | 22510           | 50.01         |
| 19                 | 6719        | 428   | 267  | 7414   | 1234  | 5453      | 0    | 38    | 6928        | 6050        | -1660                | 18071                  | 0                    | 18071                         | 3298                 | 458                           | 21828           | 50.03         |
| 20                 | 6736        | 282   | 268  | 7286   | 1652  | 5563      | 0    | 3     | 6085        | 5181        | -1507                | 17741                  | 0                    | 17741                         | 3206                 | 437                           | 21384           | 50.02         |
| 21                 | 6682        | 282   | 268  | 7232   | 1558  | 5459      | 0    | 0     | 5354        | 4898        | -1327                | 17416                  | 0                    | 17416                         | 2970                 | 405                           | 20790           | 50.01         |
| 22                 | 6597        | 450   | 279  | 7326   | 1359  | 5376      | 0    | 0     | 4817        | 5058        | -1250                | 17479                  | 0                    | 17479                         | 2774                 | 391                           | 20644           | 49.97         |
| 23                 | 6803        | 1034  | 269  | 8106   | 1030  | 5802      | 0    | 0     | 4818        | 4846        | -1364                | 18023                  | 0                    | 18023                         | 2826                 | 397                           | 21246           | 49.83         |
| 24                 | 6898        | 660   | 269  | 7828   | 936   | 6149      | 0    | 0     | 5698        | 5585        | -1301                | 18830                  | 0                    | 18830                         | 2902                 | 367                           | 22098           | 49.96         |
| MUs                | 161.66      | 12.44 | 6.47 | 180.57 | 19.90 | 132.48    | 0.00 | 9.52  | 173.44      | 167.28      | -41.04               | 459.15                 | 0.00                 | 459.15                        | 74.63                | 9.57                          | 543.35          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 09/Jun/2022**

Position as on 6.30 Hrs of 10/Jun/2022

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 05/06/2022   | 00:07        |            | Continued. | Annual Overhaul                                                                                                                                         |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                                                 |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                                                                                  |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                                                                                   |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| IPP                   | JSW (J) U1              | 300      | 16/03/2022   | 23:16        |            | Continued. | Turbine Vibration                                                                                                                                       | 15/06/2022    |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      |               |
| MSPGCL                | Uran Unit B0            | 120      | 13/05/2022   | 01:34        |            | Continued. | excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)                                                                          |               |
| IPP                   | RPL(AMT) U-4            | 270      | 31/05/2022   | 01:15        |            | Continued. | Ash Conveyer problem                                                                                                                                    | 06/06/2022    |
| MSPGCL                | Koyana Unit 2           | 70       | 06/06/2022   | 08:00        | 09/06/2022 | 05:15      | Needle No.1&4 water leakage                                                                                                                             |               |
| MSPGCL                | Uran Unit 8             | 108      | 06/06/2022   | 23:03        |            | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL                | Nasik Unit 5            | 210      | 08/06/2022   | 18:18        |            | Continued. | ID Fan Problem                                                                                                                                          | 11/06/2022    |
| MSPGCL                | Chandrapur Unit 9       | 500      | 09/06/2022   | 08:46        |            | Continued. | Boiler Tube Leakage                                                                                                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 09/Jun/2022**

**Statement-VII**

Position as on 6.30 Hrs of 10/Jun/2022

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Tripping</b>      |                           |              |              |            |            |             |                                                                                                                 |
| DHULE - KHANDWA CKT - 1                  | InterState                | 09/06/2022   | 08:48        | 09/06/2022 | 20:41      | PO          | Line H/T for AMP WORK of LTE at Khandwa end. Also Line AMP works.                                               |
| KARAD - LONIKAND I                       | IntraState                | 09/06/2022   | 16:25        | 09/06/2022 | 18:13      | HT          | load management                                                                                                 |
| PADGHE - NAGOTHANE CKT - 2               | IntraState                | 09/06/2022   | 18:03        | 09/06/2022 | 23:52      | T           | Decapping at loc no 3 from Nagothane                                                                            |
| CHANDRAPUR-PARLI CKT-3                   | IntraState                | 09/06/2022   | 19:21        | 09/06/2022 | 23:10      | EO          | 400kV CVT B phase Clamp found broken during switchyard round. Clamp is to be replaced.                          |
| TAPTITANDA - EKTUNI CKT - 1              | IntraState                | 09/06/2022   | 21:33        |            |            | T           | DP Tripped                                                                                                      |
| PADGHE - KALWA CKT - 1                   | IntraState                | 10/06/2022   | 02:24        | 10/06/2022 | 05:05      | EO          | Outage is required for attending the Replacement of decapped insulator string at loc. no. 1058 B-Phase          |
| PADGHE - KALWA CKT - 2                   | IntraState                | 10/06/2022   | 05:18        | 10/06/2022 | 07:10      | EO          | Replacement of decapped insulator string at loc. no. 1028 Y-Phase                                               |
| <b>400 KV ICT Outages/Tripping</b>       |                           |              |              |            |            |             |                                                                                                                 |
| 400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE | IntraState                | 06/06/2022   | 12:33        |            |            | PO          | For CB replacement work                                                                                         |
| <b>220 KV LINE Outages/Tripping</b>      |                           |              |              |            |            |             |                                                                                                                 |
| MULUND - GIS BHANDUP                     | IntraState                | 29/01/2022   | 15:44        |            |            | T           | cABLE FAULT                                                                                                     |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 2        | IntraState                | 27/04/2022   | 12:21        |            |            | EO          | Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.                                                             |
| MUDSHINGI - CHIKODI                      | IntraState                | 06/06/2022   | 09:18        |            |            | PO          | Line reorientation work from D/C towers (Loc. 320 to 312 to M/C-9)) to M/C towers (Guide-D/C- M/C 3 to M/C 9) . |
| AAREY - AEML SAKI CKT - 1                | IntraState                | 08/06/2022   | 11:19        |            |            | PO          | Repair / restoration of 220 kV R-Phase with additional 2 nos. Joints. Repair of Y-Phase outer sheath.           |
| URSE - TALEGAON (AMBI) CKT 1             | IntraState                | 08/06/2022   | 22:31        | 09/06/2022 | 03:06      | EO          | Replacement of faulty strings at loc.14 R-ph                                                                    |
| RAYMOND - WASHALA                        | IntraState                | 09/06/2022   | 09:01        | 09/06/2022 | 17:01      | EO          | Replacement of Flashover Long Rod insulator R & B phase STN string at loc.no.243.                               |
| BIDRI - SAWANTWADI                       | IntraState                | 09/06/2022   | 09:26        | 09/06/2022 | 14:23      | PO          | For Relay testing work                                                                                          |
| FLAGSHIP-CHINCHWAD                       | IntraState                | 09/06/2022   | 09:36        | 09/06/2022 | 16:52      | PO          | 1) Half yearly bay maintenance work.<br>2) CB IR and Timing measurement work.                                   |
| VITTAL SUGAR CO GEN (VSSK) - KARKAMBH    | IntraState                | 09/06/2022   | 10:12        | 09/06/2022 | 16:02      | PO          | Outage is required 1) For changing / replacement of faulty string at loc no. 106, 107, 108, 109, 111.           |
| TALANDAGE - FIVE STAR MIDC 2             | IntraState                | 09/06/2022   | 11:48        | 09/06/2022 | 16:47      | PO          | For weak insulator strings observed in PID testing at tower loc. No. 11 (Y&B Ph.) & 1(R&B Ph)                   |
| KHADKI- CENTURY ENKA                     | IntraState                | 09/06/2022   | 13:30        | 09/06/2022 | 17:35      | EO          | To attend Y Ph auxiliary switch contact problem for spring charge                                               |
| TALANDGE - BIDRI                         | IntraState                | 09/06/2022   | 14:57        | 09/06/2022 | 17:08      | PO          | For relay testing work                                                                                          |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 1        | IntraState                | 09/06/2022   | 17:15        | 09/06/2022 | 20:46      | T           | heavy rain                                                                                                      |
| URSE - TALEGAON (AMBI) CKT 1             | IntraState                | 09/06/2022   | 17:21        | 09/06/2022 | 23:52      | T           | Heavy rain                                                                                                      |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 09/Jun/2022**

**Statement-VII**

Position as on 6.30 Hrs of 10/Jun/2022

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                      |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| KANDALGAON - KOYNA (POPHALI)              | IntraState                | 09/06/2022   | 18:45        | 09/06/2022 | 18:58      | T           | DP Trip                                                                                                                                                                                                                                                                                                               |
| KAMBA - VASAI                             | IntraState                | 09/06/2022   | 20:02        | 10/06/2022 | 08:02      | T           | DP Trip                                                                                                                                                                                                                                                                                                               |
| PADGHE - KAMBA 1                          | IntraState                | 09/06/2022   | 20:04        | 09/06/2022 | 20:08      | T           | DP TRIP                                                                                                                                                                                                                                                                                                               |
| KOLSHET - ROMA                            | IntraState                | 09/06/2022   | 20:10        | 09/06/2022 | 20:10      | T           | DP trip                                                                                                                                                                                                                                                                                                               |
| BHAVEGHAR - ROMA                          | IntraState                | 09/06/2022   | 20:10        |            |            | T           | DP Trip                                                                                                                                                                                                                                                                                                               |
| KAMBA - KHARBAO TSS                       | IntraState                | 09/06/2022   | 20:10        | 10/06/2022 | 08:00      | T           | DP TRIP                                                                                                                                                                                                                                                                                                               |
| KALWA SALSETTE - 4                        | IntraState                | 09/06/2022   | 20:43        | 09/06/2022 | 23:09      | T           | Relay Burnt at Kalwa end                                                                                                                                                                                                                                                                                              |
| PADGHE - NALASOPARA                       | IntraState                | 10/06/2022   | 08:43        |            |            | EO          | Outage is required for safety purpose for attending break down of 220KV Bhaveghar-Roma Line at Loc no.95 by LMSD Padgha.                                                                                                                                                                                              |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                       |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                                                                                                      |
| 220/22 KV 50 MVA PTR 1 @ KANDALGAON       | IntraState                | 14/12/2021   | 16:55        |            |            | EO          | For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s                                                                                                                                                                                                                                                               |
| 220/132KV 100MVA ICT 1 @ SATARA MIDC      | IntraState                | 25/05/2022   | 10:38        |            |            | PO          | Transformer painting work                                                                                                                                                                                                                                                                                             |
| 220/33 KV 50 MVA PTR 2 @ KHARGHAR         | IntraState                | 09/06/2022   | 06:07        | 09/06/2022 | 10:18      | PO          | For premonsoon Maintenance work                                                                                                                                                                                                                                                                                       |
| 220/33kV 125 MVA TF 2 @ SAKI (AEML)       | IntraState                | 09/06/2022   | 09:54        | 09/06/2022 | 16:27      | PO          | ANNUAL & PREMONSOON MAINTENANCE OF TRANSFORMER                                                                                                                                                                                                                                                                        |
| 220/100 KV 100 MVA ICT 2 @ TAMBATI        | IntraState                | 09/06/2022   | 10:02        | 09/06/2022 | 17:30      | PO          | N2 Based fire protection system (CTR) Maintenance work and Oil top up work by agency.                                                                                                                                                                                                                                 |
| 220/132 KV 200 MVA PTR NO 6 @ PARVATI     | IntraState                | 09/06/2022   | 10:35        | 09/06/2022 | 17:20      | EO          | As outage proposed by EHV project Dn 1 on 132 kv Main Bus Section 2 for Metro bay beam erection.Hence outage is proposed by 220 kV parvati ss for half yearly Maintenance                                                                                                                                             |
| 220/33 kV 50 MVA PTR 1 @ VIRAJ            | IntraState                | 09/06/2022   | 11:05        | 09/06/2022 | 13:02      | PO          | Pre Monsoon Maintenance                                                                                                                                                                                                                                                                                               |
| 220/22 KV 50 MVA PTR 2 @ CHAKAN           | IntraState                | 09/06/2022   | 11:31        | 09/06/2022 | 15:10      | PO          | For reconnection of repaired HV cable and attending Hotspots alongwith premonsoon maintenance work.                                                                                                                                                                                                                   |
| 220/22 KV 25 MVA PTR 2 @ KANDALGAON       | IntraState                | 09/06/2022   | 12:58        | 09/06/2022 | 13:38      | EO          | Eraction OF 25 MVA 220/22 KV T/F No:01 work And B Phase LV CT Replacement Work.                                                                                                                                                                                                                                       |
| 220/22 KV 50 MVA PTR 3 @ CHAKAN           | IntraState                | 09/06/2022   | 15:22        | 09/06/2022 | 18:57      | PO          | For Reconnection of Repaired HT Cable and Premonsoon maintenance work.                                                                                                                                                                                                                                                |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                       |
| DHARAVI POWAI                             | IntraState                | 30/08/2021   | 00:03        |            |            | PO          | Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai. |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 09/Jun/2022**

**Statement-VII**

Position as on 6.30 Hrs of 10/Jun/2022

| Name of Line         | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                      |
|----------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DHARAVI VIKHROLI     | IntraState                   | 30/08/2021      | 00:03           |            |               | PO             | Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai. |
| WAGHIVALI - CHEMBUR  | IntraState                   | 04/02/2022      | 10:30           |            |               | PO             | Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.                                                                    |
| WAGHIVALI - MANKHURD | IntraState                   | 04/02/2022      | 10:30           |            |               | PO             | Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.                                                                    |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage