

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Jun/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	174.215	1361.738	1) Gujrat	-3.345	-28.882
2) Hydro	6.144	186.565	2) Madhya Pradesh	2.496	58.003
3) Gas	4.669	45.898	3) Chattisgarh	3.170	27.770
Total MSPGCL	185.028	1594.201	4) Maharashtra	215.419	1954.791
B) 1) APLM	69.968	596.016	5) Goa (Amona)	-1.614	-13.604
2) JSWEL	24.044	223.935	Total	216.126	1998.078
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.730	392.113
4) RPL(AMT)	30.684	277.355	b) Mumbai Drawl	48.698	433.855
5) SWPGPL	9.382	92.656	c) MSEDCL Bilateral *	103.861	974.623
6) Other IPP	6.982	29.115	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.585	391.929
C) 1) TPCL Thermal	14.048	116.114	Include PX	0.000	0.000
2) TPCL Hydro	6.365	50.424	Standby	0.145	0.184
3) TPCL Gas	1.829	18.881	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.742	79.056	1) MSEDCL	533.663	4678.159
D) STATE			2) Mumbai Discoms	81.682	698.330
1) Thermal	340.065	2775.985	3) Other Discoms	10.904	96.479
(A1+C1+C4+(B1-B6))			TOTAL STATE	626.249	5472.968
2) Hydro (A2+C2)	12.509	236.989			
3) Gas (A3+B7+C3)	6.498	64.779			
4) Wind	34.400	251.878			
6) SOLAR	16.651	145.259			
TOTAL STATE	410.123	3474.890			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	7272	7281	7375	7152
MSPGCL Hydro	145	147	241	278
MSPGCL Gas	187	176	185	208
MSPGCL Total Generation	7604	7604	7801	7638
Central Sector Receipt	10098	9945	8306	8926
WIND	738	985	1948	1258
CPP / IPP Thermal	5018	6207	6140	5560
CPP / IPP Gas	0	0	0	0
SOLAR	2162	1423	0	597
Exchange with Mumbai	-2543	-2451	-1992	-1703
MSEDCL DEMAND MET	22585	23233	21705	21813
Load Shedding	0	344	0	0
MSEDCL DEMAND	22585	23577	21705	21813
TPCL GENERATION	780	1158	1029	760
AEML GENERATION	496	499	420	335
MUMBAI DEMAND	3819	4108	3441	2798
OTHER DISCOM DEMAND	492	480	498	463
STATE DEMAND MET	26896	27821	25644	25074
STATE DEMAND	26896	28165	25644	25074
Frequency (Hz)	50.00	50.03	50.08	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 16.05 Hrs	49.84 Hz at 12.13 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.71	42.63	205	185
Unit 8	13.55	47.55	606	522
Unit 9	13.89	31.92	605	556
Unit 10	12.81	117.77	545	520
Total	44.96	239.87		
Bhusawal				
Unit 3	3.19	18.87	145	100
Unit 4	9.93	88.29	440	390
Unit 5	10.52	95.84	485	410
Total	23.64	203.00		
Parli				
Unit 6	4.60	44.59	241	145
Unit 7	4.82	43.98	245	147
Unit 8	4.30	39.28	200	148
Total	13.73	127.85		
Chandrapur				
Unit 3	3.78	23.10	164	145
Unit 4	3.65	32.99	159	135
Unit 5	0.00	0.00	0	0
Unit 6	9.42	61.86	415	335
Unit 7	10.05	84.29	430	369
Unit 8	10.82	100.45	473	247
Unit 9	11.40	101.82	500	445
Total	49.12	404.50		
Paras				
Unit 3	4.98	44.88	232	181
Unit 4	5.47	46.83	234	204
Total	10.45	91.72		
Khaparkheda				
Unit 1	2.66	26.36	120	100
Unit 2	2.77	26.23	135	102
Unit 3	4.19	26.68	183	158
Unit 4	4.26	36.58	186	165
Unit 5	10.32	96.34	475	290
Total	24.20	212.20		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	4.10	36.69	182	151
Unit 5	4.00	35.82	180	154
Total	8.10	82.60		
Uran				
All Units	4.67	45.90	212	176
Total	4.67	45.90		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.11	0.92	27	0
Total	0.11	0.92		
Koyna				
Stage 1-2	2.04	43.16	475	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.42	28.28	160	0
Total	2.46	152.66		
Hydro				
KDPH	0.20	3.62	9	8
VTRNA	1.10	10.14	61	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.40	3.37	80	0
SMLHY_PTN	1.87	14.63	92	65
GHATGHAR	0.00	0.19	0	0
Total	3.58	32.99		
Wind				
Total	34.40	251.88	0	0
Total	34.40	251.88		
CPP				
APML(Mus)	69.97	596.02	0	0
JSWEL(Mus)	24.04	223.94	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.68	277.36	0	0
SWPGPL-Mus	9.38	92.66	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.76	7.58	226	177
Other(Mus)	2.22	21.54	0	0
Total	141.06	1219.08		
SOLAR				
Total	16.65	145.26	0	0
Total	16.65	145.26		
Tata				
Trombay 5	9.03	75.95	424	273
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.96	10.33	48	35
Trombay 7B	0.87	8.55	42	33
TATA Hydro	6.36	50.42	440	91
Trombay 8	5.02	40.16	230	148
Total	22.24	185.42		
AEML				
DTPS U-1&2	10.74	79.06	502	297
Total	10.74	79.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	174.22	1361.74	MSPGCL Total	185.03	1594.20
			MSPGCL Thml+Gas	178.88	1407.64	Koyna 1,2 & 4 Total	2.04	124.38
			MSPGCL Hydro	6.14	186.56	State Total	410.12	3474.89

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7395	759	210	8364	1393	6454	0	0	7735	8107	-1766	22143	241	58	22384	3408	409	26201	50.01
2	7337	302	210	7849	1477	6441	0	0	8703	8617	-1607	22399	0	58	22399	3185	378	25962	50.01
3	7310	191	210	7711	1528	6433	0	0	8508	8589	-1422	22497	0	14	22497	2983	342	25822	49.97
4	7317	192	211	7720	1566	6389	0	0	8470	8547	-1404	22472	0	0	22472	2845	346	25663	50.03
5	7314	201	212	7727	1469	6196	0	0	8857	8882	-1409	22498	0	0	22498	2762	367	25627	50.01
6	7318	197	211	7726	1555	6077	0	6	9371	9375	-1451	22883	0	0	22883	2736	405	26024	50.00
7	7264	199	209	7672	1433	5890	0	142	9184	9277	-1542	22434	0	53	22434	2693	438	25565	50.01
8	7152	278	208	7638	1258	5560	0	597	8643	8926	-1703	21813	0	91	21813	2798	463	25074	50.03
9	7170	277	206	7653	1242	5274	0	1146	8886	9134	-2142	21818	0	30	21818	3092	489	25399	49.99
10	7198	235	199	7632	1007	5307	0	1693	9358	9395	-2400	22147	0	0	22147	3440	487	26074	49.96
11	7193	232	193	7618	710	4803	0	2011	9966	9967	-2555	22071	0	9	22071	3693	483	26247	49.98
12	7272	145	187	7604	738	5018	0	2162	10028	10098	-2543	22585	0	54	22585	3819	492	26896	50.00
13	7202	125	184	7511	604	5487	0	2229	9997	9953	-2522	22767	0	77	22767	3828	495	27090	49.98
14	7122	119	183	7424	648	5693	0	2078	9850	9855	-2416	22805	0	34	22805	3769	477	27051	49.98
15	7274	127	177	7578	774	6006	0	1778	9985	10154	-2442	23370	0	105	23370	3980	478	27828	49.97
16	7281	147	176	7604	985	6207	0	1423	9587	9945	-2451	23233	344	135	23577	4108	480	28165	50.03
17	7152	132	176	7460	1482	5910	0	918	9907	9595	-2404	22473	0	109	22473	3984	488	26945	50.07
18	7055	179	178	7412	1723	5318	0	418	10160	9370	-2498	21231	0	67	21231	3782	512	25525	50.00
19	7289	270	179	7738	1832	5749	0	50	8741	8526	-2429	20961	0	0	20961	3519	505	24985	50.09
20	7375	241	185	7801	1948	6140	0	0	8420	8306	-1992	21705	0	0	21705	3441	498	25644	50.08
21	7364	231	185	7780	2308	5978	0	0	8095	8013	-1932	21657	0	0	21657	3425	490	25572	50.00
22	7376	215	191	7782	2464	6156	0	0	8014	7562	-1859	21628	0	0	21628	3409	477	25514	50.06
23	7305	364	194	7863	2297	6265	0	0	7890	7809	-1881	21888	0	0	21888	3457	465	25810	50.00
24	7180	786	195	8161	1959	6309	0	0	7643	8124	-1928	22185	335	0	22520	3526	440	26486	49.99
MUs	174.21	6.14	4.67	185.03	34.40	141.06	0.00	16.65	216.00	216.13	-48.70	533.66	0.92	0.89	534.58	81.68	10.90	627.17	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to overloading of 220KV Nasik GCR-BBLR-2 line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Jun/2023

Position as on 6.30 Hrs of 10/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	13/06/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Parli Unit 6	250	10/06/2023	12:04	10/06/2023	14:17	Furnace Pressure High	
MSPGCL	Parli Unit 6	250	10/06/2023	21:36		Continued.	Drum Level low	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (414) OF PADGHE PG CKT - 1 @ KUDUS	InterState	09/06/2023	11:01	10/06/2023	19:12	PO	CT Replacement Work
400 KV MAINBAY Outages/Trippings							
MAIN BAY (401) OF GT 9 @ 400KV CHANDRAPUR SWITCHING S/S	InterState	09/06/2023	11:59	09/06/2023	15:24	PO	Diagnostic testing and allied bay maintenance work
MAIN BAY (415) OF PADGHE PG CKT - 1 @ KUDUS	InterState	09/06/2023	18:34	09/06/2023	20:40	T	Tie bay 414 of Padghe PG ckt 1 outage was under progress for CT replacement , during testing of CT of said bay due to maloperation DT send to other end.
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 2	InterState	09/06/2023	09:07	09/06/2023	19:55	PO	Under MTAMC Project work, Main -II Dist Protn relay replacement work
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/06/2023	23:37		Continued.	HT	HT for load management
LONIKAND I - KOYNA STAGE-IV	IntraState	06/06/2023	21:04	10/06/2023	02:36	T	Tripped on distance protection
PADGHE - NAGOTHANE CKT - 2	IntraState	08/06/2023	13:08			PO	Work of shifting/height raising of various EHV (220/110KV) transmission lines infringing in Samruddhi crossing . 1) Erection of 5 no. of Monopple 2) Stringing of 6.nos. of spans between location nos. 310-313
KORADI - KHADKA	IntraState	10/06/2023	08:34	10/06/2023	20:00	PO	For replacement of R and B phase CVT old jump replacement work and routine bay maintenance works etc.
TBC @ PARLI	IntraState	10/06/2023	10:01	10/06/2023	12:47	PO	Bay Maintenance Work is to be carried out.
WARORA - IEPL	IntraState	10/06/2023	14:12	10/06/2023	16:30	T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	09/06/2023	10:37	09/06/2023	14:40	PO	(1) IV breaker testing work. (2) Bay maintenance work.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	09/06/2023	11:01	09/06/2023	20:35	EO	For attending red hot spot on 29A isolator B-Ph 220KV Bus side by hot line unit.
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	09/06/2023	11:04	09/06/2023	16:52	PO	Diagnostic testing & routine maintenance work
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	10/06/2023	16:05	10/06/2023	18:35	T	220KV BUS SECTION -1 DEAD.
220 KV TIEBAY Outages/Trippings							
220 KV TBC	IntraState	09/06/2023	08:22	09/06/2023	17:30	PO	220 KV BUS-2 ISOLATOR ALIGNMENT WORK
220 KV TBC Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TBC @ ANANDNAGAR	IntraState	10/06/2023	09:45	10/06/2023	15:30	PO	For separation of common dropper jumper of 220kv PT & TBC bay & TBC bay Isolator maintenance.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							
220 KV HARANGUL - PARLY (PG) CKT	InterState	10/06/2023	17:38	10/06/2023	18:45	T	Tripped on distance protection
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
IPCL - SPCL	IntraState	08/06/2023	10:22	09/06/2023	16:13	PO	ABB MAKE CB OVERHAULING WORK AT IPCL END CB
MIRAJ - ICHALKARANJI	IntraState	08/06/2023	17:19	09/06/2023	02:38	HT	Emergency outage for project work.
TROMBAY MSETCL TIE - 2	IntraState	09/06/2023	00:05	09/06/2023	02:48	PO	Attending to CT oil leakage.
MAHAD - KANDALGAON	IntraState	09/06/2023	01:15	10/06/2023	15:54	PO	1. Erection of 2 nos. inline monopole 2. Stringing of 3 nos. conductor on new erected monopole. 3. Stringing of 3 nos. conductor both sides of 2 nos. erected monopole. 4. Dismantling of old conductor.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	09/06/2023	02:58	09/06/2023	08:11	PO	Conversion Of single to Twin Jump at Various Cut point
CHEMBUR (AEML) - NERUL (M)	IntraState	09/06/2023	04:52	09/06/2023	19:10	PO	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL
SONKHAR - TROMBAY	IntraState	09/06/2023	05:29	09/06/2023	08:10	PO	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL
CHIKHALI-JALNA I	IntraState	09/06/2023	10:31	09/06/2023	13:01	HT	IN VIEW OF 220KV PARAS-CHIKHLI CKT 2 UNDER OUTAGE.
CHIKHALI-JALNA II	IntraState	09/06/2023	10:36	09/06/2023	13:08	HT	IN VIEW OF 220KV PARAS-CHIKHLI CKT 2 UNDER OUTAGE.
KANHAN-UMRED 1	IntraState	09/06/2023	10:38	09/06/2023	17:22	PO	FOR DIAGNOSTIC TESTING WORK.
PARAS-CHIKHALI CKT NO-II	IntraState	09/06/2023	10:40	09/06/2023	12:51	PO	REPLACEMENT OF JUMPER FROM LINE ISOLATOR 29D TO CT -R PHASE FOR ATTENDING HOT SPOT.
KARAD -NIGADE	IntraState	09/06/2023	10:59	09/06/2023	16:31	PO	Replacement work of Y & B Ph damaged jump between Bus to isolator.
KOLSHET - KHARBAO	IntraState	09/06/2023	13:04	09/06/2023	19:05	EO	1) R-phase line wave trap to line isolator jumper replacement due to hotspot of 150+ ° c temperature 2) R-phase CT to CB jumper replacement. 3) R-phase Bus isolator to PT jumper Replacement.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WPCL-WARORA 2	IntraState	09/06/2023	13:25	09/06/2023	22:05	HT	CKT EMERGENCY HANDTRIPPED DUE TO BURNING OF WAVE TRAP AT WPCI END.
MALINAGAR - TEMBHURNI	IntraState	09/06/2023	16:40	09/06/2023	18:12	EO	Outage is required for Tree trimming coming under induction zone at Loc no. 79-80, 81-82
COLOURCHEM - TEMGHAR	IntraState	09/06/2023	22:32	10/06/2023	03:55	EO	To attend Hotspot on B phase jumper Cone at Line Incoming gantry near LA. Also Y phase WT jumper will be replace which looks deteriorated.
PADGHE - TEMGHAR - 2	IntraState	10/06/2023	01:54	10/06/2023	03:26	EO	For safety purpose to attend hot spot on bottom ph dead end h/w of 220 kV Colourchem & Temghar line at Loc. No. 39
KHARGHAR - SONKHAR	IntraState	10/06/2023	04:09	10/06/2023	08:26	EO	1] Attending hotspot on 1.R phase wavetrap top jumper (line side)(99degC) 2.Y phase dead end clamp on line side (97degC) 2] Taking IR values of LAs due to increasing LCM values of B phase LA 3] Diagnostic testing & RM work
GADCHANDUR - VIRUR-I	IntraState	10/06/2023	09:10	10/06/2023	11:50	HT	For diagnostic testing work.
EKLAHARA(OCR)-RAYMOND	IntraState	10/06/2023	09:12	10/06/2023	17:21	PO	1. Attending red hot on B ph wave trap bottom side by replacement of existing jump along with Nut bolt and bay maintenance. 2. Attending red hot on B ph CT line side by replacement of Nut bolt 3. Diagnostic testing of breaker and CTs. & Premonson maintence.
HINJAWADI I- CHINCHWAD	IntraState	10/06/2023	09:45	10/06/2023	19:20	PO	1) Fixing of earthwire MS joint at loc no-172-173 2) Pilot string jump replacement at loc no-179(B ph)
BUTIBORI 3- VIPL CKT I	IntraState	10/06/2023	15:30	10/06/2023	18:21	HT	Eavy spark seen on metering r ph pt side jumper which was open and in hanging position.
220 KV GIRWALI (400 KV) -PARLI U -8 CKT	IntraState	10/06/2023	16:05	10/06/2023	18:22	T	220Kv bus section dead.
MAHAD-KALAMBANI(TSS)	IntraState	10/06/2023	19:32			PO	1) Erection of 06 nos cross-arm on 02 nos monopole. 2) Stringing of 03 nos conductor on new erected monopole. 3) Stringing of 03 nos conductor both sides of 02 nos erected monopole. 4) Dismantling of old conductor and tower (02 nos)
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	09/06/2023	07:06	09/06/2023	12:05	PO	Pre monsoon bus maintenance work
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	09/06/2023	09:00	09/06/2023	12:45	PO	Plastic wrapping work to be carried out.
220/132 KV 80 MVA ICT 1	IntraState	09/06/2023	09:06	09/06/2023	12:01	EO	FOR REPLACEMENT OF HV Y PH LA DUE TO HIGH LCM VALUE.(IR CORRECTED-2025μA).

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 10/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33KV 100MVA TF No.1 @ BOTHE	IntraState	09/06/2023	09:16	09/06/2023	12:28	PO	Overhauling work of drive mechanism of HV CB & Quarterly maintenance work
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	09/06/2023	10:35	09/06/2023	17:15	PO	Diagnostic testing & Quarterly maintenance work
220/132KV 100MVA ICT 1	IntraState	09/06/2023	11:35	09/06/2023	14:55	PO	PREMONSOON MAINTENANCE WORK
100 MVA 220/132 KV ICT - II	IntraState	09/06/2023	12:10	09/06/2023	18:01	PO	PREMONSOON MAINTENANCE WORK
220/33KV 50MVA PTR 2@ PETH	IntraState	09/06/2023	12:15	09/06/2023	15:30	PO	Structure painting work
220/33KV 100MVA TF No.2 @ BOTHE	IntraState	09/06/2023	12:30	09/06/2023	18:24	PO	Overhauling work of drive mechanism of HV CB & Quarterly maintenance work
220/132 KV 100 MVA ICT 1 @ BHENDA	IntraState	09/06/2023	18:05	09/06/2023	19:30	EO	To attend the red hot on 100MVA ICT -1 at LV Y Phase CT P1 Side
100 MVA 220/132 KV ICT - I	IntraState	09/06/2023	18:24	09/06/2023	19:43	PO	PREMONSOON MAINTENANCE WORK
100 MVA 220/132 KV ICT 2	IntraState	09/06/2023	18:40	09/06/2023	19:50	HT	LV SIDE PRV OPTD
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	09/06/2023	20:55	09/06/2023	23:33	PO	For 1) Premonsoon maintenance work & 2) RM work.
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	10/06/2023	05:43	10/06/2023	08:30	PO	PM CHECKS
220/110 KV 155MVA ICT-2@ BHIRA (T)-220 KV	IntraState	10/06/2023	08:50	10/06/2023	12:51	PO	PM CHECKS
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	10/06/2023	09:36	10/06/2023	16:45	PO	For Pre-monsoon maintenance work on 100MVA, 220/100KV ICT
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	10/06/2023	10:00	10/06/2023	17:46	PO	1. Diagnostic testing of Bushings, Windings, Breaker and CTs. & Premonson maintence. 2. Attending red hot and replacement of Nut bolts.
220/132KV 200 MVA ICT 2	IntraState	10/06/2023	10:20	10/06/2023	11:19	HT	For premansoon maint. work.
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	IntraState	10/06/2023	10:22	10/06/2023	16:47	PO	Quarterly Maint and pre monsoon maint. work.
220/132 100MVA ICT-1 @ AMRAPUR	IntraState	10/06/2023	11:08	10/06/2023	14:31	PO	Diagnostic testing work
220/132KV 200 MVA ICT 2	IntraState	10/06/2023	11:32	10/06/2023	12:20	HT	For premansoon maint. work.
220/132 100MVA ICT-2 @ AMRAPUR	IntraState	10/06/2023	14:59	10/06/2023	18:38	PO	Diagnostic testing work
220/132 KV 200 MVA ICT 2 @ AMALNER	IntraState	10/06/2023	19:05	10/06/2023	20:50	HT	Replacement of HV R PH LA.
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ ANANDNAGAR	IntraState	10/06/2023	09:45	10/06/2023	15:35	PO	For separation of common dropper jumper of 220kV PT & TBC bay & TBC bay Isolator maintenance.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage