

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Jul/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.101	1238.430	1) Gujrat	-1.651	15.237
2) Hydro	4.860	57.221	2) Madhya Pradesh	0.692	21.942
3) Gas	6.411	59.172	3) Chattisgarh	1.040	11.680
Total MSPGCL	159.372	1354.823	4) Maharashtra	151.611	1354.567
B) 1) APML	62.234	519.849	5) Goa (Amona)	-2.014	-17.130
2) JSWEL	19.266	175.918	Total	149.678	1386.296
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.915	355.731
4) RPL(AMT)	19.000	206.107	b) Mumbai Drawl	35.264	377.203
5) SWPGPL	12.153	107.134	c) MSEDCL Bilateral *	75.809	841.065
6) Other IPP	12.109	109.074	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.915	355.731
C) 1) TPCL Thermal	12.200	106.078	Include PX	0.000	0.000
2) TPCL Hydro	4.550	41.927	Standby	0.000	0.000
3) TPCL Gas	3.967	33.491	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.340	87.988	1) MSEDCL	429.077	3942.257
D) STATE			2) Mumbai Discoms	66.321	646.685
1) Thermal	295.403	2550.578	3) Other Discoms	11.376	101.653
(A1+C1+C4+(B1-B6))			TOTAL STATE	506.774	4690.595
2) Hydro (A2+C2)	9.410	99.148			
3) Gas (A3+B7+C3)	10.378	92.663			
4) Wind	27.676	437.328			
6) SOLAR	14.229	124.584			
TOTAL STATE	357.096	3304.301			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6104	5591	6968	5964
MSPGCL Hydro	183	142	624	145
MSPGCL Gas	254	252	358	258
MSPGCL Total Generation	6541	5985	7950	6367
Central Sector Receipt	7699	7574	5889	5181
WIND	754	932	1834	731
CPP / IPP Thermal	4630	4227	5903	5113
CPP / IPP Gas	0	0	0	0
SOLAR	1559	1839	0	0
Exchange with Mumbai	-2066	-2230	-1348	-867
MSEDCL DEMAND MET	18621	17850	19710	16142
Load Shedding	0	0	0	0
MSEDCL DEMAND	18621	17850	19710	16142
TPCL GENERATION	820	877	1174	672
AEML GENERATION	476	285	486	492
MUMBAI DEMAND	3362	3392	3008	2031
OTHER DISCOM DEMAND	496	477	518	383
STATE DEMAND MET	22479	21719	23236	18556
STATE DEMAND	22479	21719	23236	18556
Frequency (Hz)	50.00	50.00	49.91	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 16:07 Hrs	49.64 Hz at 21:14 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Jul/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.28	35.43	184	145
Unit 8	11.35	104.21	520	430
Unit 9	12.06	106.09	536	407
Unit 10	11.72	58.36	510	430
Total	39.41	304.10		
Bhusawal				
Unit 3	3.35	29.50	175	115
Unit 4	0.00	0.00	0	0
Unit 5	10.15	88.69	490	300
Total	13.50	118.20		
Parli				
Unit 6	4.16	35.24	236	145
Unit 7	4.13	35.08	241	138
Unit 8	3.82	34.27	201	140
Total	12.11	104.59		
Chandrapur				
Unit 3	3.02	19.85	140	108
Unit 4	3.12	29.26	152	117
Unit 5	8.24	70.80	420	275
Unit 6	8.12	69.23	400	270
Unit 7	8.10	52.72	437	266
Unit 8	9.33	80.00	441	281
Unit 9	7.44	83.04	409	164
Total	47.36	404.89		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.04	45.01	243	146
Total	5.04	45.01		
Khaparkheda				
Unit 1	3.15	26.82	160	105
Unit 2	3.90	34.15	201	123
Unit 3	3.47	31.80	164	130
Unit 4	4.09	19.25	188	129
Unit 5	10.46	94.74	470	315
Total	25.07	206.77		
Nasik				
Unit 3	0.00	23.30	0	0
Unit 4	2.13	21.28	185	0
Unit 5	3.48	10.30	159	121
Total	5.61	54.88		
Uran				
All Units	6.41	59.17	358	252
Total	6.41	59.17		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	0.80	11.34	175	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.22	9.81	132	0
Stage 3	0.57	8.14	80	0
Total	1.59	29.29		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.26	1.01	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.25	3.13	40	0
SMLHY_PTN	2.49	21.96	106	98
GHATGHAR	0.27	1.83	125	0
Total	3.27	27.94		
Wind				
Total	27.68	437.33	0	0
Total	27.68	437.33		
CPP				
APML(Mus)	62.23	519.85	0	0
JSWEL(Mus)	19.27	175.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.00	206.11	0	0
SWPGPL-Mus	12.15	107.13	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.38	47.58	266	171
Other(Mus)	1.99	18.55	0	0
JPL	4.74	42.95	272	170
Total	124.76	1118.08		
SOLAR				
Total	14.23	124.58	0	0
Total	14.23	124.58		
Tata				
Trombay 5	7.81	68.82	396	254
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.47	20.57	108	59
Trombay 7B	1.50	12.92	64	50
TATA Hydro	4.55	41.93	394	82
Trombay 8	4.39	37.26	223	131
Total	20.72	181.50		
AEML				
DTPS U-1&2	10.34	87.99	494	283
Total	10.34	87.99		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.10	1238.43	MSPGCL Total	159.37	1354.82
			MSPGCL Thml+Gas	154.51	1297.60	Koyna 1,2 & 4 Total	1.02	21.15
			MSPGCL Hydro	4.86	57.22	State Total	357.10	3304.30

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Jul/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6238	146	257	6641	817	5951	0	0	5513	4722	-872	16820	0	0	16820	2369	439	19628	50.02
2	5897	145	257	6299	810	5591	0	0	5682	5059	-886	16459	0	0	16459	2213	414	19086	49.99
3	5932	156	256	6344	753	5374	0	0	5701	5149	-859	16388	0	0	16388	2099	373	18860	49.99
4	5964	145	258	6367	731	5113	0	0	5744	5181	-867	16142	0	0	16142	2031	383	18556	50.00
5	6220	150	260	6630	771	5282	0	0	5847	5093	-880	16510	0	0	16510	2019	386	18915	50.03
6	6458	143	257	6858	737	5817	0	1	5983	5117	-814	17282	0	0	17282	2094	434	19810	50.02
7	6428	149	254	6831	637	5863	0	93	6228	6398	-905	18453	0	0	18453	2209	464	21126	49.93
8	6297	223	258	6778	619	5891	0	427	6539	6773	-1283	18720	0	0	18720	2426	485	21631	50.02
9	6107	206	260	6573	699	5543	0	775	7300	7354	-1631	18814	0	0	18814	2779	499	22092	50.04
10	6144	186	259	6589	627	5118	0	1254	7806	7535	-1924	18682	0	26	18682	3120	517	22319	50.04
11	6104	183	254	6541	754	4630	0	1559	8264	7699	-2066	18621	0	36	18621	3362	496	22479	50.00
12	5881	141	253	6275	795	4424	0	1673	8329	7873	-2250	18301	0	0	18301	3429	489	22219	50.02
13	5591	142	252	5985	932	4227	0	1839	8006	7574	-2230	17850	0	0	17850	3392	477	21719	50.00
14	5245	139	256	5640	1267	3990	0	1904	7807	7177	-2105	17399	0	0	17399	3223	474	21096	49.90
15	5303	146	256	5705	1663	4219	0	1735	7644	7137	-2065	17925	0	0	17925	3194	469	21588	49.97
16	5425	106	261	5792	1953	4257	0	1421	7356	6775	-1969	17737	0	0	17737	3166	492	21395	50.02
17	5902	103	255	6260	2113	4315	0	1003	6773	6644	-1827	18008	0	0	18008	3152	500	21660	50.04
18	6275	158	259	6692	2025	4560	0	493	6885	6567	-1829	17983	0	0	17983	3092	525	21600	49.96
19	6569	299	290	7158	1843	5248	0	52	6537	6469	-1704	18523	0	0	18523	3031	543	22097	49.94
20	6968	624	358	7950	1834	5903	0	0	5927	5889	-1348	19710	0	0	19710	3008	518	23236	49.91
21	6982	382	346	7710	1638	5983	0	0	5837	5599	-1329	19087	0	0	19087	2888	514	22489	49.92
22	6807	339	264	7410	1273	5909	0	0	5755	5628	-1388	18324	0	0	18324	2764	508	21596	49.89
23	6920	271	265	7456	1286	6001	0	0	5685	4936	-1081	18103	0	0	18103	2675	495	21273	49.91
24	6444	178	266	6888	1099	5553	0	0	5708	5330	-1152	17237	0	0	17237	2586	481	20304	49.99
MUs	148.10	4.86	6.41	159.37	27.68	124.76	0.00	14.23	158.86	149.68	-35.26	429.08	0.00	0.06	429.08	66.32	11.38	506.77	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR Carried out due to 220kV Nashik-BBLR 1 & 2 line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Jul/2024

Position as on 6.30 Hrs of 10/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	14/07/2024
MSPGCL	Paras Unit 3	250	30/06/2024	22:35		Continued.	Annual Overhaul	14/08/2024
MSPGCL	Koyna Unit 5	80	02/07/2024	11:00		Continued.	PLC upgradation work	27/07/2024
MSPGCL	Koyna Unit 3	70	09/07/2024	11:00		Continued.	Governor replacement work.	07/08/2024
Total Capacity MSPGCL		900						
IPP								
IPP	RPL(AMT) U-1	270	01/07/2024	07:00		Continued.	Annual Overhaul	01/08/2024
Total Capacity IPP		270						
Total Capacity PLANNED OUTAGE		1170						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	10/07/2024	11:15	10/07/2024	15:14	Furnace Pressure High	
MSPGCL	Chandrapur Unit 9	500	10/07/2024	17:44		Continued.	Boiler Tube Leakage	14/07/2024
Total Capacity MSPGCL		995						
IPP								
IPP	RPL(AMT) U-5	270	07/07/2024	10:06		Continued.	Due to Bottom Ash Evacuation problem.	11/07/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1585						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	17/06/2024	21:44	10/07/2024	18:20	Zero Schedule given by MSEDCL	
MSPGCL	Uran Unit 6	108	04/07/2024	23:59		Continued.	No Schedule by MSEDCL.	
MSPGCL	Uran Unit 5	108	10/07/2024	21:00		Continued.	Due to Zero schedule given by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Jul/2024

Position as on 6.30 Hrs of 10/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity MSPGCL		324						
IPP								
IPP	JSW (J) U2	300	01/07/2024	01:12		Continued.	Non availabilty of load schedule	
Total Capacity IPP		300						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		624						
UNIT OUT ON TOLLING *								
MSPGCL								
MSPGCL	Nasik Unit 4	210	06/07/2024	14:28	09/07/2024	07:14	For Shifting Tolling on Unit3 which is syn at 07:14 Hrs dt.09.07.2024	
MSPGCL	Nasik Unit 3	210	08/07/2024	13:30		Continued.	24V Dc Supply Failed supply problem is restored.under tolling from 07:14 Hrs of dtd.	
Total Capacity MSPGCL		420						
Total Capacity UNIT OUT ON TOLLING *		420						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 10/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 705 OF EKTUNI-AKOLA II ckt-1 @ EKTUNI	IntraState	09/07/2024	11:37	09/07/2024	15:19	PO	Routine Diagnostic testing works
765 KV LINE Outages/Trippings							
SOLAPUR (PG) - PUNE (GIS)	InterState	09/07/2024	07:56	09/07/2024	21:40	PO	due to Sant Tukaram Palkhi (Procession)-2024
TIRODA - KORADI 3 CKT - 2	IntraState	10/07/2024	10:56	10/07/2024	14:23	EO	To rectify and positioning of OPGW Suspension clamp opened on TN
765 KV ICT Outages/Trippings							
TIE BAY - 709 OF 765/400KV ICT-1 @ EKTUNI	IntraState	09/07/2024	16:23	09/07/2024	18:19	PO	Routine Diagnostic testing works
400 KV TIEBAY Outages/Trippings							
TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	IntraState	08/07/2024	11:41	09/07/2024	19:42	PO	ABB Breaker Mechanism Overhauling work and necessary testing
400 KV TBC Outages/Trippings							
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	09/07/2024	16:19	09/07/2024	19:30	EO	Sparking & Hot spot Observed.
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	10/07/2024	14:38			EO	To attend hotspot at 400 kV Bus Coupler bay at 89B PG Isolator Hanger & blade Contact
400 KV MAINBAY Outages/Trippings							
400KV 167MVA SPARE ICT @ 400KV TAPTITHANDA S/S	InterState	09/07/2024	17:05	09/07/2024	20:00	EO	TCIV Repeated alarm
MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	IntraState	10/07/2024	11:25			PO	ABB Breaker Mechanism overhauling work
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	23/06/2024	19:11	10/07/2024	23:02	HT	H/T For load Management.
KHADKA-AURANGABAD (WALUJ)	IntraState	09/07/2024	02:00	09/07/2024	10:09	HT	H/T on overvoltage
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	09/07/2024	16:05	09/07/2024	20:24	PO	1) CT testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work
KHADKA-AURANGABAD (WALUJ)	IntraState	10/07/2024	00:10	10/07/2024	23:42	HT	HT for Overvoltage Control
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	10/07/2024	11:20	10/07/2024	19:12	PO	regular line maintenance work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/06/2024	00:07			HT	H/T LV side only.
400/11kv STN-4A @ DEEPNAGAR	IntraState	26/06/2024	11:13			PO	For E/M for checking, cleaning and oil filtration work at MSPGCL End.
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	08/07/2024	10:03	09/07/2024	04:19	PO	Relay testing work , Routine maint. Work
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	09/07/2024	09:02	09/07/2024	16:43	PO	Normalcy Restoration of RRS Scheme for ICT II
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	09/07/2024	09:20	09/07/2024	16:46	PO	Normalcy Restoration of RRS Scheme for ICT II

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 10/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	10/07/2024	10:24	10/07/2024	19:02		For cold welding and maintenance of 400/220/33 KV 315 MVA ICT-02
400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	IntraState	10/07/2024	10:58	10/07/2024	14:54	PO	Diagnostic Testing of Line CTs & Main Bay CTs
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
ALEPHATA-PARGAON(KATHAPUR)	IntraState	02/07/2024	14:56			HT	For controlling loading of Kharghar - Talegaon PG.
220 KV KAULEWADA-KORADI 2 CKT - II	IntraState	09/07/2024	08:09	09/07/2024	17:46	PO	Fixing of Bird flight diverter
VITA - KHANAPUR LINE	IntraState	09/07/2024	09:30	09/07/2024	18:51	PO	Insulator String Replacement Work at various locations under scheme.
KARAD - VITA CKT- 2	IntraState	09/07/2024	09:30	09/07/2024	18:51	PO	Insulator String Replacement Work at various locations under scheme
NEW TPS - WAGHALA CKT 1	IntraState	09/07/2024	10:06	09/07/2024	12:30	PO	Flash over string replacement
KALWA - MULUND 2	IntraState	09/07/2024	10:24	09/07/2024	12:41	EO	Red hotspot is observed on 220KV Kalwa-Mulund Ckt-2 after shifting the line on TBC.
ONI KHAREPATAN LINE	IntraState	09/07/2024	10:35	09/07/2024	13:12	EO	For attending Earth Leakage at 220kV Oni-Kharepatan Bay at Oni end.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	09/07/2024	10:40	10/07/2024	01:42	HT	HT for Load Management
WARDHA (PG) - BADNERA	IntraState	09/07/2024	10:47	09/07/2024	13:11	PO	Routine line maintainance work
VANKUSWADE - AJINKYATARA	IntraState	09/07/2024	14:20	09/07/2024	16:10	EO	To attend sparking observed at R Ph Line ISO Jaw on 220kV Vankuswade line at 220kV Ajinkyatara S/Stn
MAIN BUS SECTION - 2 @ PEDAMBE	IntraState	09/07/2024	15:05	09/07/2024	19:08	EO	To attend Red hotspot observed at R Phase of Adlab-Pedhambe line main bus to main bus isolator near clamp
MIRAJ - MHAISHAL	IntraState	09/07/2024	16:30	09/07/2024	21:54	PO	String Replacement Work at various locations
220 KV KAULEWADA-KORADI 2 CKT - II	IntraState	10/07/2024	08:47	10/07/2024	14:10	PO	For fixing bird divert
KALMESHWAR-PANDHURNA	IntraState	10/07/2024	09:47	10/07/2024	16:11	PO	For routine maintenance work
KALMESHWAR-PANDHURNA	IntraState	10/07/2024	09:47	10/07/2024	16:11	PO	FOR LINE MAINTENANCE WORK

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 10/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/07/2024	09:55			HT	For load managment on 220kv Nashik-Babhleshwar ckt 1&2
KARAD -MUDSHINGI CKT 2-TAK	IntraState	10/07/2024	10:20	10/07/2024	17:49	PO	Replacement of Flashover disc insulator strings at Loc no.44 B ph & 45 R Ph
KARAD -MUDSHINGI CKT 2-TAK	IntraState	10/07/2024	10:20	10/07/2024	17:49	PO	For SSN to DSN string work at loc no. 176 & 177 road crossing .
TEMBHURNI - JEUR	IntraState	10/07/2024	11:10	10/07/2024	19:12	PO	Outage is required for Replacement of LA Under LE scheme
SALSETTE - VIKHROLI (GIS) CKT-1	IntraState	10/07/2024	11:22	10/07/2024	13:50	EO	Emergency outage required for attending/for fixing of hanging member in 220 kV Monopole no 1 of Vikhroli Salsette ckt-1. Reason for Emergency shutdown: A cable supporting member in Monopole no 01 got disconnected and is hanging which can fall or come in induction zone in case of heavy wind.
TALANDGE - HAMIDWADA	IntraState	10/07/2024	11:45	10/07/2024	17:58	PO	Replacement of 2nos of 245KV Line CT due to higher tandelta.
KARAD - VITA CKT- 2	IntraState	10/07/2024	14:31	10/07/2024	18:17	PO	Insulator String Replacement Work at various locations under scheme
VITA - KHANAPUR LINE	IntraState	10/07/2024	14:31	10/07/2024	18:17	PO	Insulator String Replacement Work at various locations under scheme.
TROMBAY - KALWA	IntraState	10/07/2024	23:29			T	Distance Protection
220 KV ICT Outages/Trippings							
220/33kv 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	21/06/2024	12:50			PO	Augmentation of 100 MVA ICT-02 with 200 MVA ICT
220/100 KV 200 MVA ICT 3 @ APTA	IntraState	08/07/2024	22:10	09/07/2024	02:34	T	Tripped on oltc Buchloze relay
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	09/07/2024	10:47	09/07/2024	18:45	PO	1) Retrofitting of Num. Differential protection relay by PAC Dn. Panvel. 2) Diagnostic testing woks. 3) Bay maintenance works.
220/33 KV 50 MVA PTR 2 @ BABHLESHWAR	IntraState	10/07/2024	10:34	10/07/2024	20:19	PO	HV back-up relay replacement work
220/132 KV 100MVA ICT 2 @ BARAMATI	IntraState	10/07/2024	11:35	10/07/2024	17:25	PO	Annual diagnostic testing & relay testing work.
100 MVA 220/132 KV ICT - I @ JALKOT	IntraState	10/07/2024	11:50	10/07/2024	13:57	PO	Oil leakage attending work from top plate
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	10/07/2024	13:49	10/07/2024	16:19	PO	For replacement of Y ph suspension string with the help of Substation Maintenance Nashik.
220/132/11KV 200 MVA ICT 2 @ MALINAGAR	IntraState	10/07/2024	14:50	10/07/2024	16:25	PO	Outage is required for Quarterly Maintenance
220/132 KV 100 MVA ICT 2 @ GHATODI	IntraState	10/07/2024	15:14	10/07/2024	16:28	PO	Point to point testing work
132 KV LINE Outages/Trippings							
KANHAN-MANSAR	IntraState	10/07/2024	08:56	10/07/2024	13:17	PO	For routine maintenance work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage