

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Sep/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	113.842	1117.046	1) Gujrat	6.007	72.074
2) Hydro	11.055	128.779	2) Madhya Pradesh	-2.841	19.163
3) Gas	2.519	31.283	3) Chattisgarh	2.960	30.000
Total MSPGCL	127.416	1277.108	4) Maharashtra	157.301	1488.677
B) 1) APML	66.104	600.898	5) Goa (Amona)	-0.708	-8.345
2) JSWEL	19.541	177.139	Total	162.719	1601.569
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.892	303.651
4) RPL(AMT)	18.704	135.631	b) Mumbai Drawl	35.321	330.124
5) SWPGPL	5.429	48.082	c) MSEDCL Bilateral *	38.127	402.220
6) Other IPP	5.774	53.655	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.892	303.526
C) 1) TPCL Thermal	12.174	108.525	Include PX	0.000	0.000
2) TPCL Hydro	4.256	47.535	Standby	0.000	0.125
3) TPCL Gas	0.270	9.452	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.786	88.212	1) MSEDCL	374.940	3618.136
D) STATE			2) Mumbai Discoms	61.807	583.849
1) Thermal	251.354	2329.188	3) Other Discoms	9.036	81.536
(A1+C1+C4+(B1-B6))			TOTAL STATE	445.783	4283.521
2) Hydro	15.311	176.314			
(A2+C2)					
3) Gas	2.789	40.735			
(A3+B7+C3)					
4) Wind	4.151	51.131			
6) SOLAR	9.459	84.583			
TOTAL STATE	283.064	2681.951			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4742	4348	5087	4795
MSPGCL Hydro	348	332	684	279
MSPGCL Gas	95	93	185	96
MSPGCL Total Generation	5185	4773	5956	5170
Central Sector Receipt	8457	7877	6048	5902
WIND	113	150	250	187
CPP / IPP Thermal	4631	4059	5537	5132
CPP / IPP Gas	0	0	0	0
SOLAR	694	1294	0	0
Exchange with Mumbai	-1810	-2318	-1178	-816
MSEDCL DEMAND MET	16862	15429	16209	15279
Load Shedding	0	0	0	0
MSEDCL DEMAND	16862	15429	16209	15279
TPCL GENERATION	478	471	1026	719
AEML GENERATION	298	319	487	489
MUMBAI DEMAND	2586	3108	2691	2024
OTHER DISCOM DEMAND	408	406	404	296
STATE DEMAND MET	19856	18943	19304	17599
STATE DEMAND	19856	18943	19304	17599
Frequency (Hz)	49.99	49.95	49.89	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 16.02 Hrs	49.76 Hz at 19.12 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.92	28.90	165	65
Unit 7	0.00	0.00	0	0
Unit 8	9.42	98.08	422	363
Unit 9	0.00	0.00	0	0
Unit 10	9.69	95.38	447	371
Total	22.03	222.35		
Bhusawal				
Unit 3	2.67	25.20	125	105
Unit 4	9.34	83.16	450	290
Unit 5	0.00	0.00	0	0
Total	12.02	108.36		
Parli				
Unit 6	2.94	40.03	218	0
Unit 7	0.57	31.28	115	0
Unit 8	2.14	35.79	130	0
Total	5.65	107.09		
Chandrapur				
Unit 3	3.12	24.63	150	47
Unit 4	3.08	30.80	152	114
Unit 5	7.01	31.49	330	261
Unit 6	7.00	68.73	340	255
Unit 7	7.60	70.11	348	281
Unit 8	0.00	49.00	0	0
Unit 9	9.76	90.79	449	294
Total	37.57	365.55		
Paras				
Unit 3	3.98	41.13	192	108
Unit 4	4.44	39.82	204	155
Total	8.42	80.95		
Khaparkheda				
Unit 1	2.94	23.08	125	115
Unit 2	2.73	21.23	130	100
Unit 3	3.34	28.97	152	129
Unit 4	3.41	31.39	161	125
Unit 5	7.71	72.48	430	270
Total	20.13	177.16		
Nasik				
Unit 3	3.04	27.98	140	115
Unit 4	2.24	2.44	139	55
Unit 5	2.75	25.16	138	86
Total	8.02	55.58		
Uran				
All Units	2.52	31.28	185	91
Total	2.52	31.28		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	5.17	27	23
Total	0.59	5.17		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.74	23.86	265	35
Stage 4	1.60	25.61	495	0
Stage 3	0.75	11.38	160	0
Total	4.09	60.85		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.75	6.69	61	0
TILLARI	0.00	3.71	0	0
BHIRA T.R.	0.44	3.83	60	0
SMLHY_PTN	5.18	45.10	225	210
GHATGHAR	0.00	3.43	0	0
Total	6.37	62.76		
Wind				
Total	4.15	51.13	0	0
Total	4.15	51.13		
CPP				
APML(Mus)	66.10	600.90	0	0
JSWEL(Mus)	19.54	177.14	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.70	135.63	0	0
SWPGPL-Mus	5.43	48.08	0	0
Other(Mus)	5.77	53.66	0	0
Total	115.55	1015.40		
SOLAR				
Total	9.46	84.58	0	0
Total	9.46	84.58		
Tata				
Trombay 5	8.13	72.96	444	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.15	5.99	39	0
Trombay 7B	0.12	3.46	34	0
TATA Hydro	4.26	47.54	413	32
Trombay 8	4.04	35.57	232	130
Total	16.70	165.51		
AEMIL				
DTPS U-1&2	9.79	88.21	495	297
Total	9.79	88.21		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	113.84	1117.05	MSPGCL Total	127.42	1277.11
			MSPGCL Thml+Gas	116.36	1148.33	Koyna 1,2 & 4 Total	3.34	49.47
			MSPGCL Hydro	11.06	128.78	State Total	283.06	2681.95

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4696	285	96	5077	104	5109	0	0	6290	6081	-768	15269	0	15269	2350	334	17953	49.99
2	4827	317	96	5240	74	5074	0	0	6023	5855	-775	15135	0	15135	2217	333	17685	49.92
3	4768	289	96	5153	128	5144	0	0	5874	6072	-849	15328	0	15328	2107	319	17755	49.96
4	4795	279	96	5170	187	5132	0	0	5959	5902	-816	15279	0	15279	2024	296	17599	49.93
5	4927	281	96	5304	144	5175	0	0	6211	6238	-985	15563	0	15563	1989	312	17865	49.97
6	4784	515	96	5395	149	5112	0	0	6924	6958	-1224	16057	0	16057	2031	333	18421	49.98
7	4767	1087	96	5950	160	5434	0	46	6659	6738	-1146	16816	0	16816	2111	366	19293	49.96
8	4788	621	96	5505	182	5064	0	289	7831	7710	-1420	16937	0	16937	2278	393	19608	50.02
9	4742	348	95	5185	113	4631	0	694	8202	8457	-1810	16862	0	16862	2586	408	19856	49.99
10	4644	377	95	5116	126	4380	0	1028	8079	8315	-2076	16480	0	16480	2866	410	19755	49.96
11	4588	369	95	5052	141	4382	0	1264	8322	8091	-2314	16200	0	16200	3078	416	19694	49.99
12	4339	378	95	4812	219	4075	0	1270	8348	8160	-2337	15792	0	15792	3145	407	19344	49.97
13	4348	332	93	4773	150	4059	0	1294	7953	7877	-2318	15429	0	15429	3108	406	18943	49.95
14	4191	331	91	4613	152	3817	0	1386	7899	7490	-2150	14905	0	14905	2971	402	18279	49.99
15	4315	330	91	4736	96	3847	0	1004	8055	8014	-2140	15158	0	15158	2961	398	18518	49.98
16	4455	330	92	4877	181	4228	0	667	7636	7299	-1884	14974	0	14974	2980	395	18348	50.03
17	4498	335	94	4927	391	4297	0	397	7621	7368	-1718	15261	0	15261	2870	401	18532	50.02
18	4904	331	107	5342	424	4582	0	117	7118	6724	-1799	14987	0	14987	2719	403	18109	49.99
19	5066	514	163	5743	393	5316	0	3	6607	5840	-1428	15451	0	15451	2686	416	18553	49.93
20	5087	684	185	5956	250	5537	0	0	6367	6048	-1178	16209	0	16209	2691	404	19304	49.89
21	5074	454	171	5699	150	5376	0	0	5893	5972	-1151	15663	0	15663	2609	383	18655	50.00
22	5103	951	95	6149	47	5058	0	0	5363	5289	-1072	15090	0	15090	2525	381	17996	49.99
23	5130	877	94	6101	40	5471	0	0	4762	5010	-990	15274	0	15274	2469	358	18101	49.97
24	5006	439	95	5540	150	5250	0	0	5561	5212	-973	14820	0	14820	2436	360	17615	49.95
MUs	113.84	11.06	2.52	127.42	4.15	115.55	0.00	9.46	165.56	162.72	-35.32	374.94	0.00	374.94	61.81	9.04	445.78	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 09/Sep/2022

Position as on 6.30 Hrs of 10/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	13/09/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	05/09/2022	09:20	09/09/2022	17:38	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High	09/09/2022
TPC-G	Trombay 7B	60	09/09/2022	03:36		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	09/09/2022	03:52		Continued.	Gas shortage	
MSPGCL	Parli Unit 7	250	09/09/2022	05:34	10/09/2022	15:50	Bus Bar Protection operated	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Sep/2022

Position as on 6.30 Hrs of 10/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 6	250	09/09/2022	05:34	09/09/2022	14:00	Bus Bar Protection operated	
MSPGCL	Parli Unit 8	250	09/09/2022	18:07	10/09/2022	05:40	Auxiliary Transformer Tripped.	
MSPGCL	Uran Unit 5	108	09/09/2022	20:59	10/09/2022	18:44	Synchronised	
MSPGCL	Nasik Unit 3	210	10/09/2022	11:46		Continued.	Turbine Vibration	
MSPGCL	Uran Unit 5	108	10/09/2022	20:44		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 10/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	10/09/2022	01:10	10/09/2022	06:18	HT	Emergency Hotspot attending work
CHANDRAPUR - PADGHE POLE 1 & 2	IntraState	10/09/2022	01:10	10/09/2022	06:18	EO	To attend the Hotspot on Pole-2 Neutral Bay Isolator (P2WNQ12)
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	10/09/2022	01:10	10/09/2022	04:28	HT	Emergency Hotspot attending work
400 KV TIEBAY Outages/Trippings							
TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	IntraState	09/09/2022	11:05	09/09/2022	14:34	PO	Diagnostic testing and allied bay maintenance work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	10/09/2022	13:06	10/09/2022	17:28	PO	Taking Oil Sample of 400 KV Tarapur Line 1 CT at Padghe MSETCL SS.
CHAKAN - TALEGAON(PG)	InterState	10/09/2022	20:12		Continued.	PO	For AMP and Relay testing works.
WARORA - IEPL	IntraState	01/09/2022	07:36	10/09/2022	19:45	PO	1. Dis-Connecting Horizontal Jumper and covert 400kv IEPL-PGCIL Deoli Ckt (Temporary Arrangemet for 10 Days) 400kv IEPL-Warora Ckt. 2. Connecting 400kv IEPL-Warora through new towers.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38			T	Y Phase Ground Fault
KARAD - LONIKAND I	IntraState	07/09/2022	15:01	10/09/2022	17:42	HT	HT for Load Management
KALWA - KHARGHAR	IntraState	08/09/2022	00:03	09/09/2022	04:16	EO	Hot spot attending work for following hotspots which are required to be attended on top priority to maintain uninterrupted power supply- i) Y-ph line side ii) Y-ph wave trap iii) CB R-ph palm (Bus side) iv) CB B-ph (Bus side)
KHADKA-AURANGABAD (WALUJ)	IntraState	08/09/2022	20:04	10/09/2022	09:08	HT	H/T FOR O/V
KORADI - KHADKA	IntraState	10/09/2022	10:10	10/09/2022	13:10	PO	For CB Timing testing & attending Air leakage problem
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	08/09/2022	23:22	09/09/2022	00:55	EO	Attending hot spot (660 degree celsius) at Bph CT clamp between isolator 205-29D & 205-29C
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	09/09/2022	14:52	09/09/2022	16:32	T	TRIPPED ON NDR
220 KV TBC Outages/Trippings							
AUXILIARY BUS @ MALEGAON	IntraState	29/08/2022	16:50	09/09/2022	14:23	PO	Shifting of TBC Bay new 50MVA 220/33kv PTR 3
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/09/2022	18:16	10/09/2022	14:28	HT	HT for Load Management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 10/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - CTRLS CKT	IntraState	09/09/2022	08:29	09/09/2022	17:38	PO	For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.
KHARGHAR - BORIVALI CKT - 2	IntraState	09/09/2022	08:50	09/09/2022	17:52	PO	For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.
BHIGWAN - WALCHAND NAGAR	IntraState	09/09/2022	10:10	09/09/2022	11:50	EO	REPLACEMENT OF FLASHOVER STRING AT LOC 67 R PH
WALCHANDNAGAR-LONI DEOKAR	IntraState	09/09/2022	12:35	09/09/2022	13:45	EO	REPLACEMENT OF FLASHOVER STRING AT LOC NO 64 R PH
TALEGAON (AMBI)-GENERAL MOTORS	IntraState	09/09/2022	15:56	09/09/2022	16:58	T	TRIPPED ON DISTANCE PROTECTION
BORIVALI - CTRLS CKT	IntraState	09/09/2022	17:42	09/09/2022	19:27	T	TRIPPED ON DISTANCE PROTECTION
BHAVEGHAR - ROMA	IntraState	09/09/2022	18:22	10/09/2022	02:52	T	TRIPPED ON DISTANCE PROTECTION
PADGHE - NALASOPARA	IntraState	09/09/2022	18:24	10/09/2022	11:14	T	TRIPPED ON DISTANCE PROTECTION
BORIVALI - CTRLS CKT	IntraState	09/09/2022	20:03	09/09/2022	15:47	HT	H/T FOR SAFETY PURPOSE INVIEWOF HOT SPOT NEAR BORIVALI END.
BHAVEGHAR - ROMA	IntraState	10/09/2022	05:22	10/09/2022	11:23	EO	Damaged R-ph tension string replacement work of 220kv Bhaveghar Roma Line.
KALWA - BORIVALI	IntraState	10/09/2022	06:00	10/09/2022	08:34	EO	For safety purpose to attend hot spot on Y ph jumper of 220 kv Borivali CTRLS line at loc no.51.
BORIVALI - BOISAR (PG)	IntraState	10/09/2022	06:24	10/09/2022	09:16	EO	For safety purpose to attend hot spot on Y ph jumper of 220 kv Borivali CTRLS line at loc no.51.
KHARGHAR - BORIVALI CKT - 2	IntraState	10/09/2022	09:42	10/09/2022	15:26	PO	For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.
EKLAHARE (OCR) - PADGHE	IntraState	10/09/2022	09:52	10/09/2022	21:57	HT	Load management
NEW KOYNA - POPHALI	IntraState	10/09/2022	10:37	10/09/2022	12:10	PO	For replacement of damaged conductor at loc no. 26 B phase New Koyna side, Y phase jump damaged, R phase 2 Red hot-New Koyna side
KANDALGAON - KOYNA (POPHALI)	IntraState	10/09/2022	11:07	10/09/2022	13:34	T	Tripped on Distance protection
SHEDYAL-JATH	IntraState	10/09/2022	12:28	10/09/2022	14:55	PO	Relay testing work at 220KV Shedyal end
CHEMBUR (AEML) - NERUL (M)	IntraState	10/09/2022	14:29	10/09/2022	15:02	T	Tripped on Dist Prot
NEW KOYNA - POPHALI	IntraState	10/09/2022	14:46	10/09/2022	18:56	HT	Approved outage
BORIVALI - CTRLS CKT	IntraState	10/09/2022	20:03	10/09/2022	15:47	PO	For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.
HINJAWADI I- CHINCHWAD	IntraState	10/09/2022	20:05		Continued.	HT	For load management of 400kv Talegaon-Chakan Line Outage
SATANA - GANGAPUR	IntraState	10/09/2022	21:18	10/09/2022	23:27	T	Tripped on Dist. Protection
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 10/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT 2@ PETH	IntraState	10/09/2022	10:01	10/09/2022	14:05	PO	Quarterly maintenance work
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage