

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 09/Oct/2017 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.374	979.760	1) Gujrat	-5.064	-8.624
2) Hydro	4.930	111.101	2) Madhya Pradesh	9.738	127.950
3) Gas	6.571	70.889	3) Chattisgarh	7.150	66.510
Total MSPGCL	119.875	1161.750	4) Maharashtra Net	129.162	1122.905
B) 1) APML	47.081	395.715	5) Goa (Amona)	-0.220	-1.628
2) JSWEL	24.055	232.038	Total	140.766	1307.113
3) VIPL	10.335	71.955	a) Mumbai Schedule	30.289	271.595
4) RPL(AMT)	9.999	115.119	b) Mumbai Drawl	37.482	309.433
5) WPCL	1.459	17.569	c) MSEDCL Bilateral *	46.126	304.025
6) PGPL	0.000	0.000	Include PX	6.409	47.831
7) Other IPP	5.909	56.158	d) Mumbai Bilateral *	30.008	271.314
C) 1) TPCL Thermal	13.671	137.620	Include PX	4.483	69.992
2) TPCL Hydro	3.894	39.694	Include Standby	0.281	0.281
3) TPCL Gas	2.444	26.689	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	5.172	50.461	1) MSEDCL	328.073	3114.398
D) STATE			2) Mumbai Discoms	62.663	563.896
1) Thermal	226.055	2056.395	TOTAL STATE	390.736	3678.294
(A1+C1+C4+(B1-B6))					
2) Hydro	8.824	150.795			
(A2+C2)					
3) Gas	9.015	97.578			
(A3+B6+C3)					
4) Wind	3.923	44.765			
6) SOLAR	2.153	21.649			
TOTAL STATE	249.970	2371.182			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	4398	4376	4693	4494
MSPGCL Hydro	171	126	446	67
MSPGCL Gas	272	267	270	278
MSPGCL Total Generation	4841	4769	5409	4839
Central Sector Receipt	6905	6723	5734	4928
WIND	82	46	313	169
CPP / IPP Thermal	3974	3937	4543	3879
CPP / IPP Gas	0	0	0	0
SOLAR	318	327	0	0
Exchange with Mumbai	-1788	-1785	-1597	-1379
MSEDCL DEMAND MET	14332	14017	14401	12436
Load Shedding	0	0	0	0
MSEDCL DEMAND	14332	14017	14401	12436
TPCL GENERATION	1187	1176	1181	468
R-INFRA GENERATION	247	249	249	191
MUMBAI DEMAND	3222	3210	3027	2038
STATE DEMAND MET	17554	17227	17428	14474
STATE DEMAND	17554	17227	17428	14474
Frequency (Hz)	50.01	49.98	49.93	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 09.03 Hrs	49.78 Hz at 17.41 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 09/Oct/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.13	96.92	470	261
Unit 9	0.00	0.00	0	0
Unit 10	9.73	86.14	520	310
Total	19.86	183.06		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	7.48	69.82	360	295
Unit 5	7.59	70.46	355	300
Total	15.08	140.28		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.36	39.25	190	176
Unit 7	4.34	26.40	194	176
Unit 8	0.00	10.92	0	0
Total	8.71	76.56		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	28.26	0	0
Unit 5	9.09	82.61	415	365
Unit 6	0.00	39.40	0	0
Unit 7	9.26	80.40	444	356
Unit 8	9.14	64.57	500	352
Unit 9	9.30	56.83	468	360
Total	36.79	352.07		
Paras				
Unit 3	3.95	35.60	176	147
Unit 4	3.90	34.96	171	152
Total	7.85	70.56		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	3.61	5.22	164	134
Unit 5	8.64	81.18	362	360
Total	12.26	86.40		
Nasik				
Unit 3	3.80	26.71	164	150
Unit 4	0.00	7.83	0	0
Unit 5	4.04	36.29	187	160
Total	7.83	70.83		
Uran				
All Units	6.57	70.89	287	256
Total	6.57	70.89		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.77	2.94	37	30
Total	0.77	2.94		
Koyna				
Stage 1-2	1.84	38.12	390	40
Stage 4	0.08	44.49	78	0
Stage 3	0.86	18.17	138	0
Total	2.78	100.79		
Hydro				
KDPH	0.00	0.18	0	0
VTRNA	0.91	2.05	61	0
TILLARI	0.12	0.12	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.26	2.78	77	0
RNGR+BHTSA	0.10	2.51	15	0
BHANDARDRA	0.31	0.50	15	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.26	1.93	11	10
GHATGHAR	0.19	0.24	93	0
Total	2.15	10.31		
Wind				
Total	3.92	44.76	0	0
Total	3.92	44.76		
CPP				
APML(Mus)	47.08	395.72	0	0
JSWEL(Mus)	24.06	232.04	0	0
VIPL(Mus)	10.34	71.96	0	0
RPLAMT(Mus)	10.00	115.12	0	0
WPCL(Mus)	1.46	17.57	0	0
Other(Mus)	5.91	56.16	0	0
Total	98.84	888.55		
SOLAR				
Total	2.15	21.65	0	0
Total	2.15	21.65		
Tata				
Trombay 5	8.45	87.71	483	164
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.36	15.36	72	50
Trombay 7B	1.09	11.33	53	41
Trombay 8	5.22	49.91	247	203
TATA Hydro	3.89	39.69	427	0
Total	20.01	204.00		
R-INFRA				
DTPS U-1&2	5.17	50.46	250	191
Total	5.17	50.46		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	108.37	979.76	MSPGCL Total	119.88	1161.75
			MSPGCL Thml+Gas	114.94	1050.65	Koyna 1,2 & 4 Total	1.92	82.62
			MSPGCL Hydro	4.93	111.10	State Total	249.97	2371.18

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Oct/2017

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4501	67	276	4844	158	3987	0	0	5300	5063	-1552	12500	0	12500	2208	14708	50.02
2	4494	67	278	4839	169	3879	0	0	4864	4928	-1379	12436	0	12436	2038	14474	49.98
3	4463	67	277	4807	227	3844	0	0	5090	4982	-1235	12625	0	12625	1893	14518	49.99
4	4472	77	269	4818	218	3853	0	0	5152	4932	-1137	12684	0	12684	1810	14494	50.03
5	4474	82	286	4842	193	3832	0	0	5044	5105	-1095	12878	0	12878	1770	14648	49.96
6	4591	112	278	4981	122	4094	0	0	5396	5632	-1164	13665	0	13665	1860	15525	49.95
7	4835	127	277	5239	112	4229	0	8	6184	5992	-1144	14437	0	14437	1939	16376	49.97
8	4700	132	278	5110	67	4202	0	47	6442	6202	-1289	14339	0	14339	2116	16455	50.04
9	4536	372	287	5195	65	3979	0	147	6156	6281	-1440	14227	0	14227	2389	16616	50.02
10	4483	380	273	5136	44	3946	0	223	6455	6453	-1823	13980	0	13980	2837	16817	49.96
11	4478	327	273	5078	47	3953	0	294	6850	6687	-1772	14287	0	14287	2987	17274	50.02
12	4398	171	272	4841	82	3974	0	318	7077	6905	-1788	14332	0	14332	3222	17554	50.01
13	4376	126	267	4769	46	3937	0	327	6806	6723	-1785	14017	0	14017	3210	17227	49.98
14	4419	166	267	4852	111	3745	0	296	6637	6777	-1978	13803	0	13803	3130	16933	49.97
15	4479	140	267	4886	186	3891	0	241	7060	6708	-1941	13971	0	13971	3164	17135	49.99
16	4424	135	256	4815	261	3907	0	165	6889	6426	-1692	13882	0	13882	3177	17059	49.97
17	4381	476	268	5125	296	3896	0	73	5636	6084	-1644	13830	0	13830	3140	16970	49.91
18	4515	621	278	5414	342	4021	0	14	5862	5972	-1720	14043	0	14043	3048	17091	49.90
19	4693	446	270	5409	313	4543	0	0	5959	5734	-1597	14401	0	14401	3027	17428	49.93
20	4536	258	272	5066	231	4902	0	0	6086	5823	-1626	14396	0	14396	2963	17359	50.01
21	4602	176	273	5051	172	4790	0	0	5634	5528	-1600	13940	0	13940	2825	16765	50.00
22	4595	175	272	5042	163	4725	0	0	5572	5240	-1632	13538	0	13538	2765	16303	49.99
23	4564	128	284	4976	144	4535	0	0	5512	5301	-1780	13176	0	13176	2654	15830	50.02
24	4365	102	273	4740	154	4174	0	0	5384	5287	-1669	12686	0	12686	2491	15177	49.96
MUs	108.37	4.93	6.57	119.88	3.92	98.84	0.00	2.15	143.05	140.77	-37.48	328.07	0.00	328.07	62.66	390.74	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Oct/2017

Position as on 6.30 Hrs of 10/Oct/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	TARAPUR 4	540	23/04/2017	19:55		Continued.	Annual Maintenance	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
MSPGCL	Koradi Unit 9	660	07/09/2017	00.38		Continued.	Coal shortage form 12.09.2017 converted to AOH dt.1.10.2017.	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Shutdown	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
CPP	SWPGL U-3	135	26/08/2017	17.40		Continued.	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 3	210	27/08/2017	07.43		Continued.	Coal Shortage From 29.08.2017.	
MSPGCL	Khaparkheda Unit 1	210	08/09/2017	12.23		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	12/09/2017	00.12		Continued.	Coal Shortage	
IPP	RPL(AMT) U-3	270	17/09/2017	00.02		Continued.	Coal Shortage	
IPP	RPL(AMT) U-5	270	17/09/2017	02.01		Continued.	Coal Shortage	
RINFRA-G	REL Unit 2	250	22/09/2017	00.11	10/10/2017	02.24	Coal Shortage	
MSPGCL	Khaparkheda Unit 2	210	25/09/2017	06.50		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 4	210	03/10/2017	00.08		Continued.	Coal Shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Oct/2017

Position as on 6.30 Hrs of 10/Oct/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 8	250	03/10/2017	17.00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 7	108	05/10/2017	00.06		Continued.	Gas Turbine Work	
MSPGCL	Uran Unit B0	120	05/10/2017	00.11		Continued.	Gas Turbine Work	
IPP	Adani U-3	660	05/10/2017	04.07		Continued.	Control Valve Problem	
IPP	RPL(AMT) U-1	270	06/10/2017	00.45		Continued.	Problem in submerged Scrapper chain	
MSPGCL	Chandrapur Unit 6	500	07/10/2017	00.35		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 4	210	08/10/2017	22.57		Continued.	Coal Shortage	
IPP	VIPL U-1	300	09/10/2017	13.10	09/10/2017	13.55	Generator Protection operated	
IPP	JSW (J) U2	300	10/10/2017	04.13		Continued.	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Oct/2017

Statement-VII

Position as on 6.30 Hrs of 10/Oct/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe HvdC Pole 2	IntraState	09/10/2017	08.04	09/10/2017	20.05	PO	Maintenance & testing work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	07/10/2017	19.22	10/10/2017	06.10	HT	Over Voltage
Karad - Jaigad - II	IntraState	27/09/2017	20.43	09/10/2017	10.51	HT	Over Voltage
karad -kolhapur-II	IntraState	05/10/2017	23.23		Continued.	HT	Over Voltage
Ektuni-Bableshwar ckt II	IntraState	06/10/2017	15.03		Continued.	EO	To attend Hot Spot
Bhusawal-Aurangabad	IntraState	06/10/2017	21.04	09/10/2017	09.27	HT	Over Voltage
Chandrapur-II - Nanded ckt II	IntraState	09/10/2017	11.32		Continued.	PO	Routine Maintenance Work
Ektuni-Bableshwar ckt I	IntraState	09/10/2017	19.14	09/10/2017	20.09	T	tripped at ektuni end.
Bableshwar- Aurangabad (Waluj)	IntraState	09/10/2017	19.15	09/10/2017	20.53	T	Bus Bar Protection Operated
Babhaleshwar - Padghe-II	IntraState	09/10/2017	19.15	09/10/2017	22.14	T	Bus Bar Protection Operated
Dhule - Bableshwar - li	IntraState	09/10/2017	19.15	09/10/2017	21.08	T	Bus Bar Protection Operated
Ektuni-Bableshwar ckt I	IntraState	09/10/2017	19.15	09/10/2017	20.09	T	Bus Bar Protection Operated
Bhusawal-Aurangabad	IntraState	09/10/2017	21.25		Continued.	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	09/10/2017	22.02		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ Kolhapur	IntraState	09/10/2017	10.14	09/10/2017	17.31	PO	Routine Maintenance Work
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	09/10/2017	19.15	09/10/2017	21.04	T	Bus Bar Protection Operated
400/220/33 Kv 315 MVA ICT II @Babhleshwar	IntraState	09/10/2017	19.15	09/10/2017	21.00	T	Bus Bar Protection Operated
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Mahalakshmi Amona	InterState	09/10/2017	04.00	09/10/2017	12.27	T	Over Voltage
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Pusad - Hingoli	IntraState	11/09/2017	20.06		Continued.	HT	Distance Relay Faulty at pusad end
Pedambe-Nerle	IntraState	23/09/2017	00.50		Continued.	T	B Phase CT Burst at Pedambe End
Deepnagar Amalner	IntraState	08/10/2017	22.24		Continued.	T	Distance Protection
Trombay - Kalwa	IntraState	09/10/2017	04.31	09/10/2017	06.24	PO	Line Maintenance work
Trombay - Mulund	IntraState	09/10/2017	05.41	09/10/2017	05.53	HT	Line Maintenance work
Nashik-Padgha	IntraState	09/10/2017	08.35	09/10/2017	10.55	EO	Attending Hot Spot
Ghodbunder - Gorai	IntraState	09/10/2017	09.29	09/10/2017	18.24	PO	Routine Maintenance Work
Bhugaon-WardhaPG (Deoli)	IntraState	09/10/2017	10.09	09/10/2017	17.09	PO	shifted on tbc.
Abhijeet-Wardha-I	IntraState	09/10/2017	13.11	09/10/2017	17.51	T	Distance Protection
Abhijeet-Wardha-II	IntraState	09/10/2017	13.11	09/10/2017	17.53	T	Distance Protection
Nanded-Ghatodi	IntraState	09/10/2017	17.25		Continued.	T	Distance Protection
Parli 3 (Old Gcr)-Girwali Ckt 2	IntraState	10/10/2017	02.50		Continued.	T	Bus Bar Protection Operated

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Oct/2017

Statement-VII

Position as on 6.30 Hrs of 10/Oct/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Parli 3(Old Gcr)-Parli Newtps Ckt-2	IntraState	10/10/2017	02.50	10/10/2017	04.16	T	Bus Bar Protection Operated
Parli 3(Old Gcr)-Parli Newtps Ckt 1	IntraState	10/10/2017	02.50	10/10/2017	03.48	T	Bus Bar Protection Operated
Parli 3 (Oldgcr)-Harangul Ckt 2	IntraState	10/10/2017	02.50	10/10/2017	03.50	T	Bus Bar Protection Operated
Parli 3 (Oldgcr)-Harangul Ckt I	IntraState	10/10/2017	02.50	10/10/2017	04.16	T	Bus Bar Protection Operated
Parli 3 (Old Gcr)-Osmanabad	IntraState	10/10/2017	02.50	10/10/2017	Continued.	T	Bus Bar Protection Operated
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	10/10/2017	02.50	10/10/2017	04.35	T	Bus Bar Protection Operated
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	10/10/2017	02.50	10/10/2017	04.32	T	Bus Bar Protection Operated
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/110kv 100MVA ICT-II @Miraj	IntraState	18/09/2017	11.27		Continued.	PO	Replacement Of Ict-2.
220/132 KV 200MVA ict 1@Nasik GCR	IntraState	09/10/2017	10.30	09/10/2017	15.57	PO	Routine Maintenance Work
220/132 Kv 100 Mva Ibt Ptr @Old Gcr Parli	IntraState	10/10/2017	02.50	10/10/2017	05.30	T	Bus Bar Protection Operated
132 KV LINE Outages/Trippings							
Girwali-Renapur-Ahamadpur	IntraState	08/10/2017	17.36	09/10/2017	09.13	T	Distance Protection
Amalner(220kv)-Chopda	IntraState	09/10/2017	03.10	09/10/2017	03.47	T	Distance Protection
Kaulewada-Gondia-I	IntraState	09/10/2017	14.10	09/10/2017	15.27	T	Distance Protection
Beed(220kv) -Telgaon	IntraState	09/10/2017	15.30	09/10/2017	16.06	T	Distance Protection
Kaulewada-Gondia-Ii	IntraState	09/10/2017	17.10	09/10/2017	17.27	T	Distance Protection
Bageshwari-Parbhani	IntraState	09/10/2017	21.26	09/10/2017	22.00	T	Distance Protection
Gangakhed- Sonpeth Ckt-Ii	IntraState	09/10/2017	21.30		Continued.	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage