

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 09/Oct/2019 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.416	1055.644	1) Gujrat	15.164	143.264
2) Hydro	4.738	49.926	2) Madhya Pradesh	4.587	79.045
3) Gas	6.288	77.949	3) Chattisgarh	2.580	24.890
Total MSPGCL	149.442	1183.519	4) Maharashtra	119.673	1199.938
B) 1) APLM	27.250	210.838	5) Goa (Amona)	-1.056	-4.466
2) JSWEL	19.702	160.237	Total	140.948	1442.671
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.725	267.606
4) RPL(AMT)	18.810	188.690	b) Mumbai Drawl	38.893	298.075
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	15.923	248.845
6) Other IPP	8.407	75.742	Include PX	0.000	82.585
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.725	267.606
C) 1) TPCL Thermal	12.356	118.136	Include PX	15.913	126.888
2) TPCL Hydro	4.483	30.625	Standby	0.000	0.000
3) TPCL Gas	3.600	30.586	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.952	79.072	1) MSEDCL	337.244	3068.599
D) STATE			2) Mumbai Discoms	64.284	556.492
1) Thermal	229.893	1888.359	TOTAL STATE	401.528	3625.091
(A1+C1+C4+(B1-B6))					
2) Hydro	9.221	80.551			
(A2+C2)					
3) Gas	9.888	108.535			
(A3+B7+C3)					
4) Wind	5.522	51.330			
6) SOLAR	6.056	53.647			
TOTAL STATE	260.580	2182.422			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5642	6325	6404	5270
MSPGCL Hydro	332	117	279	89
MSPGCL Gas	277	273	353	263
MSPGCL Total Generation	6251	6715	7036	5622
Central Sector Receipt	6987	6799	6215	3640
WIND	223	197	196	434
CPP / IPP Thermal	3039	3194	3654	2800
CPP / IPP Gas	0	0	0	0
SOLAR	877	430	0	0
Exchange with Mumbai	-2247	-2067	-1441	-1165
MSEDCL DEMAND MET	15130	15268	15660	11331
Load Shedding	0	0	0	0
MSEDCL DEMAND	15130	15268	15660	11331
TPCL GENERATION	861	967	1248	628
AEML GENERATION	195	246	246	195
MUMBAI DEMAND	3303	3280	2935	1988
STATE DEMAND MET	18433	18548	18595	13319
STATE DEMAND	18433	18548	18595	13319
Frequency (Hz)	50.03	50.03	50.06	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 14.04 Hrs	49.86 Hz at 21.36 Hrs	50.03	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 09/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.82	19.29	399	285
Unit 9	10.02	90.79	500	330
Unit 10	9.92	92.58	500	330
Total	27.76	202.66		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.55	87.80	500	355
Unit 5	8.92	10.31	480	225
Total	18.48	98.11		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	2.22	2.22	204	0
Unit 7	4.80	43.66	248	187
Unit 8	4.70	43.50	216	188
Total	11.71	89.38		
Chandrapur				
Unit 3	4.02	19.16	185	158
Unit 4	3.85	32.01	168	155
Unit 5	8.70	69.36	375	345
Unit 6	9.20	73.38	445	355
Unit 7	0.00	0.00	0	0
Unit 8	8.81	78.77	420	340
Unit 9	8.57	77.04	400	316
Total	43.14	349.72		
Paras				
Unit 3	4.40	27.92	195	158
Unit 4	0.00	0.00	0	0
Total	4.40	27.92		
Khaparkheda				
Unit 1	3.42	24.43	160	125
Unit 2	0.52	27.91	110	0
Unit 3	4.04	29.93	185	160
Unit 4	4.02	34.49	185	160
Unit 5	9.82	82.61	495	365
Total	21.83	199.36		
Nasik				
Unit 3	3.63	24.52	196	117
Unit 4	3.67	31.55	186	114
Unit 5	3.80	32.43	169	135
Total	11.10	88.50		
Uran				
All Units	6.29	77.95	371	138
Total	6.29	77.95		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.21	9.59	54	23

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.21	9.59		
Koyna				
Stage 1-2	2.06	23.75	300	40
Stage 4	0.16	9.11	84	0
Stage 3	0.39	7.47	80	0
Total	2.61	40.34		
Hydro				
KDPH	0.54	2.50	37	0
VTRNA	0.00	0.00	0	0
TILLARI	0.54	0.84	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.27	2.21	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	0.79	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.39	2.24	20	12
GHATGHAR	0.38	1.01	125	0
Total	2.13	9.59		
Wind				
Total	5.52	51.33	0	0
Total	5.52	51.33		
CPP				
APML(Mus)	27.25	210.84	0	0
JSWEL(Mus)	19.70	160.24	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	18.81	188.69	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.41	75.74	0	0
Total	74.17	635.51		
SOLAR				
Total	6.06	53.65	0	0
Total	6.06	53.65		
Tata				
Trombay 5	7.68	74.63	420	290
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.22	18.84	116	56
Trombay 7B	1.38	11.75	65	45
Trombay 8	4.68	43.50	207	181
TATA Hydro	4.48	30.62	453	0
Total	20.44	179.35		
AEML				
DTPS U-1&2	4.95	79.07	250	195
Total	4.95	79.07		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.42	1055.64	MSPGCL Total	149.44	1183.52
			MSPGCL Thml+Gas	144.70	1133.59	Koyna 1,2 & 4 Total	2.22	32.86
			MSPGCL Hydro	4.74	49.93	State Total	260.58	2182.42

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5111	338	252	5701	222	2819	0	0	4196	4360	-1428	11674	0	11674	2262	13936	50.03
2	5258	93	262	5613	403	2882	0	0	4287	3973	-1278	11594	0	11594	2099	13692	50.07
3	5270	89	263	5622	434	2800	0	0	3753	3640	-1165	11331	0	11331	1988	13319	50.06
4	5287	89	168	5544	459	2776	0	0	3510	3770	-1092	11457	0	11457	1913	13370	50.05
5	5289	94	138	5521	363	2781	0	0	3793	4101	-1066	11700	0	11700	1886	13586	50.02
6	5458	443	141	6042	200	2982	0	0	4696	4958	-1165	13017	0	13017	1977	14994	50.03
7	5879	169	167	6215	135	3240	0	25	5744	5691	-1306	14000	0	14000	2094	16094	50.00
8	6069	175	157	6401	162	3300	0	173	6117	6111	-1432	14715	0	14715	2266	16981	50.05
9	5735	91	204	6030	157	3218	0	438	6452	6792	-1673	14962	0	14962	2588	17550	50.01
10	5679	218	245	6142	204	3056	0	714	6466	6860	-1913	15064	0	15064	2946	18010	50.00
11	5702	172	278	6152	243	3060	0	820	6795	6923	-2146	15052	0	15052	3196	18248	50.02
12	5642	332	277	6251	223	3039	0	877	6933	6987	-2247	15130	0	15130	3303	18433	50.03
13	5656	234	265	6155	183	2997	0	870	6860	6915	-2215	14905	0	14905	3299	18204	50.03
14	5641	162	275	6078	172	3014	0	761	6803	6875	-2109	14791	0	14791	3203	17994	50.04
15	5920	342	263	6525	186	3048	0	628	6942	6873	-2127	15133	0	15133	3248	18381	50.04
16	6325	117	273	6715	197	3194	0	430	7102	6799	-2067	15268	0	15268	3280	18548	50.03
17	6169	128	275	6572	201	3284	0	251	6798	6536	-2006	14838	0	14838	3241	18079	50.02
18	6091	136	327	6554	178	3290	0	69	6361	6125	-1781	14434	0	14434	3155	17590	50.01
19	6468	169	371	7008	185	3422	0	0	6318	6325	-1581	15359	0	15359	3051	18410	50.04
20	6404	279	353	7036	196	3654	0	0	6350	6215	-1441	15660	0	15660	2935	18595	50.06
21	6063	264	352	6679	299	3335	0	0	6279	6071	-1442	14942	0	14942	2755	17697	50.03
22	5808	326	348	6482	253	3007	0	0	5950	6093	-1374	14461	0	14461	2611	17072	49.99
23	5768	172	320	6260	117	2999	0	0	6020	5984	-1388	13972	0	13972	2527	16499	49.97
24	5724	106	314	6144	150	2969	0	0	5920	5971	-1451	13783	0	13783	2461	16244	50.01
MUs	138.42	4.74	6.29	149.44	5.52	74.17	0.00	6.06	140.44	140.95	-38.89	337.24	0.00	337.24	64.28	401.53	50.03

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Oct/2019

Position as on 6.30 Hrs of 10/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Koyna STG- IV Unit - 1	250	18/07/2019	14.30		Continued.	Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019)	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage.Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53	09/10/2019	17.05	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyna Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
MSPGCL	Parli Unit 6	250	19/09/2019	06.24	09/10/2019	09.09	Poor Coal Receipt.	
IPP	Adani U-2	660	30/09/2019	05.37		Continued.	Coal Shortage	
IPP	Adani U-5	660	01/10/2019	23.10		Continued.	Coal Shortage	
MSPGCL	Koyna STG-IV Unit-2	250	02/10/2019	19.19		Continued.	Down Stream Seal Leakage Problem.	
MSPGCL	Uran Unit 6	108	07/10/2019	17.33	09/10/2019	05.35	Gas shortage	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 2	210	07/10/2019	22.28	09/10/2019	18.29	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Oct/2019

Position as on 6.30 Hrs of 10/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	09/10/2019	03.22		Continued.	Boiler Problem	
MSPGCL	Uran Unit B0	120	09/10/2019	03.23		Continued.	Boiler Problem	
IPP	JSW (J) U4	300	09/10/2019	12.49		Continued.	CW Duct Leakage.	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	
MSPGCL	Chandrapur Unit 4	210	10/10/2019	09.31	10/10/2019	20.22	LOW INSTRUMENT AIR PRESSURE.	
MSPGCL	Chandrapur Unit 3	210	10/10/2019	09.49	10/10/2019	17.40	VACUUM PROBLEM.	
MSPGCL	Uran Unit 7	108	10/10/2019	10.15		Continued.	Balancing work of GT	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 10/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT-II @ Koradi-III	IntraState	10/10/2019	10.05	10/10/2019	18.59	PO	Maintenance Work.
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	09/10/2019	11.42	09/10/2019	17.56	T	Protective Firing trip @ From Chandrapur End.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	05/10/2019	00.29		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	08/10/2019	23.55	09/10/2019	08.06	T	Over Voltage
Dabhol Nagothane I	InterState	10/10/2019	09.44	10/10/2019	13.20	PO	Tree Cutting.
Dabhol Nagothane II	InterState	10/10/2019	10.47	10/10/2019	14.09	HT	Due To Sparking On Won CB.
Padgha - Boisar (PG)	InterState	10/10/2019	14.41	10/10/2019	21.20	PO	CT REPLACEMENT WORK.
Karad-Jaigad - I	IntraState	05/10/2019	20.52	09/10/2019	12.05	HT	Over Voltage
Chandrapur - Parli	IntraState	07/10/2019	13.57		Continued.	T	Distance Protection, Z-2, B-Ph, 1.3KA, 317KM.
Khadka-Aurangabad (Waluj)	IntraState	07/10/2019	16.54	09/10/2019	08.28	HT	Over Voltage
Alkud-Kolhapur(Talandage)	IntraState	08/10/2019	23.36	09/10/2019	08.11	T	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	08/10/2019	23.55	09/10/2019	08.42	HT	Over Voltage
Koradi-Bhusawal	IntraState	09/10/2019	09.17	09/10/2019	18.37	PO	Tower Work.
Khadka-Aurangabad (Waluj)	IntraState	09/10/2019	18.29	10/10/2019	06.49	HT	Over Voltage
Karad-Jaigad - I	IntraState	09/10/2019	21.08		Continued.	HT	Over Voltage
karad -kolhapur-II	IntraState	10/10/2019	01.18	10/10/2019	10.36	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	10/10/2019	08.36		Continued.	PO	CB Overhauling work
Lonikand 1 - Chakan	IntraState	10/10/2019	09.34	10/10/2019	19.03	PO	Routine Maintenance Work
Chandrapu II - Chandrapur SW Ckt II	IntraState	10/10/2019	10.01	10/10/2019	16.48	PO	Diagnostic Testing Work.
Bus Coupler @ Lonikand	IntraState	10/10/2019	17.56		Continued.	PO	Attending Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	10/10/2019	17.58		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	09/10/2019	10.04	09/10/2019	18.29	PO	CTR & Diagnostic testing Work.
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	09/10/2019	11.10	09/10/2019	21.13	PO	Relay Replacement Work.
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	10/10/2019	08.33	10/10/2019	19.10	PO	CTR Make Fire Fighting System maintenance Work.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	10/10/2019	09.31	10/10/2019	16.54	PO	Half yearly maintenance work
400/220/33 kv 315 MVA ICT-I @Chandrapur GCR	IntraState	10/10/2019	09.59	10/10/2019	20.30	EO	Tan Delta Measurment of CTs
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	10/10/2019	10.50	10/10/2019	19.47	PO	Replacement Of R-PH CT.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Solapur (Pg) South Solapur I	InterState	09/10/2019	15.00	09/10/2019	16.10	T	Tripped From Solapur End Only.
Tillari Amona	InterState	10/10/2019	15.36	10/10/2019	22.02	T	Distance Protection
Talegaon(PG)-Talegaon(Ambi)-II	InterState	10/10/2019	20.45		Continued.	T	LA Brust.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 10/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand-Jejuri Line.
Versova Gorai Line	IntraState	08/10/2019	07.29	09/10/2019	18.11	PO	MMRDA Work.
Adlabs - Pedambe	IntraState	09/10/2019	00.05	09/10/2019	00.30	T	Tripped on distance protection from pedambe end only
Pophali - Pedambe II	IntraState	09/10/2019	08.00	09/10/2019	12.25	PO	SF6 Gas low.
Shirsuphal-Kurkumbh	IntraState	09/10/2019	09.00	09/10/2019	17.29	PO	Diagnostic Work.
Harangul-Parly	IntraState	09/10/2019	10.07	09/10/2019	21.26	PO	For LILO Arrangement.
Peth- Mudshingi -I	IntraState	09/10/2019	10.40	09/10/2019	12.03	PO	Routine Maintenance Work
Badnera-Akola I	IntraState	09/10/2019	10.40	09/10/2019	14.52	PO	Faulty Disc Replacement.
Chalisgaon-Sayne	IntraState	09/10/2019	11.43	09/10/2019	14.45	EO	Attending Hot Spot
Kharghar-Panvel TSS	IntraState	09/10/2019	12.35	09/10/2019	15.17	EO	Emergency tree cutting Work.
Ghatghar - Bapgaon	IntraState	09/10/2019	13.01	09/10/2019	17.30	PO	Emergency Tree Cutting.
Karad - Kadegaon	IntraState	09/10/2019	14.01	09/10/2019	19.04	T	Tripped On O/C At Karad,B PH Kadegaon End-B PH,17.25 km.
Virur - Gadchiroli	IntraState	09/10/2019	14.30	09/10/2019	14.40	T	PDR Operated.
Nagothane - ACCIL	IntraState	09/10/2019	16.20	10/10/2019	03.58	T	Distance Protection
Nagothane - Posco	IntraState	09/10/2019	22.53	10/10/2019	03.17	HT	Safety Permit.
Ghodbunder - Gorai	IntraState	10/10/2019	07.00	10/10/2019	14.41	PO	Replacement Of Existing in Service Polymer insulator.
Dahanu Ghodbunder Line 2	IntraState	10/10/2019	07.41	10/10/2019	18.10	PO	Annual Bay Maintenance.
Bablesghwar-Alephata ckt I	IntraState	10/10/2019	08.58	10/10/2019	17.40	PO	CRM & Tan Delta Measurement.
Karad -Mudshingi Ckt- IV	IntraState	10/10/2019	09.50	10/10/2019	15.15	PO	Faulty String Replacement Work.
Alkud Miraj	IntraState	10/10/2019	10.55	10/10/2019	17.45	PO	Faulty String Replacement Work.
Walchandnagar-Bhigwan	IntraState	10/10/2019	11.01	10/10/2019	15.40	PO	Replacement Of Flash over String.
Wardha - Wardharytss1	IntraState	10/10/2019	11.27	10/10/2019	17.20	PO	DIAGNOSTIC TESTING WORK & RELAY TESTING WORK.
Nanded-Parbhani	IntraState	10/10/2019	12.05	10/10/2019	12.24	T	Distance Protection
Kandalgaon - Bhira	IntraState	10/10/2019	14.30	10/10/2019	19.15	PO	Routine Maintenance Work
Pophali - New Koyana	IntraState	10/10/2019	15.16	10/10/2019	15.50	T	Tripped On Back Up.
Kandalgaon - Koyana (Pophali)	IntraState	10/10/2019	15.16		Continued.	T	35.2 KM, A/R L,Y-E 4.15 KAMP EARTH WIRE BROKEN AT LOCATION NO. 271 & 272.
REL Borivali Aarey Line	IntraState	10/10/2019	15.17	10/10/2019	18.01	PO	MMRD Work.
Kalyani - Baramati Agro	IntraState	10/10/2019	16.08	10/10/2019	19.18	PO	Line Maintenance work
Loteparshuram- Dasturi Line	IntraState	10/10/2019	16.30	10/10/2019	22.10	HT	JUMPER REPLACEMENT.
Nanded - Parli Ext. Ckt II	IntraState	10/10/2019	20.10	10/10/2019	20.35	T	Distance Protection
Chinchwad-Hinjewadi I	IntraState	10/10/2019	21.08	10/10/2019	23.56	HT	Load Management Purpose.
Sahara-Urse	IntraState	10/10/2019	22.48		Continued.	HT	TO CONTROL LOADING.
220 KV ICT Outages/Trippings							
220/100 Kv 200 Mva Bhel Ict 1 @Kalwa	IntraState	09/10/2019	11.32	09/10/2019	19.19	PO	OLTC Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage