

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Nov/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.280	1304.917	1) Gujrat	-7.689	-84.753
2) Hydro	6.664	75.648	2) Madhya Pradesh	-2.555	-20.101
3) Gas	1.465	14.632	3) Chattisgarh	5.610	52.310
Total MSPGCL	163.409	1395.197	4) Maharashtra	170.858	1478.319
B) 1) APML	71.297	563.813	5) Goa (Amona)	-0.842	-12.634
2) JSWEL	12.877	116.172	Total	165.382	1413.141
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.180	284.151
4) RPL(AMT)	25.610	229.758	b) Mumbai Drawl	36.589	318.184
5) SWPGPL	8.036	53.592	c) MSEDCL Bilateral *	70.996	582.520
6) Other IPP	31.050	252.203	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.180	284.151
C) 1) TPCL Thermal	11.440	97.104	Include PX	0.000	0.000
2) TPCL Hydro	4.651	35.594	Standby	0.000	0.000
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.561	78.278	1) MSEDCL	453.568	3835.433
D) STATE			2) Mumbai Discoms	62.241	536.150
1) Thermal	325.151	2695.837	3) Other Discoms	9.283	83.681
(A1+C1+C4+(B1-B6))			TOTAL STATE	525.092	4455.264
2) Hydro	11.315	111.242			
(A2+C2)					
3) Gas	1.465	21.622			
(A3+B7+C3)					
4) Wind	9.923	103.092			
6) SOLAR	11.856	110.330			
TOTAL STATE	359.710	3042.123			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6503	6593	6693	6415
MSPGCL Hydro	182	177	1469	158
MSPGCL Gas	61	61	61	61
MSPGCL Total Generation	6746	6831	8223	6634
Central Sector Receipt	8153	7898	6686	5342
WIND	452	383	371	292
CPP / IPP Thermal	6423	6228	6560	6047
CPP / IPP Gas	0	0	0	0
SOLAR	1600	1357	0	0
Exchange with Mumbai	-1752	-1727	-1582	-1458
MSEDCL DEMAND MET	21185	20565	19828	16519
Load Shedding	0	0	0	0
MSEDCL DEMAND	21185	20565	19828	16519
TPCL GENERATION	834	798	909	491
AEML GENERATION	488	496	481	317
MUMBAI DEMAND	3074	3021	2972	2266
OTHER DISCOM DEMAND	437	405	430	338
STATE DEMAND MET	24696	23991	23230	19123
STATE DEMAND	24696	23991	23230	19123
Frequency (Hz)	50.02	49.96	50.05	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.13 Hz at 16.02 Hrs	49.78 Hz at 13.45 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.84	41.10	210	180
Unit 7	0.00	0.00	0	0
Unit 8	13.02	108.45	592	480
Unit 9	12.61	110.94	600	481
Unit 10	9.51	83.14	400	395
Total	39.99	343.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.84	81.07	450	328
Unit 5	9.79	84.49	475	148
Total	19.63	165.57		
Parli				
Unit 6	4.00	33.30	215	147
Unit 7	3.96	32.04	238	140
Unit 8	3.64	25.15	168	144
Total	11.60	90.49		
Chandrapur				
Unit 3	3.15	29.13	165	110
Unit 4	2.71	25.98	140	98
Unit 5	6.70	57.81	300	255
Unit 6	7.38	58.67	355	274
Unit 7	7.64	64.74	350	278
Unit 8	10.85	87.56	468	393
Unit 9	10.03	83.22	432	351
Total	48.44	407.12		
Paras				
Unit 3	4.63	44.52	204	175
Unit 4	0.00	0.00	0	0
Total	4.63	44.52		
Khaparkheda				
Unit 1	2.86	24.12	130	105
Unit 2	2.77	23.15	130	105
Unit 3	4.07	30.91	184	145
Unit 4	4.00	29.60	179	138
Unit 5	11.55	90.26	490	444
Total	25.25	198.03		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	2.77	28.41	147	0
Unit 5	2.98	27.16	144	109
Total	5.75	55.56		
Uran				
All Units	1.46	14.63	62	60
Total	1.46	14.63		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.00	8.95	46	17
Total	1.00	8.95		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.38	22.66	210	40
Stage 4	1.20	16.11	884	0
Stage 3	0.54	8.62	238	0
Total	3.12	47.39		
Hydro				
KDPH	0.31	0.31	36	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.22	1.50	77	0
SMLHY_PTN	1.76	14.93	76	68
GHATGHAR	0.26	2.57	125	0
Total	2.55	19.30		
Wind				
Total	9.92	103.09	0	0
Total	9.92	103.09		
CPP				
APML(Mus)	71.30	563.81	0	0
JSWEL(Mus)	12.88	116.17	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.61	229.76	0	0
SWPGPL-Mus	8.04	53.59	0	0
Other(Mus)	31.05	252.20	0	0
Total	148.87	1215.54		
SOLAR				
Total	11.86	110.33	0	0
Total	11.86	110.33		
Tata				
Trombay 5	7.74	65.88	466	262
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	4.65	35.59	427	24
Trombay 8	3.70	31.22	240	129
Total	16.09	139.69		
AEML				
DTPS U-1&2	9.56	78.28	498	301
Total	9.56	78.28		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	155.28	1304.92	MSPGCL Total	163.41	1395.20
			MSPGCL Thml+Gas	156.74	1319.55	Koyna 1,2 & 4 Total	2.58	38.77
			MSPGCL Hydro	6.66	75.65	State Total	359.71	3042.12

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6415	158	61	6634	292	6047	0	0	5555	5342	-1458	16519	0	16519	2266	338	19123	49.98
2	6437	158	61	6656	353	5990	0	0	5596	5622	-1342	16968	0	16968	2105	311	19384	49.97
3	6467	167	61	6695	461	5848	0	0	5600	5682	-1251	17139	0	17139	1986	296	19421	49.99
4	6481	162	62	6705	372	6016	0	0	5525	5715	-1174	17352	0	17352	1905	282	19539	50.00
5	6581	162	62	6805	395	6270	0	0	5710	6087	-1157	18084	0	18084	1888	316	20288	50.03
6	6632	162	61	6855	399	6382	0	0	6249	6521	-1227	18577	0	18577	1986	353	20916	49.98
7	6728	176	60	6964	442	6293	0	31	7115	7469	-1271	19548	0	19548	2113	380	22041	49.95
8	6794	165	61	7020	372	6466	0	339	7328	7373	-1308	19871	0	19871	2269	391	22531	50.00
9	6665	183	61	6909	207	6384	0	842	7340	7680	-1526	20071	0	20071	2552	425	23048	49.97
10	6576	339	61	6976	222	6386	0	1280	7587	8046	-1600	20890	0	20890	2857	420	24167	49.95
11	6503	182	61	6746	452	6423	0	1600	8326	8153	-1752	21185	0	21185	3074	437	24696	50.02
12	6386	153	61	6600	445	6171	0	1713	8514	8022	-1724	20822	0	20822	3131	405	24358	50.03
13	6409	154	61	6624	339	5825	0	1725	8016	7951	-1678	20381	0	20381	3086	405	23872	50.03
14	6406	159	61	6626	319	5943	0	1547	7686	7623	-1673	19984	0	19984	2976	401	23361	49.98
15	6593	177	61	6831	383	6228	0	1357	7887	7898	-1727	20565	0	20565	3021	405	23991	49.96
16	6589	158	61	6808	374	6294	0	940	8435	7668	-1813	19859	0	19859	3070	412	23341	49.97
17	6512	143	61	6716	335	6350	0	421	8039	7990	-1676	19711	0	19711	3018	425	23154	49.97
18	6607	426	61	7094	314	6425	0	61	7322	7203	-1644	19014	0	19014	2952	439	22405	49.99
19	6693	1469	61	8223	371	6560	0	0	6437	6686	-1582	19828	0	19828	2972	430	23230	50.05
20	6583	748	61	7392	431	6476	0	0	7009	6709	-1594	18980	0	18980	2849	434	22263	50.03
21	6305	291	61	6657	578	6444	0	0	6690	6235	-1646	17853	0	17853	2702	415	20970	50.01
22	6264	216	61	6541	671	6035	0	0	6150	5831	-1632	17037	0	17037	2575	409	20021	50.01
23	6034	195	61	6290	702	5878	0	0	5926	5928	-1573	16831	0	16831	2478	394	19703	49.99
24	5620	361	61	6042	694	5736	0	0	5896	5948	-1561	16501	0	16501	2410	358	19269	49.99
MUs	155.28	6.66	1.46	163.41	9.92	148.87	0.00	11.86	165.94	165.38	-36.59	453.57	0.00	453.57	62.24	9.28	525.09	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Nov/2022

Position as on 6.30 Hrs of 10/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05	10/11/2022	08:45	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	14/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	14/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-3	135	21/10/2022	01:33		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	22/10/2022	16:51	10/11/2022	01:27	Turbine Vibration	15/11/2022
MSPGCL	Uran Unit 5	108	02/11/2022	17:35		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	
IPP	IEPL Unit 1	270	08/11/2022	03:17	09/11/2022	00:00	Due to clinkering in Boiler	
IPP	IEPL Unit 1	270	09/11/2022	00:45	09/11/2022	02:58	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Nov/2022

Position as on 6.30 Hrs of 10/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JSW (J) U3	300	09/11/2022	08:08		Continued.	Generator Elect. Fault	12/11/2022
MSPGCL	Nasik Unit 4	210	09/11/2022	22:00		Continued.	Boiler validity work	12/11/2022
MSPGCL	Bhusawal Unit 5	500	09/11/2022	23:22	10/11/2022	02:47	Flame Failure	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 09/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 712 OF 765/400KV ICT-2 AND BUS RECTOR @ EKTUNI	IntraState	10/11/2022	10:52			PO	Diagnostic Testing of CB & Routine Maintenance
TIE BAY (708) OF AKOLA CKT - 1 & TIRODA CKT - 2 @ KORADI - 3	IntraState	10/11/2022	10:56			PO	Annual Maintenance of Bay Equipment
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	IntraState	09/11/2022	09:50	09/11/2022	18:56	PO	Annual Maintenance of Bay Equipment
765 KV BR Outages/Trippings							
Main bay 711 of 765 kv Bus Reactor @ Ektuni	IntraState	09/11/2022	10:58	09/11/2022	20:18	PO	Diagnostic Testing of CB & Routine Maintenance
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21			PO	Annual Maintenance work AC & DC yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance, etc.
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	IntraState	10/11/2022	10:14			PO	Testing and Maintenance Work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
BUS COUPLER @ CHANDRAPUR	IntraState	09/11/2022	16:15	09/11/2022	20:16	EO	To attend the hot spot on B-ph PG -2 Isolator (Main Bus-2 Isolator) having temperature of more than 135 Degree Celsius on cross arm of scissor assembly of PG Isolator.
BUS COUPLER @ CHANDRAPUR	IntraState	09/11/2022	16:15	09/11/2022	20:16	EO	To attend the hot spot on B-ph PG -2 Isolator (Main Bus-2 Isolator) having temperature of more than 135 Degree Celsius on cross arm of scissor assembly of PG Isolator.
400 KV LINE Outages/Trippings							
TBC @ KOLHAPUR(TALANDGE)	IntraState	03/11/2022	16:15			PO	Overhauling of A bus, B Bus, C Bus PG isolators.
PADGHE - PADGHE HVDC CKT- 2	IntraState	05/11/2022	12:21			PO	1. Bay maint. work 2. Diagnostic testing work 3. Bhel CB Pole Overhauling work 4. A bus PG Isolator Replacement work under LES 5. If pole Overhauling work not completed due to any reason line will be charge on TBC. 6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator 7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change .
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
JAIGAD - KARAD CKT - 1	IntraState	08/11/2022	08:41	09/11/2022	08:06	PO	CVT replacement work
NAGOTHANE - DABHOL CKT - 1	IntraState	09/11/2022	03:53	09/11/2022	04:41	T	CB Tripped at Dabhol end only. AR successful at Nagothane end.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	09/11/2022	06:36	09/11/2022	17:43	PO	Replacement of faulty Disc Insulator strings by LRP strings
JAIGAD - KARAD CKT - 2	IntraState	09/11/2022	09:15	10/11/2022	08:30	PO	CVT replacement work
BUS - 1 @ NEW KOYNA	IntraState	09/11/2022	13:07			PO	1) 09/11/2022 to 10/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 11/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 and damage conductor replacement work 3) 12/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 13/11/2022 Bus Insulator replacement work at section Koyna -I & II 5) 14/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 15/11/2022 to 16/11/2022 Bus Insulator replacement work at section Jaigad - I & II
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	10/11/2022	06:10			PO	Replacement of faulty Disc Insulator strings by LRP strings
CHANDRAPUR 2 - DHARIWAL CKT - 2	IntraState	10/11/2022	10:21			PO	Diagnostic testing & allied bay maintenance work
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	07/11/2022	10:17			PO	Overhauling of 400kV Circuit Breaker (CGL Make) of 400/220kV, 315 MVA ICT-2 @ Girwali. 400/220kV, 315 MVA ICT-2 @ Girwali will remain charged through TBC
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	09/11/2022	09:12			PO	For HV CB Mechanism overhauling work
MAIN BAY (404) OF ICT -1 @ WARORA	IntraState	09/11/2022	09:24	09/11/2022	13:08	PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	09/11/2022	09:45	09/11/2022	18:12	PO	Overhauling of 400kV Circuit Breaker (CGL Make) of 400/220kV, 315 MVA ICT-2 @ Girwali
400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	IntraState	09/11/2022	10:04	10/11/2022	08:41	PO	CB Timing
400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	IntraState	09/11/2022	11:25	09/11/2022	16:58	PO	Diagnostic Testing of CBs
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	09/11/2022	12:42	09/11/2022	14:28	PO	Outage on 400/220/33 KV 501 MVA ICT - 3 @ WALUJ IV Bay Through TBC. 1) 29A & 29B Isolator Bus Jumpers removing and reconnecting work by Hot Line Team.2) 29A & 29B Isolator Overhauling & alignment work.
220 KV TBC Outages/Trippings							
BUS COUPLER @ JEJURI	IntraState	08/11/2022	10:59	09/11/2022	17:30	PO	CB Mechanism overhauling work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	07/11/2022	07:42			HT	For Overloading of 220kV Nashik-BBLR Line
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24			HT	For Load Management
SONKHAR - TROMBAY	IntraState	09/11/2022	00:10	09/11/2022	04:00	EO	To attend Hot spot on Y ph CB bottom plate.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LAMBOTI - PANDHARPUR	IntraState	09/11/2022	06:34	09/11/2022	17:43	PO	Outage is required for Replacement of old Tower of Loc no. 506 by B+9 mtr due to low ground clearance alongwith allied work.
LAMBOTI - KARKAMB	IntraState	09/11/2022	06:47			PO	Replacement of old Tower of Loc no. 506 by B+9 mtr due to low ground clearance alongwith allied work.
LONAND-BARAMATI	IntraState	09/11/2022	07:35	09/11/2022	17:58	HT	H/T TO CONTROL LINE LOADING
HINJAWADI I- CHINCHWAD	IntraState	09/11/2022	08:28	09/11/2022	12:29	HT	H/T TO CONTROL LINE LOADING
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	09/11/2022	08:41	09/11/2022	10:30	HT	H/T TO CONTROL LINE LOADING
URAN - KHARGHAR 1	IntraState	09/11/2022	09:24	09/11/2022	18:48	PO	For Disc Insulator String Repalcement work
IPCL - SPCL	IntraState	09/11/2022	11:05	09/11/2022	18:51	PO	Jumper tightening, Diagnostic testing and Maintenance work.
KALMESHWAR-PANDHURNA	IntraState	09/11/2022	11:14	09/11/2022	17:22	PO	Routine Maintenance & Dignostic testing work restringing of bottom ph conductor.
LOTEPARSHURAM- DASTURI LINE	IntraState	09/11/2022	12:40	09/11/2022	19:20	PO	Replacement of Y & B ph CTs of 220KV Dasturi line having higher Tan-delta values at 220KV Lote s/s. CB testing & relay testing to be done.
DAHANU - VIRAJ	IntraState	09/11/2022	14:59	09/11/2022	20:06	PO	Diagnostic Testing Work.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	10/11/2022	07:35			HT	H/T TO CONTROL BBLR LINE LOADING
NAGOTHANE - IPCL	IntraState	10/11/2022	10:00			PO	For jumper tightening and cable termination work
MAHINDRA VEHICLE-BRIDGESTONE	IntraState	10/11/2022	10:00			PO	Relay Testing and Maintanace work of 220kVMVML Bay at 220kV Bridgestone ss and 220kV Bridgestone Bay at 220kV MVML SS
HINJEWADI 2 - PEGASUS	IntraState	10/11/2022	10:08			PO	CB overhauling work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33KV 100MVA TF No.1 @ BOTHE	IntraState	09/11/2022	09:05	09/11/2022	18:11	PO	Overhauling of drive mechanism of HV CB & Bay maintenance work.
220/132 KV 200 MVA PTR NO 5 @ PARVATI	IntraState	10/11/2022	10:00			PO	HV/LV CT Tan Delta measurement work to attend PNRV leakage, OLTC overhauling work.
220/33KV 100MVA TF No.2 @ BOTHE	IntraState	10/11/2022	10:19			PO	Overhauling of drive mechanism of HV CB & Bay maintenance work.
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	09/11/2022	11:27	09/11/2022	18:18	PO	insulator string replacement work.
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	09/11/2022	09:27	09/11/2022	19:04	PO	Routine Maintenance work.
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage