

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Nov/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	176.140	1557.751	1) Gujrat	1.916	20.139
2) Hydro	10.030	73.181	2) Madhya Pradesh	2.572	39.447
3) Gas	6.865	57.815	3) Chattisgarh	8.200	69.390
Total MSPGCL	193.035	1688.747	4) Maharashtra	213.299	1903.632
B) 1) APLM	57.785	546.042	5) Goa (Amona)	-1.426	-13.449
2) JSWEL	25.254	234.409	Total	224.561	2019.159
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.595	346.948
4) RPL(AMT)	25.067	229.192	b) Mumbai Drawl	43.016	364.057
5) SWPGPL	9.283	96.019	c) MSEDCL Bilateral *	93.603	934.844
6) Other IPP	23.023	169.846	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.578	346.931
C) 1) TPCL Thermal	12.647	117.766	Include PX	0.000	0.000
2) TPCL Hydro	2.880	25.697	Standby	0.017	0.017
3) TPCL Gas	2.457	21.849	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.063	92.805	1) MSEDCL	523.336	4731.880
D) STATE			2) Mumbai Discoms	71.063	622.171
1) Thermal	339.262	3043.830	3) Other Discoms	10.625	94.691
(A1+C1+C4+(B1-B6))			TOTAL STATE	605.024	5448.742
2) Hydro (A2+C2)	12.910	98.878			
3) Gas (A3+B7+C3)	9.322	79.664			
4) Wind	6.536	91.327			
6) SOLAR	12.433	115.887			
TOTAL STATE	380.463	3429.586			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7513	6974	7215	7592
MSPGCL Hydro	411	325	1485	224
MSPGCL Gas	282	274	279	296
MSPGCL Total Generation	8206	7573	8979	8112
Central Sector Receipt	10922	10937	8667	8072
WIND	319	161	168	270
CPP / IPP Thermal	5927	6011	6721	5431
CPP / IPP Gas	0	0	0	0
SOLAR	1804	1434	0	0
Exchange with Mumbai	-2261	-2197	-1631	-1416
MSEDCL DEMAND MET	24441	23451	22410	20127
Load Shedding	0	0	0	0
MSEDCL DEMAND	24441	23451	22410	20127
TPCL GENERATION	791	822	1278	499
AEML GENERATION	387	485	488	314
MUMBAI DEMAND	3439	3504	3397	2229
OTHER DISCOM DEMAND	476	468	494	342
STATE DEMAND MET	28356	27423	26301	22698
STATE DEMAND	28356	27423	26301	22698
Frequency (Hz)	49.97	49.91	49.91	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 06.01 Hrs	49.64 Hz at 17.50 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Nov/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.66	38.08	185	105
Unit 8	14.12	70.87	629	565
Unit 9	13.87	123.62	621	517
Unit 10	14.10	126.16	601	563
Total	45.76	358.73		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.09	87.88	445	205
Unit 5	8.79	88.88	395	330
Total	16.88	176.76		
Parli				
Unit 6	4.28	44.38	240	0
Unit 7	5.26	32.22	245	158
Unit 8	5.33	49.05	239	182
Total	14.87	125.65		
Chandrapur				
Unit 3	3.71	31.80	160	147
Unit 4	3.60	32.85	153	140
Unit 5	10.64	94.47	465	420
Unit 6	7.85	75.83	375	255
Unit 7	7.95	70.22	348	310
Unit 8	11.36	98.83	488	464
Unit 9	11.29	101.30	481	455
Total	56.41	505.28		
Paras				
Unit 3	5.45	48.56	240	211
Unit 4	5.51	47.67	251	210
Total	10.96	96.23		
Khaparkheda				
Unit 1	3.94	27.08	175	155
Unit 2	2.84	24.25	133	92
Unit 3	4.06	32.00	180	125
Unit 4	3.97	35.25	178	123
Unit 5	11.06	95.81	470	440
Total	25.87	214.39		
Nasik				
Unit 3	0.00	25.50	0	0
Unit 4	3.56	29.62	158	135
Unit 5	1.84	25.59	126	0
Total	5.40	80.71		
Uran				
All Units	6.86	57.82	298	274
Total	6.86	57.82		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.93	8.38	40	33
Total	0.93	8.38		
Koyna				
Stage 1-2	3.32	18.40	535	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.06	10.83	500	0
Stage 3	0.76	6.85	216	0
Total	5.14	36.08		
Hydro				
KDPH	0.36	4.88	19	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.14	1.56	40	0
SMLHY_PTN	3.03	21.29	131	121
GHATGHAR	0.44	1.00	125	0
Total	3.97	28.73		
Wind				
Total	6.54	91.33	0	0
Total	6.54	91.33		
CPP				
APML(Mus)	57.78	546.04	0	0
JSWEL(Mus)	25.25	234.41	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.07	229.19	0	0
SWPGPL-Mus	9.28	96.02	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.37	48.58	268	204
Other(Mus)	17.66	116.46	0	0
JPL	0.00	4.81	0	0
Total	140.41	1275.51		
SOLAR				
Total	12.43	115.89	0	0
Total	12.43	115.89		
Tata				
Trombay 5	8.36	76.54	450	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.40	12.77	108	39
Trombay 7B	1.05	9.08	65	36
TATA Hydro	2.88	25.70	443	25
Trombay 8	4.29	41.23	238	132
Total	17.98	165.31		
AEML				
DTPS U-1&2	10.06	92.80	496	310
Total	10.06	92.80		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	176.14	1557.75	MSPGCL Total	193.04	1688.75
			MSPGCL Thml+Gas	183.00	1615.57	Koyna 1,2 & 4 Total	4.37	29.22
			MSPGCL Hydro	10.03	73.18	State Total	380.46	3429.59

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Nov/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7592	220	293	8105	228	5708	0	0	8603	8062	-1764	19941	0	0	19941	2690	398	23029	50.00
2	7642	223	293	8158	277	5799	0	0	8452	8227	-1585	20504	0	0	20504	2495	372	23371	50.01
3	7652	233	294	8179	276	5573	0	0	8479	8099	-1490	20287	0	0	20287	2336	350	22973	50.01
4	7592	224	296	8112	270	5431	0	0	8563	8072	-1416	20127	0	0	20127	2229	342	22698	50.03
5	7542	223	296	8061	318	5383	0	0	9002	8640	-1382	20665	0	0	20665	2194	355	23214	50.00
6	7558	222	298	8078	357	5549	0	0	9468	9311	-1385	21526	0	0	21526	2254	384	24164	50.01
7	7554	228	294	8076	433	5519	0	14	9792	9609	-1419	21818	0	2	21818	2333	414	24565	50.01
8	7542	508	292	8342	359	5581	0	263	9559	9820	-1661	22264	0	5	22264	2523	440	25227	49.98
9	7568	264	293	8125	368	5887	0	751	10003	10116	-1943	22841	0	29	22841	2862	463	26166	49.98
10	7561	400	286	8247	360	5622	0	1333	10543	10644	-2178	23555	0	87	23555	3185	473	27213	49.93
11	7513	411	282	8206	319	5927	0	1804	11126	10922	-2261	24441	0	114	24441	3439	476	28356	49.97
12	7178	229	277	7684	302	5339	0	1972	11556	11358	-2233	23939	0	112	23939	3539	483	27961	49.93
13	7195	231	277	7703	241	5205	0	1915	11172	11015	-2195	23411	0	47	23411	3531	473	27415	49.99
14	6991	543	274	7808	218	5337	0	1722	10575	10651	-2127	23144	0	4	23144	3428	465	27037	49.98
15	6974	325	274	7573	161	6011	0	1434	11305	10937	-2197	23451	0	133	23451	3504	468	27423	49.91
16	6988	235	276	7499	208	6343	0	836	11320	11037	-2083	23363	0	203	23363	3539	477	27379	50.02
17	6895	520	278	7693	237	5997	0	342	10677	10295	-1946	22129	0	275	22129	3465	489	26083	49.93
18	7139	985	279	8403	190	6699	0	47	8616	8613	-1604	21855	0	275	21855	3383	493	25731	49.81
19	7215	1485	279	8979	168	6721	0	0	8790	8667	-1631	22410	0	276	22410	3397	494	26301	49.91
20	7268	794	280	8342	235	6769	0	0	9078	8710	-1679	21889	0	87	21889	3272	488	25649	50.00
21	7282	461	283	8026	278	6610	0	0	8306	7631	-1774	20292	0	0	20292	3112	479	23883	49.96
22	7211	417	289	7917	254	5849	0	0	8103	7768	-1810	19509	0	0	19509	2942	469	22920	50.01
23	7294	418	291	8003	232	5575	0	0	7918	8012	-1682	19687	0	0	19687	2756	453	22896	49.95
24	7194	231	291	7716	247	5978	0	0	7958	8345	-1571	20285	0	0	20285	2655	430	23370	50.02
MUs	176.14	10.03	6.86	193.04	6.54	140.41	0.00	12.43	228.96	224.56	-43.02	523.34	0.00	1.65	523.34	71.06	10.63	605.02	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR carried due to overloading of 220KV Nasik- BBLR-I&II Line. 2) 220/33 kV 50 MVA TF 1 & 2 overload at 220KV Kopargaon s/s & 132Kv MIDC- Sonewadi Line overload .

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Nov/2023

Position as on 6.30 Hrs of 10/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyana Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	20/11/2023
MSPGCL	Bhusawal Unit 3	210	31/10/2023	23:45		Continued.	ID Fan Problem	16/11/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	For attending Hotspot of 220 KV Evacuation Line	20/11/2023
MSPGCL	Nasik Unit 3	210	08/11/2023	00:55	10/11/2023	04:02	Boiler Tube Leakage	10/11/2023
IPP	SWPGPL U-3	135	09/11/2023	00:09		Continued.	SSC CHAIN PROBLEM.	14/11/2023
MSPGCL	Parli Unit 6	250	09/11/2023	13:18	09/11/2023	17:02	Loss of fuel	
MSPGCL	Nasik Unit 5	210	09/11/2023	15:48		Continued.	ID Fan Problem	15/11/2023
MSPGCL	Bhusawal Unit 4	500	09/11/2023	23:46		Continued.	Heavy Clunker formed.	12/11/2023
MSPGCL	Khaparkheda Unit 4	210	10/11/2023	13:48		Continued.	Air heater 4A stopped rotating	15/11/2023
IPP	RPL(AMT) U-3	270	10/11/2023	14:00		Continued.	Master fuel tripped	13/11/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF PARLI (GIRWALI) CKT-1 @ NANDED	IntraState	09/11/2023	11:34	09/11/2023	14:52	PO	TIE CT Tan-d Test
400 KV TBC Outages/Trippings							
BUS COUPLER @ KOYNA STAGE IV	IntraState	10/11/2023	13:31	10/11/2023	1172	PO	Bus coupler time testing work
400 KV MAINBAY Outages/Trippings							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	09/11/2023	15:36			PO	For alignment work of 89L isolator of Station Transformer 6A
400/6.9KV 63MVA STN T/F 1 @ NANDGAONPETH	InterState	10/11/2023	14:00	10/11/2023	22:35	T	STN T/F-1 tripped on over current protection
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
PUNE(GIS) - TALEGAON(PG) CKT - 3	InterState	10/11/2023	19:14		Continued.	T	TRIPPED ON D/P, Rphase to earth fault.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\epsilon Y \epsilon$ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/10/2023	08:04			HT	H/T for load management.
KHARGHAR - VIKHROLI GIS CKT - 1	IntraState	29/10/2023	04:43		Continued.	HT	Line Hand tripped for safety purpose during tap period of Katai nakka.
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	29/10/2023	04:45			HT	Line Hand tripped for safety purpose during tap period of Katai nakka.
PARLI-SOLAPUR (LAMBOTI)	IntraState	09/11/2023	14:31	09/11/2023	19:43	PO	1) String replacement work. (2) Bay maintenance work.
LONIKAND 2 - KARJAT CKT - 2	IntraState	10/11/2023	19:37		Continued.	T	Tripped on distance protection. Yphase to earth fault.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	23/10/2023	00:10		Continued.	EO	CHECKING AND TESTING OF TRANSFORMER
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	28/10/2023	22:20			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	28/10/2023	22:27			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	28/10/2023	22:32			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
220 KV MAINBAY Outages/Trippings							
220KV AMALNER - JPL CKT 1	IntraState	09/11/2023	11:23	09/11/2023	14:25	PO	For maintenance of bay equipment at 22kv Amalner end.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV AMALNER - JPL CKT 2	IntraState	10/11/2023	11:26	10/11/2023	16:43	PO	For maintenance of bay equipment at 220kv Amalner end.
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ TALEGAON (PG)	InterState	10/11/2023	14:30	10/11/2023	20:21	PO	AMP Work
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	26/10/2023	20:16			HT	Charged from Navsary end only
VERSOVA - GHODBUNDER	IntraState	06/11/2023	20:15	09/11/2023	15:47	EO	Outage required for attending hotspot on B-phase isolator
BHOSARI 2 - TELCO	IntraState	09/11/2023	07:42	09/11/2023	19:51	PO	220KV ABB Make CB Pole Overhauling work by Agency (M/s Power Electronical)
BIDRI - SAWANTWADI	IntraState	09/11/2023	09:45	09/11/2023	17:25	PO	Faulty insulator found in PID replacement work
VILEBHAGAD - INOX	IntraState	09/11/2023	09:48	10/11/2023	01:02	PO	Replacement of 6no's of CT's at 220kV EHV Consumer INOX, Post Monsoon maintenance & Diagnostic testing work of 220kV Vilebhagad-INOX Line
FLAGSHIP-CHINCHWAD	IntraState	09/11/2023	10:08	09/11/2023	17:11	PO	Installation of LA Monitoring Device (LAMDD)
TALOJA II - OCIL 1	IntraState	09/11/2023	11:45	09/11/2023	14:47	PO	Routine maintenance, tree cutting work at Loc No. 4 to 5
MALEGAON - KALWAN CKT-1	IntraState	09/11/2023	11:47	09/11/2023	15:32	PO	attending red hot spot at loc no.123 Y phase
PADEGAON-SAWANGI	IntraState	09/11/2023	13:20	09/11/2023	16:24	PO	Attending red hot & bay maintenance work.
POPHALI - KDPH	IntraState	09/11/2023	15:30	09/11/2023	19:05	PO	Fixing of suspension clamp at Loc.no.3 & tightening of jumps at Loc.no.14
JEJURI (400 KV)-JEJURI- II	IntraState	09/11/2023	15:59	09/11/2023	19:05	PO	Annual CT tan delta & capacitance testing
BORIVALI - TARAPUR	IntraState	09/11/2023	20:29	10/11/2023	19:16	T	Tripped on Distance Protection.
BORIVALI - BOISAR (PG)	IntraState	09/11/2023	20:29	10/11/2023	20:12	T	Tripped on Distance Protection.
BHAVEGHAR - ROMA	IntraState	09/11/2023	20:52	10/11/2023	00:20	T	Tripped on Distance Protection.
HINGANGHAT - BHUGAON	IntraState	10/11/2023	03:50	10/11/2023	06:02	T	Distance Protection.
PADGHE - TEMGHAR - 1	IntraState	10/11/2023	05:59	10/11/2023	13:40	PO	1)For replacement of existing Back up relay with Distance Relay (M2) as per scheme for Padghe-Temghar-Kalwa Gateway by M/s GE T&D) 2) 220kV bus strengthening work (Replacement of Bus section 3 bus conductor 0.4 ACSR to 0.5 ACSR Moose)
TALANDGE - SAWANTWADI	IntraState	10/11/2023	09:29	10/11/2023	17:20	PO	Replacement of faulty insulator found in PID
KANDALGAON - KOYNA (POPHALI)	IntraState	10/11/2023	12:58	10/11/2023	19:12	PO	220kV B-ph CT replacement work to be carried out. (220kV B-ph CT need to be replace due to high Tan-delta Value)
132KV CHIKHALI(220KV)-DEULGAON MAHI CKT	IntraState	10/11/2023	16:07	10/11/2023	16:33	T	Distance Protection.
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 10/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 50 MVA PTR 2 @ BABHLESHWAR	IntraState	09/11/2023	17:01	09/11/2023	20:38	PO	Bay Maintenance work.
220/110 KV 250 MVA ICT - 1 @ VERSOVA (TATA)	IntraState	10/11/2023	08:49	10/11/2023	19:00	PO	220kV Bushing Tap Replacement.
220/132 KV 200 MVA ICT - 1 @ HARANGUL	IntraState	10/11/2023	10:05	10/11/2023	15:53	PO	Quarterly Maintenance Work.
220/33KV 25MVA PTR 1 @ NEW KOYNA	IntraState	10/11/2023	15:21	10/11/2023	15:32	PO	TBC Shifting for interchanging the Bus that is from Bus 1 to Bus 2 for black start mock drill arrangement
220/33KV 25MVA PTR 2 @ NEW KOYNA	IntraState	10/11/2023	15:41	10/11/2023	15:51	PO	TBC Shifting for interchanging the Bus that is from Bus 2 to Bus 1 for black start mock drill arrangement
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
MAIN BUS -2 @ 220 kV NET MAGIC GIS	IntraState	09/11/2023	11:23	09/11/2023	15:56	PO	Gas density monitor replacement work of 220kV GIS TF-2 D05 bay GC02 L2 phase due to leakage of SF6 gas from it for which Bus-II (having CTRLS - NET MAGIC GIS) is required to be dead.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
AMBERNATH - KALYAN CKT - 1	IntraState	10/11/2023	10:06	10/11/2023	18:25	PO	Closer inspection

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage