

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Dec/2019 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	130.675	1079.208	1) Gujrat	4.656	43.644
2) Hydro	20.288	148.707	2) Madhya Pradesh	7.192	93.688
3) Gas	6.111	76.547	3) Chattisgarh	7.550	63.650
Total MSPGCL	157.074	1304.462	4) Maharashtra	116.119	1038.809
B) 1) APML	75.412	667.978	5) Goa (Amona)	-0.748	-6.248
2) JSWEL	23.115	211.870	Total	134.769	1233.543
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.660	251.805
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	29.709	268.339
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	33.645	273.737
6) Other IPP	14.551	124.050	Include PX	11.572	70.272
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.660	251.805
C) 1) TPCL Thermal	10.146	88.836	Include PX	8.799	95.146
2) TPCL Hydro	6.196	45.395	Standby	0.000	0.000
3) TPCL Gas	2.207	30.360	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.021	97.314	1) MSEDCL	388.131	3447.807
D) STATE			2) Mumbai Discoms	59.278	530.243
1) Thermal	264.920	2269.256	TOTAL STATE	447.409	3978.050
(A1+C1+C4+(B1-B6))					
2) Hydro	26.484	194.102			
(A2+C2)					
3) Gas	8.318	106.907			
(A3+B7+C3)					
4) Wind	7.944	129.541			
6) SOLAR	4.975	44.702			
TOTAL STATE	312.641	2744.508			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5592	5597	5721	4735
MSPGCL Hydro	1445	1481	1473	66
MSPGCL Gas	273	237	271	230
MSPGCL Total Generation	7310	7315	7465	5031
Central Sector Receipt	7140	6761	5088	4491
WIND	335	220	237	462
CPP / IPP Thermal	4897	4880	4805	4447
CPP / IPP Gas	0	0	0	0
SOLAR	751	765	0	0
Exchange with Mumbai	-1502	-1469	-1386	-1013
MSEDCL DEMAND MET	18931	18472	16209	13418
Load Shedding	0	0	0	0
MSEDCL DEMAND	18931	18472	16209	13418
TPCL GENERATION	1026	1028	1029	376
AEML GENERATION	502	502	499	374
MUMBAI DEMAND	3030	2999	2914	1763
STATE DEMAND MET	21961	21471	19123	15181
STATE DEMAND	21961	21471	19123	15181
Frequency (Hz)	49.93	49.96	49.95	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.19 Hz at 21.59 Hrs	49.7 Hz at 14.19 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 09/Dec/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.66	109.07	610	350
Unit 9	12.19	107.30	545	480
Unit 10	12.82	34.89	565	500
Total	37.67	251.26		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.07	55.92	70	0
Unit 5	10.42	66.40	485	360
Total	10.48	122.32		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.76	50.35	250	190
Unit 7	5.59	27.79	249	187
Unit 8	4.09	34.44	250	0
Total	15.44	112.58		
Chandrapur				
Unit 3	4.38	37.42	193	163
Unit 4	3.59	29.48	170	128
Unit 5	8.79	79.42	370	353
Unit 6	10.82	94.79	480	360
Unit 7	0.00	0.00	0	0
Unit 8	10.63	93.80	490	360
Unit 9	10.73	94.10	480	360
Total	48.94	429.00		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.01	0.01	10	0
Unit 2	0.04	0.04	40	0
Unit 3	0.09	0.09	60	0
Unit 4	3.94	34.14	182	145
Unit 5	9.83	91.69	445	365
Total	13.91	125.97		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	4.23	38.08	194	160
Total	4.23	38.08		
Uran				
All Units	6.11	76.55	281	227
Total	6.11	76.55		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	1.12	29	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.13	1.12		
Koyna				
Stage 1-2	5.72	42.62	485	35
Stage 4	9.96	71.26	760	0
Stage 3	3.36	24.19	320	0
Total	19.04	138.06		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.30	2.64	80	0
RNGR+BHTSA	0.34	3.31	16	0
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.16	2.43	7	6
GHATGHAR	0.44	2.27	125	0
Total	1.24	10.64		
Wind				
Total	7.94	129.54	0	0
Total	7.94	129.54		
CPP				
APML(Mus)	75.41	667.98	0	0
JSWEL(Mus)	23.12	211.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	14.55	124.05	0	0
Total	113.08	1003.90		
SOLAR				
Total	4.98	44.70	0	0
Total	4.98	44.70		
Tata				
Trombay 5	10.15	88.74	479	282
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.21	18.38	54	49
Trombay 7B	1.00	11.98	44	40
Trombay 8	0.00	0.10	0	0
TATA Hydro	6.20	45.40	459	0
Total	18.55	164.59		
AEML				
DTPS U-1&2	11.02	97.31	502	373
Total	11.02	97.31		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	130.68	1079.21	MSPGCL Total	157.07	1304.46
			MSPGCL Thml+Gas	136.79	1155.76	Koyna 1,2 & 4 Total	15.68	113.88
			MSPGCL Hydro	20.29	148.71	State Total	312.64	2744.51

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 09/Dec/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4760	46	239	5045	419	4313	0	0	5025	4837	-1271	13343	0	13343	2021	15364	50.02
2	4743	61	238	5042	421	4437	0	0	4891	4743	-1115	13528	0	13528	1866	15394	50.00
3	4735	66	230	5031	462	4447	0	0	4755	4491	-1013	13418	0	13418	1763	15181	50.02
4	4741	66	239	5046	451	4448	0	0	4687	4531	-948	13528	0	13528	1695	15223	50.00
5	5131	57	250	5438	498	4473	0	0	4752	4813	-931	14291	0	14291	1678	15969	49.97
6	5476	169	270	5915	536	4476	0	0	5321	5296	-943	15280	0	15280	1794	17074	49.99
7	5552	813	278	6643	510	4532	0	3	6126	5888	-793	16783	0	16783	1974	18757	49.96
8	5577	1393	278	7248	480	4694	0	87	6064	5883	-766	17626	0	17626	2137	19763	49.95
9	5591	1322	280	7193	436	4798	0	311	6032	5990	-925	17803	0	17803	2425	20228	49.99
10	5570	1279	279	7128	451	4838	0	558	6087	6258	-1215	18018	0	18018	2740	20758	49.96
11	5526	1337	268	7131	382	4843	0	702	6686	6508	-1427	18139	0	18139	2954	21093	49.95
12	5592	1445	273	7310	335	4897	0	751	7002	7140	-1502	18931	0	18931	3030	21961	49.93
13	5597	1481	237	7315	220	4880	0	765	6758	6761	-1469	18472	0	18472	2999	21471	49.96
14	5590	1587	228	7405	166	4910	0	702	6556	6688	-1526	18345	0	18345	2891	21236	49.94
15	5570	1630	236	7436	136	4904	0	573	6704	6693	-1509	18233	0	18233	2935	21168	49.82
16	5626	1653	238	7517	153	4871	0	367	6679	6846	-1445	18309	0	18309	2959	21268	49.92
17	5678	1477	227	7382	104	4860	0	140	6448	6336	-1408	17414	0	17414	2936	20350	49.95
18	5717	1282	238	7237	122	4847	0	16	5678	5710	-1378	16554	0	16554	2886	19440	49.97
19	5721	1473	271	7465	237	4805	0	0	4957	5088	-1386	16209	0	16209	2914	19123	49.95
20	5745	1101	281	7127	238	4943	0	0	4869	4867	-1291	15884	0	15884	2797	18681	49.98
21	5627	336	272	6235	257	4866	0	0	4801	4735	-1198	14895	0	14895	2647	17542	49.95
22	5531	93	281	5905	263	4733	0	0	4988	4912	-1328	14485	0	14485	2515	17000	50.04
23	5581	58	253	5892	312	4642	0	0	5050	5044	-1446	14444	0	14444	2415	16859	50.01
24	5698	63	227	5988	355	4621	0	0	5024	4711	-1476	14199	0	14199	2308	16507	50.00
MUs	130.68	20.29	6.11	157.07	7.94	113.08	0.00	4.97	135.94	134.77	-29.71	388.13	0.00	388.13	59.28	447.41	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Dec/2019

Position as on 6.30 Hrs of 10/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
MSPGCL	Nasik Unit 4	210	20/11/2019	04.15		Continued.	ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019	
TPC_G	Trombay 8	250	01/12/2019	00.50		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-4	250	06/12/2019	12.00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11	09/12/2019	23.32	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17	09/12/2019	22.58	Zero Schedule	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 09/Dec/2019

Position as on 6.30 Hrs of 10/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 3	210	27/11/2019	22.53	09/12/2019	22.35	Zero Schedule.	
MSPGCL	Uran Unit 8	108	30/11/2019	19.14		Continued.	Over Speed Bolt Trip.	
MSPGCL	Parli Unit 8	250	06/12/2019	12.59	09/12/2019	03.47	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 4	500	06/12/2019	22.00	09/12/2019	23.13	Burner Drill problem & Tap Changer problem.	
MSPGCL	Uran Unit 7	108	07/12/2019	07:14		Continued.	Gas shortage	
MSPGCL	Uran Unit B0	120	07/12/2019	07:14		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Dec/2019

Statement-VII

Position as on 6.30 Hrs of 10/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	07/12/2019	10.04	09/12/2019	08.36	PO	Work At SSNL End.(RFC AT 17:17 HRS.)
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	09/12/2019	10.25	09/12/2019	10.54	T	Bus-Bar Operated
Dhule Sar'Sarovar I	InterState	09/12/2019	19.24		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/12/2019	09.54		Continued.	PO	Construction Work
Koradi-Bhusawal	IntraState	04/12/2019	08.41		Continued.	PO	Restranging of Conductor
karad -kolhapur-II	IntraState	09/12/2019	10.25	09/12/2019	11.10	T	Bus-Bar Operated
Alkud-Kolhapur(Talandage)	IntraState	09/12/2019	10.25	09/12/2019	11.52	T	Bus-Bar Operated
Warora -IEPL	IntraState	10/12/2019	08.28	10/12/2019	15.31	PO	Routine Maintenance Work & Testing Work.
New Koyna - Dabhol - II	IntraState	10/12/2019	10.10	10/12/2019	19.53	PO	Maintenance Work,Earth wire Replacement Work.
Koradi III(Adani)-Korad II Ckt-I	IntraState	10/12/2019	10.25	10/12/2019	13.46	PO	For Investigation & Racti.Of Low SF6 Gas.
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)	IntraState	09/12/2019	10.25	09/12/2019	11.03	T	Bus-Bar Operated
400/220KV 500MVA ICT-II@Taptitanda	IntraState	09/12/2019	13.45	09/12/2019	15.32	T	Tripped due to Snake
400/220kv 315 Mva ICT I @Karad	IntraState	10/12/2019	10.17	10/12/2019	16.25	PO	Quarterly Maintainance Work
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	10/12/2019	10.27		Continued.	PO	For Replacment Of Y-PH UNIT By Overhauled Unit.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BADNERA - WARDHA (PG) (Deoli)	InterState	10/12/2019	08.31	10/12/2019	10.54	PO	To Control OD.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Oni Kharepatan Line	IntraState	09/12/2019	08.41	09/12/2019	18.50	PO	Isolator Maintenance Work
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	09/12/2019	08.42	09/12/2019	18.22	PO	Replacement work
Pedhambe - Oni	IntraState	09/12/2019	09.05	09/12/2019	19.30	PO	Isolator Maintenance Work
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	09/12/2019	09.24	09/12/2019	13.47	PO	Annual Maintenance Work
Mahad-Kandalgaon	IntraState	09/12/2019	09.31	09/12/2019	19:40	PO	Replacement of Cross ARM
Peth- Mudshingi -I	IntraState	09/12/2019	09.35	09/12/2019	18.51	PO	Earth Wire Replacement
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	09/12/2019	09.43	09/12/2019	18.54	PO	Earth Wire Replacement
Kolhapur-Bidri	IntraState	09/12/2019	10.05	09/12/2019	16.05	PO	Annual Maintenance Work
Nanded - Parli Ext. Ckt I	IntraState	09/12/2019	11.28	09/12/2019	13.33	PO	Diagnostic Testing Work
Koradi-Butibori Rly Tss	IntraState	09/12/2019	12.23	09/12/2019	18.51	PO	Relay Testing Work
Nanded - Parli Ext. Ckt II	IntraState	09/12/2019	13.35	09/12/2019	15.29	PO	Diagnostic Testing Work
Ghatghar - Bapgaon	IntraState	09/12/2019	13.37	09/12/2019	14.01	T	Distance Protection
Talandge(400kv)- Ichalkaranji ckt-2	IntraState	09/12/2019	13.53	09/12/2019	18.26	EO	Attending Hot Spot
Bableshtar Ahamadnagar-I	IntraState	09/12/2019	14.33	09/12/2019	14.52	T	Distance Protection
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	10/12/2019	08.50	10/12/2019	18.27	PO	Replacment of Disc.Insulator.
Peth- Mudshingi -I	IntraState	10/12/2019	09.31	10/12/2019	17.07	PO	For Destringing of old Earth Wire With New Earth Wire.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Dec/2019

Statement-VII

Position as on 6.30 Hrs of 10/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	10/12/2019	09.33	10/12/2019	17.09	PO	For Destringing of old Earth Wire With New Earth Wire.
Parli 2-(Girwali) -Murud	IntraState	10/12/2019	10.49	10/12/2019	14.19	EO	Attending Hot Spot
Vita - Ghatnandre	IntraState	10/12/2019	10.56	10/12/2019	12.41	PO	Emergency Tree Cutting.
Nanded-Ghatodi	IntraState	10/12/2019	11.04	10/12/2019	14.16	PO	CT Tan Delta & Relay Testing Work.
Centuri Enka- Bhosari	IntraState	10/12/2019	11.53	10/12/2019	13.13	PO	CRM Measurement Of CB & Timing Test Of CB.
Paras-Chikhali Ckt No-I	IntraState	10/12/2019	13.45	10/12/2019	15.30	HT	In View Of 220KV Akola Bus Section 2 Outage.
Eklahare (Ocr)Nasik - Padghe 2	IntraState	10/12/2019	14.34	10/12/2019	14.38	PO	For managing Load On GCR-Bablesghwar CKT-2.
Eklahara(Gcr)(Nasik)- Bablesghwar-I	IntraState	10/12/2019	14.35	10/12/2019	19.42	T	Distance Protection
Pedambe-Nerle	IntraState	10/12/2019	18.37	10/12/2019	18.57	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132-110kv 100mva Imp Ptr 1 @Wathar	IntraState	09/12/2019	09.50	09/12/2019	16.58	PO	Quarterly Maintenance Work
220/132/11 Kv 200 Mva Cgl Ict 2 @Amravati	IntraState	09/12/2019	09.51	09/12/2019	18.46	PO	Diagnostic Testing Work
220/132 Kv 200mva Vijay Ict 2 @Jalna	IntraState	09/12/2019	10.37	09/12/2019	16.55	PO	Tan Delta Measurement
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	10/12/2019	09.56	10/12/2019	13.21	PO	Tan Delta Measurement of CTs
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	10/12/2019	13.28	10/12/2019	16.05	PO	100Kv Isolator Service & Alignment.RMW.
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	10/12/2019	14.12	10/12/2019	18.20	PO	diagnostic Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage