

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 09/Dec/2021 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	141.413	1208.925	1) Gujrat	-4.896	-58.394
2) Hydro	8.946	68.239	2) Madhya Pradesh	-7.366	23.802
3) Gas	3.712	34.642	3) Chattisgarh	6.230	49.450
Total MSPGCL	154.071	1311.806	4) Maharashtra	142.389	1167.348
B) 1) APLM	55.509	472.754	5) Goa (Amona)	-1.875	-15.773
2) JSWEL	14.560	128.993	Total	134.482	1166.433
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.074	224.482
4) RPL(AMT)	26.952	216.729	b) Mumbai Drawl	30.251	236.686
5) SWPGPL	8.051	65.293	c) MSEDCL Bilateral *	53.190	356.349
6) Other IPP	38.408	308.510	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.074	224.482
C) 1) TPCL Thermal	7.816	87.713	Include PX	0.000	1.590
2) TPCL Hydro	5.162	39.208	Standby	0.000	0.000
3) TPCL Gas	2.333	24.324	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.556	86.122	1) MSEDCL	405.275	3463.204
D) STATE			2) Mumbai Discoms	55.118	474.050
1) Thermal	302.265	2575.039	3) Other Discoms	9.900	87.997
(A1+C1+C4+(B1-B6))			TOTAL STATE	470.293	4025.251
2) Hydro	14.108	107.447			
(A2+C2)					
3) Gas	6.045	58.966			
(A3+B7+C3)					
4) Wind	7.800	72.630			
6) SOLAR	5.593	44.739			
TOTAL STATE	335.811	2858.821			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6451	6020	6278	5331
MSPGCL Hydro	760	373	678	200
MSPGCL Gas	142	149	152	145
MSPGCL Total Generation	7353	6542	7108	5676
Central Sector Receipt	6444	6508	6193	4659
WIND	216	92	228	339
CPP / IPP Thermal	6593	5932	6316	5314
CPP / IPP Gas	0	0	0	0
SOLAR	809	895	0	0
Exchange with Mumbai	-1566	-1524	-1239	-1043
MSEDCL DEMAND MET	8663	7532	7389	6453
Load Shedding	0	0	0	0
MSEDCL DEMAND	8663	7532	7389	6453
TPCL GENERATION	741	759	1005	392
AEML GENERATION	442	501	479	351
MUMBAI DEMAND	2749	2784	2723	1786
OTHER DISCOM DEMAND	373	364	374	283
STATE DEMAND MET	22598	21229	21329	16731
STATE DEMAND	22598	21229	21329	16731
Frequency (Hz)	49.92	49.98	50.01	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 06.01 Hrs	49.77 Hz at 16.27 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 09/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.60	31.40	185	120
Unit 7	0.00	0.00	0	0
Unit 8	14.92	125.51	660	400
Unit 9	15.18	62.86	660	520
Unit 10	13.15	118.84	620	400
Total	46.85	338.60		
Bhusawal				
Unit 3	0.00	6.30	0	0
Unit 4	8.83	77.21	450	280
Unit 5	8.88	75.63	465	280
Total	17.70	159.14		
Parli				
Unit 6	0.00	3.90	0	0
Unit 7	0.00	0.00	0	0
Unit 8	4.24	15.50	204	151
Total	4.24	19.40		
Chandrapur				
Unit 3	3.31	10.04	158	120
Unit 4	3.52	22.56	161	120
Unit 5	3.72	51.99	210	114
Unit 6	8.86	53.14	415	269
Unit 7	7.88	71.86	363	288
Unit 8	9.20	82.45	408	352
Unit 9	9.45	83.50	442	351
Total	45.94	375.54		
Paras				
Unit 3	4.43	36.75	246	138
Unit 4	4.78	37.62	252	136
Total	9.21	74.37		
Khaparkheda				
Unit 1	0.06	24.87	60	0
Unit 2	0.20	25.46	115	0
Unit 3	0.00	27.06	0	0
Unit 4	0.00	20.47	0	0
Unit 5	10.54	87.86	500	285
Total	10.80	185.72		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.15	27.37	145	119
Unit 5	3.51	28.79	187	118
Total	6.66	56.16		
Uran				
All Units	3.71	34.64	236	138
Total	3.71	34.64		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	0.69	30	0
Total	0.10	0.69		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.92	19.71	510	40
Stage 4	0.97	5.30	250	0
Stage 3	0.93	6.06	80	0
Total	4.81	31.07		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.04	0.04	25	0
TILLARI	0.58	1.82	58	0
BHIRA T.R.	0.32	2.34	80	0
SMLHY_PTN	3.19	32.97	159	99
GHATGHAR	0.00	0.00	0	0
Total	4.13	37.17		
Wind				
Total	7.80	72.63	0	0
Total	7.80	72.63		
CPP				
APML(Mus)	55.51	472.75	0	0
JSWEL(Mus)	14.56	128.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.95	216.73	0	0
SWPGPL-Mus	8.05	65.29	0	0
Other(Mus)	38.41	308.51	0	0
Total	143.48	1192.28		
SOLAR				
Total	5.59	44.74	0	0
Total	5.59	44.74		
Tata				
Trombay 5	7.82	65.91	470	270
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.28	14.50	70	49
Trombay 7B	1.05	9.82	54	40
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.16	39.21	449	0
Total	15.31	151.24		
AEML				
DTPS U-1&2	9.56	86.12	501	329
Total	9.56	86.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	141.41	1208.92	MSPGCL Total	154.07	1311.81
			MSPGCL Thml+Gas	145.12	1243.57	Koyna 1,2 & 4 Total	3.89	25.02
			MSPGCL Hydro	8.95	68.24	State Total	335.81	2858.82

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 09/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4945	203	145	5293	427	5305	0	0	5139	5098	-1161	14659	0	14659	1910	303	16872	49.99
2	5331	200	145	5676	339	5314	0	0	5070	4659	-1043	14662	0	14662	1786	283	16731	50.00
3	5119	203	144	5466	375	5301	0	0	4956	4989	-939	14926	0	14926	1686	266	16878	49.97
4	5267	204	157	5628	429	5318	0	0	4865	4853	-894	15070	0	15070	1641	264	16975	49.96
5	5570	209	146	5925	474	5301	0	0	4859	4961	-897	15496	0	15496	1633	268	17397	50.06
6	6041	204	146	6391	477	5776	0	0	5261	5376	-973	16732	0	16732	1716	315	18763	50.03
7	6370	283	147	6800	428	6351	0	6	5515	5211	-918	17536	0	17536	1836	342	19714	50.03
8	6446	911	146	7503	399	6604	0	76	5484	5287	-944	18572	0	18572	2021	353	20946	49.94
9	6517	794	157	7468	270	6578	0	323	5977	6012	-1248	19044	0	19044	2308	359	21711	49.98
10	6468	739	144	7351	252	6544	0	557	6241	6217	-1462	19097	0	19097	2575	362	22034	50.00
11	6451	760	142	7353	216	6593	0	809	6419	6444	-1566	19476	0	19476	2749	373	22598	49.92
12	6038	551	141	6730	168	6299	0	929	6554	6132	-1454	18430	0	18430	2818	374	21622	49.94
13	6020	373	149	6542	92	5932	0	895	6896	6508	-1524	18081	0	18081	2784	364	21229	49.98
14	5838	214	139	6191	70	5768	0	755	6743	7141	-1533	18033	0	18033	2650	359	21042	50.01
15	6172	206	139	6517	65	6006	0	626	6617	6729	-1699	17887	0	17887	2672	357	20916	50.04
16	6279	222	138	6639	75	6436	0	423	6613	6280	-1552	17941	0	17941	2690	360	20991	50.00
17	6277	216	140	6633	73	6378	0	176	6182	5832	-1335	17388	0	17388	2682	369	20439	49.93
18	6249	264	142	6655	109	6412	0	18	5719	5680	-1190	17305	0	17305	2691	379	20375	49.97
19	6278	678	152	7108	228	6316	0	0	5993	6193	-1239	18232	0	18232	2723	374	21329	50.01
20	6306	270	142	6718	375	6495	0	0	5590	5410	-1320	17296	0	17296	2608	382	20286	50.02
21	6185	228	150	6563	510	6410	0	0	4658	4125	-1296	15948	0	15948	2441	364	18753	50.00
22	5449	398	195	6042	568	5586	0	0	5033	5124	-1427	15548	0	15548	2286	345	18179	50.02
23	4904	323	230	5457	693	5192	0	0	5411	5343	-1362	14981	0	14981	2157	342	17480	50.03
24	4893	293	236	5422	688	5265	0	0	5306	4878	-1275	14643	0	14643	2055	335	17033	50.02
MUs	141.41	8.95	3.71	154.07	7.80	143.48	0.00	5.59	137.10	134.48	-30.25	406.98	0.00	406.98	55.12	8.19	470.29	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 09/Dec/2021

Position as on 6.30 Hrs of 10/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-4	660	10/11/2021	23.58	10/12/2021	17:14	Capital Overhauling	10/12/2021
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09.55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Uran Unit 5	108	07/11/2021	23.28	09/12/2021	20:27	Turbine problem.	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Parli Unit 7	250	28/11/2021	23.57		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	02/12/2021	00:00		Continued.	ZERO SCHEDULE	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	02/12/2021	23:25		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Koyna Unit 2	70	09/12/2021	12:00	09/12/2021	16:30	Testing Work	
MSPGCL	Chandrapur Unit 5	500	10/12/2021	23:57		Continued.	PA Fan Vibration Problem	15/12/2021

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 10/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (418) OF PADGHE PG CKT - 2 @ KUDUS	InterState	09/12/2021	11:31	09/12/2021	17:33	PO	MP OF 418 Main Bay of 400 KV Padghe Kudus Line 2 at Kudus MSETCL SS.
400 KV LINE Outages/Trippings							
DHULE - KHANDWA CKT - 2	InterState	08/12/2021	08:53		Continued.	PO	Simultaneous outage of 400kV Khandwa-Dhule-1 & 2 for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam
DHULE - KHANDWA CKT - 1	InterState	08/12/2021	08:53		Continued.	PO	Simultaneous outage of 400kV Khandwa-Dhule-1 & 2 for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam
PADGHE (GIS) PG - KUDUS CKT - 2	InterState	09/12/2021	11:31	09/12/2021	11:55	T	CKT TRIPPED WHILE AVAILING OUTAGE ON MAIN BAY 418, TIE CB 417 ALSO TRIPPED
JAIGAD - KARAD CKT - 1	IntraState	08/12/2021	23:03	09/12/2021	09:35	HT	over voltage control
LONIKAND I - KOYNA STAGE-IV	IntraState	08/12/2021	23:06	09/12/2021	09:37	HT	over voltage control
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	IntraState	09/12/2021	09:44	09/12/2021	19:03	PO	Half yearly bay maintenance and DT work.
PADGHE - NAGOTHANE CKT - 2	IntraState	09/12/2021	16:03	09/12/2021	18:14	EO	To cut out conductor stranded of R ph at loc. no 132
JAIGAD - KARAD CKT - 2	IntraState	09/12/2021	21:49	10/12/2021	09:07	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	09/12/2021	21:57	10/12/2021	09:06	HT	HT FOR OVERVOLTAGE
NEW KOYNA - DABHOL CKT - 1	IntraState	10/12/2021	10:04		Continued.	PO	Cold washing work
MAIN BUS - 1 @ WARORA	IntraState	10/12/2021	10:30	10/12/2021	17:27	PO	Routine maintainance and diagnostic testing such as CVT/ CT tan delta, and, isolater maintainance work.
KORADI - KHADKA	IntraState	10/12/2021	11:25		Continued.	PO	For removal of Live 400 KV Main Bus-1&2 section jumpers of 400 KV Akola & Aurangabad section (i.e removal of jumpers between Koradi and Aurangabad bay) by Hot line unit Jalgaon for hot man clearance
KHADKA-AURANGABAD	IntraState	10/12/2021	11:50		Continued.		For replacement of Faulty Disc insulator found in Monkey patrolling
JAIGAD - KARAD CKT - 1	IntraState	10/12/2021	21:52		Continued.	HT	HT DUE TO OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	10/12/2021	22:00		Continued.	HT	HT DUE TO OVERVOLTAGE
400 KV ICT Outages/Trippings							
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	IntraState	07/12/2021	13:43	09/12/2021	17:44	EO	Retrofitting of Numerical REF relay & Trip relay under MTAMC project work.
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	09/12/2021	10:00	09/12/2021	15:17	PO	Outage for 400 kv side CB timing, CRM & DCRM
400/220/33KV SPARE ICT @ KORADI 2	IntraState	10/12/2021	10:48	10/12/2021	17:50	PO	Tan delta measurement of bushings of spare ICT unit.
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	10/12/2021	07:24	10/12/2021	13:55	PO	For safety purpose for the scheme of Replacement of all phase conductor of 220kv Boisar - PGCIL line no.02 at loc. No. 16 & 16A.
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 09/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 10/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - TFIPL	IntraState	08/12/2021	08:13		Continued.	PO	For carrying out jumpering at Loc. 48 to LILO Loc. No 01 to form 220 KV Kharghar Tiffil Borivali TAP Line during the period 07.12.2021 to 09.12.2021.
KHARGHAR - BORIVALI CKT - 1	IntraState	08/12/2021	13:02	10/12/2021	19:48	PO	For carrying out the Jumpering for making LILO at Loc. No 48 of 220 KV Kharghar Borivali Ckt-1 Line for Power supply of 30 MVA (1 50MVA) to Newly proposed 220/22 KV GIS S/St at M/S CTRLS Mahape
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB
VANKUSWADE - AJINKYATARA	IntraState	08/12/2021	18:25	09/12/2021	02:17	EO	Attending hot spot at Loc No-97 B ph
TROMBAY - SALSETTE CKT - 1	IntraState	08/12/2021	22:52	09/12/2021	07:05		Metro work
TROMBAY SALSETTE LINE-2	IntraState	08/12/2021	23:23	09/12/2021	06:40		Metro work
KHAREPATAN -PAWAS LINE	IntraState	09/12/2021	08:52	09/12/2021	18:23	PO	Replacement of insulators, detected faulty in PID testing.
NERLE- POPHALI	IntraState	09/12/2021	10:00	09/12/2021	19:05	PO	For replacement of Damaged conductor at Nerle side of R,Y,B-phs at loc no. 66.
WALCHANDNAGAR-LONI DEOKAR	IntraState	09/12/2021	10:40	09/12/2021	13:25	PO	MAINTENANCE WORK
CHAKAN PH II - VOLKSWAGEN	IntraState	09/12/2021	10:55	09/12/2021	18:44	PO	SCADA Trial/Commissioning work
JEJURI - BARAMATI	IntraState	09/12/2021	12:39	09/12/2021	16:56	EO	1) For Non-Auto reclosure investigation 2) For A/R trial on CB 3) For CT Tan delta testing 4) Y ph wavetrap removal work
MIRAJ - ICHALKARANJI	IntraState	09/12/2021	15:17	09/12/2021	18:03	PO	Quarterly maintenance work. CT tan delta measurement
TROMBAY - SALSETTE CKT - 1	IntraState	09/12/2021	22:52	10/12/2021	03:04		Metro work
TROMBAY SALSETTE LINE-2	IntraState	09/12/2021	23:01	10/12/2021	02:55		Metro work
NERLE - PEDAMBE	IntraState	10/12/2021	09:50	10/12/2021	17:45	PO	For replacement of , Damaged conductor at both side of Y-B phase at Loc No. 57; Damaged conductor at both side of R-Y-B phase at Loc No. 58; Damaged conductor at both side of B phase & at Pedhambe side of R-phase at Loc No. 60.
PHALTAN MIDC - CSSK BHAVANI NAGAR	IntraState	10/12/2021	10:18	10/12/2021	16:06	EO	Replace flashover insulator string at Loc no.38 R Ph
PADGHE - JAMBHUL 2	IntraState	10/12/2021	10:53	10/12/2021	19:13	PO	1. Retrofitting of Master 86 relay 2. Diagnostic testing work 3. Attending hotspot on R Phase CT
DAHANU - VERSOVA	IntraState	10/12/2021	13:58		Continued.	PO	NHSRCL Project activityModification / relocation of existing tower no SS 221 & SS 222. Details of activity to be carried out:1. De-stringing of existing conductors & OPGW cable.2. Dismantling of existing tower.3. Erection of Monopoles.4. Re-stringing of conductors & OPGW cable.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 09/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 10/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	10/12/2021	14:07		Continued.	PO	NHSRCL Project activity Modification / relocation of existing tower no SS 221 & SS 222. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing tower. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	07/12/2021	11:03	09/12/2021	18:05	PO	CB pole overhauling work by agency.
220/33KV 50MVA PTR 2 @ BARAMATI	IntraState	09/12/2021	10:00	09/12/2021	16:30	PO	REPLACEMENT OF 33KV CB OF LV BAY
220/132-110 KV 100MVA ICT No-02 @ OGLEWADI	IntraState	09/12/2021	10:02	09/12/2021	21:06	PO	1. Attending oil leakage for HV B Ph turret & PRV 2.Q.M work
220/22 KV 50 MVA PTR 1 @ CHAKAN	IntraState	09/12/2021	10:59	09/12/2021	18:05	EO	To attend the 22 kV cable joint work and routine diagnostic testing and maintenance work
220/22 KV 50 MVA PTR 2 @ BHANDUP GIS	IntraState	10/12/2021	08:51	10/12/2021	17:39	PO	For Diagnostic testing work & Bushing, winding SFRA,PI,10KV Excitation, Tan-δ#948, PI of TF2.
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	10/12/2021	09:25	10/12/2021	11:34	PO	diagnostic and Relay testing work
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	10/12/2021	09:40	10/12/2021	14:34	PO	1)Quatry bay maintenance work 2) HV CB CRM testing work
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	10/12/2021	14:47	10/12/2021	18:20	PO	diagnostic and Relay testing work
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	10/12/2021	11:25	10/12/2021	17:25	EO	Outage required for Y phase protection ct replacement work due to higher tan delta value
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	08/12/2021	06:14		Continued.		For formation of three terminal line Kalyan Mukund Kalwa line
KALYAN KALWA SALSETTE 1	IntraState	09/12/2021	12:32	09/12/2021	14:27	PO	For checking performance of Kalwa-Mukund Kalyan line
KALYAN KALWA SALSETTE 2	IntraState	09/12/2021	12:33	09/12/2021	14:28	PO	checking performance of Kalwa-Mukund Kalyan line
KALYAN KALWA SALSETTE 2	IntraState	10/12/2021	06:20	10/12/2021	06:48	PO	Both KKS 1 & 2 lines remain out. For External parties work.
KALYAN KALWA SALSETTE 1	IntraState	10/12/2021	06:25	10/12/2021	16:33	PO	Both KKS 1 & 2 lines remain out. For External parties work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage