

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jan/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	134.420	1488.387	1) Gujrat	-3.890	-75.639
2) Hydro	15.074	109.191	2) Madhya Pradesh	8.987	54.610
3) Gas	3.216	42.255	3) Chattisgarh	7.140	57.380
Total MSPGCL	152.710	1639.833	4) Maharashtra	122.915	1279.616
B) 1) APLM	67.852	690.535	5) Goa (Amona)	-1.385	-14.598
2) JSWEL	14.276	136.627	Total	133.767	1301.369
3) VIPL	0.000	0.000	a) Mumbai Schedule	18.833	222.061
4) RPL(AMT)	25.203	264.578	b) Mumbai Drawl	20.727	236.705
5) SWPGPL	5.733	44.836	c) MSEDCL Bilateral *	57.427	531.289
6) Other IPP	37.797	389.382	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	18.833	221.964
C) 1) TPCL Thermal	10.143	101.081	Include PX	0.000	0.000
2) TPCL Hydro	4.077	40.920	Standby	0.000	0.096
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.286	93.405	1) MSEDCL	420.485	4289.831
D) STATE			2) Mumbai Discoms	43.233	481.452
1) Thermal	303.710	3208.831	3) Other Discoms	8.171	87.978
(A1+C1+C4+(B1-B6))			TOTAL STATE	471.889	4859.261
2) Hydro	19.151	150.111			
3) Gas	3.216	51.595			
4) Wind	5.732	84.574			
6) SOLAR	6.313	62.780			
TOTAL STATE	338.122	3557.891			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6193	5693	6007	4608
MSPGCL Hydro	1278	1188	530	333
MSPGCL Gas	148	147	148	0
MSPGCL Total Generation	7619	7028	6685	4941
Central Sector Receipt	6914	6757	5510	4922
WIND	135	121	213	141
CPP / IPP Thermal	6763	6428	6931	5553
CPP / IPP Gas	0	0	0	0
SOLAR	863	952	0	0
Exchange with Mumbai	-998	-1166	-961	-611
MSEDCL DEMAND MET	20923	19776	17988	14679
Load Shedding	0	0	0	0
MSEDCL DEMAND	20923	19776	17988	14679
TPCL GENERATION	866	669	781	391
AEML GENERATION	446	380	362	306
MUMBAI DEMAND	2310	2215	2104	1308
OTHER DISCOM DEMAND	373	344	390	267
STATE DEMAND MET	23606	22335	20482	16254
STATE DEMAND	23606	22335	20482	16254
Frequency (Hz)	50.09	50.00	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 15.05 Hrs	49.85 Hz at 06.13 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.61	30.59	120	0
Unit 7	0.00	0.00	0	0
Unit 8	13.89	135.51	602	392
Unit 9	13.89	101.63	605	387
Unit 10	11.57	114.89	531	395
Total	39.96	382.62		
Bhusawal				
Unit 3	2.38	22.44	160	0
Unit 4	7.84	84.18	440	280
Unit 5	7.80	84.07	410	275
Total	18.01	190.69		
Parli				
Unit 6	2.82	38.72	194	0
Unit 7	3.73	38.26	191	144
Unit 8	3.92	39.62	201	149
Total	10.48	116.60		
Chandrapur				
Unit 3	0.00	29.65	0	0
Unit 4	3.03	33.71	155	115
Unit 5	7.70	78.17	365	300
Unit 6	8.37	86.75	440	260
Unit 7	0.00	54.01	0	0
Unit 8	9.72	98.80	446	265
Unit 9	9.28	96.16	442	280
Total	38.10	477.26		
Paras				
Unit 3	3.70	43.14	202	134
Unit 4	3.86	41.48	226	133
Total	7.57	84.63		
Khaparkheda				
Unit 1	0.02	20.50	20	0
Unit 2	0.00	0.00	0	0
Unit 3	3.28	34.96	160	125
Unit 4	3.25	33.36	166	119
Unit 5	8.78	95.62	450	280
Total	15.33	184.43		
Nasik				
Unit 3	3.06	26.00	159	119
Unit 4	0.00	18.28	0	0
Unit 5	1.92	7.88	161	0
Total	4.98	52.16		
Uran				
All Units	3.22	42.26	164	0
Total	3.22	42.26		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.26	3.77	26	0
Total	0.26	3.77		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.88	23.41	360	35
Stage 4	5.00	12.89	739	0
Stage 3	1.24	8.07	160	0
Total	8.12	44.36		
Hydro				
KDPH	0.00	0.88	0	0
VTRNA	0.88	3.79	60	0
TILLARI	0.52	5.22	58	0
BHIRA T.R.	0.14	2.51	50	0
SMLHY_PTN	5.40	52.42	234	200
GHATGHAR	0.00	0.00	0	0
Total	6.95	64.83		
Wind				
Total	5.73	84.57	0	0
Total	5.73	84.57		
CPP				
APML(Mus)	67.85	690.54	0	0
JSWEL(Mus)	14.28	136.63	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.20	264.58	0	0
SWPGPL-Mus	5.73	44.84	0	0
Other(Mus)	37.80	389.38	0	0
Total	150.86	1525.96		
SOLAR				
Total	6.31	62.78	0	0
Total	6.31	62.78		
Tata				
Trombay 5	6.94	65.78	454	257
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	3.20	35.30	161	129
TATA Hydro	4.08	40.92	358	0
Total	14.22	151.34		
AEML				
DTPS U-1&2	8.29	93.40	485	294
Total	8.29	93.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	134.42	1488.39	MSPGCL Total	152.71	1639.83
			MSPGCL Thml+Gas	137.64	1530.64	Koyna 1,2 & 4 Total	6.88	36.29
			MSPGCL Hydro	15.07	109.19	State Total	338.12	3557.89

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4562	343	150	5055	182	5436	0	0	4931	4870	-670	14589	0	14589	1391	284	16264	50.00
2	4608	333	0	4941	141	5553	0	0	4861	4922	-611	14679	0	14679	1308	267	16254	50.00
3	5167	279	42	5488	200	5572	0	0	4798	4342	-556	14794	0	14794	1253	252	16299	49.99
4	5209	273	90	5572	318	5567	0	0	4779	4403	-534	15062	0	15062	1233	264	16559	50.00
5	5135	269	109	5513	374	5570	0	0	4894	4858	-546	15500	0	15500	1244	269	17013	50.00
6	5414	267	136	5817	346	5817	0	0	5044	5106	-634	16145	0	16145	1341	307	17793	50.01
7	5863	262	139	6264	279	6616	0	3	5098	4937	-678	17100	0	17100	1469	321	18890	50.01
8	6274	538	164	6976	212	6894	0	72	5499	5442	-695	18553	0	18553	1664	348	20565	49.99
9	6051	917	153	7121	169	6850	0	348	5888	6157	-779	19500	0	19500	1950	366	21816	50.01
10	6187	1253	149	7589	177	6845	0	671	6349	6357	-902	20374	0	20374	2180	363	22917	50.04
11	6193	1278	148	7619	135	6763	0	863	7136	6914	-998	20923	0	20923	2310	373	23606	50.09
12	5643	1295	146	7084	100	6549	0	954	7252	7128	-1075	20377	0	20377	2299	363	23039	50.03
13	5693	1188	147	7028	121	6428	0	952	7001	6757	-1166	19776	0	19776	2215	344	22335	50.00
14	5616	1074	141	6831	183	5891	0	863	7034	6945	-1080	19275	0	19275	2079	358	21712	50.05
15	5626	1020	145	6791	215	6335	0	667	7110	7074	-1063	19670	0	19670	2040	349	22059	50.02
16	5717	888	144	6749	240	6747	0	560	7057	6624	-1043	19516	0	19516	2014	361	21891	50.05
17	5869	676	147	6692	217	6919	0	300	6255	5793	-956	18593	0	18593	2017	372	20982	50.01
18	6089	521	147	6757	171	6862	0	60	5449	5243	-935	17768	0	17768	2029	390	20187	50.01
19	6007	530	148	6685	213	6931	0	0	5442	5510	-961	17988	0	17988	2104	390	20482	50.00
20	6214	649	160	7023	256	6967	0	0	5059	5097	-1045	17905	0	17905	2091	393	20389	50.00
21	5952	330	149	6431	428	6714	0	0	5131	4315	-1011	16493	0	16493	1986	384	18863	50.03
22	5194	333	152	5679	293	5958	0	0	5378	5374	-1057	15880	0	15880	1838	367	18085	50.00
23	5192	286	150	5628	353	5526	0	0	5243	4935	-926	15168	0	15168	1666	348	17182	50.03
24	4945	272	160	5377	409	5551	0	0	5008	4664	-806	14858	0	14858	1512	337	16707	50.01
MUs	134.42	15.07	3.22	152.71	5.73	150.86	0.00	6.31	137.70	133.77	-20.73	420.48	0.00	420.48	43.23	8.17	471.89	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/Jan/2022

Position as on 6.30 Hrs of 11/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	07/01/2022	23:55		Continued.	Condenser tube checking, Inspection of Emergency Governer.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	02/01/2022	23:25	10/01/2022	07:16	Boiler Validity Renevoation	
CPP	SWPGL U-4	135	03/01/2022	18:28	11/01/2022	14:20	TRIPPED DUE TO P.A FAN PROBLEM	
MSPGCL	Uran Unit 5	108	04/01/2022	00:15	10/01/2022	02:11	Gas shortage	
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	07/01/2022	02:00	10/01/2022	02:58	Boiler Tube Leakage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
MSPGCL	Khaparkheda Unit 1	210	08/01/2022	10:10	10/01/2022	22:00	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 3	210	09/01/2022	06:10		Continued.	Hydrogen Leakage	
MSPGCL	Uran Unit B0	120	10/01/2022	01:13	10/01/2022	05:30	Turbine protection.	
MSPGCL	Uran Unit 8	108	10/01/2022	01:14	10/01/2022	02:49	Turbine protection.	
MSPGCL	Koradi Unit 6	210	10/01/2022	05:07		Continued.	Flame Failure.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jan/2022

Position as on 6.30 Hrs of 11/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 6	250	10/01/2022	17:46	11/01/2022	12:20	tripped on electrical fault	
MSPGCL	Khaparkheda Unit 1	210	10/01/2022	22:30	10/01/2022	23:56	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (706) OF BUS REACTOR @ KORADI 3	IntraState	10/01/2022	09:51	10/01/2022	19:02	PO	Annual maintenance of Bay equipments
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	10/01/2022	08:51	10/01/2022	17:54	PO	Preventive maintenance & switchyard Maintenance
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadraple CB. 3) Measurement of Timing, DCRM and CRM of CB.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/12/2021	12:35			HT	HAND TRIPPED TO CONTROL LINE LOADING OF 400KV TALEGAON-KALWA AND 400KV TALEGAON - KHARGHAR CKT
PARLI - LONIKAND 2 CKT - 1	IntraState	09/01/2022	09:10			PO	Completion of jumpering at LILO point for charging of 400kv Karjat SS
JAIGAD - KARAD CKT - 1	IntraState	09/01/2022	21:53	10/01/2022	07:28	HT	Over Voltage.
PADGHE - NAGOTHANE CKT - 1	IntraState	09/01/2022	23:58	10/01/2022	09:02	HT	Over Voltage.
BABHALESHWAR - PADGHE CKT - 2	IntraState	10/01/2022	10:20	10/01/2022	18:03	PO	1) Replacement of 29D Isolator 2) Replacement of PG isolator 3) MTAMC work
KORADI - KHAPERKHEDA CKT - 1	IntraState	10/01/2022	10:38			PO	Retrofitting of Distance Relay I & II under MTAMC Project
NAGOTHANE - DABHOL CKT - 1	IntraState	10/01/2022	12:02	10/01/2022	19:55	PO	Earthwire replacement Work & cold washing work
AKOLA - KHADKA (BHUSAWAL)	IntraState	10/01/2022	12:39	10/01/2022	18:37	EO	400 KV Khadka-Akola Ckt on R Phase line Isolator Jaw bottom side nut bolts redhot observed hence Emergency outage required for attending this work on priority.
JAIGAD - KARAD CKT - 2	IntraState	10/01/2022	22:48			HT	Over voltage
NAGOTHANE - DABHOL CKT - 1	IntraState	11/01/2022	08:52			PO	Earthwire replacement Work & cold washing work
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ PADGHE	IntraState	07/01/2022	09:56			PO	1) Diagnostic testing work 2) Bay maintenance work 3) MTAMC work (project work)
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	10/01/2022	09:02	10/01/2022	20:20	PO	1. C & Tan delta testing of Bushing & Wdg 2. C & Tan delta Testing of HV CT 3. C & Tan delta Testing of IV CT 4. QM Work
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	11/01/2022	09:18			PO	for MTAMC Relay retrofitting work and routine bay maintenance activities including CB DCRM, Bushing, wdg tan Delta, HV CT tan delta testing
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	07/01/2022	11:25			PO	For shifting to New GIS at Tata Borivali
AAREY - MSETCL BORIVALI CKT - 1	IntraState	07/01/2022	11:59			T	differential prot optd,Y=33.29 kA,dist-3.2 km from Borivali
KALWA - COLOURCHEM	IntraState	07/01/2022	15:22			PO	To carry out stringing work between Location no. 17 to 19 at Lodha Paradise Thane
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/01/2022	09:51			PO	REPLACEMENT OF old CONDUCTOR by HTLS CONDUCTOR
NAGAR BELWANDI CKT 1	IntraState	10/01/2022	15:25	10/01/2022	18:58	EO	Replacement of jumper and attending red hotspot on Bus to Bus Isolator Jump with help of Hotline team.
NAGAR BELWANDI CKT 2	IntraState	10/01/2022	15:35	10/01/2022	18:58	EO	Replacement of jumper and attending red hotspot on Bus to Bus Isolator Jump with help of Hotline team.
TROMBAY DHARAVI - 6	IntraState	10/01/2022	16:14	10/01/2022	17:15	EO	FOR EMERGENCY TREE TRIMMING
SALSETTE BORIVLI - 2	IntraState	10/01/2022	19:12			EO	For removing Kite string entangled at Loc-2
BABLESHWAR -BHENDA	IntraState	10/01/2022	22:53			PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit,Nasik
BIDRI - SAWANTWADI	IntraState	11/01/2022	09:43			PO	for conversion of SSN to DSN
OSMANABAD - SOLAPUR (BALE)	IntraState	11/01/2022	10:22			PO	Outages is required for Quarterly Maintenance
KANDALGAON - ONGC PANVEL	IntraState	11/01/2022	11:50			PO	R&Y phase CT Oil leakage attending work & Other maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 100 MVA ICT - 1 @KALWAN	IntraState	10/01/2022	10:04	10/01/2022	13:50	PO	For Diagnostic Testing Work
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	10/01/2022	10:20	10/01/2022	18:00	PO	Nitrogen injection system servicing work
220/33 KV 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	10/01/2022	11:00	10/01/2022	17:32	PO	Quarterly maint of TF & bay equipments
220/33 KV 50 MVA PTR 2 @ KHARGHAR	IntraState	11/01/2022	08:54			PO	For SFRA testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 200MVA PTR 2 @ LONAND	IntraState	11/01/2022	10:15			PO	Nitrogen injection system servicing work
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	10/01/2022	09:38	10/01/2022	19:38	PO	Jumper & insulator string replacement at loc.no.156 & other maintenance work.
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	10/01/2022	09:38	10/01/2022	15:20	PO	Attending to HOT SPOT at loc no.200A and 138

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage