

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Mar/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	164.931	1640.086	1) Gujrat	1.410	35.055
2) Hydro	9.058	87.245	2) Madhya Pradesh	5.586	42.640
3) Gas	3.752	41.087	3) Chattisgarh	4.540	38.440
Total MSPGCL	177.741	1768.418	4) Maharashtra	170.935	1606.466
B) 1) APML	75.281	674.700	5) Goa (Amona)	-1.992	-14.090
2) JSWEL	24.631	250.117	Total	180.479	1708.511
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.225	301.969
4) RPL(AMT)	31.260	295.261	b) Mumbai Drawl	35.768	363.563
5) SWPGPL	10.367	99.987	c) MSEDCL Bilateral *	86.964	861.845
6) Other IPP	40.400	425.314	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.225	301.969
C) 1) TPCL Thermal	11.022	110.479	Include PX	0.000	0.000
2) TPCL Hydro	3.226	27.526	Standby	0.000	0.000
3) TPCL Gas	2.714	24.991	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.664	109.750	1) MSEDCL	515.589	5016.486
D) STATE			2) Mumbai Discoms	63.394	636.309
1) Thermal	368.556	3605.694	3) Other Discoms	10.037	100.264
(A1+C1+C4+(B1-B6))			TOTAL STATE	589.020	5753.059
2) Hydro	12.284	114.771			
(A2+C2)					
3) Gas	6.466	66.078			
(A3+B7+C3)					
4) Wind	6.467	122.927			
6) SOLAR	14.768	135.078			
TOTAL STATE	408.541	4044.548			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6542	6560	7099	6663
MSPGCL Hydro	437	681	596	219
MSPGCL Gas	130	192	206	112
MSPGCL Total Generation	7109	7433	7901	6994
Central Sector Receipt	9127	9010	7251	6299
WIND	247	108	337	503
CPP / IPP Thermal	7446	7366	7852	7550
CPP / IPP Gas	0	0	0	0
SOLAR	2065	1294	0	0
Exchange with Mumbai	-1949	-1774	-1433	-1411
MSEDCL DEMAND MET	23594	22983	21452	19567
Load Shedding	0	0	0	0
MSEDCL DEMAND	23594	22983	21452	19567
TPCL GENERATION	760	1017	968	547
AEML GENERATION	486	363	491	456
MUMBAI DEMAND	3195	3154	2892	2414
OTHER DISCOM DEMAND	451	454	456	368
STATE DEMAND MET	27240	26591	24800	22349
STATE DEMAND	27240	26591	24800	22349
Frequency (Hz)	49.98	49.97	50.00	49.92

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 18.01 Hrs	49.71 Hz at 06.12 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.56	45.70	205	175
Unit 8	14.77	132.72	650	573
Unit 9	13.94	130.93	625	505
Unit 10	0.00	102.93	0	0
Total	33.27	412.29		
Bhusawal				
Unit 3	3.21	32.80	160	110
Unit 4	9.34	93.42	495	0
Unit 5	10.72	99.88	490	285
Total	23.28	226.10		
Parli				
Unit 6	4.48	44.49	250	146
Unit 7	4.47	43.72	245	140
Unit 8	3.41	33.03	160	117
Total	12.35	121.24		
Chandrapur				
Unit 3	3.74	35.80	173	120
Unit 4	3.23	32.09	148	125
Unit 5	8.19	33.79	395	285
Unit 6	8.30	83.95	395	290
Unit 7	8.52	81.20	433	292
Unit 8	11.66	105.04	501	436
Unit 9	11.91	107.61	500	484
Total	55.55	479.49		
Paras				
Unit 3	5.40	48.32	243	211
Unit 4	5.82	52.54	247	233
Total	11.23	100.86		
Khaparkheda				
Unit 1	2.42	27.80	140	0
Unit 2	3.04	30.96	152	112
Unit 3	3.87	38.12	185	135
Unit 4	4.19	38.03	191	130
Unit 5	11.11	99.99	480	420
Total	24.64	234.90		
Nasik				
Unit 3	0.97	0.97	125	0
Unit 4	0.00	29.97	0	0
Unit 5	3.65	34.25	171	119
Total	4.62	65.20		
Uran				
All Units	3.75	41.09	210	112
Total	3.75	41.09		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	1.32	38	0
Total	0.04	1.32		
Koyna				
Stage 1-2	2.22	22.44	400	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.52	14.61	525	0
Stage 3	0.85	8.12	134	0
Total	4.59	45.17		
Hydro				
KDPH	0.86	8.19	36	36
VTRNA	1.17	10.07	61	0
TILLARI	0.35	0.99	58	0
BHIRA T.R.	0.12	1.33	40	0
SMLHY_PTN	1.92	20.18	83	76
GHATGHAR	0.00	0.00	0	0
Total	4.42	40.75		
Wind				
Total	6.47	122.93	0	0
Total	6.47	122.93		
CPP				
APML(Mus)	75.28	674.70	0	0
JSWEL(Mus)	24.63	250.12	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.26	295.26	0	0
SWPGPL-Mus	10.37	99.99	0	0
Dhariwal	6.07	59.53	271	233
IEPL	4.98	51.25	254	195
Other(Mus)	29.35	314.54	0	0
Total	181.94	1745.38		
SOLAR				
Total	14.77	135.08	0	0
Total	14.77	135.08		
Tata				
Trombay 5	7.27	72.90	403	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.54	14.62	107	44
Trombay 7B	1.17	10.37	65	38
TATA Hydro	3.23	27.53	344	16
Trombay 8	3.75	37.57	230	131
Total	16.96	163.00		
AEML				
DTPS U-1&2	10.66	109.75	499	190
Total	10.66	109.75		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	164.93	1640.09	MSPGCL Total	177.74	1768.42
			MSPGCL Thml+Gas	168.68	1681.17	Koyna 1,2 & 4 Total	3.74	37.05
			MSPGCL Hydro	9.06	87.24	State Total	408.54	4044.55

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6663	219	112	6994	503	7550	0	0	6787	6299	-1411	19567	0	19567	2414	368	22349	49.92
2	6734	197	113	7044	391	7519	0	0	6697	6626	-1261	19966	0	19966	2253	353	22572	49.90
3	6723	152	113	6988	349	7524	0	0	6596	6620	-1178	19976	0	19976	2116	327	22419	49.96
4	6991	152	114	7257	366	7505	0	0	6436	6423	-1054	20192	0	20192	2024	305	22521	49.98
5	7273	155	113	7541	345	7548	0	0	6469	6394	-1034	20456	0	20456	2008	338	22802	49.94
6	7363	277	115	7755	363	7623	0	0	6865	6752	-1074	21066	0	21066	2074	353	23493	49.94
7	7468	682	112	8262	386	7772	0	24	7224	7179	-1161	22061	0	22061	2190	401	24652	49.94
8	7543	1120	112	8775	339	7864	0	309	6909	6984	-1155	22677	0	22677	2350	439	25466	50.04
9	7566	510	115	8191	232	7762	0	842	7666	7418	-1411	22568	0	22568	2607	466	25641	50.08
10	7156	362	114	7632	201	7607	0	1424	8149	7911	-1537	22785	0	22785	2887	453	26125	49.97
11	6997	352	112	7461	235	7508	0	1850	8713	8646	-1822	23430	0	23430	3100	448	26978	50.00
12	6542	437	130	7109	247	7446	0	2065	9029	9127	-1949	23594	0	23594	3195	451	27240	49.98
13	6217	371	187	6775	204	7436	0	2111	8719	8916	-1931	23077	0	23077	2874	434	26385	50.03
14	6209	305	194	6708	179	7403	0	2043	8662	8725	-1799	22837	0	22837	2747	422	26006	50.05
15	6146	289	189	6624	121	7388	0	1751	9376	8958	-2060	22354	0	22354	3100	428	25882	50.00
16	6560	681	192	7433	108	7366	0	1294	9182	9010	-1774	22983	0	22983	3154	454	26591	49.97
17	6639	391	188	7218	120	7466	0	774	8488	8571	-1865	21827	0	21827	3105	457	25389	49.95
18	6957	275	192	7424	182	7590	0	270	8002	7984	-1691	21283	0	21283	3011	476	24770	50.01
19	7126	240	197	7563	306	7762	0	11	7448	7465	-1558	21083	0	21083	2918	466	24467	50.01
20	7099	596	206	7901	337	7852	0	0	7053	7251	-1433	21452	0	21452	2892	456	24800	50.00
21	6789	344	208	7341	214	7729	0	0	6718	6825	-1448	20207	0	20207	2741	454	23402	50.01
22	6679	382	210	7271	207	7555	0	0	6676	6777	-1350	20003	0	20003	2603	457	23063	49.99
23	6714	325	206	7245	232	7640	0	0	7052	6721	-1377	20033	0	20033	2522	428	22983	49.99
24	6777	244	208	7229	300	7524	0	0	7133	6897	-1435	20112	0	20112	2509	403	23024	49.98
MUs	164.93	9.06	3.75	177.74	6.47	181.94	0.00	14.77	182.05	180.48	-35.77	515.59	0.00	515.59	63.39	10.04	589.02	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Mar/2023

Position as on 6.30 Hrs of 11/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 6	108	08/03/2023	13:13	10/03/2023	11:31	zero schedule by msedcl	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00	10/03/2023	04:05	boiler tube leakage (under tooling from dtd-27.2.2023 @ 16:00 hrs	
MSPGCL	Koradi Unit-10	660	09/03/2023	11:11		Continued.	Boiler Tube Leakage	14/03/2023
MSPGCL	Nasik Unit 4	210	09/03/2023	15:55		Continued.	FD Fan Problem.	11/03/2023
MSPGCL	Nasik Unit 3	210	10/03/2023	05:00	10/03/2023	06:55	Due to suspected Stuck up of I/L Valve of Hydrogen Cooler.	
MSPGCL	Khaparkheda Unit 1	210	10/03/2023	10:34	10/03/2023	14:27	Furnace Pressure High	10/03/2023
MSPGCL	Nasik Unit 3	210	10/03/2023	15:22		Continued.	Axial shift high	17/03/2023
MSPGCL	Bhusawal Unit 4	500	10/03/2023	20:50	10/03/2023	23:28	DRUM LEVEL DATA PROCESSING UNIT HANG	
MSPGCL	Uran Unit B0	120	11/03/2023	09:02		Continued.	Bearing vibration high	25/03/2023
MSPGCL	Khaparkheda Unit 3	210	11/03/2023	20:07		Continued.	Boiler Tube Leakage	14/03/2023
MSPGCL	Chandrapur Unit 5	500	11/03/2023	23:36		Continued.	PA Fan problem	13/03/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 11/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ EKTUNI	IntraState	11/03/2023	12:29	11/03/2023	18:30	PO	Diagnostic, Relay Testing & Routine Maintenance
400 KV LINE Outages/Trippings							
KORADI 2-WARDHA (PG)	InterState	10/03/2023	11:18	10/03/2023	16:14	EO	To attend the hot spot at location no. 5 (Rph)
KALWA - TALEGAON (PG)	InterState	10/03/2023	14:52	10/03/2023	15:44	T	Tripped on Distance Protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36	10/03/2023	10:50	HT	HAND TRIPPED FOR LOAD MANAGEMENT
PADGHE - NAGOTHANE CKT - 1	IntraState	09/03/2023	09:30			PO	CB replacement work
NEW KOYNA-KARAD CKT - 1	IntraState	10/03/2023	08:27	10/03/2023	20:54	PO	PID Faulty disc insulator replacement work & Cold line washing work
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	10/03/2023	11:05	10/03/2023	20:14	HT	Planned outage
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	10/03/2023	13:37	10/03/2023	16:25	EO	"On dt.- 09/03/2023 at 10:30 Hrs, while performing thermovision scanning, a hotspot observed on 400KV CBI Isolator (Bph) in male-female contact assembly . The temperature is about 282 ◦C.The image for reference is attached herewith."
DEEPNAGAR - THAPTI TANDA	IntraState	10/03/2023	13:59	10/03/2023	19:31	T	Tripped on distance protection.
DEEPNAGAR - THAPTI TANDA	IntraState	10/03/2023	20:46	10/03/2023	19:31	T	Tripped on Distance Protection.
DEEPNAGAR - THAPTI TANDA	IntraState	10/03/2023	20:46	11/03/2023	05:02	T	Tripped on distance protection
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	11/03/2023	06:54	11/03/2023	11:09	EO	To attend Hot Spot of 89C PG Isolator pad. (Line iso. Side Pad and CT side Pad)
GT-10 @ KORADI-2	IntraState	11/03/2023	12:41	11/03/2023	14:32		1) nut bolt tightning/clamp replacement of jumper connection of CT, Isolator & other equipment 2)Routine Bay maintenance work.
NEW KOYNA-KARAD CKT - 2	IntraState	11/03/2023	12:50	11/03/2023	20:06	PO	PID Faulty disc insulator replacement work & Cold line washing work
DABHOL - NAGOTHANE CKT - 1	IntraState	11/03/2023	13:03	11/03/2023	14:21	T	Tripped at Dabhol end only
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	11/03/2023	15:14	11/03/2023	18:22	HT	For load management
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	11/03/2023	11:47	11/03/2023	13:05	PO	MTAMC work. No outage required only pemiission for shorting metering core to replace MFM meter
220 KV MAINBAY Outages/Trippings							
MAIN BUS - 1 @ NEW KOYNA	IntraState	08/03/2023	11:15	10/03/2023	18:43	PO	A) Bus isolator Routine maint. Works following bay will be transfer on A Bus by TBC Shifting 1) 220KV side ICT-II 2)220KV Pophali 3)220KV Lote 4) 220KV side 25 MVA T/F-I B) Jumper works for ICT-3 New Bay

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 11/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TBC @ HINJEWADI-1	IntraState	11/03/2023	10:45	11/03/2023	16:22	PO	Yearly bay maintenance work
220KV BUS SECTION 1	IntraState	11/03/2023	17:41	11/03/2023	18:48	PO	Diagnostic testing CRM, Timing test and tan delta test
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	11/03/2023	05:52	11/03/2023	06:25	T	AR successful at Nalasopara end, tripped at PG end
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
CTRLS - NET MAGIC GIS	IntraState	07/03/2023	12:43			T	Distance Protection.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	09/03/2023	15:27		Continued.	HT	H/T Due to load management.
TROMBAY SALSETTE LINE-2	IntraState	10/03/2023	00:21	10/03/2023	03:12	PO	Project work - Work in vicinity of line of Salsette Vikhroli line for connecting to New 110 KV Vikhroli GIS
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/03/2023	07:19	10/03/2023	13:06	EO	To attend Hot Spot at Loc no. 6 (R -Ph towards Boisar- side. Temp. 137 deg C.
SADAWAGHAPUR KARAD CKT 2	IntraState	10/03/2023	09:27	10/03/2023	19:27	PO	Cold washing of insulator
220 KV KHADKA (400 KV) -BHADLI TSS CKT-2	IntraState	10/03/2023	09:50	10/03/2023	12:44	PO	Work at TSS end
MIRAJ - MHAISHAL	IntraState	10/03/2023	09:59	10/03/2023	16:45	PO	Cold washing of Insulator
NERLE - DASGAON	IntraState	10/03/2023	10:26	10/03/2023	20:55	PO	Diagnostic Testing Work & Quarterly maintenance work
SALSETTE - SAKI -7	IntraState	10/03/2023	10:47	10/03/2023	16:20	PO	Tree Trimming
MUDSHINGI- BELEWADI LINE	IntraState	10/03/2023	10:50	10/03/2023	19:09	PO	Quarterly Maintence Work & CT' replacement work
MAIN BUS - 2 @ VERSOVA	IntraState	10/03/2023	11:01	10/03/2023	17:14	PO	Annual Maintenance of Main Bus 2 and Bus Side Isolator
EKLAHARA(OCR)-RAYMOND	IntraState	10/03/2023	11:02	10/03/2023	14:37	PO	1. Attending red hot on B ph CT line side by replacement of Nut bolt 2. Replacement of line isolator support structure damaged member with new one/repairing of same 3. Attending red hot on B ph wave trap bottom side by replacement of existing jump along with Nut bolt and bay maintenance.
BORIVALI - TARAPUR	IntraState	10/03/2023	13:47	10/03/2023	18:30	PO	Replacement of Rusted Hardware, conductor & old earthwire.
PADGHE - KAMBA 2	IntraState	10/03/2023	14:37	11/03/2023	12:30	PO	220KV CGL make CB overhauling work by agency and bay maintenance.
WARDHA (PG) - BADNERA	IntraState	11/03/2023	02:44	11/03/2023	13:08	T	Tripped on distance protection
VERSOVA - GHODBUNDER	IntraState	11/03/2023	06:54	11/03/2023	11:38	PO	Lifting of Pier Cap by MMRDA between Span LS 276-LS 277 for metro 09 project.
PHALTAN MIDC - SWARAJ CO GEN	IntraState	11/03/2023	07:15	11/03/2023	20:25	PO	For shifting of 220kV Phaltan MIDC-Swaraj line from loc no.20-23
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	11/03/2023	07:30	11/03/2023	07:48	PO	For raising SF6 gas pressure.
SADAWAGHAPUR KARAD CKT 2	IntraState	11/03/2023	09:21	11/03/2023	13:45	PO	Cold washing of insulator
PETH- MUDSHINGI 1 LINE	IntraState	11/03/2023	09:44	11/03/2023	12:53	T	Tripped on Distance Protection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/03/2023	09:48	11/03/2023	12:48	PO	Replacement of old pilot insulator strings of R & Y ph at loc. No. 401.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 11/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHAKAN (400KV) - VOLKSWAGEN	IntraState	11/03/2023	10:01	11/03/2023	16:56	PO	SCADA Trial and Commissioning work & Diagnostic testing work in opportunity outage
CHAKAN PH II - VOLKSWAGEN	IntraState	11/03/2023	10:02	11/03/2023	16:53	PO	SCADA Trial and Commissioning work & Diagnostic testing work in opportunity outage
BORIVALI - TARAPUR	IntraState	11/03/2023	12:42	11/03/2023	20:23	PO	Replacement of Rusted Hardware, conductor & old earthwire.
LONIKAND 2 - VSNL	IntraState	11/03/2023	14:39	11/03/2023	17:31	EO	1) Fixing of repair sleeve between loc No-16-17 (B ph) due to broken strands 2) Replacement of flashover string at loc no-08 (R ph). 3) Removal of internet wire which is stuck at BPh,Loc 26 .
JAMDE-DONDAICHA 1	IntraState	11/03/2023	15:08	11/03/2023	18:08	PO	Replacement of back up O/C E/F relay and bay maintenance work.
DASTURI-KANDALGAON LINE	IntraState	11/03/2023	16:40	11/03/2023	23:20	PO	Jumper replacement at Loc.No.197,Cold washing of insulator string,Outage tree cutting and other line maintenance work.
KARAD -MUDSHINGI CKT- 4	IntraState	11/03/2023	16:45	11/03/2023	18:03	T	Tripped on distance protection
MHAISAL - ALKUD	IntraState	11/03/2023	17:44	11/03/2023	19:08	PO	Disc replacement work at Loc No.22 R ph.
TALANDGE - MUDSHINGI CKT - 1	IntraState	11/03/2023	18:40	11/03/2023	21:26	PO	To attend hot spot observed in thermoscaning at loc no. 1 (R ph), M/C- 8 (B ph), M/C- 12 (Y ph).
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	11/03/2023	19:03	11/03/2023	19:35	HT	To control overdrawal
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	09/03/2023	10:36	10/03/2023	02:57	PO	For air cell commissioning , attending oil leakage, replacement of OSR
220/100 KV 100 MVA ICT 1 @ TALOJA	IntraState	10/03/2023	10:04	10/03/2023	17:26	PO	Testing ,Maintenances & R & M work
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	10/03/2023	10:45	10/03/2023	23:40	PO	1) CTR system reinstallation & commissioning work of 200 MVA, 220/100 KV ICT no-2. 2) Diagnostic testing work WRM 3) Isolator servicing &Alignment work 4) Hot spot attending work & RMW
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	10/03/2023	12:09	10/03/2023	14:28	PO	attending minor oil leakage
200 MVA 220/132 KV ICT 2	IntraState	10/03/2023	12:11	10/03/2023	13:30	EO	OLTC trial taking work
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	10/03/2023	14:08	10/03/2023	15:38	EO	ATTENDING HOT SPOT AT LVCT R PHASE
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	10/03/2023	15:56	10/03/2023	18:02	EO	ICT is charged on dtd. 09.03.2023. For airing of ICT outage is required
220/132 KV 200 MVA PTR NO 3 @ PHURSUNGI	IntraState	10/03/2023	17:28	10/03/2023	21:31	PO	Bushing Tan Delta, winding Tan delta and PI measurement.
220/132 KV 150 MVA ICT @ BOISAR-II	IntraState	10/03/2023	18:15	10/03/2023	18:30	PO	DC supply shifting from old charger to new DCDB for both the ICTs.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 11/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	11/03/2023	15:10	11/03/2023	16:30	EO	Attending red hot on HV (220 KV) side Y ph bushing stud
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
WAGHIVALI - MANKHURD	IntraState	10/03/2023	00:02	10/03/2023	04:20	PO	PROJECT WORK-MOVEMENT OF JACK UP BARGE IN VICINITY OF LINE.
KHOPOLI - DAVDI	IntraState	10/03/2023	08:46			PO	Breaker O/H

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage