

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Apr/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.686	1648.225	1) Gujrat	-3.837	-44.973
2) Hydro	27.121	354.071	2) Madhya Pradesh	9.269	103.837
3) Gas	6.612	62.984	3) Chattisgarh	4.460	49.780
Total MSPGCL	193.419	2065.280	4) Maharashtra	161.733	1640.731
B) 1) APLM	76.272	754.083	5) Goa (Amona)	-1.419	-17.154
2) JSWEL	18.128	179.669	Total	170.206	1732.221
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.601	292.659
4) RPL(AMT)	31.482	303.022	b) Mumbai Drawl	29.433	322.970
5) SWPGPL	9.475	90.232	c) MSEDCL Bilateral *	79.135	693.806
6) Other IPP	34.140	349.311	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.601	292.653
C) 1) TPCL Thermal	15.126	155.446	Include PX	0.000	0.000
2) TPCL Hydro	1.679	33.021	Standby	0.000	0.006
3) TPCL Gas	4.035	29.901	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.505	115.553	1) MSEDCL	519.295	5285.978
D) STATE			2) Mumbai Discoms	61.778	656.894
1) Thermal	355.814	3595.541	3) Other Discoms	8.960	89.326
(A1+C1+C4+(B1-B6))			TOTAL STATE	590.033	6032.198
2) Hydro	28.800	387.092			
3) Gas	10.647	92.885			
4) Wind	15.829	134.730			
6) SOLAR	8.737	89.726			
TOTAL STATE	419.827	4299.974			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6468	6471	6636	6700
MSPGCL Hydro	757	737	875	1248
MSPGCL Gas	269	258	270	271
MSPGCL Total Generation	7494	7466	7781	8219
Central Sector Receipt	9659	10574	5816	5839
WIND	208	250	1053	983
CPP / IPP Thermal	6713	6760	7071	7037
CPP / IPP Gas	0	0	0	0
SOLAR	1218	1031	0	0
Exchange with Mumbai	-1333	-1704	-1174	-1286
MSEDCL DEMAND MET	23704	24115	20274	20546
Load Shedding	0	0	0	0
MSEDCL DEMAND	23704	24115	20274	20546
TPCL GENERATION	839	574	971	1030
AEML GENERATION	496	438	484	423
MUMBAI DEMAND	2668	2716	2629	2739
OTHER DISCOM DEMAND	388	393	403	377
STATE DEMAND MET	26760	27224	23306	23662
STATE DEMAND	26760	27224	23306	23662
Frequency (Hz)	50.03	50.02	49.92	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 18.02 Hrs	49.55 Hz at 00.08 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.50	34.57	200	175
Unit 7	0.00	0.00	0	0
Unit 8	14.00	136.68	605	556
Unit 9	13.95	136.13	603	563
Unit 10	0.00	60.94	0	0
Total	32.45	368.31		
Bhusawal				
Unit 3	3.26	11.47	150	130
Unit 4	8.34	96.62	380	280
Unit 5	9.12	95.68	415	370
Total	20.73	203.76		
Parli				
Unit 6	4.13	37.63	209	134
Unit 7	4.36	39.07	194	166
Unit 8	3.29	34.24	153	130
Total	11.78	110.95		
Chandrapur				
Unit 3	4.01	44.57	193	130
Unit 4	3.78	40.53	174	131
Unit 5	8.87	88.25	380	360
Unit 6	7.34	64.22	323	297
Unit 7	9.19	88.62	420	336
Unit 8	10.80	104.21	475	432
Unit 9	10.03	101.49	433	397
Total	54.00	531.89		
Paras				
Unit 3	4.58	53.34	232	122
Unit 4	4.94	50.11	227	190
Total	9.53	103.46		
Khaparkheda				
Unit 1	2.84	32.06	135	105
Unit 2	3.03	33.23	140	120
Unit 3	3.39	39.67	153	129
Unit 4	3.63	39.10	185	133
Unit 5	10.86	107.50	470	425
Total	23.75	251.56		
Nasik				
Unit 3	3.48	37.54	194	0
Unit 4	3.97	40.75	184	108
Unit 5	0.00	0.00	0	0
Total	7.45	78.30		
Uran				
All Units	6.61	62.98	292	258
Total	6.61	62.98		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	1.30	42	0
Total	0.14	1.30		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	7.10	72.36	535	40
Stage 4	9.30	155.58	1000	0
Stage 3	3.17	48.48	320	0
Total	19.57	276.42		
Hydro				
KDPH	0.84	8.59	35	35
VTRNA	0.76	7.16	59	0
TILLARI	0.35	4.66	58	0
BHIRA T.R.	0.21	1.56	80	0
SMLHY_PTN	5.25	54.38	223	215
GHATGHAR	0.00	0.00	0	0
Total	7.41	76.35		
Wind				
Total	15.83	134.73	0	0
Total	15.83	134.73		
CPP				
APML(Mus)	76.27	754.08	0	0
JSWEL(Mus)	18.13	179.67	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.48	303.02	0	0
SWPGPL-Mus	9.48	90.23	0	0
Other(Mus)	34.14	349.31	0	0
Total	169.50	1676.32		
SOLAR				
Total	8.74	89.73	0	0
Total	8.74	89.73		
Tata				
Trombay 5	10.11	104.72	459	287
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.52	17.52	114	70
Trombay 7B	1.51	12.38	67	52
TATA Hydro	1.68	33.02	325	4
Trombay 8	5.02	50.73	242	129
Total	20.84	218.37		
AEMIL				
DTPS U-1&2	11.50	115.55	502	413
Total	11.50	115.55		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.69	1648.22	MSPGCL Total	193.42	2065.28
			MSPGCL Thml+Gas	166.30	1711.21	Koyna 1,2 & 4 Total	16.40	227.94
			MSPGCL Hydro	27.12	354.07	State Total	419.83	4299.97

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6874	1801	281	8956	1062	7316	0	0	5530	5271	-1142	21120	1489	22609	2845	343	25797	49.86
2	6785	1671	280	8736	921	7295	0	0	5456	5303	-1158	20777	1605	22382	2649	320	25351	49.98
3	6793	1668	281	8742	1027	7226	0	0	5231	5250	-1054	20897	1773	22670	2469	294	25433	49.99
4	6799	1776	282	8857	696	7243	0	0	5132	5096	-977	20605	1539	22144	2363	310	24817	49.97
5	6839	1919	281	9039	656	7287	0	0	5077	5072	-868	20877	1971	22848	2300	309	25457	49.94
6	6867	2033	291	9191	654	7285	0	1	5163	4985	-917	20859	2191	23050	2356	340	25746	49.92
7	6865	1799	272	8936	579	7256	0	33	5246	5199	-975	20662	2156	22818	2328	366	25512	50.00
8	6807	1511	292	8610	620	7198	0	206	5805	6169	-932	21486	262	21748	2302	385	24435	50.03
9	6665	521	271	7457	393	6898	0	531	7566	7463	-1003	21339	0	21339	2371	400	24110	50.04
10	6648	657	290	7595	315	6863	0	864	8107	8366	-1141	22452	0	22452	2482	410	25344	50.05
11	6490	903	269	7662	241	6865	0	1083	8971	9317	-1264	23509	0	23509	2600	395	26504	50.05
12	6468	757	269	7494	208	6846	0	1218	9624	9659	-1333	23704	0	23704	2668	388	26760	50.03
13	6437	649	268	7354	217	6846	0	1227	9817	10066	-1416	23910	0	23910	2671	384	26965	50.06
14	6356	858	268	7482	222	6800	0	1170	9378	9814	-1484	23616	0	23616	2672	388	26676	50.09
15	6471	737	258	7466	250	6891	0	1031	10359	10574	-1704	24115	0	24115	2716	393	27224	50.02
16	6524	784	268	7576	418	6906	0	744	10316	10244	-1725	23781	0	23781	2724	382	26887	50.00
17	6433	571	268	7272	437	6875	0	455	9694	9869	-1679	22850	0	22850	2637	379	25866	50.04
18	6559	706	270	7535	607	6908	0	162	7837	7574	-1388	20980	0	20980	2551	418	23949	50.05
19	6612	456	259	7327	824	7016	0	12	6810	6511	-1149	20131	0	20131	2533	410	23074	50.04
20	6636	875	270	7781	1053	7201	0	0	5734	5816	-1174	20274	0	20274	2629	403	23306	49.92
21	6675	594	281	7550	1311	6960	0	0	5955	5591	-1209	19796	0	19796	2668	407	22871	49.95
22	6708	613	281	7602	1129	7137	0	0	5468	5558	-1146	19886	0	19886	2690	394	22970	49.93
23	6700	1248	271	8219	983	7168	0	0	5514	5839	-1286	20546	0	20546	2739	377	23662	49.91
24	6675	2013	291	8979	1006	7211	0	0	5643	5601	-1309	21124	0	21124	2815	364	24303	50.01
MUs	159.69	27.12	6.61	193.42	15.83	169.50	0.00	8.74	169.43	170.21	-29.43	519.29	12.99	532.28	61.78	8.96	603.02	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Apr/2022

Position as on 6.30 Hrs of 11/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25		Continued.	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	12/04/2022
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Nasik Unit 5	210	22/03/2022	23:40		Continued.	Withdrawn	
MSPGCL	Uran Unit B0	120	01/04/2022	19:02		Continued.	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Uran Unit 8	108	01/04/2022	19:21		Continued.	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Koradi Unit-10	660	07/04/2022	08:08		Continued.	Condenser Cleaning work.	
MSPGCL	Koyana STG-IV Unit-1	250	09/04/2022	21:55	10/04/2022	03:30	Guide vanes Control Fault attending work	
MSPGCL	Nasik Unit 3	210	10/04/2022	10:14	10/04/2022	13:21	STATOR WINDING TEMP. HIGH	
MSPGCL	Nasik Unit 3	210	10/04/2022	13:30	10/04/2022	14:03	Low Forward Power.	
MSPGCL	Bhusawal Unit 4	500	11/04/2022	00:44	11/04/2022	05:15	HP bypass impulse line leakage work	
MSPGCL	Bhusawal Unit 4	500	11/04/2022	10:17	11/04/2022	13:07	Low furnace pressure	
MSPGCL	Nasik Unit 3	210	11/04/2022	10:24	11/04/2022	19:30	GENERATOR SEAL HYDROGEN LEAKAGE	
MSPGCL	Bhusawal Unit 4	500	11/04/2022	13:53	11/04/2022	17:12	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 11/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	10/04/2022	02:49	10/04/2022	11:26	EO	Replacement work of Pole-1 R-phase Converter CT
400 KV LINE Outages/Trippings							
400 KV AKOLA - AURANGABAD(PG) CKT -1	InterState	10/04/2022	14:05	10/04/2022	16:30	T	TRIPPED ON DIST. PROTN
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	29/03/2022	13:28			T	HT FOR LOAD MANAGEMENT
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	10/04/2022	12:22	10/04/2022	18:44	PO	attending red hot at loc no 490, and attending broken conductor strands at loc no 87
BABHALESHWAR - PADGHE CKT - 2	IntraState	10/04/2022	18:55	10/04/2022	21:52	EO	To attend Hot-Spot at jumpers of Cut-point Towers. Loc. No. 946; 984; 996 under HVDC Padghe Lines Sub Division. In Thermovision scanning, the Hot-spot at jumpers of Cut-point towers location no. 946; 984; 996 are identified. At loc 984, Y-phase, Padghe side the temperature recorded is 132 C, at loc 996, Y-Ph, PDG side the temperature recorded is 88.2 C and at loc 946, Y-Ph, BBLR side the temperature recorded is 82.3 C.
CHANDRAPUR 2 - DHARIWAL CKT - 1	IntraState	11/04/2022	09:19	11/04/2022	17:17	PO	For replacement of main BCU of 400KV Chandrapur2 - Dhariwal ckt. I at Dhariwal end
NAGOTHANE - DABHOL CKT - 1	IntraState	11/04/2022	13:32	11/04/2022	19:32	PO	Cold washing work
400 KV ICT Outages/Trippings							
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	23/03/2022	10:14			EO	Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in ICT-I R ph unit
167 MVA SPARE ICT @ TALANDGE	IntraState	09/04/2022	13:25			PO	Isolator, BPI erection for Rapid Restoration scheme at 400 KV Talandage S/stn.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	10/04/2022	05:45	10/04/2022	09:23	PO	OTI calibration work.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	11/04/2022	09:01	11/04/2022	20:05	PO	400 KV BPI erection for R4pid Restoration scheme at 400 KV Tatandage S/s
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	11/04/2022	11:39	11/04/2022	13:36	PO	checking of CB compressor mechanism
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GOREGAON - AAREY CKT - 1	IntraState	31/03/2022	10:50	10/04/2022	19:22	PO	Under MMRC Line Diversion scheme for Metro-3 project, 220kV Outdoor termination at 220kV AEML Aarey and
EKLAHARE (GCR) - GHATGHAR	IntraState	02/04/2022	12:29	11/04/2022	20:46	PO	Samruddhi Highway Monopole work, 13 No:s (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 11/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	02/04/2022	12:51	11/04/2022	20:52	PO	Samruddhi Highway Monopole work, 13 No.s (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 2	IntraState	09/04/2022	21:51	10/04/2022	08:20	HT	HT FOR OVERDRAWAL
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	09/04/2022	21:52	10/04/2022	08:57	HT	HT FOR OVERDRAWAL
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	09/04/2022	22:40	10/04/2022	08:32	HT	HT for Overdrawal
BHUGAON - WARDHA (PG)	IntraState	09/04/2022	23:20	10/04/2022	08:24	HT	HT FOR OVERDRAWAL
WARDHA (PG) - BADNERA	IntraState	09/04/2022	23:31	10/04/2022	08:26	HT	HT FOR OVERDRAWAL
OSMANABAD - PARLY (PG)	IntraState	09/04/2022	23:36	10/04/2022	07:53	HT	HT FOR OVERDRAWAL
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 1	IntraState	09/04/2022	23:44	10/04/2022	08:19	HT	HT FOR OVERDRAWAL
KADEGAON-MIRAJ	IntraState	10/04/2022	09:00	10/04/2022	10:54	PO	Tower painting
TROMBAY - ANTOP HILL CKT - 2	IntraState	10/04/2022	09:48	10/04/2022	16:15	PO	FOR LA REPLACEMENT AT TROMBAY AND ATTENDING HISSING NOISE
JEJURI - KONDHWA	IntraState	10/04/2022	10:45	10/04/2022	11:45	T	Distance protecion
NEW KOYNA - LOTEPARSHURAM	IntraState	10/04/2022	12:49	10/04/2022	16:58	PO	Attending hot spot of Y-ph wavetrap bottom jumper having temp.= 73˚C. Maintenance of line isolator of 220KV Lote-Newkoyna line having alignment issue.
CHEMBUR (AEML) - NERUL (M)	IntraState	10/04/2022	13:41	11/04/2022	00:42	PO	To Check Non operation of Autorelclose of Nerul-Chembur(adani) line by personals from M/s Adani , M/s COSPHI and Testing team Kalwa.
BHIRA - KARANJADE 7	IntraState	11/04/2022	00:20	11/04/2022	03:51	PO	FOR TWFL CT AND PT WIRING
NIWALI - PAWAS LINE	IntraState	11/04/2022	02:09	11/04/2022	12:03	T	Distance Protection
BHIRA - KARANJADE 8	IntraState	11/04/2022	04:08	11/04/2022	06:48	PO	FOR TWFL CT AND PT WIRING
KADEGAON-MIRAJ	IntraState	11/04/2022	09:44	11/04/2022	20:34	PO	Tower painting
MUMEWADI -HALKARNI 1 LINE	IntraState	11/04/2022	09:48		Continued.	PO	For Overhauling of 245 KV CGL make Circuit Breaker & maintenance work.
TALANDGE - MUDSHINGI CKT - 1	IntraState	11/04/2022	10:09	11/04/2022	18:58	EO	For replacement of polymer pilot insulator strings of R phase jump by disc insulator strings at tower location nos. M/C 11. In stormy and heavy wind condition due to less weight of polymer insulator R phase jump swinging more towards cross arm. Sparking is observed to crossarm.
TALANDGE - MUDSHINGI CKT - 1	IntraState	11/04/2022	10:09	11/04/2022	18:58	PO	1.QM Work Bay by S/S 2. Line maintenance Work by Line Sdn
VITA - GHATNANDRE	IntraState	11/04/2022	11:22	11/04/2022	17:18	PO	Replacement of pilot string at Loc no.23 Y pH by HLU
WARDHA (PG) - BADNERA	IntraState	11/04/2022	13:15	11/04/2022	23:50	PO	For replacement of PT selection relay

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 11/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MUDSHINGI - CHIKODI	IntraState	11/04/2022	14:55	11/04/2022	22:16	EO	1. Chemical washing planned for 100 locations 2. Arial Patrolling of Total 275 locations planned 3. Thermovision Target :- 100% 4. Earthing rennovation is planned for 50 locations
JEJURI (400 KV)-JEJURI- II	IntraState	11/04/2022	16:31	11/04/2022	20:30	EO	TO ATTEND HOTSPOT OF R & Y PH ISOLATOR
EKLAHARE (GCR) - GHATGHAR	IntraState	11/04/2022	16:42	11/04/2022	20:46	EO	Bunching is done at loc.no.107 towards Kalwa side so it's need to be remove before final charging.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/04/2022	16:42	11/04/2022	20:52	EO	Bunching is done at loc.no.107 towards Kalwa side so it's need to be remove before final charging.
PADGHE - JINDAL	IntraState	11/04/2022	23:15		Continued.	EO	1) For replacement of faulty Power Supply module of Backup Relay.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220 / 110 / 33kV 315 MVA ICT 6 @ CARNAC	IntraState	03/04/2022	11:00			PO	FOR SHIFTING ON NEW 110 KV GIS
220 / 110 / 33kV 250MVA ICT 10 @ DHARAVI	IntraState	10/04/2022	11:58	10/04/2022	18:56	PO	33 KV CABLE TERMINATION REPLACEMENT
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	11/04/2022	00:35	11/04/2022	05:15	PO	GT OIL TOP UP
220/33-33KV 100MVA TF NO. - 1 @ ICHALKARANJI - II	IntraState	11/04/2022	09:15	11/04/2022	17:27	PO	1)Quaterly bay maintenance work 2) Bay diagnostic testing work 3) Replacement of OTI meter along with capillary tube. 4) Attending Oil Leakage
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	11/04/2022	15:23	11/04/2022	20:17	EO	For Oil leakage attending work
110 KV LINE Outages/Trippings							
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage