

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/May/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	175.936	1524.973	1) Gujrat	-3.222	-32.273
2) Hydro	22.702	205.474	2) Madhya Pradesh	5.665	82.296
3) Gas	5.835	58.897	3) Chattisgarh	5.370	58.530
Total MSPGCL	204.473	1789.344	4) Maharashtra	205.788	2002.530
B) 1) APLM	56.815	439.493	5) Goa (Amona)	-1.332	-12.279
2) JSWEL	20.326	198.048	Total	212.269	2098.804
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.752	375.889
4) RPL(AMT)	24.707	249.113	b) Mumbai Drawl	44.506	415.491
5) SWPGPL	9.755	94.476	c) MSEDCL Bilateral *	85.626	923.811
6) Other IPP	10.378	123.304	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.752	375.889
C) 1) TPCL Thermal	12.148	110.095	Include PX	0.000	0.000
2) TPCL Hydro	5.856	34.959	Standby	0.000	0.000
3) TPCL Gas	2.793	23.998	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.219	99.982	1) MSEDCL	508.128	4725.673
D) STATE			2) Mumbai Discoms	76.522	684.525
1) Thermal	321.284	2839.484	3) Other Discoms	10.453	103.122
(A1+C1+C4+(B1-B6))			TOTAL STATE	595.103	5513.320
2) Hydro	28.558	240.433			
(A2+C2)					
3) Gas	8.628	82.895			
(A3+B7+C3)					
4) Wind	7.981	106.286			
6) SOLAR	16.383	145.418			
TOTAL STATE	382.834	3414.516			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7204	7291	7446	7274
MSPGCL Hydro	386	262	1738	1300
MSPGCL Gas	215	217	229	261
MSPGCL Total Generation	7804	7770	9414	8834
Central Sector Receipt	10391	10515	8064	7660
WIND	178	210	513	471
CPP / IPP Thermal	4072	4919	5984	5084
CPP / IPP Gas	0	0	0	0
SOLAR	2172	1347	0	0
Exchange with Mumbai	-2349	-2378	-1661	-1445
MSEDCL DEMAND MET	21804	21912	21851	20275
Load Shedding	0	0	0	0
MSEDCL DEMAND	21804	21912	21851	20275
TPCL GENERATION	750	789	1209	674
AEML GENERATION	498	496	475	478
MUMBAI DEMAND	3597	3663	3345	2597
OTHER DISCOM DEMAND	465	471	463	330
STATE DEMAND MET	25866	26046	25658	23202
STATE DEMAND	25866	26046	25658	23202
Frequency (Hz)	50.04	50.01	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18:32 Hrs	49.74 Hz at 08:22 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/May/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.52	43.68	200	160
Unit 8	12.47	86.56	557	487
Unit 9	11.95	125.24	526	481
Unit 10	12.32	49.12	545	475
Total	41.27	304.60		
Bhusawal				
Unit 3	3.26	33.90	150	125
Unit 4	10.14	62.02	460	375
Unit 5	11.09	105.04	495	410
Total	24.49	200.96		
Parli				
Unit 6	5.33	53.64	250	130
Unit 7	5.33	31.21	245	148
Unit 8	5.01	47.71	228	165
Total	15.67	132.56		
Chandrapur				
Unit 3	3.76	36.11	166	130
Unit 4	3.78	25.60	161	155
Unit 5	9.55	61.14	409	355
Unit 6	9.45	90.55	415	355
Unit 7	9.66	88.88	424	320
Unit 8	5.82	73.31	457	0
Unit 9	11.24	105.02	480	453
Total	53.26	480.60		
Paras				
Unit 3	4.93	45.96	216	199
Unit 4	5.18	47.42	223	193
Total	10.11	93.37		
Khaparkheda				
Unit 1	3.20	30.78	140	120
Unit 2	2.78	30.83	122	103
Unit 3	1.51	38.74	185	0
Unit 4	4.30	42.38	186	172
Unit 5	11.45	91.98	495	464
Total	23.24	234.71		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.16	40.39	185	160
Unit 5	3.73	37.78	161	148
Total	7.90	78.17		
Uran				
All Units	5.84	58.90	335	215
Total	5.84	58.90		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.02	0.10	15	0
Total	0.02	0.10		
Koyna				
Stage 1-2	4.52	45.69	555	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	11.32	92.65	1014	0
Stage 3	3.58	30.54	320	0
Total	19.42	168.88		
Hydro				
KDPH	0.68	7.19	29	29
VTRNA	0.11	8.92	60	0
TILLARI	0.00	0.23	0	0
BHIRA T.R.	0.30	1.53	80	0
SMLHY_PTN	2.17	18.62	103	81
GHATGHAR	0.00	0.00	0	0
Total	3.26	36.49		
Wind				
Total	7.98	106.29	0	0
Total	7.98	106.29		
CPP				
APML(Mus)	56.82	439.49	0	0
JSWEL(Mus)	20.33	198.05	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.71	249.11	0	0
SWPGPL-Mus	9.76	94.48	0	0
Dhariwal	0.00	16.14	0	0
IEPL	5.38	48.76	269	196
Other(Mus)	5.00	58.40	0	0
Total	121.98	1104.43		
SOLAR				
Total	16.38	145.42	0	0
Total	16.38	145.42		
Tata				
Trombay 5	8.12	71.86	408	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.62	13.51	108	43
Trombay 7B	1.17	10.49	64	38
TATA Hydro	5.86	34.96	441	92
Trombay 8	4.03	38.23	232	129
Total	20.80	169.05		
AEML				
DTPS U-1&2	11.22	99.98	501	315
Total	11.22	99.98		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	175.94	1524.97	MSPGCL Total	204.47	1789.34
			MSPGCL Thml+Gas	181.77	1583.87	Koyna 1,2 & 4 Total	15.84	138.34
			MSPGCL Hydro	22.70	205.47	State Total	382.83	3414.52

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/May/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	7161	1798	335	9294	604	5245	0	0	7515	7535	-1458	20837	0	0	20837	3097	384	24318	49.99
2	7135	1774	330	9240	544	5239	0	0	7333	7325	-1360	20626	0	0	20626	2905	362	23892	50.02
3	7251	1710	259	9220	427	5195	0	0	7439	7439	-1466	20477	0	0	20477	2720	337	23534	49.99
4	7274	1300	261	8834	471	5084	0	0	7595	7660	-1445	20275	0	0	20275	2597	330	23202	50.00
5	7320	1450	261	9030	363	5135	0	0	7719	7732	-1418	20501	0	0	20501	2542	342	23384	49.98
6	7339	1532	261	9132	296	5189	0	1	7935	7989	-1422	20796	0	0	20796	2558	389	23744	50.02
7	7458	1070	261	8788	224	5152	0	134	8390	8632	-1513	21005	0	0	21005	2556	413	23974	50.05
8	7530	274	259	8062	158	5004	0	596	8886	8814	-1764	20430	0	0	20430	2667	440	23538	50.02
9	7349	272	251	7872	163	4359	0	1163	9434	9572	-1990	20691	0	4	20691	2927	447	24066	49.95
10	7432	306	237	7976	178	4442	0	1689	9555	9809	-2102	21522	0	20	21522	3251	469	25242	50.01
11	7402	294	220	7916	177	4235	0	2020	9898	10024	-2302	21585	0	6	21585	3491	485	25560	50.03
12	7204	386	215	7804	178	4072	0	2172	10149	10391	-2349	21804	0	4	21804	3597	465	25866	50.04
13	7333	380	220	7932	173	4128	0	2199	9961	10103	-2352	21723	0	0	21723	3596	460	25780	50.07
14	7191	258	217	7666	172	4083	0	1968	9962	9984	-2281	21126	0	0	21126	3494	466	25086	50.01
15	7306	292	219	7818	202	4238	0	1796	10533	10579	-2379	21770	0	0	21770	3593	484	25846	49.95
16	7291	262	217	7770	210	4919	0	1347	10755	10515	-2378	21912	0	0	21912	3663	471	26046	50.01
17	7342	166	217	7724	224	5125	0	895	10390	10251	-2299	21419	0	0	21419	3636	501	25556	50.06
18	7335	300	223	7858	279	5601	0	354	9581	9539	-2096	21037	0	0	21037	3537	499	25072	49.99
19	7337	672	220	8228	482	5893	0	49	8839	8361	-1951	20567	0	0	20567	3390	496	24452	50.04
20	7399	1926	221	9546	269	5966	0	0	8031	8031	-1723	21612	0	0	21612	3405	477	25494	50.00
21	7446	1738	229	9414	513	5984	0	0	7849	8064	-1661	21851	0	0	21851	3345	463	25658	50.00
22	7416	1114	230	8760	537	5938	0	0	7802	7646	-1558	20882	0	0	20882	3289	442	24612	49.95
23	7372	1630	235	9238	551	5893	0	0	7881	7978	-1598	21639	0	0	21639	3321	423	25382	49.93
24	7313	1798	237	9348	586	5862	0	0	8071	8296	-1641	22042	0	0	22042	3345	409	25796	50.00
MUs	175.94	22.70	5.84	204.47	7.98	121.98	0.00	16.38	211.50	212.27	-44.51	508.13	0.00	0.03	508.13	76.52	10.45	595.10	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

1)Due to overloading of 220kV jejuri-Lonand line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/May/2023

Position as on 6.30 Hrs of 11/May/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 3	210	17/04/2023	21:27		Continued.	Boiler Tube Leakage	20/05/2023
IPP	Adani U-2	660	29/04/2023	08:21	10/05/2023	15:09	Zero Schedule.	10/05/2023
IPP	JSW (J) U4	300	01/05/2023	09:29		Continued.	NO SCHEDULE	
IPP	RPL(AMT) U-4	270	01/05/2023	15:30		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 8	500	07/05/2023	12:29	10/05/2023	06:00	Boiler Tube Leakage	09/05/2023
MSPGCL	Uran Unit 6	108	10/05/2023	02:00		Continued.	Zero Schedule.	
MSPGCL	Khaparkheda Unit 3	210	10/05/2023	08:11	11/05/2023	00:24	Air heater problem	11/05/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/May/2023

Statement-VII

Position as on 6.30 Hrs of 11/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF BUS REACTOR AND ICT - 1 @ KARJAT	IntraState	10/05/2023	15:10	10/05/2023	20:50	PO	diagnostic testing and bay maintenance work
400 KV MAINBAY Outages/Trippings							
MAIN BAY (411) of THAPTITANDA @ DEEPNAGAR	IntraState	08/05/2023	09:43	10/05/2023	22:52	PO	For servicing & overhauling of 400kV AREVA make THAPTITANDA Line Main C.B. Mechanism
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
CHANDRAPUR - BHADRAVATI CKT - 2	InterState	09/05/2023	08:25	10/05/2023	18:54	PO	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works.
DHULE - KHANDWA CKT - 1	InterState	10/05/2023	15:21	10/05/2023	17:13	T	Tripped on distance protection
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
LONIKAND - JEJURI CKT - 1	IntraState	08/05/2023	08:37			PO	400kV CB O/H work by shifting on TBC
AKOLA - KHADKA (BHUSAWAL)	IntraState	10/05/2023	06:18	10/05/2023	19:13	PO	String replacement work on 400 kV Akola- Bhusawal Line will be carried out by engaging agency which are detected punctured in PID testing.
DHULE- - BABLESHWAR CKT - 1	IntraState	10/05/2023	09:30	10/05/2023	10:16	PO	Routine Line maintenance and Insulator cleaning work
DHULE- - BABLESHWAR CKT - 1	IntraState	10/05/2023	13:22	10/05/2023	20:39	HT	Planned outage previously taken back due to loading condition
DEEPNAGAR - THAPTI TANDA	IntraState	11/05/2023	07:07			PO	FOR REPLACEMENT OF FAULTY STRING S OBSERVED IN PID.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	25/04/2023	10:41			PO	For termination of power cable
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	10/05/2023	08:29	10/05/2023	15:18	PO	For taking NIFPS trials by M/s CTR Pune. Old 220KV PT will be remove from circuit due to non avilability of Tan delta point.Bus PT extended through PT selector switch relay.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	10/05/2023	14:40			PO	1) ICT-III spare unit taken out of service by removing connection of RRS scheme. (HV, IV and tertiary) 2) ICT-III Yph unit taken into service by making connection/termination with Yph. (HV, IV and tertiary)
400 KV BUSBAR Outages/Trippings							
MAIN BAY (403) OF ICT - 1 @ KARJAT	IntraState	10/05/2023	15:10	10/05/2023	20:50	PO	Diagnostic testing and bay maintenance
220 KV TBC Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/May/2023

Statement-VII

Position as on 6.30 Hrs of 11/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS COUPLER @ MULUND	IntraState	04/05/2023	12:39			EO	1) CB Dew Point test of 220 KV Bus Coupler which is found very Low. 2) The 220 KV Bus Coupler is already in OFF condition. Permission is required to open Both isolators. 3) Due to Low value of dew point values, the breaker pole may burst, hence CB kept out of service and now same is proposed to be attended.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
TROMBAY CARNAC - 5	IntraState	10/05/2023	06:07	10/05/2023	06:30	PO	For removal of Mesh and Bird nest from gantries at Trombay generating station
BORIVALI - BOISAR II LINE	IntraState	10/05/2023	06:08	10/05/2023	06:33	PO	Bird nest removal from R-Ph Wave Trap TOp Gantry.
BIDRI - SAWANTWADI	IntraState	10/05/2023	08:42	10/05/2023	19:17	PO	For cold washing of line insulators.
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	IntraState	10/05/2023	08:49	10/05/2023	16:53	HT	1. stringing between loc ap1a to ap1b for circuit -ii 2. 220kv bays reorientation of 220kv pandharkawda circuit-I and 220kv Chandrapur line at 220kv wani s/stn.
VITA WAIPHALE	IntraState	10/05/2023	09:14	10/05/2023	18:15	PO	Quarterly maintenance work at 220kV Waiphale S/Stn. also cold washing of insulator
WALCHANDNAGAR-LONI DEOKAR	IntraState	10/05/2023	09:30	10/05/2023	16:50	PO	The work of cold line insulator string cleaning at bird fault proven locations.
IPCL - SPCL	IntraState	10/05/2023	09:40			PO	ABB MAKE CB OVERHAULING WORK.
BHALVANI - VARKUTI	IntraState	10/05/2023	10:13	10/05/2023	12:43	PO	Outage is required for Quarterly Maintenance
220 KV PARAS - MALKAPUR CKT	IntraState	10/05/2023	11:29	10/05/2023	12:42	HT	Replacement of damage insulator string at loc. loc. no 95 r-ph , 76 b-ph pilot disc of 220kv paras & malkapur line under EHV line maintenance sub division, khamgaon.
GHATODI-NANDED	IntraState	10/05/2023	11:41	10/05/2023	18:05	HT	Commissioning of auxiliary relay for a/r and distance relay testing.
220 KV BALAPUR - MALKAPUR LINE	IntraState	10/05/2023	11:47	10/05/2023	15:41	T	M=DIST PROTN OPTD.Z1,Y-B,1.1KA,1.0KA.
MAIN BUS @ JEUR	IntraState	10/05/2023	12:05	10/05/2023	18:30	PO	Outage is required for Quarterly Maintenance
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 2	IntraState	10/05/2023	12:14	10/05/2023	15:31	HT	Attending mechanical problem of cgl make cb.
KALMESHWAR-PANDHURNA	IntraState	10/05/2023	12:52	10/05/2023	18:52	PO	Routine Maint. Work
220KV MALEGAON - DHULE	IntraState	10/05/2023	17:33	10/05/2023	21:35	PO	outage/AR out for fixing of repair sleeve at loc no 45Bph & attending red hot at R-Phase towards MLG at loc no 112 (Temp 72°C) & tightening of other various cutpoints.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/05/2023	06:08	11/05/2023	06:49	T	Distance Protection
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/May/2023

Statement-VII

Position as on 6.30 Hrs of 11/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
250 MVA ICT-5 @ TROMBAY	IntraState	10/05/2023	06:44	10/05/2023	06:55	PO	for removal of Mesh and Bird nest from gantries at Trombay B
220/132 KV 200 MVA ICT - 1 @ HARANGUL	IntraState	10/05/2023	07:08	10/05/2023	14:02	HT	Premansoon maint work and auxillary protection trails.
220/132 KV 100 MVA ICT - 1 @KALWAN	IntraState	10/05/2023	08:25			PO	Pre monsoon maintenance works
220/132 100MVA ICT-1 @ AMRAPUR	IntraState	10/05/2023	08:28			PO	Outage for Pre-masoon maintenance work
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	10/05/2023	10:53	10/05/2023	14:30	PO	Outage is required for Quarterly Maintenance
220/132-110/11KV 200MVA ICT 3 @ MIRAJ	IntraState	10/05/2023	11:00	10/05/2023	16:41	PO	R Ph HV LA's support insulator replacement work.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIRA (T) - KHOPOLI 2	IntraState	10/05/2023	06:18	10/05/2023	11:02	PO	Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link
BHIRA (T) - KHOPOLI 2	IntraState	11/05/2023	05:42			PO	Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage