

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/May/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	172.962	1731.874	1) Gujrat	2.016	25.581
2) Hydro	26.962	170.374	2) Madhya Pradesh	9.285	69.869
3) Gas	6.873	69.463	3) Chattisgarh	5.270	35.640
Total MSPGCL	206.797	1971.711	4) Maharashtra	184.265	1894.532
B) 1) APML	60.228	634.194	5) Goa (Amona)	-1.817	-19.709
2) JSWEL	26.782	280.594	Total	199.019	2005.913
3) VIPL	0.000	0.000	a) Mumbai Schedule	46.439	420.327
4) RPL(AMT)	31.323	306.489	b) Mumbai Drawl	46.147	437.625
5) SWPGPL	12.232	121.967	c) MSEDCL Bilateral *	75.556	884.156
6) Other IPP	18.131	184.609	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	46.439	420.327
C) 1) TPCL Thermal	9.142	120.707	Include PX	0.000	0.000
2) TPCL Hydro	5.130	50.031	Standby	0.000	0.000
3) TPCL Gas	4.058	36.831	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.444	97.963	1) MSEDCL	523.453	5311.353
D) STATE			2) Mumbai Discoms	75.921	743.156
1) Thermal	342.244	3478.397	3) Other Discoms	11.653	113.870
(A1+C1+C4+(B1-B6))			TOTAL STATE	611.027	6168.379
2) Hydro	32.092	220.405			
(A2+C2)					
3) Gas	10.931	106.294			
(A3+B7+C3)					
4) Wind	11.158	176.287			
6) SOLAR	15.583	181.084			
TOTAL STATE	412.008	4162.467			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	7256	6509	7428	7047
MSPGCL Hydro	814	1078	882	1079
MSPGCL Gas	280	279	289	290
MSPGCL Total Generation	8350	7866	8599	8416
Central Sector Receipt	9402	9585	7781	8278
WIND	255	457	878	306
CPP / IPP Thermal	5365	5319	6370	6101
CPP / IPP Gas	0	0	0	0
SOLAR	2071	1865	0	471
Exchange with Mumbai	-2232	-2236	-1826	-1599
MSEDCL DEMAND MET	22666	22332	21272	21499
Load Shedding	0	0	0	0
MSEDCL DEMAND	22666	22332	21272	21499
TPCL GENERATION	932	911	989	558
AEML GENERATION	500	503	501	503
MUMBAI DEMAND	3664	3650	3316	2660
OTHER DISCOM DEMAND	545	524	531	474
STATE DEMAND MET	26875	26506	25118	24633
STATE DEMAND	26875	26506	25118	24633
Frequency (Hz)	50.03	49.98	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.33 Hz at 22:04 Hrs	49.87 Hz at 23:59 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.06	42.54	185	145
Unit 8	12.98	61.61	650	479
Unit 9	13.74	138.86	603	517
Unit 10	13.22	139.10	641	489
Total	43.99	382.12		
Bhusawal				
Unit 3	3.66	28.06	170	130
Unit 4	1.90	97.87	465	0
Unit 5	11.14	80.04	490	330
Total	16.70	205.97		
Parli				
Unit 6	4.64	45.12	240	145
Unit 7	4.18	43.85	216	140
Unit 8	4.81	44.80	250	142
Total	13.64	133.77		
Chandrapur				
Unit 3	3.67	35.43	160	129
Unit 4	3.70	36.65	165	117
Unit 5	9.49	86.43	445	280
Unit 6	7.92	81.69	380	280
Unit 7	9.02	91.33	427	286
Unit 8	10.52	104.26	455	360
Unit 9	11.23	111.61	490	380
Total	55.55	547.41		
Paras				
Unit 3	0.00	41.85	0	0
Unit 4	5.56	55.78	253	181
Total	5.56	97.63		
Khaparkheda				
Unit 1	3.91	34.50	170	135
Unit 2	4.29	40.88	200	149
Unit 3	3.81	38.37	177	128
Unit 4	3.25	36.30	191	0
Unit 5	11.20	109.85	490	425
Total	26.46	259.89		
Nasik				
Unit 3	3.72	30.87	180	126
Unit 4	3.81	39.21	181	124
Unit 5	3.53	35.00	162	123
Total	11.06	105.08		
Uran				
All Units	6.87	69.46	294	277
Total	6.87	69.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.32	2.52	53	0
Total	0.32	2.52		
Koyna				
Stage 1-2	4.92	35.82	575	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	13.95	72.76	1011	0
Stage 3	4.27	24.27	320	0
Total	23.14	132.86		
Hydro				
KDPH	0.67	6.97	28	28
VTRNA	0.91	8.93	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.24	19.61	99	88
GHATGHAR	0.00	2.00	0	0
Total	3.82	37.52		
Wind				
Total	11.16	176.29	0	0
Total	11.16	176.29		
CPP				
APML(Mus)	60.23	634.19	0	0
JSWEL(Mus)	26.78	280.59	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.32	306.49	0	0
SWPGPL-Mus	12.23	121.97	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.39	53.82	266	170
Other(Mus)	7.04	75.63	0	0
JPL	5.70	55.16	268	214
Total	148.70	1527.85		
SOLAR				
Total	15.58	181.08	0	0
Total	15.58	181.08		
Tata				
Trombay 5	8.56	84.26	465	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.54	22.57	108	103
Trombay 7B	1.52	14.26	64	63
TATA Hydro	5.13	50.03	323	92
Trombay 8	0.59	36.44	122	0
Total	18.33	207.57		
AEML				
DTPS U-1&2	11.44	97.96	504	373
Total	11.44	97.96		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	172.96	1731.87	MSPGCL Total	206.80	1971.71
			MSPGCL Thml+Gas	179.84	1801.34	Koyna 1,2 & 4 Total	18.88	108.59
			MSPGCL Hydro	26.96	170.37	State Total	412.01	4162.47

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7769	1714	290	9773	356	7088	0	0	7725	7739	-1916	22601	0	0	22601	3130	439	26170	50.01
2	7691	1420	290	9401	531	7024	0	0	7747	7531	-1734	22343	0	0	22343	2878	410	25631	50.00
3	7571	1685	292	9548	298	6965	0	0	7678	7572	-1667	22335	0	0	22335	2684	381	25400	50.02
4	7475	1618	293	9386	315	6954	0	0	7682	7524	-1644	22168	0	0	22168	2553	367	25088	49.99
5	7325	1353	292	8970	426	6951	0	0	7679	7441	-1577	21818	0	0	21818	2490	393	24701	49.96
6	7300	1788	294	9382	474	6857	0	0	7684	7417	-1478	22230	0	0	22230	2505	422	25157	49.98
7	7401	1300	292	8993	421	6842	0	107	8059	7791	-1472	22223	0	13	22223	2515	459	25197	50.00
8	7047	1079	290	8416	306	6101	0	471	8259	8278	-1599	21499	0	14	21499	2660	474	24633	49.98
9	7060	1089	288	8437	211	5533	0	937	8807	9007	-1857	21759	0	6	21759	2963	509	25231	50.02
10	7265	857	286	8408	154	5549	0	1474	9146	9169	-2055	22173	0	0	22173	3298	526	25997	50.04
11	7381	815	283	8479	227	5395	0	1814	9544	9265	-2192	22472	0	44	22472	3554	516	26542	50.07
12	7256	814	280	8350	255	5365	0	2071	10248	9402	-2232	22666	0	10	22666	3664	545	26875	50.03
13	6279	754	281	7314	278	5268	0	2150	10290	9885	-2246	22122	0	0	22122	3648	527	26297	49.95
14	6264	965	280	7509	306	5261	0	2112	9924	9565	-2159	22076	0	3	22076	3549	518	26143	49.99
15	6509	1078	279	7866	457	5319	0	1865	9751	9585	-2236	22332	0	13	22332	3650	524	26506	49.98
16	7063	976	278	8317	586	5494	0	1405	9417	9162	-2357	22089	0	22	22089	3726	518	26333	50.00
17	7034	533	277	7844	742	5576	0	833	9016	8530	-2325	20677	0	2	20677	3666	523	24866	50.02
18	6986	417	281	7684	816	5531	0	309	8596	8257	-2278	19777	0	0	19777	3526	542	23845	50.02
19	7139	574	278	7991	819	5649	0	35	8018	8134	-1952	20133	0	0	20133	3352	543	24028	50.04
20	7428	882	289	8599	878	6370	0	0	8222	7781	-1826	21272	0	0	21272	3316	531	25118	50.01
21	7279	480	290	8049	818	6582	0	0	8121	7965	-1739	21154	0	0	21154	3209	521	24884	50.00
22	7462	1383	289	9134	586	6874	0	0	7111	7014	-1709	21396	0	0	21396	3117	503	25016	50.05
23	7480	1680	290	9450	492	7106	0	0	7239	7321	-1926	21955	0	0	21955	3106	488	25549	50.18
24	7498	1708	291	9497	406	7042	0	0	7843	7684	-1971	22183	0	0	22183	3162	475	25820	50.04
MUs	172.96	26.96	6.87	206.80	11.16	148.70	0.00	15.58	203.81	199.02	-46.15	523.45	0.00	0.13	523.45	75.92	11.65	611.03	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to Overload of 132kV BBLR-Rahuri line.2) DLS carried out due to Overloading of Lonikand & PTR3 at Chakan. 3) FLS done due to Overloading of 400kV Karad ICTs.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/May/2024

Position as on 6.30 Hrs of 11/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Paras Unit 3	250	09/05/2024	00:45	11/05/2024	11:22	Boiler Tube Leakage	11/05/2024
MSPGCL	Khaparkheda Unit 4	210	09/05/2024	22:14	10/05/2024	04:07	Generator Protection operated	
MSPGCL	Koyna STG-IV Unit-3	250	09/05/2024	22:33	10/05/2024	01:35	Labyrinth valve control problem.	10/05/2024
MSPGCL	Bhusawal Unit 4	500	10/05/2024	04:30	11/05/2024	10:58	Boiler Tube Leakage	12/05/2024
MSPGCL	Koradi Unit 6	210	11/05/2024	01:18		Continued.	Boiler Tube Leakage	14/05/2024
MSPGCL	Khaparkheda Unit 5	500	11/05/2024	04:22		Continued.	Generator protection	15/05/2024
MSPGCL	Nasik Unit 4	210	11/05/2024	11:53		Continued.	BTL in economizer zone	13/05/2024
Total Capacity MSPGCL		2250						
TPC-G								
TPC-G	Trombay 8	250	09/05/2024	01:24	10/05/2024	18:03	To attend both debris filter chocking due to shell & barnacles.	10/05/2024
Total Capacity TPC-G		250						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2820						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	06/05/2024	23:54		Continued.	Zero Schedule given by MSEDCL	
MSPGCL	Uran Unit 5	108	09/05/2024	20:15		Continued.	No Schedule from MSEDCL	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/May/2024

Position as on 6.30 Hrs of 11/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/May/2024

Statement-VII

Position as on 6.30 Hrs of 11/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	10/05/2024	15:57	10/05/2024	17:59	T	Tripped on distance protection
765 KV ICT Outages/Trippings							
765/400kV 1500 MVA ICT-1 @ EKTUNI	IntraState	10/05/2024	11:42	10/05/2024	15:17	HT	0 to attend the hotspot on 410 89t y-ph isolator stud (male arm) of ict -1 iv 400kv side (back side of ict).
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	11/05/2024	00:55	11/05/2024	02:48	HT	Emergency outage for removing drip irrigation pipe hanging on Pole-I conductor at Loc No. 1622
400 KV MAINBAY Outages/Trippings							
TBC @ KARAD	IntraState	06/05/2024	11:15	10/05/2024	19:31	PO	For Panel rewiring work and retrofitting of LBB Relay
400 KV LINE Outages/Trippings							
400KV NANDED(KUMBHARGAON)-PARLY CKT 2	InterState	11/05/2024	19:35		Continued.	EO	Repairing broken conductor strands
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	01/05/2024	22:11			HT	For faciliating outage on 765 Kv Aurangabad - Padghe line.
CHANDRAPUR 2 - DHARIWAL CKT - 2	IntraState	10/05/2024	06:08	10/05/2024	19:02	PO	for 400 kv line maintenance work and bay equipments testing & PM work
BABHALESHWAR - PADGHE CKT - 2	IntraState	10/05/2024	09:56			PO	1. B Bus PG Isolator Replacement work under LES Scheme. 2. CB Diagnostic Testing Work. 3.400KV BBLR-II in service through TBC.
220 KV THAPTITANDA - NAGEWADI CKT - II	IntraState	10/05/2024	09:56	10/05/2024	22:05	HT	Relay retrofitting work at 220kv nagewadi ss.
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	IntraState	10/05/2024	10:03	10/05/2024	22:22	HT	1.retrofitting of distance relay alstom/ge make. 2.routine isolator and bay maintenance work.
MAIN BUS - 2 @ PADGHE	IntraState	10/05/2024	10:23			PO	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.
DABHOL - NEW KOYNA CKT - 1	IntraState	10/05/2024	10:26	10/05/2024	20:19	PO	Bay Maintenance and testing
LONIKAND 2 - KARJAT CKT - 2	IntraState	10/05/2024	12:55	10/05/2024	14:41	T	Tripped on distance protection
BABHALESHWAR - PADGHE CKT-1	IntraState	10/05/2024	14:27	10/05/2024	21:16	T	Tripped on distance protection
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	11/05/2024	05:15	11/05/2024	08:59	EO	To attend heavy DC leakage from FDS of line shunt reactor
DABHOL - NEW KOYNA CKT - 1	IntraState	11/05/2024	09:44	11/05/2024	19:43	PO	Bay Maintenance and testing
LONIKAND I - CHAKAN	IntraState	11/05/2024	22:08		Continued.	HT	Emergency outage for attending hotspot at Chakan end.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
200 MVA 220/132 KV ICT - 4 @ KHADKA	IntraState	11/05/2024	08:26	11/05/2024	15:00	PO	Maintenance and testing work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/May/2024

Statement-VII

Position as on 6.30 Hrs of 11/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400220kV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	11/05/2024	09:40	11/05/2024	14:22	PO	For Pre-Monsoon Maintenance Work, Tan Delta Measurement of Bushing and Winding with Chemical Washing
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
AAREY - AEML SAKI CKT - 2	IntraState	08/05/2024	21:48			T	Tripped on Yph to ground fault
KALWA - TFIPL	IntraState	09/05/2024	22:19	10/05/2024	07:44	PO	For the installation of saver assembly sets at TL no. 27/3, 28, 43, 45, 46, 47 & 48 (Total 24 sets out of 24 sets are to be installed)
BORIVALI - CTRLS CKT	IntraState	09/05/2024	22:32	10/05/2024	07:41	PO	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22, 23, 25 & 26 (Total 30 sets out of 60 sets are to be installed)
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/05/2024	05:02	10/05/2024	09:31	PO	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
AMRAPUR - TAPTITANDA CKT - 2	IntraState	10/05/2024	07:01	10/05/2024	19:02	HT	Ektuni ict load management.
220KV BADNERA -NER CKT	IntraState	10/05/2024	07:38	10/05/2024	19:02	HT	PID testing work.
TALANDAGE - FIVE STAR MIDC 1	IntraState	10/05/2024	09:03	10/05/2024	14:18	PO	For earth wire replacement between tower loc no. 12 to Gantry & STN to DTN work at loc no. 8 & 9.
PADGHE - KAMBA 2	IntraState	10/05/2024	09:17	10/05/2024	22:23	PO	For attending C.B. mechanism problem
PADGHE - KAMBA 2	IntraState	10/05/2024	09:17	10/05/2024	22:23	PO	1. Retrofitting of Dist. Protection relay 2. Diagnostic Testing work 3. Bay maintenance work 4. Replacement of Y & B Phase
PANDHARPUR - MALINAGAR	IntraState	10/05/2024	11:16	10/05/2024	20:07	PO	Outage is required for Destrining and stringing from Loc No. 37 to 46 to attain issue of low Ground clearance.
NANDED CITY - PARVATI	IntraState	10/05/2024	15:58	10/05/2024	18:07	T	Tripped on distance protection
PADGHE - KAMBA 1	IntraState	10/05/2024	17:03	10/05/2024	17:41	T	Tripped on distance protection
SAHARA-URSE	IntraState	10/05/2024	18:14	11/05/2024	00:11	T	Tripped due to Yph. PT burst at Sahara S/S
BOMBAY DYEING - SAHARA	IntraState	10/05/2024	18:14	11/05/2024	00:29	T	Tripped due to Yph. PT burst at Sahara S/S
VSNL- KHADKI	IntraState	11/05/2024	08:07	11/05/2024	17:13	PO	For Stringing between New Monopole Loc No. 30 A to 30 B, stringing & destring of Old Loc No 30 & 31
PANDHARPUR - MALINAGAR	IntraState	11/05/2024	10:15	11/05/2024	20:48	PO	Outage is required for Destrining and stringing from Loc No. 37 to 46 to attain issue of low Ground clearance.
NEW KOYNA - NIWALI	IntraState	11/05/2024	12:07	11/05/2024	16:54	PO	For replacement of faulty string found in PID loc no. 132.
220 KV PADEGAON -WALUJ CKT I	IntraState	11/05/2024	13:02	11/05/2024	16:25	PO	to attend Hot Spot
220 KV KARJAT-BELWANDI-CKT-1	IntraState	11/05/2024	15:33	11/05/2024	20:23	T	Tripped on distance protection.
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	11/05/2024	15:33	11/05/2024	20:35	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/May/2024

Statement-VII

Position as on 6.30 Hrs of 11/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VANKUSWADE - KDPH	IntraState	11/05/2024	15:38		Continued.	T	Tripped on distance protect.
POPHALI - KDPH	IntraState	11/05/2024	16:40		Continued.	T	Tripped on distance protection
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	11/05/2024	17:20			T	H/T for load management
MAHALAXMI - AMONA	IntraState	11/05/2024	20:34	11/05/2024	22:24	T	Tripped from Amona end only
KHARGHAR - SONKHAR	IntraState	11/05/2024	22:51		Continued.	PO	For the installation of saver assembly sets at TL no. 678 & 679 (Total 6 sets out of 6 sets are to be installed)
KHARGHAR - NET MAGIC GIS	IntraState	11/05/2024	23:08		Continued.	PO	For the installation of saver assembly sets at TL no. 678 & 679 (Total 6 sets out of 6 sets are to be installed)
220 KV ICT Outages/Trippings							
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	08/05/2024	08:47	10/05/2024	15:14	PO	Replacement of HV/LV bushing work to be carried out.
220/132KV 200MVA ICT 2 @ LONAND	IntraState	11/05/2024	08:20	11/05/2024	12:00	PO	Inspecting & attending oil leakage from LV Y Ph Bushing
220/132 KV 150 MVA ICT 2 @ SATANA	IntraState	11/05/2024	12:02	11/05/2024	13:20	PO	For premansoon Maintenance work, Auxiliary Relay commissioning & Testing work & Fan Cubical setting work by agency.
220/132 KV 200 MVA ICT 1 @ SATANA	IntraState	11/05/2024	13:20	11/05/2024	16:32	PO	For premansoon Maintenance work & Fan Cubical setting work by agency.
220/132 KV 200 MVA ICT 2 @ BABHLESHWAR	IntraState	11/05/2024	15:10	11/05/2024	22:05	PO	Attending oil leakage of ICT from top plate.
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	10/05/2024	06:02	10/05/2024	14:16	PO	For earthwire replacement & routine maintenance work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage