

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jun/2018 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.806	1280.172	1) Gujrat	-7.470	-66.517
2) Hydro	3.551	64.346	2) Madhya Pradesh	6.732	81.494
3) Gas	8.236	90.871	3) Chattisgarh	5.820	58.570
Total MSPGCL	120.593	1435.389	4) Maharashtra Net	102.082	1210.353
B) 1) APML	30.249	387.998	5) Goa (Amona)	-0.550	-1.694
2) JSWEL	22.870	253.553	Total	106.614	1282.206
3) VIPL	9.116	96.175	a) Mumbai Schedule	20.774	299.731
4) RPL(AMT)	14.095	169.190	b) Mumbai Drawl	28.182	313.022
5) WPCL	2.531	49.225	c) MSEDCL Bilateral *	25.869	406.935
6) PGPL	0.000	0.000	Include PX	-0.396	82.870
7) Other IPP	7.965	113.246	d) Mumbai Bilateral *	20.774	298.195
C) 1) TPCL Thermal	14.224	166.336	Include PX	2.991	74.620
2) TPCL Hydro	0.453	39.585	Include Standby	0.000	1.536
3) TPCL Gas	3.544	35.518	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	10.400	116.619	1) MSEDCL	346.620	3771.998
D) STATE			2) Mumbai Discoms	56.803	671.082
1) Thermal	220.256	2632.514	TOTAL STATE	403.423	4443.080
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	4.004	103.931			
3) Gas (A3+B6+C3)	11.780	126.389			
4) Wind	55.671	249.896			
6) SOLAR	5.098	48.142			
TOTAL STATE	296.809	3160.872			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4502	4493	4473	4637
MSPGCL Hydro	131	356	151	55
MSPGCL Gas	341	333	353	363
MSPGCL Total Generation	4974	5182	4977	5055
Central Sector Receipt	4955	4641	4570	3566
WIND	2170	2659	2654	2350
CPP / IPP Thermal	3609	3556	3733	3508
CPP / IPP Gas	0	0	0	0
SOLAR	663	523	0	0
Exchange with Mumbai	-1362	-1392	-1410	-793
MSEDCL DEMAND MET	15009	15169	14524	13686
Load Shedding	0	0	0	0
MSEDCL DEMAND	15009	15169	14524	13686
TPCL GENERATION	701	739	726	770
R-INFRA GENERATION	380	377	376	501
MUMBAI DEMAND	2443	2508	2512	2064
STATE DEMAND MET	17452	17677	17036	15750
STATE DEMAND	17452	17677	17036	15750
Frequency (Hz)	50.02	49.94	49.98	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 08.14 Hrs	49.74 Hz at 15.13 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 10/Jun/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	3.45	35.65	160	130
Unit 8	0.00	24.11	0	0
Unit 9	7.97	78.50	451	0
Unit 10	9.67	75.30	451	330
Total	21.09	213.56		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.66	100.88	435	345
Unit 5	8.68	100.40	425	355
Total	17.33	201.27		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.61	48.87	198	187
Unit 7	4.44	47.78	192	162
Unit 8	2.57	36.31	188	0
Total	11.62	132.96		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	9.06	106.36	440	355
Unit 6	0.00	0.00	0	0
Unit 7	8.77	101.36	379	353
Unit 8	8.95	90.98	445	350
Unit 9	0.00	62.75	0	0
Total	26.79	361.45		
Paras				
Unit 3	4.50	54.39	196	175
Unit 4	4.48	54.31	190	172
Total	8.98	108.70		
Khaparkheda				
Unit 1	0.00	6.78	0	0
Unit 2	3.42	31.86	160	125
Unit 3	3.47	34.33	157	113
Unit 4	0.01	19.72	7	0
Unit 5	8.18	87.77	350	320
Total	15.07	180.47		
Nasik				
Unit 3	3.95	43.20	170	161
Unit 4	0.00	0.13	0	0
Unit 5	3.98	38.43	170	159
Total	7.92	81.76		
Uran				
All Units	8.24	90.87	368	191
Total	8.24	90.87		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	0.45	17	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.04	0.45		
Koyna				
Stage 1-2	2.04	26.70	265	40
Stage 4	0.00	10.78	0	0
Stage 3	0.34	8.95	80	0
Total	2.38	46.42		
Hydro				
KDPH	0.00	2.46	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.78	1.58	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.08	2.37	43	0
RNGR+BHTSA	0.22	2.44	10	9
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.10	2.56	12	1
GHATGHAR	0.00	6.51	0	0
Total	1.17	17.92		
Wind				
Total	55.67	249.90	0	0
Total	55.67	249.90		
CPP				
APML(Mus)	30.25	388.00	0	0
JSWEL(Mus)	22.87	253.55	0	0
VIPL(Mus)	9.12	96.18	0	0
RPLAMT(Mus)	14.10	169.19	0	0
WPCL(Mus)	2.53	49.22	0	0
Other(Mus)	7.96	113.25	0	0
Total	86.83	1069.39		
SOLAR				
Total	5.10	48.14	0	0
Total	5.10	48.14		
Tata				
Trombay 5	8.92	110.48	451	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.18	21.94	100	63
Trombay 7B	1.36	13.57	60	48
Trombay 8	5.30	55.85	232	212
TATA Hydro	0.45	39.58	76	4
Total	18.22	241.44		
R-INFRA				
DTPS U-1&2	10.40	116.62	502	376
Total	10.40	116.62		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	108.81	1280.17	MSPGCL Total	120.59	1435.39
			MSPGCL Thml+Gas	117.04	1371.04	Koyna 1,2 & 4 Total	2.04	37.48
			MSPGCL Hydro	3.55	64.35	State Total	296.81	3160.87

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Jun/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4694	51	368	5113	2056	3544	0	0	4404	4534	-1111	14136	0	14136	2398	16534	49.99
2	4714	51	359	5124	2160	3521	0	0	4276	4173	-981	13997	0	13997	2268	16265	50.00
3	4697	60	360	5117	2039	3542	0	0	4316	3875	-864	13709	0	13709	2149	15858	49.98
4	4654	50	359	5063	2178	3547	0	0	4020	3817	-793	13812	0	13812	2074	15886	49.98
5	4637	55	363	5055	2350	3508	0	0	3559	3566	-793	13686	0	13686	2064	15750	50.01
6	4650	100	349	5099	2058	3554	0	0	3884	4451	-832	14330	0	14330	2104	16434	50.00
7	4694	130	350	5174	2018	3566	0	45	4530	4847	-741	14909	0	14909	2059	16968	50.03
8	4548	50	349	4947	1989	3554	0	142	4638	4918	-769	14781	0	14781	2088	16869	50.04
9	4490	111	361	4962	2123	3541	0	297	4548	4552	-826	14649	0	14649	2161	16810	50.11
10	4484	126	348	4958	2248	3561	0	357	4763	4548	-936	14736	0	14736	2277	17013	50.09
11	4450	126	334	4910	1861	3580	0	538	4642	4872	-1150	14611	0	14611	2381	16992	50.02
12	4502	131	341	4974	2170	3609	0	663	5022	4955	-1362	15009	0	15009	2443	17452	50.02
13	4483	158	342	4983	2489	3607	0	672	5279	4791	-1393	15149	0	15149	2470	17619	50.02
14	4456	164	353	4973	2532	3623	0	717	4752	4553	-1416	14982	0	14982	2487	17469	50.04
15	4444	229	341	5014	2614	3636	0	609	4329	4303	-1400	14776	0	14776	2507	17283	49.94
16	4493	356	333	5182	2659	3556	0	523	4488	4641	-1392	15169	0	15169	2508	17677	49.94
17	4418	241	350	5009	2686	3590	0	327	4522	4296	-1368	14540	0	14540	2455	16995	50.02
18	4157	196	367	4720	2736	3589	0	156	3854	3862	-1320	13743	0	13743	2391	16134	49.99
19	4272	356	363	4991	2683	3610	0	52	3530	3946	-1320	13962	0	13962	2388	16350	50.00
20	4473	151	353	4977	2654	3733	0	0	4492	4570	-1410	14524	0	14524	2512	17036	49.98
21	4493	111	341	4945	2551	3756	0	0	4616	4531	-1443	14340	0	14340	2555	16895	49.94
22	4505	161	364	5030	2426	3719	0	0	4455	4661	-1512	14324	0	14324	2650	16974	49.95
23	4629	276	297	5202	2272	3802	0	0	4405	4719	-1533	14462	0	14462	2677	17139	49.96
24	4769	111	191	5071	2119	3977	0	0	4599	4633	-1517	14283	0	14283	2737	17020	50.00
MUs	108.81	3.55	8.24	120.59	55.67	86.83	0.00	5.10	105.92	106.61	-28.18	346.62	0.00	346.62	56.80	403.42	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jun/2018

Position as on 6.30 Hrs of 11/Jun/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
MSPGCL	Chandrapur Unit 6	500	04/01/2018	13.30		Continued.	Water Shortage, converted to AOH w.e.f 01.02.2018, 00:00Hrs	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown. (NO PPA FROM 01.04.2018)	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Chandrapur Unit 3	210	03/12/2017	01.35		Continued.	Water Shortage	
MSPGCL	Chandrapur Unit 4	210	03/12/2017	14.17		Continued.	Water Shortage	
MSPGCL	Ghatghar Unit-1	125	14/04/2018	23.45		Continued.	Stator Earth Fault	
IPP	Adani U-5	660	24/04/2018	08.53		Continued.	Bottom Ash problem	
IPP	RPL(AMT) U-1	270	01/05/2018	00.00		Continued.	Coal Shortage	
IPP	RPL(AMT) U-2	270	06/05/2018	18.00		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	IEPL INTER CHANGE.	
MSPGCL	Nasik Unit 4	210	01/06/2018	00.53		Continued.	Boiler Tube Leakage (Available since 03.06.2018 16:00Hrs)	
MSPGCL	Khaparkhedha Unit 1	210	02/06/2018	23.57		Continued.	Poor coal receipt.	
MSPGCL	Koradi Unit-8	660	04/06/2018	18.15		Continued.	abnormal combustion.	
MSPGCL	Khaparkhedha Unit 4	210	06/06/2018	23.44	10/06/2018	23.51	poor coal receipt	
CPP	IEPL Unit 1	270	07/06/2018	00.00		Continued.	Coal Shortage	
IPP	Adani U-4	660	07/06/2018	12.06		Continued.	Due to APH-A Hot PA duct below leakage	
MSPGCL	Chandrapur Unit 9	500	08/06/2018	21.52	11/06/2018	17.50	Boiler Tube Leakage	
MSPGCL	Uran Unit 6	108	09/06/2018	11.50		Continued.	bucholz realy operated.	
CPP	SWPGL U-4	135	10/06/2018	00.01		Continued.	Maintenance work	
MSPGCL	Parli Unit 8	250	10/06/2018	06.52	10/06/2018	15.21	Failure of DC Supply to Digital Control System	
MSPGCL	Koradi Unit 9	660	10/06/2018	16.45	10/06/2018	18.48	Flame Failure	
MSPGCL	Uran Unit 8	108	10/06/2018	22.35	11/06/2018	02.35	REF protection.	
MSPGCL	Uran Unit B0	120	10/06/2018	22.59	10/06/2018	23.54	CEP tripping.	
IPP	VIPL U-1	300	11/06/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 9	660	11/06/2018	08.27	11/06/2018	11.30	ID Fan Problem	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jun/2018

Position as on 6.30 Hrs of 11/Jun/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 9	660	11/06/2018	11.56	11/06/2018	12.03	Generator Elect. Fault	
IPP	Dhariwal	300	11/06/2018	16.00	11/06/2018	17.24	Relay malfunction.	
MSPGCL	Koradi Unit 7	210	11/06/2018	22.10		Continued.	Coal Shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2018

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Tirora ckt-II	IntraState	02/06/2018	20.17		Continued.	T	Distance Protection,tower collapsed.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	09/06/2018	17.12	10/06/2018	07.14	HT	Over Voltage
Dabhol New koyna I	InterState	10/06/2018	13.32	11/06/2018	21.36	HT	due to sparking r phase gantry sparking.
Dhule Sar'Sarovar II	InterState	10/06/2018	17.16	11/06/2018	11.52	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	11/06/2018	18.33		Continued.	HT	Over Voltage
Dhule - Bableswhar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule- Bableswhar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Akola-Nandgaonpeth (RPL)	IntraState	08/06/2018	03.07	10/06/2018	15.56	T	Over Voltage
Bhusawal-Aurangabad	IntraState	09/06/2018	17.06	11/06/2018	06.34	HT	Over Voltage
Deepnagar Waluj 1	IntraState	11/06/2018	06.59	11/06/2018	18.50	PO	Replacement of fault mid span joints.
Khadka-Aurangabad (Waluj)	IntraState	11/06/2018	18.58		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 500 Mva Ict 1 @Chandrapur 2	IntraState	31/03/2018	21.21		Continued.	HT	hand tripped after charge.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	01/06/2018	01.02		Continued.	T	Differential Protection and PRV Operated
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Nasik Navsari II	InterState	10/06/2018	00.16	10/06/2018	00.35	T	Distance Protection
Nasik Navsari II	InterState	10/06/2018	00.44	10/06/2018	02.22	T	Distance Protection
Tillari Amona	InterState	11/06/2018	15.06	11/06/2018	15.55	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Kalwa - Borivali	IntraState	01/06/2018	01.26		Continued.	HT	To control load on ICT.
Kalwa 52B Interconnector CB	IntraState	01/06/2018	01.35		Continued.	HT	To control load on ICT.
Trombay - Kalwa	IntraState	01/06/2018	01.43		Continued.	HT	To control load on ICT.
SAKI (REL) - SAKI (TATA) CKT - 1	IntraState	01/06/2018	03.29		Continued.	HT	To control load on ICT.
SAKI (REL) - SAKI (TATA) CKT - 2	IntraState	01/06/2018	03.29		Continued.	HT	To control load on ICT.
Kalwa-TIFIL	IntraState	01/06/2018	09.27		Continued.	HT	400KV Kalwa To Control ICT Overloading.
Salsette Borivli 1	IntraState	01/06/2018	10.45		Continued.	HT	Due To Overloading On ICT
Salsette Borivli 2	IntraState	01/06/2018	10.58		Continued.	HT	Due To Overloading On ICT.
Chalisgaon -Babhaleswar	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection,tower collapsed.
Talandage - Sawantwadi I	IntraState	10/06/2018	01.29	10/06/2018	02.21	T	Distance Protection
Ghodbunder - Versova	IntraState	10/06/2018	01.33	10/06/2018	06.41	HT	Safety Work.
Eklahare (Gcr) - Airoli Know Park	IntraState	10/06/2018	06.36	10/06/2018	14.54	PO	damaged e/w replacement.
Eklahare (Ocr)Nasik - Padghe 2	IntraState	10/06/2018	06.53	10/06/2018	09.50	PO	safety purpose as crossing below 220kv akp- nsk line.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2018

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Padghe - Jindal	IntraState	10/06/2018	07.04	10/06/2018	09.53	PO	safety purpose as crossing below 220kv akp- nsk line.
Gorai MSETCL Borivali Line-2	IntraState	10/06/2018	08.50	11/06/2018	12.48	PO	Gorai main bus -1 & main bus-ii outage to attend faulty bus isolator cum earth switch module.
Versova Gorai Line	IntraState	10/06/2018	10.22	11/06/2018	12.03	PO	Gorai main bus -1 & main bus-ii outage to attend faulty bus isolator cum earth switch module.
Ghodbunder - Gorai	IntraState	10/06/2018	10.30	11/06/2018	12.03	PO	Gorai main bus -1 & main bus-ii outage to attend faulty bus isolator cum earth switch module.
Gorai MSETCL Borivali Line-1	IntraState	10/06/2018	10.38	11/06/2018	12.47	PO	Gorai main bus -1 & main bus-ii outage to attend faulty bus isolator cum earth switch module.
Khaparkheda-Ambazari-I	IntraState	11/06/2018	08.14	11/06/2018	20.58	PO	Shifting of source of 220 KV ambazari from 220 khaparkheda to 400/220 kv khaparkhedda.
Mudshingi-Belewadi	IntraState	11/06/2018	09.04	11/06/2018	18.00	EO	String replacement work real time.
REL Borivali Aarey Line	IntraState	11/06/2018	10.00	11/06/2018	16.05	PO	Annual Maintenance Work
Main Bus Section @ Ichalkaranji II	IntraState	11/06/2018	10.15	11/06/2018	14.23	PO	Quarterly Maintainance Work
Karad(400kv) - Wathar	IntraState	11/06/2018	10.51	11/06/2018	18.05	PO	Quarterly Maintainance Work
Ambazari-Amravati	IntraState	11/06/2018	11.13	11/06/2018	12.36	PO	Isolator alignment work.
Uran - Ongc Uran	IntraState	11/06/2018	11.24	11/06/2018	16.18	EO	To attend Hot Spot
Pedambe-Pophali	IntraState	11/06/2018	13.40	11/06/2018	15.55	T	Distance Protection
Dasturi-Kandalgaon Line	IntraState	11/06/2018	15.20	11/06/2018	16.07	T	LBB operated
Kandalgaon - Bhira	IntraState	11/06/2018	15.20	11/06/2018	16.20	T	LBB operated
Kandalgaon - ONGC Panvel	IntraState	11/06/2018	15.20	11/06/2018	16.18	T	LBB operated
Kandalgaon - Pirangut	IntraState	11/06/2018	15.20	11/06/2018	16.15	T	LBB operated
Kandalgaon - Koyna	IntraState	11/06/2018	15.20	11/06/2018	16.14	T	LBB operated
Kandalgaon - Sona Alloys	IntraState	11/06/2018	15.20		Continued.	T	LBB operated
Vilebagad-Kandalgaon(Inox tap)	IntraState	11/06/2018	15.20	11/06/2018	16.17	T	LBB operated
Virur - Gadchiroli	IntraState	11/06/2018	19.58	11/06/2018	21.32	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(repaired and ready for commissioning)
220/33kv 125 Mva Transformer 2 @Gorai R/S	IntraState	27/05/2018	09.03	11/06/2018	20.03	T	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.
220/33kv 125 MVA Transformer 1 @Gorai R/S	IntraState	10/06/2018	10.34	11/06/2018	20.03	PO	Gorai main bus -1 & main bus-ii outage to attend faulty bus isolator cum earth switch module.
220/132Kv 200MVA ICT-I @ Chikhali	IntraState	10/06/2018	11.21	10/06/2018	17.51	PO	oil top up work.
220/132 Kv 100 Mva Vijai Ict 2 @Gadchiroli	IntraState	11/06/2018	19.10	11/06/2018	19.25	T	Back up protection operated O/C & F/E.
220/33 Kv 25 Mva Hhe Ptr 1 @Gadchiroli	IntraState	11/06/2018	19.58	11/06/2018	21.35	T	Distance Protection
220/132/11 Kv 50 Mva Cgl Ict 1 @Gadchiroli	IntraState	11/06/2018	19.58	11/06/2018	22.00	T	Distance Protection
132 KV LINE Outages/Trippings							
Mansar Pench	InterState	06/06/2018	16.21		Continued.	HT	Over Voltage
Kanhan-Bhandara	IntraState	10/06/2018	03.10	10/06/2018	04.12	HT	due to relay problem.
Jalna (220kv) - Badnapur	IntraState	10/06/2018	07.15	10/06/2018	08.12	T	Distance Protection
Cosmofilms-Badnapur	IntraState	10/06/2018	08.27	10/06/2018	12.03	T	Distance Protection
Waghala (Nanded2) - Umri 1	IntraState	10/06/2018	19.58	10/06/2018	20.24	T	c.b.pdr.optd.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2018

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kardha-Asgaon	IntraState	11/06/2018	19.53	11/06/2018	20.40	T	Distance Protection
Kardha-Sakoli	IntraState	11/06/2018	19.53	11/06/2018	20.22	T	Back up protection operated O/C & E/F.
Sakoli-Asgaon	IntraState	11/06/2018	19.53	11/06/2018	20.25	T	DC supply fail, carrier fail.