

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jun/2019 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	154.955	1617.533	1) Gujrat	-2.773	-17.098
2) Hydro	4.463	42.484	2) Madhya Pradesh	5.072	70.399
3) Gas	2.424	56.255	3) Chattisgarh	2.840	34.290
Total MSPGCL	161.842	1716.272	4) Maharashtra	116.665	1135.051
B) 1) APLM	68.487	714.796	5) Goa (Amona)	-0.374	-3.740
2) JSWEL	21.631	238.882	Total	121.430	1218.902
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.685	309.280
4) RPL(AMT)	23.494	245.314	b) Mumbai Drawl	41.932	390.170
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	6.111	102.133
6) Other IPP	6.260	71.087	Include PX	-6.203	-41.284
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.685	309.280
C) 1) TPCL Thermal	12.836	132.766	Include PX	15.500	136.933
2) TPCL Hydro	3.962	28.233	Standby	0.000	0.000
3) TPCL Gas	4.152	43.094	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.553	95.735	1) MSEDCL	386.182	4161.610
D) STATE			2) Mumbai Discoms	72.435	689.999
1) Thermal	297.216	3116.113	TOTAL STATE	458.617	4851.609
(A1+C1+C4+(B1-B6))					
2) Hydro	8.425	70.717			
(A2+C2)					
3) Gas	6.576	99.349			
(A3+B7+C3)					
4) Wind	18.736	284.991			
6) SOLAR	6.234	61.536			
TOTAL STATE	337.187	3632.706			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7007	7175	6863	6106
MSPGCL Hydro	132	198	263	359
MSPGCL Gas	132	143	0	0
MSPGCL Total Generation	7271	7516	7126	6465
Central Sector Receipt	5678	5692	3793	4116
WIND	631	773	1065	610
CPP / IPP Thermal	5101	5673	5225	4690
CPP / IPP Gas	0	0	0	0
SOLAR	812	506	0	0
Exchange with Mumbai	-2176	-2137	-1717	-1311
MSEDCL DEMAND MET	17317	18023	15492	14570
Load Shedding	0	0	0	0
MSEDCL DEMAND	17317	18023	15492	14570
TPCL GENERATION	962	1170	975	919
AEML GENERATION	376	437	404	398
MUMBAI DEMAND	3514	3744	3096	2628
STATE DEMAND MET	20831	21767	18588	17198
STATE DEMAND	20831	21767	18588	17198
Frequency (Hz)	49.98	49.89	50.00	49.79

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.12 Hz at 04.02 Hrs	49.66 Hz at 22.50 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 10/Jun/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.38	37.28	165	120
Unit 7	2.37	27.65	155	0
Unit 8	9.28	87.80	450	280
Unit 9	9.84	102.33	517	275
Unit 10	8.91	101.08	401	320
Total	33.79	356.14		
Bhusawal				
Unit 3	0.00	12.44	0	0
Unit 4	9.16	99.01	500	355
Unit 5	9.08	78.97	455	355
Total	18.24	190.42		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	11.77	0	0
Total	0.00	11.77		
Chandrapur				
Unit 3	4.32	43.20	195	163
Unit 4	4.00	39.21	174	160
Unit 5	9.30	95.09	415	365
Unit 6	9.89	99.75	455	370
Unit 7	9.52	96.00	440	365
Unit 8	10.43	109.68	495	360
Unit 9	10.27	105.18	485	365
Total	57.72	588.11		
Paras				
Unit 3	5.42	57.95	258	187
Unit 4	5.42	55.05	258	194
Total	10.84	113.00		
Khaparkheda				
Unit 1	3.35	32.27	145	130
Unit 2	1.58	27.82	70	60
Unit 3	3.54	33.69	154	140
Unit 4	3.51	33.64	150	140
Unit 5	10.42	109.90	500	380
Total	22.40	237.32		
Nasik				
Unit 3	4.07	41.08	195	156
Unit 4	4.10	39.16	194	160
Unit 5	3.80	40.54	180	90
Total	11.97	120.78		
Uran				
All Units	2.42	56.26	148	132
Total	2.42	56.26		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.01	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.01		
Koyna				
Stage 1-2	1.84	13.56	205	40
Stage 4	0.00	0.00	0	0
Stage 3	0.38	3.18	80	0
Total	2.22	16.74		
Hydro				
KDPH	0.43	4.32	18	18
VTRNA	0.78	9.30	61	0
TILLARI	0.00	0.97	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.17	1.49	40	0
RNGR+BHTSA	0.00	1.71	0	0
BHANDARDRA	0.00	1.07	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.02	1.58	1	0
GHATGHAR	0.84	5.30	160	0
Total	2.24	25.75		
Wind				
Total	18.74	284.99	0	0
Total	18.74	284.99		
CPP				
APML(Mus)	68.49	714.80	0	0
JSWEL(Mus)	21.63	238.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	23.49	245.31	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	6.26	71.09	0	0
Total	119.87	1270.08		
SOLAR				
Total	6.23	61.54	0	0
Total	6.23	61.54		
Tata				
Trombay 5	8.05	83.60	464	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.62	27.47	116	65
Trombay 7B	1.53	15.62	66	51
Trombay 8	4.78	49.16	201	197
TATA Hydro	3.96	28.23	398	18
Total	20.95	204.09		
AEML				
DTPS U-1&2	9.55	95.74	484	374
Total	9.55	95.74		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	154.96	1617.53	MSPGCL Total	161.84	1716.27
			MSPGCL Thml+Gas	157.38	1673.79	Koyna 1,2 & 4 Total	1.84	13.56
			MSPGCL Hydro	4.46	42.48	State Total	337.19	3632.71

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Jun/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6411	64	146	6621	1417	5130	0	0	4962	4736	-1804	16100	0	16100	2927	19027	49.97
2	5976	129	137	6242	1209	4833	0	0	5050	4789	-1641	15432	0	15432	2733	18165	50.00
3	5802	335	147	6284	1000	4823	0	0	4563	4998	-1517	15588	0	15588	2572	18160	49.96
4	5838	159	147	6144	1094	4779	0	0	5038	4841	-1457	15401	0	15401	2471	17872	50.01
5	5887	120	148	6155	904	4796	0	0	4956	4719	-1390	15184	0	15184	2396	17580	50.03
6	5967	129	148	6244	642	4816	0	0	5346	5276	-1388	15590	0	15590	2402	17992	50.00
7	6221	164	147	6532	229	4801	0	49	5257	5564	-1295	15880	0	15880	2364	18244	49.95
8	6736	144	137	7017	241	4940	0	226	5179	4895	-1383	15936	0	15936	2456	18392	50.02
9	6222	124	146	6492	506	4770	0	471	5389	4963	-1664	15538	0	15538	2735	18273	49.99
10	6140	124	144	6408	494	4721	0	647	5558	5779	-1950	16099	0	16099	3100	19199	49.95
11	6633	162	144	6939	624	4753	0	772	5829	6059	-2145	17002	0	17002	3373	20375	50.00
12	7007	132	132	7271	631	5101	0	812	5845	5678	-2176	17317	0	17317	3514	20831	49.98
13	7108	86	142	7336	622	5196	0	792	6193	5641	-2184	17403	0	17403	3533	20936	49.95
14	6831	59	142	7032	654	5228	0	747	5937	6157	-2115	17703	0	17703	3499	21202	49.88
15	6959	209	132	7300	745	5675	0	654	5950	5918	-2236	18056	0	18056	3644	21700	49.85
16	7175	198	143	7516	773	5673	0	506	6019	5692	-2137	18023	0	18023	3744	21767	49.89
17	6984	159	142	7285	868	5339	0	374	5946	5453	-2043	17276	0	17276	3662	20938	49.91
18	6237	224	0	6461	1086	4987	0	166	5388	5648	-1945	16403	0	16403	3476	19879	49.99
19	6594	198	0	6792	811	4734	0	18	4638	4641	-1848	15148	0	15148	3260	18408	50.02
20	6859	294	0	7153	1002	5212	0	0	4551	3701	-1730	15338	0	15338	3181	18519	49.95
21	6863	263	0	7126	1065	5225	0	0	4398	3793	-1717	15492	0	15492	3096	18588	50.00
22	6238	194	0	6432	935	5007	0	0	4102	3471	-1608	14237	0	14237	2964	17201	49.92
23	6106	359	0	6465	610	4690	0	0	4043	4116	-1311	14570	0	14570	2628	17198	49.79
24	6161	434	0	6595	574	4643	0	0	4385	4902	-1248	15466	0	15466	2705	18171	49.85
MUs	154.95	4.46	2.42	161.84	18.74	119.87	0.00	6.23	124.52	121.43	-41.93	386.18	0.00	386.18	72.44	458.62	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jun/2019

Position as on 6.30 Hrs of 11/Jun/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	20/05/2019	16.01		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 3	210	04/06/2019	20.15		Continued.	Zero Schedule	
MSPGCL	Koyana STG-IV Unit-3	250	07/06/2019	10.00		Continued.	Stepup T/F Oil Leakage and Shaft Seal replacement	
MSPGCL	Uran Unit 5	108	07/06/2019	23.45	11/06/2019	05.00	Air Filter Replacement & Allied Work.	
MSPGCL	Koradi Unit 7	210	10/06/2019	17.06		Continued.	ID Fan Problem	
IPP	RPL(AMT) U-5	270	11/06/2019	17.01		Continued.	Zero Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	04/06/2019	18.55		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	10/06/2019	10.55	10/06/2019	14.32	EO	TBC SHIFTING AT KOLHAPUR END HOT SPOT ATTENDING WORK.
Akola Wardha li	InterState	10/06/2019	14.24	10/06/2019	19.40	HT	H/T FROM WARDHA PG END WORK BY PGCIL.
Chakan Talegaon(Pg)	InterState	10/06/2019	17.50	11/06/2019	01.16	T	Distance Protection
Dhule(MS)- Dhule(BDTCL) -II	InterState	11/06/2019	18.29	11/06/2019	19.47	EO	To connect Broken LA E/W
Khadka-Aurangabad (Waluj)	IntraState	07/06/2019	21.13	10/06/2019	08.20	HT	Over Voltage
Chakan-Talegaon (Pgcil)	IntraState	09/06/2019	20.03	10/06/2019	07.32	T	TRIPPED FROM CHAKAN END Z1,Y-E,4KM,20KA FROM TALEGAON PG 1.03KM,18.70KAMP.
Karad - Jaigad - II	IntraState	10/06/2019	09.16	10/06/2019	19.15	PO	ATTENDING DECAPPING.
Lonikand I - Koyna stage-IV	IntraState	10/06/2019	09.54	10/06/2019	18.14	PO	CHEMICAL CLEANING OF DISC INSULATOR.
Deepnagar Taptitanda	IntraState	10/06/2019	09.57	10/06/2019	15.03	PO	DISTANCE RELAY REPLACEMENT WORK.
Akola II - RPL(Rattanindia) Ckt-II	IntraState	10/06/2019	14.24	10/06/2019	19.49	HT	EMERGENCY OUTAGE AT WARDHA PG END.
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	10/06/2019	17.42	10/06/2019	19.40	T	Distance Protection
Bhusawal-Aurangabad	IntraState	10/06/2019	18.18		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	10/06/2019	19.38	10/06/2019	19.52	PO	DUE TO EMERGENCY O/G ON WARDHA PG-AKOLA CKT 2.
Padghe - Nagothane - I	IntraState	10/06/2019	19.43	11/06/2019	13.30	T	Distance Protection
Padghe - Nagothane - II	IntraState	10/06/2019	19.44	11/06/2019	15.36	T	Distance Protection
Padghe - Kalwa-II	IntraState	10/06/2019	21.25	11/06/2019	16.11	T	Distance Protection
Kharghar-Talegaon(PG)	IntraState	10/06/2019	22.31	11/06/2019	03.42	T	Distance Protection
Jaigad-New Koyna Ckt-II	IntraState	11/06/2019	08.00	11/06/2019	16.27	PO	To attend Decapping
Lonikand I - Koyna stage-IV	IntraState	11/06/2019	08.20	11/06/2019	18.06	PO	Chemical cleaning of Disc Insulator
Deepnagar Taptitanda	IntraState	11/06/2019	09.53	11/06/2019	18.10	PO	Disc Replacement work
Koradi-RattanIndia	IntraState	11/06/2019	13.23	11/06/2019	17.15	EO	Replacement of Flashover String
Parly(MS)- Nanded ckt II	IntraState	11/06/2019	13.47	11/06/2019	16.49	T	Distance Protection Y Phase to E/F
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	10/06/2019	12.50	10/06/2019	13.50	T	TRIPPED ON PDR.
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	10/06/2019	14.50	10/06/2019	15.22	T	TRIPPED ON PDR.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	10/06/2019	21.24	11/06/2019	00.47	T	Buccholz Protection Optd
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	11/06/2019	00.46	11/06/2019	11.03	HT	TO CONTROL OVERLOADING.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	11/06/2019	16.40	11/06/2019	19.00	T	Tripped on Master Trip
400/220/33 Kv 500 Mva Ict 3 @Dhule	IntraState	11/06/2019	16.40	11/06/2019	17.56	T	Tripped on Master Trip
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Warora - Hinganghat	IntraState	07/06/2019	17.16		Continued.	T	Tower Collapsed At Location No.327, RYB 3.94KA, 4.41KA, 4.11KA.
Warora - Wardha	IntraState	07/06/2019	17.16		Continued.	T	Wrora-Y PH Pick, B PH Pick Up,Z1.Wardha-Y PH B PH, Z1-B 91.8 KM.3.31KAMP.3.24KAMP.
Lonikand-VSNL	IntraState	09/06/2019	17.27	10/06/2019	06.07	T	Distance Protection
Loteparshuram- Dasturi Line	IntraState	09/06/2019	18.06	10/06/2019	13.48	T	INSULATOR BROKEN AT LOC. NO.97.
Pusad-Ghatodi	IntraState	10/06/2019	08.01	10/06/2019	10.35	PO	ARRESTING MINOR LEAKAGE PF R-PH. CT. ROUTINE MAINTENANCE WORK.
Nagothane-Wadkhal II	IntraState	10/06/2019	09.08	10/06/2019	19.38	PO	PROVIDING EART WIRE AT MISSING SPAN LOC. NO.56 TO 60.
Oni Kharepatan Line	IntraState	10/06/2019	09.15	10/06/2019	16.43	PO	BUS OUTAGE AT ONI.
Mudshingi-Wathar	IntraState	10/06/2019	10.00	10/06/2019	16.40	PO	INSULATOR CLEANING WORK.
Raymond - Washala	IntraState	10/06/2019	11.05	10/06/2019	12.35	PO	EO-HOT SPOT ATTENDING WORK AT WAVE TRAP.
Kandalgaon - ONGC Panvel	IntraState	10/06/2019	11.23	10/06/2019	15.25	PO	INSULATOR CHATTERING WORK.
Miraj - Mhaishal	IntraState	10/06/2019	11.47	10/06/2019	13.52	PO	Quarterly Maintainance Work
CHAKAN (400 KV)- Chinchwad2	IntraState	10/06/2019	18.00	11/06/2019	04.50	T	Distance Protection
Chinchwad-Hinjewadi I	IntraState	10/06/2019	18.01	11/06/2019	04.55	HT	TO CONTROL OVERLOADING.
Raymond - Washala	IntraState	10/06/2019	18.30	10/06/2019	19.09	T	Distance Protection
Eklahara(Gcr)(Nasik)- Bableshtar-I	IntraState	10/06/2019	18.44	11/06/2019	03.02	T	Distance Protection
Ghatghar - Jindal	IntraState	10/06/2019	18.50	10/06/2019	19.34	T	Distance Protection
Bombay Dyeing - Sahara	IntraState	10/06/2019	20.29	11/06/2019	00.25	T	Distance Protection
Uran - Kharghar 2	IntraState	10/06/2019	21.13	10/06/2019	21.30	T	Distance Protection
Uran - Ongc Uran	IntraState	10/06/2019	21.22	11/06/2019	02.20	T	Distance Protection
Colourchem - Temghar	IntraState	10/06/2019	21.34	11/06/2019	19.55	T	Distance Protection
Roma-Bhavegar	IntraState	10/06/2019	21.39	11/06/2019	11.52	T	Distance Protection
ANANDNAGAR - PALAVA	IntraState	10/06/2019	21.42	11/06/2019	13.23	T	TRIPPED FROM PALAVA END.
Dahanu Versova	IntraState	10/06/2019	21.51	10/06/2019	22.14	T	Distance Protection
Mulund - GIS Bhandup	IntraState	10/06/2019	21.52	10/06/2019	23.08	T	Distance Protection
Tata Borivli MSETCL Borivli 5	IntraState	11/06/2019	06.49	11/06/2019	09.35	PO	Tree Trimming
Kalwa1 - Taloja	IntraState	11/06/2019	08.12	11/06/2019	09.14	EO	Removing Banner Hanging on line
Parli(U-VIII) GCR CKT	IntraState	11/06/2019	10.32	11/06/2019	12.07	PO	Breaker Timing CRM
OSMANABAD PARANDA	IntraState	11/06/2019	11.23	11/06/2019	14.51	PO	Tan Delta Measurment of CTs
Ongc Panvel - Tss Panvel	IntraState	11/06/2019	11.33	11/06/2019	20.52	PO	Replacement of Rusted E/W
Bombay Dyeing - Sahara	IntraState	11/06/2019	13.30	11/06/2019	13.48	EO	To attend Y Phase LA Earthing open
Niwali - Pawas Line	IntraState	11/06/2019	15.30	11/06/2019	18.53	T	Distance Protection R Phase to E/F
Boisar Versova Line	IntraState	11/06/2019	16.19	11/06/2019	18.27	EO	To attend Hot Spot

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PARANDA BARSHI	IntraState	11/06/2019	16.30	11/06/2019	17.20	PO	Tan Delta Measurment of CTs
Jambhul - Anandnagar	IntraState	11/06/2019	16.55	11/06/2019	17.41	HT	Sparking on CC
Kharghar-Borivali ckt I	IntraState	11/06/2019	18.31	11/06/2019	20.00	T	Tripped on PDR
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Buccholz Trip.
220/100 Kv 100 MVA ICT II @Kandalgaon	IntraState	01/06/2019	11.30		Continued.	PO	Oil Filtration Work.(Charged On Humming).
220/33kv 125 Mva Transformer 2 @Aarey R/S	IntraState	10/06/2019	09.10	10/06/2019	17.58	PO	Annual Maintenance Work
220/132 Kv 200 Mva Cgl Ict @Satana	IntraState	10/06/2019	09.10	10/06/2019	10.30	PO	PRE MONSOON MAINTENANCE WORK.
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	10/06/2019	10.24	10/06/2019	16.30	PO	Quarterly Maintainance Work
220/132Kv 200MVA ICT-I @ Akola	IntraState	10/06/2019	10.39	10/06/2019	19.03	PO	ROUTINE BAY MAINTENANCE AND DIAGNOSTIC TESTING WORK.
220/33kv 125 MVA T/F-III @ Goregaon	IntraState	10/06/2019	10.44	10/06/2019	17.20	PO	PRE MONSOON MAINTENANCE WORK.
220/100 KV 200MVA ICT II @ Pal	IntraState	10/06/2019	22.10	11/06/2019	00.02	T	INTERNAL FAULT.
220/132kv 200 Mva Aditya Vidyut Ict 1 @Kanhani	IntraState	11/06/2019	08.04	11/06/2019	11.39	EO	Hot Spot on CT Stud
220/33kv 100 MVA Transformer 4 @Aarey R/S	IntraState	11/06/2019	09.00	11/06/2019	18.53	PO	Annual Maintenance Work
220/132 kv 200MVA ICT II @ Girwali	IntraState	11/06/2019	11.18	11/06/2019	16.18	PO	Testing Work
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	11/06/2019	12.24	11/06/2019	13.00	PO	PRV Replacement work
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	11/06/2019	13.17	11/06/2019	14.20	PO	Pre Monsoon maint.work
220/100 Kv 200 Mva Aval Ict 2 @Taloja	IntraState	11/06/2019	16.22		Continued.	T	Differential protection
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	11/06/2019	16.25	11/06/2019	19.25	PO	Testing Work
110 KV LINE Outages/Trippings							
Kalyan Kalwa Salsette 1	IntraState	10/06/2019	10.23	10/06/2019	12.42	PO	TREE TRIMMING.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage