

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jun/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.873	1695.646	1) Gujrat	-6.628	-59.924
2) Hydro	9.539	133.622	2) Madhya Pradesh	3.634	36.184
3) Gas	6.514	45.102	3) Chattisgarh	2.330	21.050
Total MSPGCL	175.926	1874.370	4) Maharashtra	171.254	1753.780
B) 1) APML	71.375	721.863	5) Goa (Amona)	-0.819	-10.054
2) JSWEL	18.000	169.886	Total	169.771	1741.036
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.700	350.779
4) RPL(AMT)	25.620	248.434	b) Mumbai Drawl	38.380	387.101
5) SWPGPL	9.287	86.569	c) MSEDCL Bilateral *	63.280	750.144
6) Other IPP	13.412	151.090	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.700	350.580
C) 1) TPCL Thermal	15.181	153.287	Include PX	0.000	0.000
2) TPCL Hydro	4.868	52.998	Standby	0.000	0.199
3) TPCL Gas	2.167	14.845	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.128	113.456	1) MSEDCL	465.230	4881.269
D) STATE			2) Mumbai Discoms	71.728	721.690
1) Thermal	323.876	3340.231	3) Other Discoms	9.656	95.281
(A1+C1+C4+(B1-B6))			TOTAL STATE	546.614	5698.240
2) Hydro	14.407	186.620			
(A2+C2)					
3) Gas	8.681	59.947			
(A3+B7+C3)					
4) Wind	20.804	273.695			
6) SOLAR	9.071	96.708			
TOTAL STATE	376.839	3957.201			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6650	6752	6765	6641
MSPGCL Hydro	532	426	320	344
MSPGCL Gas	256	266	278	279
MSPGCL Total Generation	7438	7444	7364	7264
Central Sector Receipt	8537	8464	6026	6341
WIND	419	758	1123	764
CPP / IPP Thermal	5469	6017	5940	6007
CPP / IPP Gas	0	0	0	0
SOLAR	1223	774	0	0
Exchange with Mumbai	-2101	-2016	-1427	-1161
MSEDCL DEMAND MET	20564	21000	18583	18920
Load Shedding	0	0	0	0
MSEDCL DEMAND	20564	21000	18583	18920
TPCL GENERATION	875	1067	1173	791
AEML GENERATION	489	494	487	468
MUMBAI DEMAND	3465	3577	3087	2420
OTHER DISCOM DEMAND	421	442	442	295
STATE DEMAND MET	24450	25018	22112	21634
STATE DEMAND	24450	25018	22112	21634
Frequency (Hz)	50.00	50.00	50.01	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 08:02 Hrs	49.87 Hz at 12:41 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.27	43.50	195	140
Unit 7	0.00	0.00	0	0
Unit 8	13.79	132.77	602	478
Unit 9	12.18	121.90	526	480
Unit 10	12.55	123.06	554	443
Total	42.79	421.23		
Bhusawal				
Unit 3	3.04	33.64	145	110
Unit 4	10.43	103.59	460	375
Unit 5	9.44	85.94	430	340
Total	22.90	223.18		
Parli				
Unit 6	4.69	48.54	245	151
Unit 7	4.13	41.84	208	144
Unit 8	3.13	31.13	142	126
Total	11.95	121.50		
Chandrapur				
Unit 3	3.12	27.84	155	115
Unit 4	2.89	30.31	132	113
Unit 5	8.80	85.83	375	333
Unit 6	9.17	91.99	400	310
Unit 7	8.74	86.95	391	325
Unit 8	11.16	108.09	475	444
Unit 9	0.00	84.83	0	0
Total	43.88	515.85		
Paras				
Unit 3	4.69	49.96	222	160
Unit 4	4.53	44.06	217	157
Total	9.22	94.03		
Khaparkheda				
Unit 1	3.14	32.20	145	110
Unit 2	3.67	35.66	160	145
Unit 3	4.29	41.85	187	169
Unit 4	0.00	13.16	0	0
Unit 5	10.87	109.54	476	430
Total	21.96	232.42		
Nasik				
Unit 3	3.62	38.05	183	122
Unit 4	3.54	24.22	175	124
Unit 5	0.00	25.17	0	0
Total	7.17	87.44		
Uran				
All Units	6.51	45.10	289	256
Total	6.51	45.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.26	3.27	38	0
Total	0.26	3.27		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.10	30.80	235	35
Stage 4	0.05	27.05	47	0
Stage 3	1.41	14.92	160	0
Total	3.56	72.77		
Hydro				
KDPH	0.49	5.12	21	21
VTRNA	0.00	0.00	0	0
TILLARI	0.29	0.84	58	0
BHIRA T.R.	0.30	3.11	80	0
SMLHY_PTN	4.63	47.50	216	168
GHATGHAR	0.00	1.01	0	0
Total	5.72	57.58		
Wind				
Total	20.80	273.70	0	0
Total	20.80	273.70		
CPP				
APML(Mus)	71.38	721.86	0	0
JSWEL(Mus)	18.00	169.89	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.62	248.43	0	0
SWPGPL-Mus	9.29	86.57	0	0
Other(Mus)	13.41	151.09	0	0
Total	137.69	1377.84		
SOLAR				
Total	9.07	96.71	0	0
Total	9.07	96.71		
Tata				
Trombay 5	9.74	99.76	446	310
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.18	10.00	54	45
Trombay 7B	0.98	4.85	44	38
TATA Hydro	4.87	53.00	420	6
Trombay 8	5.44	53.52	242	220
Total	22.22	221.13		
AEML				
DTPS U-1&2	11.13	113.46	495	345
Total	11.13	113.46		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.87	1695.65	MSPGCL Total	175.93	1874.37
			MSPGCL Thml+Gas	166.39	1740.75	Koyna 1,2 & 4 Total	2.15	57.85
			MSPGCL Hydro	9.54	133.62	State Total	376.84	3957.20

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6918	392	288	7598	733	6158	0	0	6065	6044	-1202	18989	0	18989	2839	343	22170	49.96
2	6830	392	268	7490	756	6105	0	0	5882	6146	-1139	19030	0	19030	2667	329	22026	50.02
3	6710	554	279	7544	900	6071	0	0	5928	6094	-1126	19161	0	19161	2516	322	21998	50.01
4	6641	344	279	7264	764	6007	0	0	6495	6341	-1161	18920	0	18920	2420	295	21634	50.01
5	6691	344	280	7314	761	5946	0	0	6420	6658	-1099	19265	0	19265	2359	316	21940	49.99
6	6678	396	279	7352	649	5942	0	0	6967	7173	-1188	19576	0	19576	2377	352	22306	49.98
7	6748	546	269	7564	541	6108	0	81	6833	6951	-1224	19625	0	19625	2391	395	22412	50.02
8	6788	442	289	7518	554	5699	0	324	6833	7062	-1424	19314	0	19314	2502	420	22236	50.05
9	6743	330	268	7340	678	5420	0	623	7507	7416	-1752	19286	0	19286	2773	440	22498	50.04
10	6623	352	268	7244	574	5227	0	878	8073	7771	-1893	19344	0	19344	3113	456	22914	49.99
11	6594	384	276	7254	473	5233	0	1121	8433	8484	-2137	19982	0	19982	3356	446	23784	49.95
12	6650	532	256	7438	419	5469	0	1223	8144	8537	-2101	20564	0	20564	3465	421	24450	50.00
13	6620	366	265	7252	327	5568	0	1190	8494	8269	-2095	20092	0	20092	3432	418	23942	49.99
14	6678	460	265	7404	401	5574	0	1201	8431	8344	-2000	20503	0	20503	3365	421	24288	49.99
15	6713	344	265	7322	503	5805	0	1017	8746	8767	-2031	20943	0	20943	3498	440	24880	50.00
16	6752	426	266	7444	758	6017	0	774	8808	8464	-2016	21000	0	21000	3577	442	25018	50.00
17	6568	424	257	7248	1116	5501	0	436	8012	7663	-2025	19509	0	19509	3528	430	23468	50.02
18	6373	418	267	7058	1395	5252	0	176	7497	7048	-1979	18498	0	18498	3382	453	22332	50.01
19	6323	404	268	6996	1401	5091	0	27	6787	6735	-1674	18142	0	18142	3180	433	21756	50.02
20	6721	374	267	7362	1337	5807	0	0	6191	5894	-1499	18442	0	18442	3142	458	22042	49.97
21	6765	320	278	7364	1123	5940	0	0	5885	6026	-1427	18583	0	18583	3087	442	22112	50.01
22	6717	268	268	7252	1547	6092	0	0	6259	5546	-1349	18668	0	18668	2981	421	22070	50.00
23	6361	438	269	7068	1554	5738	0	0	6666	6505	-1343	19118	0	19118	2861	405	22384	49.96
24	6668	286	280	7234	1540	5924	0	0	6340	5833	-1496	18677	0	18677	2913	358	21948	50.00
MUs	159.87	9.54	6.51	175.93	20.80	137.69	0.00	9.07	171.70	169.77	-38.38	465.23	0.00	465.23	71.72	9.66	546.61	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/Jun/2022

Position as on 6.30 Hrs of 11/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34	11/06/2022	17:36	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
IPP	RPL(AMT) U-4	270	31/05/2022	01:15		Continued.	Ash Conveyer problem.(Coal shortage From Dt 02.06.2022 @	
MSPGCL	Uran Unit 8	108	06/06/2022	23:03	11/06/2022	17:36	Gas shortage	
MSPGCL	Nasik Unit 5	210	08/06/2022	18:18		Continued.	ID Fan Problem	11/06/2022
MSPGCL	Koyna Unit 12	80	09/06/2022	07:40		Continued.	TO ATTEND BUTTERFLY VALVE PROBLEM.	
MSPGCL	Chandrapur Unit 9	500	09/06/2022	08:46		Continued.	Boiler Tube Leakage	13/06/2022
IPP	SWPGPL U-4	135	10/06/2022	23:00		Continued.	Boiler Bottom Ash System problem.	13/06/2022
MSPGCL	Chandrapur Unit 7	500	11/06/2022	07:00		Continued.	Air heater problem	12/06/2022
MSPGCL	Uran Unit 5	108	11/06/2022	14:29		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 3	210	11/06/2022	17:08	11/06/2022	19:34	Furnace Pressure High	
AEML	AEML Unit 1	250	11/06/2022	23:53		Continued.	Boiler Tube Leakage	13/06/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BR Outages/Trippings							
BUS REACTOR (240 MVar) @ EKTUNI	IntraState	10/06/2022	11:25	10/06/2022	18:31	PO	"Diagnostic Testing of Bus Reactor & Routine Maintenance "
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	10/06/2022	13:20	10/06/2022	19:32	HT	PROBLEM IN B-PHASE CT AT PADGHA END
DHULE - KHANDWA CKT - 2	InterState	10/06/2022	15:42	10/06/2022	16:16	T	Distance Protection
400 KV AKOLA - AURANGABAD(PG) CKT - 2	InterState	11/06/2022	18:59	11/06/2022	20:24	T	Tripped on Distance Protection.
DHULE - SSNNL CKT - 2	InterState	11/06/2022	19:42		Continued.	T	Tripped on Distance Protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/06/2022	16:32			HT	Load management
TAPTITANDA - EKTUNI CKT - 1	IntraState	09/06/2022	21:33	10/06/2022	09:18	T	DP Tripped
PADGHE - KALWA CKT - 1	IntraState	10/06/2022	02:24	10/06/2022	05:05	EO	Outage is required for attending the Replacement of decapped insulator string at loc. no. 1058 B-Phase
PADGHE - KALWA CKT - 2	IntraState	10/06/2022	05:18	10/06/2022	07:10	EO	Replacement of decapped insulator string at loc. no. 1028 Y-Phase
CHANDRAPUR 2 - CHD SWITCHING CKT - 1	IntraState	10/06/2022	10:18	10/06/2022	14:15	PO	Diagnostic testing & allied bay maintenance work
PARLI-SOLAPUR (LAMBOTI)	IntraState	10/06/2022	10:36	10/06/2022	18:01	PO	Tightening of hardware
NEW KOYNA - DABHOL CKT - 2	IntraState	10/06/2022	12:50	11/06/2022	11:25	T	Distance Protection
KALWA - KHARGHAR	IntraState	10/06/2022	12:53	10/06/2022	13:11	T	TRIPPED ONLY FROM KALWA END
KORADI - KHADKA	IntraState	10/06/2022	20:11	11/06/2022	02:15	T	Distance Protection
DEEPNAGAR - THAPTI TANDA	IntraState	10/06/2022	20:40	11/06/2022	16:10	T	Distance Protection
PADGHE - NAGOTHANE CKT - 1	IntraState	11/06/2022	07:00	11/06/2022	15:28	T	DP
CHANDRAPUR 2 - WARORA CKT-1	IntraState	11/06/2022	11:56	11/06/2022	21:34	HT	Line outage is required for restoration of broken OPGW between Tower No.477-478 of 400kV Bhadrawati-Ramagundam Ckt-2 line
CHANDRAPUR 2 - WARORA CKT-2	IntraState	11/06/2022	11:56	11/06/2022	21:38	HT	Line outage is required for restoration of broken OPGW between Tower No.477-478 of 400kV Bhadrawati-Ramagundam Ckt-2 line
EKTUNI - TAPTITANDA CKT - 1	IntraState	11/06/2022	13:10	11/06/2022	20:09	T	TRIPPED ON DISTANCE PROTECTION
PADGHE - NAGOTHANE CKT - 1	IntraState	11/06/2022	17:07	11/06/2022	23:47	T	Tripped on Distance Protection.
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2022	12:33			PO	For CB replacement work. ICT will be in service through TBC.
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	10/06/2022	11:36	10/06/2022	17:18	PO	Routine Maintenance work & Diagnostic Testing
400 KV BR Outages/Trippings							
125 MVar BUS REACTOR @ TALANDGE	IntraState	10/06/2022	17:17	10/06/2022	23:18	T	Differential Protection
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ KHARGHAR	IntraState	10/06/2022	15:25	10/06/2022	18:40	EO	For replacement of Damaged A Bus B Ph Bus side isolator Jaw and blade by hotline unit.
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132 KV KANHAN (220 KV) - PENCH CKT	InterState	10/06/2022	12:58	10/06/2022	18:12	EO	Outage required for For replacement of Y-ph CC High tan delta value of Y-ph CC observed on dt.09.06.2022. Hence emergency outage applied.
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
MUDSHINGI - CHIKODI	IntraState	06/06/2022	09:18			PO	Line reorientation work from D/C towers (Loc. 320 to 312 to M/C-9)) to M/C towers (Guide-D/C- M/C 3 to M/C 9) .
AAREY - AEML SAKI CKT - 1	IntraState	08/06/2022	11:19	11/06/2022	22:30	PO	Repair / restoration of 220 kV R-Phase with additional 2 nos. Joints. Repair of Y-Phase outer sheath.
THEUR-JEJURI	IntraState	09/06/2022	09:20			PO	1)L.N.-9 old tower dismantling work , Errection of New tower, Destrining between L.N.- 8 to 9 & 9 to 10 , Stringing between L.N.- 8 to 9 & 9 to 10 (As L.N.- 9 bended & new tower foundation work completed) 2)L.N.-11, B, Pahgse,L.N.-18, B Phase, L.N.-21, B Phase 220 kV Jejuri Phursungi ckt I Double Jump ring work due to Hot spot Restrining between L.N.- 70 to 76 & 76 to 79 of 220 kV Theur Jejuri due to increased sag & ground clearance reduced
JEJURI-PHURSUNGI 1	IntraState	09/06/2022	09:43	11/06/2022	19:49	PO	1)L.N.-9 old tower dismantling work , Errection of New tower, Destrining between L.N.- 8 to 9 & 9 to 10 , Stringing between L.N.- 8 to 9 & 9 to 10 (As L.N.- 9 bended & new tower foundation work completed) 2)L.N.-11, B, Pahgse,L.N.-18, B Phase, L.N.-21, B Phase 220 kV Jejuri Phursungi ckt I Double Jump ring work due to Hot spot Restrining between L.N.- 70 to 76 & 76 to 79 of 220 kV Theur Jejuri due to increased sag & ground clearance reduced
KAMBA - VASAI	IntraState	09/06/2022	20:02	10/06/2022	08:02	T	DP Trip
BHAVEGHAR - ROMA	IntraState	09/06/2022	20:10	10/06/2022	11:53	T	DP Trip
KAMBA - KHARBAO TSS	IntraState	09/06/2022	20:10	10/06/2022	08:00	T	DP TRIP
PADGHE - NALASOPARA	IntraState	10/06/2022	08:43	10/06/2022	12:04	EO	Outage is required for safety purpose for attending break down of 220KV Bhaveghar-Roma Line at Loc no.95 by LMSD Padgha.
220KV MALEGAON - DHULE	IntraState	10/06/2022	09:39	10/06/2022	12:35	PO	For Pre monsoon Maintenance work.
ANANDNAGAR - PALAVA	IntraState	10/06/2022	12:02	10/06/2022	15:18	PO	Pre-monsoon Maintenance Work
BAPGAON - KALWA	IntraState	10/06/2022	12:06	10/06/2022	21:28	T	TRIPPED ON DIST.PROTECTION
MALEGAON - SAYNE	IntraState	10/06/2022	12:57	10/06/2022	15:07	PO	For Pre monsoon Maintenance work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	10/06/2022	15:24	10/06/2022	18:55	EO	220Kv BBLR Nashik line ckt No.2, LOC 110 y PH Nsk side, y Ph BBLR side. B ph BBLR side, 230-Y ph Nsk side as detected in the thermovision carried on dated 10.06.2022.
URAN - KHARGHAR 1	IntraState	11/06/2022	01:19	11/06/2022	09:16	T	TRIPPED ON DIST. PROTN
NAGOTHANE - IPCL	IntraState	11/06/2022	05:05	11/06/2022	13:09	T	DP
NERLE - DASGAON	IntraState	11/06/2022	10:08	11/06/2022	17:21	PO	Insulator cleaning and jumper tightening
OSMANABAD - SOLAPUR (BALE)	IntraState	11/06/2022	10:24	11/06/2022	13:23	PO	Outage is required for Replacement of Suspension string at loc no. 2 & 3 R ph.
BOISAR II - BOISAR (PG) CKT - 1	IntraState	11/06/2022	10:29		Continued.	PO	220kV PGCIL Line 1 Bay Strengthening at 220kV Boisar 2 S/s (MSETCL).
A BUS @ BOISAR II	IntraState	11/06/2022	10:40	11/06/2022	21:00	PO	220kV PGCIL Line 1 Bay Strengthening at 220kV Boisar 2 S/s (MSETCL) however Stub Bus of PGCIL Line 1 passes over both 220kV A and 220kV B Bus, therefore for safety purpose 220kV A and 220kV B-Bus outage (from 11.06.2022 to 12.06.2022) is essential.
PANDHARPUR - MALINAGAR	IntraState	11/06/2022	10:45	11/06/2022	18:24	PO	Outage is required for changing / replacement of faulty string at loc no. LILO Portion - 12, 15, 19, 28, 78, 79, 81, 82.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	11/06/2022	11:39	11/06/2022	14:39	EO	220Kv BBLR Nashik line ckt No.1, LOC 231 Y ph BBLR side , 232 Y ph nasik side . 133 Y Ph Nasik side . 123 Y Ph Nasik side , 142 Y ph Nasik side . 144 Y ph Nasik side , 147 B ph . Jumper replacement 191 Y ph nasik side . as detected in the thermovision carried on dated 10.06.2022.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/33kv 125 MVA TF 3 @ SAKI (AEML)	IntraState	10/06/2022	09:35	10/06/2022	17:01	PO	ANNUAL & PREMONSOON MAINTENANCE OF TRANSFORMER
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	10/06/2022	09:37	10/06/2022	10:38	PO	For wrapping plastic paper to Buchloz Relay and Pre-monsoon maintenance work
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	10/06/2022	10:10	10/06/2022	16:35	PO	N2 Based fire protection system (CTR) Maintenance work by agency.
220/22 KV 50 MVA PTR 1	IntraState	11/06/2022	06:40	11/06/2022	09:39	T	TRIPPED ON DIFFERENTIAL PROTECTION
220/22 KV 50 MVA PTR 4 @ COLOURCHEM	IntraState	11/06/2022	08:20	11/06/2022	09:40	PO	For Premonsoon maintenance work including transformer buccholz , PRV relay, MOG, OSR plastic paper wrapping work.
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	11/06/2022	10:49	11/06/2022	13:50	PO	For Attending Oil Leakage and Oil Top up of ICT
220/132 KV 100 MVA ICT 2 @ BELWANDI	IntraState	11/06/2022	14:02	11/06/2022	16:11	PO	For Attending Oil Leakage and Oil Top up of ICT
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 10/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	10/06/2022	09:12	10/06/2022	16:17	PO	ATTENDING HOT SPOT AT LOC -33

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage