

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jun/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	170.993	1532.731	1) Gujrat	-5.000	-33.882
2) Hydro	5.078	191.643	2) Madhya Pradesh	2.783	60.786
3) Gas	4.472	50.370	3) Chattisgarh	2.360	30.130
Total MSPGCL	180.543	1774.744	4) Maharashtra	214.015	2168.806
B) 1) APLM	63.487	659.503	5) Goa (Amona)	-1.481	-15.085
2) JSWEL	23.790	247.725	Total	212.677	2210.755
3) VIPL	0.000	0.000	a) Mumbai Schedule	42.874	434.988
4) RPL(AMT)	31.126	308.481	b) Mumbai Drawl	47.313	481.168
5) SWPGPL	10.634	103.290	c) MSEDCL Bilateral *	116.655	1091.278
6) Other IPP	7.473	36.588	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	42.872	434.801
C) 1) TPCL Thermal	12.170	128.284	Include PX	0.000	0.000
2) TPCL Hydro	5.593	56.017	Standby	0.003	0.187
3) TPCL Gas	1.840	20.721	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.950	89.006	1) MSEDCL	526.849	5205.008
D) STATE			2) Mumbai Discoms	76.866	775.196
1) Thermal	329.623	3105.608	3) Other Discoms	10.608	107.087
(A1+C1+C4+(B1-B6))			TOTAL STATE	614.323	6087.291
2) Hydro	10.671	247.660			
(A2+C2)					
3) Gas	6.312	71.091			
(A3+B7+C3)					
4) Wind	39.371	291.249			
6) SOLAR	15.669	160.928			
TOTAL STATE	401.646	3876.536			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7230	7272	7040	7116
MSPGCL Hydro	148	124	270	214
MSPGCL Gas	177	176	181	193
MSPGCL Total Generation	7556	7572	7490	7522
Central Sector Receipt	9526	9760	8392	7651
WIND	1544	1618	2206	1556
CPP / IPP Thermal	4719	6116	5481	6482
CPP / IPP Gas	0	0	0	0
SOLAR	2129	1103	0	0
Exchange with Mumbai	-2331	-2330	-2109	-1701
MSEDCL DEMAND MET	22643	23400	20982	21052
Load Shedding	0	0	0	0
MSEDCL DEMAND	22643	23400	20982	21052
TPCL GENERATION	685	852	801	1110
AEML GENERATION	477	459	299	432
MUMBAI DEMAND	3493	3641	3209	3243
OTHER DISCOM DEMAND	499	439	479	459
STATE DEMAND MET	26636	27480	24670	24754
STATE DEMAND	26636	27480	24670	24754
Frequency (Hz)	49.95	50.03	49.97	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 17:04 Hrs	49.82 Hz at 12:50 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.52	47.15	195	170
Unit 8	13.74	61.29	596	547
Unit 9	14.15	46.07	602	571
Unit 10	12.52	130.28	546	503
Total	44.92	284.80		
Bhusawal				
Unit 3	3.26	22.13	145	120
Unit 4	10.10	98.40	440	375
Unit 5	10.59	106.43	490	380
Total	23.96	226.96		
Parli				
Unit 6	3.44	48.03	242	0
Unit 7	4.40	48.38	244	144
Unit 8	4.01	43.29	197	144
Total	11.85	139.70		
Chandrapur				
Unit 3	3.73	26.83	170	139
Unit 4	3.65	36.64	163	127
Unit 5	0.00	0.00	0	0
Unit 6	9.14	70.99	405	320
Unit 7	9.64	93.93	422	330
Unit 8	9.12	109.57	455	177
Unit 9	10.70	112.52	497	395
Total	45.97	450.47		
Paras				
Unit 3	5.21	50.10	224	201
Unit 4	5.10	51.93	227	196
Total	10.31	102.03		
Khaparkheda				
Unit 1	3.03	29.40	140	105
Unit 2	3.15	29.38	141	117
Unit 3	4.25	30.93	186	164
Unit 4	4.25	40.84	187	165
Unit 5	11.28	107.62	475	460
Total	25.96	238.16		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	4.08	40.77	181	132
Unit 5	3.93	39.75	174	126
Total	8.01	90.61		
Uran				
All Units	4.47	50.37	199	175
Total	4.47	50.37		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	0.98	21	0
Total	0.06	0.98		
Koyna				
Stage 1-2	1.20	44.36	150	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.34	28.62	160	0
Total	1.55	154.20		
Hydro				
KDPH	0.20	3.82	9	9
VTRNA	0.96	11.10	61	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.40	3.77	80	0
SMLHY_PTN	1.91	16.53	102	72
GHATGHAR	0.00	0.19	0	0
Total	3.47	36.46		
Wind				
Total	39.37	291.25	0	0
Total	39.37	291.25		
CPP				
APML(Mus)	63.49	659.50	0	0
JSWEL(Mus)	23.79	247.72	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.13	308.48	0	0
SWPGPL-Mus	10.63	103.29	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.32	12.89	270	196
Other(Mus)	2.16	23.69	0	0
Total	136.51	1355.59		
SOLAR				
Total	15.67	160.93	0	0
Total	15.67	160.93		
Tata				
Trombay 5	8.02	83.98	420	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.97	11.30	48	35
Trombay 7B	0.87	9.42	41	33
TATA Hydro	5.59	56.02	429	75
Trombay 8	4.14	44.30	230	128
Total	19.60	205.02		
AEML				
DTPS U-1&2	9.95	89.01	486	299
Total	9.95	89.01		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	170.99	1532.73	MSPGCL Total	180.54	1774.74
			MSPGCL Thml+Gas	175.46	1583.10	Koyna 1,2 & 4 Total	1.20	125.58
			MSPGCL Hydro	5.08	191.64	State Total	401.65	3876.54

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7137	438	195	7770	1937	6508	0	0	8443	8319	-1876	22248	81	0	22329	3449	411	26188	49.99
2	7151	186	198	7536	2086	6556	0	0	8516	8368	-1682	22492	0	0	22492	3223	372	26086	49.99
3	7152	186	196	7534	1900	6468	0	0	8148	8351	-1546	22356	0	0	22356	3028	350	25734	50.02
4	7055	182	198	7434	1801	6288	0	0	8203	8646	-1529	22294	0	0	22294	2882	347	25522	50.00
5	7050	188	196	7434	1662	6146	0	0	8786	8888	-1624	22143	0	0	22143	2803	364	25310	49.99
6	7198	186	199	7582	1383	6254	0	2	9164	9569	-1604	22785	0	0	22785	2779	401	25966	50.02
7	7446	196	195	7836	1269	6121	0	184	9144	9134	-1685	22431	0	0	22431	2663	428	25522	49.97
8	7305	268	195	7768	1228	5732	0	596	8928	8736	-1828	21785	0	0	21785	2696	448	24928	50.06
9	7260	266	191	7716	1138	5272	0	1210	8936	9014	-1954	21931	0	0	21931	2848	466	25244	50.02
10	7169	252	181	7602	1078	5064	0	1734	9209	9112	-2035	22083	0	2	22083	3103	472	25658	50.03
11	6953	226	177	7356	1299	4778	0	2061	9782	9142	-2187	21974	0	2	21974	3341	476	25790	49.99
12	7230	148	177	7556	1544	4719	0	2129	9909	9526	-2331	22643	0	3	22643	3493	499	26636	49.95
13	7101	124	175	7400	1550	4877	0	2074	9691	9882	-2361	22944	0	0	22944	3510	478	26932	49.96
14	7043	124	176	7342	1438	4960	0	1927	9647	9555	-2267	22497	0	0	22497	3428	458	26384	49.96
15	7222	124	176	7522	1364	5531	0	1630	9744	9932	-2219	23308	0	0	23308	3535	451	27294	49.97
16	7272	124	176	7572	1618	6116	0	1103	9759	9760	-2330	23400	0	0	23400	3641	439	27480	50.03
17	6862	138	177	7176	2024	5359	0	655	10022	9190	-2289	21649	0	0	21649	3572	466	25688	50.06
18	7013	146	180	7340	2210	4915	0	311	9222	8792	-2409	20681	0	0	20681	3401	478	24560	50.06
19	6810	224	180	7214	2203	4788	0	53	8438	8398	-2250	19923	0	0	19923	3244	484	23650	50.01
20	7040	270	181	7490	2206	5481	0	0	8333	8392	-2109	20982	0	0	20982	3209	479	24670	49.97
21	7126	226	182	7534	1995	5760	0	0	8109	7727	-1984	20572	0	0	20572	3218	461	24250	49.98
22	7150	186	184	7520	1906	5767	0	0	7613	7795	-1690	20820	0	0	20820	3217	478	24514	50.01
23	7116	214	193	7522	1556	6482	0	0	7782	7651	-1701	21052	0	0	21052	3243	459	24754	49.98
24	7132	456	194	7782	976	6568	0	0	8185	8798	-1823	21857	0	0	21857	3340	443	25640	49.96
MUs	170.99	5.08	4.47	180.54	39.37	136.51	0.00	15.67	213.71	212.68	-47.31	526.85	0.08	0.01	526.93	76.87	10.61	614.40	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)FLS done at shirwal S/S. due to 132kv Kamthadi-phursungi line overloading.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jun/2023

Position as on 6.30 Hrs of 11/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	13/06/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Parli Unit 6	250	10/06/2023	12:04	10/06/2023	14:17	Furnace Pressure High	
MSPGCL	Parli Unit 6	250	10/06/2023	21:36	11/06/2023	06:16	Drum Level low	
MSPGCL	Paras Unit 4	250	11/06/2023	13:46		Continued.	Boiler Tube Leakage	14/06/2023
MSPGCL	Chandrapur Unit 4	210	11/06/2023	18:51		Continued.	SUSPECTED BTL AT AB-4 ELEVATION	13/06/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (414) OF PADGHE PG CKT - 1 @ KUDUS	InterState	09/06/2023	11:01	10/06/2023	19:12	PO	CT Replacement Work
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 2	InterState	11/06/2023	11:20	11/06/2023	13:41	T	Tripped from Dhule end only
DHULE - SSNNL CKT - 1	InterState	11/06/2023	11:20	11/06/2023	14:09	T	TRIPPED ON OVER VOLTAGE
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/06/2023	23:37	11/06/2023	14:58	HT	HT for load management
LONIKAND I - KOYNA STAGE-IV	IntraState	06/06/2023	21:04	10/06/2023	02:36	T	Tripped on distance protection
PADGHE - NAGOTHANE CKT - 2	IntraState	08/06/2023	13:08			PO	Work of shifting/height raising of various EHV (220/110KV) transmission lines infringing in Samruddhi crossing . 1) Erection of 5 no. of Monopple 2) Stringing of 6.nos. of spans between location nos. 310-313
KORADI - KHADKA	IntraState	10/06/2023	08:34	10/06/2023	20:00	PO	For replacement of R and B phase CVT old jump replacement work and routine bay maintenance works etc.
TBC @ PARLI	IntraState	10/06/2023	10:01	10/06/2023	12:47	PO	Bay Maintenance Work is to be carried out.
WARORA - IEPL	IntraState	10/06/2023	14:12	10/06/2023	16:30	T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	10/06/2023	16:05	10/06/2023	18:35	T	220KV BUS SECTION -1 DEAD.
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	11/06/2023	03:55	11/06/2023	06:18	PO	Pre monsoon Maintenance work
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	11/06/2023	06:56	11/06/2023	08:50	PO	Premonsoon work ,polythene wrapping on PRV,Buchhloz, & OSR.
220 KV TBC Outages/Trippings							
TBC @ ANANDNAGAR	IntraState	10/06/2023	09:45	10/06/2023	15:30	PO	For separation of common dropper jumper of 220kv PT & TBC bay & TBC bay Isolator maintenance.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							
220 KV HARANGUL - PARLY (PG) CKT	InterState	10/06/2023	17:38	10/06/2023	18:45	T	Tripped on distance protection
PANCHALI TSS - BOISAR (PG)	InterState	11/06/2023	14:47	11/06/2023	18:36	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
MAHAD - KANDALGAON	IntraState	09/06/2023	01:15	10/06/2023	15:54	PO	1. Erection of 2 nos. inline monopole 2. Stringing of 3 nos. conductor on new erected monopole. 3. Stringing of 3 nos. conductor both sides of 2 nos. erected monopole. 4. Dismantling of old conductor.
COLOURCHEM - TEMGHAR	IntraState	09/06/2023	22:32	10/06/2023	03:55	EO	To attend Hotspot on B phase jumper Cone at Line Incoming gantry near LA. Also Y phase WT jumper will be replace which looks deteriorated.
PADGHE - TEMGHAR - 2	IntraState	10/06/2023	01:54	10/06/2023	03:26	EO	For safety purpose to attend hot spot on bottom ph dead end h/w of 220 kV Colourchem 2 Temghar line at Loc. No. 39
KHARGHAR - SONKHAR	IntraState	10/06/2023	04:09	10/06/2023	08:26	EO	1] Attending hotspot on 1.R phase wavetrap top jumper (line side)(99degC) 2.Y phase dead end clamp on line side (97degC) 2] Taking IR values of LAs due to increasing LCM values of B phase LA 3] Diagnostic testing & RM work
GADCHANDUR - VIRUR-I	IntraState	10/06/2023	09:10	10/06/2023	11:50	HT	For diagnostic testing work.
EKLAHARA(OCR)-RAYMOND	IntraState	10/06/2023	09:12	10/06/2023	17:21	PO	1. Attending red hot on B ph wave trap bottom side by replacement of existing jump along with Nut bolt and bay maintenance. 2. Attending red hot on B ph CT line side by replacement of Nut bolt 3. Diagnostic testing of breaker and CTs. & Premonson maintenance.
HINJAWADI I- CHINCHWAD	IntraState	10/06/2023	09:45	10/06/2023	19:20	PO	1) Fixing of earthwire MS joint at loc no-172-173 2) Pilot string jump replacement at loc no-179(B ph)
BUTIBORI 3- VIPL CKT I	IntraState	10/06/2023	15:30	10/06/2023	18:21	HT	Eavy spark seen on metering r ph pt side jumper which was open and in hanging position.
220 KV GIRWALI (400 KV) -PARLI U -8 CKT	IntraState	10/06/2023	16:05	10/06/2023	18:22	T	220Kv bus section dead.
MAHAD-KALAMBANI(TSS)	IntraState	10/06/2023	19:32			PO	1) Erection of 06 nos cross-arm on 02 nos monopole. 2) Stringing of 03 nos conductor on new erected monopole. 3) Stringing of 03 nos conductor both sides of 02 nos erected monopole. 4) Dismantling of old conductor and tower (02 nos)
CHAKAN - CHINCHWAD 2	IntraState	11/06/2023	10:26	11/06/2023	18:06	PO	1) Stringing of earth wire between loc no-23-25. 2) Replacement of damaged coductor at loc at loc no-20-21 (B ph).

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GHATGHAR - BAPGAON	IntraState	11/06/2023	14:26	11/06/2023	15:19	T	Tripped on distance protection
GORAI -MSETCL BORIVALI CKT -2	IntraState	11/06/2023	14:47	11/06/2023	16:00	T	Bus fault at Borivali s/s due to bad weather
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	11/06/2023	14:47	11/06/2023	16:02	T	Bus fault at Borivali s/s due to bad weather
KHARGHAR - BORIVALI CKT - 2	IntraState	11/06/2023	14:47	11/06/2023	16:54	T	Bus fault at Borivali s/s due to bad whether
BORIVALI - TARAPUR	IntraState	11/06/2023	14:47		Continued.	T	Bus fault at Borivali s/s due to bad whether
GIS BHANDUP - BORIVALI	IntraState	11/06/2023	14:47	11/06/2023	15:28	T	Bus fault at Borivali s/s due to bad whether
AEML BORIVALI -MSETCL BORIVALI CKT -2	IntraState	11/06/2023	14:47	11/06/2023	15:58	T	Bus fault at Borivali s/s due to bad weather
AAREY - MSETCL BORIVALI CKT - 2	IntraState	11/06/2023	14:47	11/06/2023	15:59	T	Bus fault at Borivali s/s due to bad weather
BORIVALI - BOISAR (PG)	IntraState	11/06/2023	14:47	11/06/2023	22:27	T	Bus fault at Borivali s/s due to bad weather
WAGHIVALI - DHARAVI 7	IntraState	11/06/2023	15:06	11/06/2023	20:00	PO	FOR INSULATOR REPLACEMENT
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	10/06/2023	05:43	10/06/2023	08:30	PO	PM CHECKS
220/110 KV 155MVA ICT-2@ BHIRA (T)-220 KV	IntraState	10/06/2023	08:50	10/06/2023	12:51	PO	PM CHECKS
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	10/06/2023	09:36	10/06/2023	16:45	PO	For Pre-monsoon maintenance work on 100MVA, 220/100KV ICT
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	10/06/2023	10:00	10/06/2023	17:46	PO	1. Diagnostic testing of Bushings, Windings, Breaker and CTs. & Premonson maintence. 2. Attending red hot and replacement of Nut bolts.
220/132KV 200 MVA ICT 2	IntraState	10/06/2023	10:20	10/06/2023	11:19	HT	For premansoon maint. work.
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	IntraState	10/06/2023	10:22	10/06/2023	16:47	PO	Quarterly Maint and pre monsoon maint. work.
220/132 100MVA ICT-1 @ AMRAPUR	IntraState	10/06/2023	11:08	10/06/2023	14:31	PO	Diagnostic testing work
220/132KV 200 MVA ICT 2	IntraState	10/06/2023	11:32	10/06/2023	12:20	HT	For premansoon maint. work.
220/132 100MVA ICT-2 @ AMRAPUR	IntraState	10/06/2023	14:59	10/06/2023	18:38	PO	Diagnostic testing work
220/132 KV 200 MVA ICT 2 @ AMALNER	IntraState	10/06/2023	19:05	10/06/2023	20:50	HT	Replacement of HV R PH LA.
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	11/06/2023	14:47	11/06/2023	16:09	T	Bus fault at Borivali s/s due to bad weather
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ ANANDNAGAR	IntraState	10/06/2023	09:45	10/06/2023	15:35	PO	For separation of common dropper jumper of 220kV PT & TBC bay & TBC bay Isolator maintenance.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	11/06/2023	09:44	11/06/2023	13:53	PO	repair sleeve compression on C Ph conductor in span 28-29

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 11/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA KALYAN	IntraState	11/06/2023	21:56		Continued.	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)
110 KV BUSBAR Outages/Trippings							
ZONE 2 (BUS SECTION 2&3) @ KHOPOLI	IntraState	11/06/2023	07:30	11/06/2023	14:20	PO	R/M AND TESTING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage