

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jul/2015 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	89.155	987.836	1) Gujrat	2.406	40.291
2) Hydro	4.924	70.134	2) Madhya Pradesh	15.116	145.686
3) Gas	6.513	64.878	3) Chattisgarh	5.440	55.230
Total MSPGCL	100.592	1122.848	4) Maharashtra Net	94.597	936.059
B) 1) APML	57.870	541.210	5) Goa	-6.852	-68.482
2) JSWEL	18.655	184.158	6) TAPS 1&2 Injection	2.874	28.874
3) VIPL	13.120	119.908	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	15.216	152.804	8) Pench (MS)	0.071	1.528
5) WPCL	2.794	30.956	9) Pench (Excess)	-0.071	-1.270
6) Other IPP	4.306	39.479	Total	113.510	1136.388
C) 1) TPCL Thermal	17.651	163.040	a) Mumbai Schedule	31.318	275.135
2) TPCL Hydro	3.583	36.070	b) Mumbai Drawl	30.938	288.620
3) TPCL Gas	4.463	34.340	c) MSEDCL Bilateral *	32.252	307.258
4) R-INFRA Thermal	7.473	105.766	Include PX	8.102	49.018
D) STATE			d) Mumbai Bilateral *	29.218	271.353
1) Thermal	226.240	2325.157	Include PX	3.827	31.374
(A1+C1+C4+(B1-B6))			Include Standby	2.100	3.783
2) Hydro	8.507	106.204	H) ENERGY CATERED (MUs)		
3) Gas	10.976	99.218	1) MSEDCL	340.601	3443.120
4) Wind	44.669	393.336	2) Mumbai Discoms	64.108	627.834
6) SOLAR	0.807	10.653	TOTAL STATE	404.709	4070.954
TOTAL STATE	291.199	2934.568			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	3754	3722	3784	3628
MSPGCL Hydro	162	59	178	224
MSPGCL Gas	279	277	265	268
MSPGCL Total Generation	4195	4058	4227	4120
Central Sector Receipt	5445	5676	4396	4207
WIND	1948	2028	1748	1718
CPP / IPP	4752	4686	4702	4580
SOLAR	111	140	0	0
Exchange with Mumbai	-1668	-1646	-1387	-1333
MSEDCL DEMAND MET	14783	14942	13686	13292
Load Shedding	46	32	36	36
MSEDCL DEMAND	14829	14974	13722	13328
TPCL GENERATION	1231	1229	1109	956
R-INFRA GENERATION	258	258	258	259
MUMBAI DEMAND	3157	3133	2754	2548
STATE DEMAND MET	17940	18075	16440	15840
STATE DEMAND	17986	18107	16476	15876
Frequency (Hz)	50.00	49.98	49.84	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.24 Hz at 18.05 Hrs	49.68 Hz at 19.37 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 10/Jul/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	17.13	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.76	24.17	172	135
Total	3.76	41.30		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	4.08	40.94	180	160
Unit 4	0.00	73.37	0	0
Unit 5	11.03	77.13	495	375
Total	15.11	191.44		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.18	0	0
Unit 5	0.00	19.87	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	37.92	0	0
Total	0.00	57.96		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.52	34.52	152	141
Unit 3	4.23	42.63	199	145
Unit 4	3.95	41.21	175	146
Unit 5	8.72	91.81	385	325
Unit 6	0.00	0.00	0	0
Unit 7	8.81	86.54	407	326
Total	29.22	296.70		
Paras				
Unit 3	5.29	51.10	250	199
Unit 4	5.18	50.36	250	191
Total	10.48	101.46		
Khaparkheda				
Unit 1	3.28	37.01	155	105
Unit 2	3.92	37.84	185	130
Unit 3	4.41	39.08	200	165
Unit 4	0.00	0.00	0	0
Unit 5	9.62	101.78	440	330
Total	21.22	215.70		
Nasik				
Unit 3	4.72	46.58	205	185
Unit 4	4.63	36.68	199	185
Unit 5	0.00	0.00	0	0
Total	9.36	83.26		
Uran				
All Units	6.51	64.88	280	264
Total	6.51	64.88		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.07	1.53	20	0
Total	0.07	1.53		
Koyna				
Stage 1-2	2.80	33.36	485	40
Stage 4	0.78	13.77	445	0
Stage 3	0.44	10.97	80	0
Total	4.02	58.10		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.20	0.37	64	0
BHTGR/VEER	0.09	0.45	4	3
BHIRA T.R.	0.13	2.10	80	0
RNGR+BHTSA	0.23	1.28	10	9
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.06	1.08	8	0
GHATGHAR	0.19	6.75	125	0
Total	0.90	12.03		
Wind				
Total	44.67	393.34	0	0
Total	44.67	393.34		
CPP				
APML(Mus)	57.87	541.21	0	0
JSWEL(Mus)	18.66	184.16	0	0
VIPL(Mus)	13.12	119.91	0	0
RPLAMT(Mus)	15.22	152.80	0	0
WPCL(Mus)	2.79	30.96	0	0
Other(Mus)	4.31	39.48	0	0
Total	111.96	1068.52		
SOLAR				
Total	0.81	10.65	0	0
Total	0.81	10.65		
Tata				
Trombay 5	11.68	106.00	492	466
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.84	20.74	127	88
Trombay 7B	1.62	13.60	70	59
Trombay 8	5.97	57.04	250	247
TATA Hydro	3.58	36.07	306	0
Total	25.70	233.45		
R-INFRA				
1-2	7.47	105.77	518	257
Total	7.47	105.77		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	89.16	987.84
MSPGCL Thml+Gas	95.67	1052.71

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	4.92	70.13
MSPGCL Total	100.59	1122.85

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	3.58	47.13
State Total	291.20	2934.57

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Jul/2015

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	3635	177	270	4082	1768	4661	0	4392	4719	-998	14232	53	14285	2446	16731	49.95
2	3677	52	271	4000	1801	4614	0	4325	4276	-797	13894	40	13934	2239	16173	49.94
3	3720	53	270	4043	1860	4489	0	4120	4065	-671	13786	40	13826	2110	15936	49.95
4	3729	53	271	4053	1836	4692	0	4114	3851	-580	13852	40	13892	2018	15910	49.95
5	3633	68	271	3972	1767	4434	0	4127	4267	-591	13849	40	13889	1995	15884	49.97
6	3669	401	271	4341	1743	4442	0	4201	4685	-933	14278	45	14323	2063	16386	50.03
7	3751	1067	271	5089	1678	4530	9	4707	4845	-756	15395	45	15440	2121	17561	50.00
8	3768	590	271	4629	1737	4691	30	5255	5169	-1050	15206	45	15251	2250	17501	50.01
9	3797	226	270	4293	1960	4784	55	5629	5618	-1326	15384	48	15432	2542	17974	49.98
10	3821	332	278	4431	1921	4667	78	5322	5291	-1510	14878	48	14926	2948	17874	49.97
11	3754	162	279	4195	1948	4752	111	5518	5445	-1668	14783	46	14829	3157	17986	50.00
12	3687	62	280	4029	2143	4702	107	5458	5440	-1722	14699	44	14743	3208	17951	49.98
13	3749	64	280	4093	2095	4753	115	5069	5350	-1704	14702	44	14746	3191	17937	50.01
14	3741	54	277	4072	2099	4684	130	5086	5319	-1588	14716	32	14748	3073	17821	50.05
15	3722	59	277	4058	2028	4686	140	5211	5676	-1646	14942	32	14974	3133	18107	49.98
16	3696	54	271	4021	1960	4830	101	5321	5096	-1669	14339	32	14371	3153	17524	49.95
17	3704	114	264	4082	1968	4699	80	5152	5032	-1635	14226	32	14258	3122	17380	49.93
18	3729	83	269	4081	1852	4808	41	4276	4017	-1584	13215	32	13247	3051	16298	49.98
19	3664	268	269	4201	1871	4706	6	3866	3347	-1604	12527	36	12563	2895	15458	49.98
20	3728	450	267	4445	1722	4755	0	4346	3898	-1439	13381	36	13417	2844	16261	49.87
21	3784	178	265	4227	1748	4702	0	4892	4396	-1387	13686	36	13722	2754	16476	49.84
22	3753	69	265	4087	1703	4596	0	4656	4575	-1410	13551	36	13587	2657	16244	49.90
23	3616	64	268	3948	1743	4704	0	4558	4926	-1337	13984	36	14020	2590	16610	49.94
24	3628	224	268	4120	1718	4580	0	4490	4207	-1333	13292	36	13328	2548	15876	49.97
MUs	89.16	4.92	6.51	100.59	44.67	111.96	1.00	114.09	113.51	-30.94	340.80	0.95	341.75	64.11	405.86	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jul/2015

Position as on 6.30 Hrs of 11/Jul/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling work	
MSPGCL	Chandrapur Unit 6	500	09/06/2015	23.58		Continued.	COH	
MSPGCL	Khaparkheda Unit 4	210	19/06/2015	23.57		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 5	210	30/06/2015	23.50		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn	
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22		Continued.	BLR Tripped.	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem	
TPC-G	Trombay 6	500	05/06/2015	05.59		Continued.	Economic Shutdown.	
TPC-G	Bhira PSU	150	09/06/2015	10.53		Continued.	Stator Earth Fault	
MSPGCL	Koyna STG- IV Unit - 1	250	09/06/2015	14.22		Continued.	Excitation T/F Burst	
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/06/2015	00.00	11/07/2015	10.54	No Schdule	
IPP	WPCL U-2	135	16/06/2015	00.00		Continued.	No Schdule	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
IPP	JSW (J) U1	300	29/06/2015	13.32		Continued.	Turbine bearing Vabration high	
IPP	Adani U-3	660	04/07/2015	15:03		Continued.	Super heater drain leakage.	
IPP	WPCL U-3	135	04/07/2015	17:45		Continued.	Not schdule.	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jul/2015

Position as on 6.30 Hrs of 11/Jul/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-1	270	06/07/2015	00.37		Continued.	Furnace Pressure High	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
MSPGCL	Bhusawal Unit 4	500	08/07/2015	15.15	11/07/2015	07.23	Boiler Tube Leakage	
MSPGCL	Koradi Unit 5	200	09/07/2015	19.19		Continued.	ID Fan Problem	
RINFRA-G	REL Unit 1	250	10/07/2015	04.57		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 4	210	11/07/2015	03.47	11/07/2015	07.58	Turbine tripped	
MSPGCL	Chandrapur Unit 5	500	11/07/2015	04.43		Continued.	Boiler Tube Leakage	
CPP	WPCL U-4	135	11/07/2015	06.58		Continued.	ID Fan Vibration High	
IPP	RPL(AMT) U-3	270	11/07/2015	08.30	11/07/2015	15.38	Turbine Problem.	
MSPGCL	Koradi Unit 7	210	11/07/2015	08.50	11/07/2015	11.02	Flame Failure	
IPP	RPL(AMT) U-4	270	11/07/2015	09.12	11/07/2015	20.15	Turbine Problem.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jul/2015

Statement-VII

Position as on 6.30 Hrs of 11/Jul/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Raichur(PG)-Solapur(PG)- II	InterState	11/07/2015	00.28	11/07/2015	21.03	PO	Routine Maintenance Work
400 KV LINE Outages/Trippings							
Dabhol Nagothane I	InterState	30/06/2015	16.53		Continued.	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	09/07/2015	17.39	11/07/2015	08.39	HT	Over Voltage
Kolhapur Mapusa I	InterState	09/07/2015	19.10	10/07/2015	07.26	HT	Over Voltage
Akola Wardha I	InterState	10/07/2015	12.42	10/07/2015	19.39	PO	Isolator maintenance work
Kolhapur Mapusa II	InterState	10/07/2015	16.35	11/07/2015	08.53	HT	Over Voltage
Kolhapur Mapusa I	InterState	11/07/2015	17.05		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	11/07/2015	17.13	11/07/2015	23.07	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	11/07/2015	23.07		Continued.	HT	Over Voltage
Akola II - Taptitanda ckt-I	IntraState	20/05/2015	08.59		Continued.	HT	Ckt I and Ckt 2 new charged to control BBLR ICT loading.
karad -kolhapur-II	IntraState	09/07/2015	16.43	10/07/2015	07.15	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	09/07/2015	17.16	10/07/2015	06.50	HT	Over Voltage
Babhaleshwar-Taptitanda ckt-I	IntraState	09/07/2015	17.30		Continued.	HT	To control Line Loading of Padghe -BBLR D/C.
Deepnagar Taptitanda	IntraState	10/07/2015	09.13	10/07/2015	20.21	PO	Line Maintenance work
karad -kolhapur-I	IntraState	10/07/2015	16.41	11/07/2015	10.55	HT	Over Voltage
Karad-Jaigad - I	IntraState	10/07/2015	16.51	11/07/2015	08.37	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	10/07/2015	20.30	11/07/2015	06.47	HT	Over Voltage
Dhule- Bableswhar - I	IntraState	11/07/2015	07.28	11/07/2015	20.19	PO	A/R Out.
Dhule - Bableswhar - li	IntraState	11/07/2015	07.28	11/07/2015	20.19	PO	A/R Out.
Padghe - Talegaon (PG)	IntraState	11/07/2015	08.12	11/07/2015	18.50	PO	A/R Out.
Dhule- Bableswhar - I	IntraState	11/07/2015	12.27	11/07/2015	14.37	T	Distance Protection B Phase.
karad -kolhapur-I	IntraState	11/07/2015	16.35		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	11/07/2015	16.38		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	11/07/2015	21.04	11/07/2015	22.36	T	Distance Protection B Ph E/F.
Bhusawal-Aurangabad	IntraState	11/07/2015	21.26		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva Ict 1 @Dhule	IntraState	04/07/2015	14.32		Continued.	PO	Commissioning Of Spare ICT In Place Of R-Ph Unit.
400/220/33 Kv 315 MVA ICT II @Babhleshwar	IntraState	11/07/2015	17.19	11/07/2015	20.35	PO	Maintenanace Work @ LV Side.
220 KV LINE Outages/Trippings							
Borivali - Tarapur	InterState	11/07/2015	07.00	11/07/2015	07.30	PO	Taken on TBC.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Boisar Versova Line	IntraState	05/07/2015	08.08		Continued.	PO	Making LILO for 220KV Viraj S/S
Dahanu-Viraj	IntraState	05/07/2015	08.32		Continued.	PO	Making LILO for 220KV Viraj S/S
Boisar-Viraj	IntraState	05/07/2015	08.32		Continued.	PO	Making LILO for 220KV Viraj S/S
Ghatghar - Jindal	IntraState	10/07/2015	09.46	10/07/2015	13.27	PO	Insulator Replacement Work
Talegaon (Ambi)-General Motors	IntraState	10/07/2015	11.30	10/07/2015	12.55	T	Bus Bar operated at Talegaon end only
Urse - Talegaon (Ambi) Ckt 1	IntraState	10/07/2015	11.30	10/07/2015	14.20	T	Bur Bar Prot.operated at

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jul/2015

Statement-VII

Position as on 6.30 Hrs of 11/Jul/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Talegaon end
Mahape - Tfipl	IntraState	10/07/2015	13.04	10/07/2015	13.49	EO	Removing Bird Nest on Bus section bay gantry
Parli New Tps - Beed Ckt 2	IntraState	10/07/2015	13.05	10/07/2015	13.08	T	Bus Bar Prot.operated during TBC Trial
Nanded - Parli Ext. Ckt I	IntraState	10/07/2015	13.05	10/07/2015	13.09	T	Bus Bar Prot.operated during TBC Trial
Parli 3(Old Gcr)-Parli Newtps Ckt 1	IntraState	10/07/2015	13.05	10/07/2015	13.07	T	Bus Bar Prot.operated during TBC Trial
REL Borivali TPC Borivali line	IntraState	10/07/2015	16.22		Continued.	T	Distance Protection
Nashik-Padgha	IntraState	11/07/2015	07.26	11/07/2015	17.43	PO	A/R Out.
New Koyna - Loteparshuram	IntraState	11/07/2015	09.32	11/07/2015	15.13	PO	Hot Spot Attended @ Wavetrap.
Aurangabad (Waluj)-Bhenda	IntraState	11/07/2015	10.18	11/07/2015	13.30	PO	R.M.Work.
Virur - Virur Rly Tss 2	IntraState	11/07/2015	11.15	11/07/2015	12.28	PO	To Carry Out Half Yearly Maint.Schedule of DP Isolator @ TSS End.
Bableshtar- Alephata	IntraState	11/07/2015	23.34		Continued.	HT	Babaleshtar ICT Over Loading.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Internal Fault
220/100 kv 200 MVA ICT II @Padghe	IntraState	10/07/2015	10.14	10/07/2015	19.40	PO	R Phase CT replacement work
220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded	IntraState	11/07/2015	08.19	11/07/2015	10.03	PO	Attending Hot Spot on Y Ph CT Clamp.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage