

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 10/Jul/2020 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 104.134        | 961.326         | 1) Gujrat                      | 4.330          | 46.097          |
| 2) Hydro            | 5.669          | 71.152          | 2) Madhya Pradesh              | 10.554         | 100.273         |
| 3) Gas              | 2.816          | 29.295          | 3) Chattisgarh                 | 6.000          | 52.000          |
| <b>Total MSPGCL</b> | <b>112.619</b> | <b>1061.773</b> | 4) Maharashtra                 | 113.253        | 1161.295        |
| B) 1) APML          | 27.387         | 278.016         | 5) Goa (Amona)                 | 0.000          | -1.892          |
| 2) JSWEL            | 17.210         | 171.197         | <b>Total</b>                   | <b>134.137</b> | <b>1357.773</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 26.558         | 256.542         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 28.347         | 252.339         |
| 5) WPCL             | 7.511          | 55.842          | c) MSEDCL Bilateral *          | 30.431         | 322.490         |
| 6) Other IPP        | 6.921          | 70.437          | Include PX                     | 6.102          | 55.624          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 26.558         | 256.542         |
| C) 1) TPCL Thermal  | 7.164          | 76.041          | Include PX                     | 17.777         | 167.416         |
| 2) TPCL Hydro       | 5.724          | 45.954          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.478          | 37.312          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 4.542          | 47.217          | 1) MSEDCL                      | 315.387        | 3175.922        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 48.255         | 458.863         |
| 1) Thermal          | 174.869        | 1660.076        | <b>TOTAL STATE</b>             | <b>363.642</b> | <b>3634.785</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 11.393         | 117.106         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 5.294          | 66.607          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 32.662         | 378.516         |                                |                |                 |
| 6) SOLAR            | 5.287          | 54.707          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>229.505</b> | <b>2277.012</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4274                      | 4253                  | 4340                      | 4218                      |
| MSPGCL Hydro             | 291                       | 222                   | 309                       | 185                       |
| MSPGCL Gas               | 116                       | 114                   | 116                       | 117                       |
| MSPGCL Total Generation  | 4681                      | 4589                  | 4765                      | 4520                      |
| Central Sector Receipt   | 6423                      | 6020                  | 5715                      | 4976                      |
| WIND                     | 1330                      | 1355                  | 1616                      | 996                       |
| CPP / IPP Thermal        | 2591                      | 2464                  | 2408                      | 2172                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 486                       | 682                   | 0                         | 0                         |
| Exchange with Mumbai     | -1277                     | -1479                 | -1040                     | -983                      |
| <b>MSEDCL DEMAND MET</b> | <b>14234</b>              | <b>13631</b>          | <b>13464</b>              | <b>11681</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14234                     | 13631                 | 13464                     | 11681                     |
| TPCL GENERATION          | 681                       | 697                   | 804                       | 477                       |
| AEML GENERATION          | 190                       | 190                   | 189                       | 189                       |
| <b>MUMBAI DEMAND</b>     | <b>2148</b>               | <b>2366</b>           | <b>2033</b>               | <b>1649</b>               |
| STATE DEMAND MET         | 16382                     | 15997                 | 15497                     | 13330                     |
| <b>STATE DEMAND</b>      | <b>16382</b>              | <b>15997</b>          | <b>15497</b>              | <b>13330</b>              |
| Frequency (Hz)           | 50.02                     | 50.02                 | 49.95                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 13.02 Hrs | 49.82 Hz at 16.50 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 10/Jul/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 11.12        | 106.67        | 465      | 460      |
| Unit 10            | 10.43        | 101.63        | 460      | 375      |
| <b>Total</b>       | <b>21.55</b> | <b>208.30</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.99         | 26.77         | 175      | 153      |
| Unit 4             | 3.85         | 35.47         | 163      | 160      |
| Unit 5             | 8.70         | 89.59         | 385      | 336      |
| Unit 6             | 9.09         | 67.53         | 450      | 355      |
| Unit 7             | 8.56         | 90.88         | 375      | 342      |
| Unit 8             | 9.26         | 95.68         | 445      | 360      |
| Unit 9             | 9.15         | 67.08         | 435      | 360      |
| <b>Total</b>       | <b>52.60</b> | <b>473.01</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.50         | 46.14         | 220      | 163      |
| Unit 4             | 4.61         | 47.79         | 231      | 181      |
| <b>Total</b>       | <b>9.12</b>  | <b>93.93</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.50         | 35.32         | 155      | 125      |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 3.92         | 35.25         | 180      | 158      |
| Unit 4             | 3.96         | 40.89         | 190      | 162      |
| Unit 5             | 9.49         | 74.63         | 460      | 360      |
| <b>Total</b>       | <b>20.87</b> | <b>186.08</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 2.82         | 29.30         | 129      | 105      |
| <b>Total</b>       | <b>2.82</b>  | <b>29.30</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.12         | 1.04          | 36       | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.12</b>  | <b>1.04</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 1.85         | 26.82         | 340      | 40       |
| Stage 4         | 0.75         | 9.25          | 500      | 0        |
| Stage 3         | 1.60         | 14.80         | 80       | 0        |
| <b>Total</b>    | <b>4.20</b>  | <b>50.86</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.74         | 6.86          | 31       | 31       |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 0.00         | 7.29          | 0        | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.46         | 3.29          | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 0.63          | 0        | 0        |
| BHANDARDRA      | 0.07         | 0.52          | 18       | 0        |
| ELDARY          | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.20         | 1.70          | 9        | 8        |
| GHATGHAR        | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>1.47</b>  | <b>20.29</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 32.66        | 378.52        | 0        | 0        |
| <b>Total</b>    | <b>32.66</b> | <b>378.52</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 27.39        | 278.02        | 0        | 0        |
| JSWEL(Mus)      | 17.21        | 171.20        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 7.51         | 55.84         | 0        | 0        |
| Other(Mus)      | 6.92         | 70.44         | 0        | 0        |
| <b>Total</b>    | <b>59.03</b> | <b>575.49</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 5.29         | 54.71         | 0        | 0        |
| <b>Total</b>    | <b>5.29</b>  | <b>54.71</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 7.16         | 76.04         | 302      | 294      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 1.39         | 23.15         | 67       | 49       |
| Trombay 7B      | 1.09         | 14.16         | 50       | 39       |
| Trombay 8       | 0.00         | 0.00          | 0        | 0        |
| TATA Hydro      | 5.72         | 45.95         | 415      | 66       |
| <b>Total</b>    | <b>15.37</b> | <b>159.31</b> |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 4.54         | 47.22         | 190      | 188      |
| <b>Total</b>    | <b>4.54</b>  | <b>47.22</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 104.13      | 961.33        | MSPGCL Total        | 112.62      | 1061.77       |
|                |             |         | MSPGCL Thml+Gas | 106.95      | 990.62        | Koyna 1,2 & 4 Total | 2.60        | 36.06         |
|                |             |         | MSPGCL Hydro    | 5.67        | 71.15         | State Total         | 229.50      | 2277.01       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 10/Jul/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4184        | 175  | 119  | 4478   | 1089  | 2473      | 0    | 0     | 5422        | 5306        | -1212                | 12134                 | 0                    | 12134                     | 1911             | 14045           | 50.01         |
| 2                  | 4152        | 175  | 120  | 4447   | 1183  | 2290      | 0    | 0     | 5252        | 5198        | -1114                | 12004                 | 0                    | 12004                     | 1795             | 13799           | 50.02         |
| 3                  | 4195        | 175  | 128  | 4498   | 1089  | 2190      | 0    | 0     | 5182        | 4891        | -1051                | 11617                 | 0                    | 11617                     | 1715             | 13332           | 50.01         |
| 4                  | 4218        | 185  | 117  | 4520   | 996   | 2172      | 0    | 0     | 4869        | 4976        | -983                 | 11681                 | 0                    | 11681                     | 1649             | 13330           | 49.99         |
| 5                  | 4456        | 165  | 117  | 4738   | 1050  | 2311      | 0    | 0     | 5059        | 5226        | -950                 | 12375                 | 0                    | 12375                     | 1620             | 13995           | 50.00         |
| 6                  | 4646        | 164  | 116  | 4926   | 1207  | 2632      | 0    | 0     | 5482        | 5258        | -943                 | 13080                 | 0                    | 13080                     | 1640             | 14720           | 50.00         |
| 7                  | 4501        | 179  | 117  | 4797   | 1074  | 2640      | 0    | 27    | 6348        | 6281        | -900                 | 13919                 | 0                    | 13919                     | 1652             | 15571           | 49.99         |
| 8                  | 4440        | 157  | 117  | 4714   | 1106  | 2605      | 0    | 130   | 6685        | 6493        | -1017                | 14031                 | 0                    | 14031                     | 1749             | 15780           | 50.00         |
| 9                  | 4438        | 129  | 116  | 4683   | 1181  | 2607      | 0    | 279   | 6682        | 6857        | -1193                | 14414                 | 0                    | 14414                     | 1941             | 16355           | 49.98         |
| 10                 | 4274        | 291  | 116  | 4681   | 1330  | 2591      | 0    | 486   | 6423        | 6423        | -1277                | 14234                 | 0                    | 14234                     | 2148             | 16382           | 50.02         |
| 11                 | 4252        | 222  | 115  | 4589   | 1223  | 2534      | 0    | 534   | 6294        | 6309        | -1362                | 13827                 | 0                    | 13827                     | 2292             | 16119           | 50.00         |
| 12                 | 4267        | 277  | 115  | 4659   | 1275  | 2500      | 0    | 656   | 6254        | 6229        | -1494                | 13825                 | 0                    | 13825                     | 2371             | 16196           | 49.99         |
| 13                 | 4253        | 222  | 114  | 4589   | 1355  | 2464      | 0    | 682   | 6148        | 6020        | -1479                | 13631                 | 0                    | 13631                     | 2366             | 15997           | 50.02         |
| 14                 | 4264        | 224  | 116  | 4604   | 1388  | 2294      | 0    | 680   | 6022        | 5985        | -1487                | 13464                 | 0                    | 13464                     | 2320             | 15784           | 50.07         |
| 15                 | 4266        | 204  | 114  | 4584   | 1877  | 2167      | 0    | 678   | 6022        | 5352        | -1449                | 13209                 | 0                    | 13209                     | 2311             | 15520           | 50.04         |
| 16                 | 4263        | 214  | 105  | 4582   | 1981  | 2087      | 0    | 524   | 5614        | 5267        | -1346                | 13095                 | 0                    | 13095                     | 2267             | 15362           | 50.02         |
| 17                 | 4253        | 999  | 115  | 5367   | 1841  | 2150      | 0    | 370   | 4789        | 4841        | -1242                | 13327                 | 0                    | 13327                     | 2192             | 15519           | 49.99         |
| 18                 | 4210        | 432  | 116  | 4758   | 1919  | 2335      | 0    | 182   | 5084        | 5210        | -1286                | 13118                 | 0                    | 13118                     | 2076             | 15194           | 50.01         |
| 19                 | 4224        | 159  | 116  | 4499   | 1709  | 2344      | 0    | 57    | 5398        | 5423        | -1170                | 12862                 | 0                    | 12862                     | 1987             | 14849           | 49.99         |
| 20                 | 4340        | 309  | 116  | 4765   | 1616  | 2408      | 0    | 0     | 5952        | 5715        | -1040                | 13464                 | 0                    | 13464                     | 2033             | 15497           | 49.95         |
| 21                 | 4627        | 207  | 129  | 4963   | 1530  | 2753      | 0    | 0     | 5556        | 5204        | -1036                | 13414                 | 0                    | 13414                     | 2058             | 15472           | 50.03         |
| 22                 | 4510        | 196  | 120  | 4826   | 1374  | 2832      | 0    | 0     | 5065        | 5273        | -1062                | 13243                 | 0                    | 13243                     | 2045             | 15288           | 50.03         |
| 23                 | 4474        | 90   | 121  | 4685   | 1171  | 2853      | 0    | 0     | 4836        | 5285        | -1098                | 12896                 | 0                    | 12896                     | 2055             | 14951           | 50.02         |
| 24                 | 4427        | 119  | 121  | 4667   | 1098  | 2797      | 0    | 0     | 4944        | 5115        | -1156                | 12521                 | 0                    | 12521                     | 2062             | 14583           | 50.07         |
| MUs                | 104.13      | 5.67 | 2.82 | 112.62 | 32.66 | 59.03     | 0.00 | 5.29  | 135.38      | 134.14      | -28.35               | 315.39                | 0.00                 | 315.39                    | 48.25            | 363.64          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 10/Jul/2020**

**Position as on 6.30 Hrs of 11/Jul/2020**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| MSPGCL                | Koyna STG-IV Unit-2     | 250      | 02/07/2020   | 09.00        |           | Continued. | Annual Overhaul                                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                             |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                   | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                   | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                   | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |           | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 18/02/2020   | 00.25        |           | Continued. | Severe Hunting In Hydro Conduit Across MIV                                                  |               |
| MSPGCL                | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |           | Continued. | Gas shortage                                                                                |               |
| IPP                   | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 09/03/2020   | 10:50        |           | Continued. | Expansion joint leakage.                                                                    |               |
| IPP                   | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Parli Unit 6            | 250      | 21/03/2020   | 17.31        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Nasik Unit 4            | 210      | 25/03/2020   | 19.45        |           | Continued. | Reserve Shut Down.(Converted zero schedule from 25.03.2020)                                 |               |
| MSPGCL                | Uran Unit 5             | 108      | 06/04/2020   | 13.23        |           | Continued. | Gas shortage                                                                                |               |
| TPC_G                 | Trombay 8               | 250      | 11/04/2020   | 16.55        |           | Continued. | Zero Schedule.                                                                              |               |
| IPP                   | JSW (J) U3              | 300      | 30/04/2020   | 15.13        |           | Continued. | No Schedule                                                                                 |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/05/2020   | 19.34        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL                | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL                | Koradi Unit-8           | 660      | 31/05/2020   | 22.56        |           | Continued. | Heavy steam Leakage in super heater.(Converted in                                           |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 10/Jul/2020**

**Position as on 6.30 Hrs of 11/Jul/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                         | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------------------------------|---------------|
|                    |                         |          |              |              |           |            | To Zero schedule w.e.f 03.06.2020 01.28) |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 01/06/2020   | 07.16        |           | Continued. | Zero Schedule By MSEDCL                  |               |
| MSPGCL             | Bhusawal Unit 5         | 500      | 01/06/2020   | 12.21        |           | Continued. | Zero schedule By MSEDCL                  |               |
| MSPGCL             | Parli Unit 8            | 250      | 01/06/2020   | 13.13        |           | Continued. | Zero schedule By MSEDCL                  |               |
| IPP                | Adani U-1               | 660      | 03/06/2020   | 15.02        |           | Continued. | Converted zero schedule from 03.06.2020  |               |
| IPP                | Adani U-5               | 660      | 04/06/2020   | 12.29        |           | Continued. | Zero Schedule.                           |               |
| IPP                | Adani U-4               | 660      | 12/06/2020   | 10.30        |           | Continued. | Zero Schedule                            |               |
| MSPGCL             | Khaparkheda Unit 2      | 210      | 24/06/2020   | 11.34        |           | Continued. | Generator Earth Fault                    |               |
| AEML               | AEML Unit 1             | 250      | 27/06/2020   | 23.55        |           | Continued. | Zero schedule.                           |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 10/Jul/2020**

**Statement-VII**

**Position as on 6.30 Hrs of 11/Jul/2020**

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                            |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                             |
| Karad Solapur (PG)                      | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                    |
| Dhule Sar'Sarovar II                    | InterState                | 03/07/2020   | 13.54        |            | Continued. | T           | Distance Protection (RFC 23.10).                                                                            |
| Chandrapur Bhadravati II                | InterState                | 04/07/2020   | 21.02        | 10/07/2020 | 07.00      | HT          | Over Voltage                                                                                                |
| Dabhol Nagothane II                     | InterState                | 11/07/2020   | 02.38        | 11/07/2020 | 07.27      | T           | Over Voltage                                                                                                |
| BABHALESHWAR - RPL(NASHIK) CKT - 1      | IntraState                | 11/06/2020   | 10.40        |            | Continued. | HT          | Over Voltage                                                                                                |
| Padghe - Nagothane - I                  | IntraState                | 25/06/2020   | 19.20        |            | Continued. | HT          | Over Voltage                                                                                                |
| Bhusawal-Aurangabad                     | IntraState                | 26/06/2020   | 16.47        | 10/07/2020 | 11.13      | HT          | Over Voltage                                                                                                |
| Karad - Jaigad - II                     | IntraState                | 03/07/2020   | 20.35        |            | Continued. | HT          | Over Voltage                                                                                                |
| Karad - Talandge Ckt 2                  | IntraState                | 04/07/2020   | 22.17        |            | Continued. | HT          | Over Voltage                                                                                                |
| Padghe - Kalwa- I                       | IntraState                | 09/07/2020   | 01.12        | 10/07/2020 | 11.53      | T           | Over Voltage                                                                                                |
| Chandrapur-II - Nanded ckt II           | IntraState                | 09/07/2020   | 12.29.       | 10/07/2020 | 10.25      | PO          | Line Maintenance work.                                                                                      |
| Nagothane - Dabhol-II                   | IntraState                | 09/07/2020   | 12.41        | 10/07/2020 | 09.57      | PO          | Routine Maintenance Work.                                                                                   |
| Lonikand I - Koyna stage-IV             | IntraState                | 09/07/2020   | 20.48        | 10/07/2020 | 09.43      | HT          | Over Voltage                                                                                                |
| Dhule - Bableshwar - II                 | IntraState                | 09/07/2020   | 21.01        |            | Continued. | HT          | Over Voltage                                                                                                |
| Koradi III(Adani)-Korad II Ckt-I        | IntraState                | 10/07/2020   | 08.51        | 10/07/2020 | 20.33      | PO          | Fixing of missing & tightening of loose nut bolts on conductor hardware's at various loc & line maint work. |
| Koradi-Khaperkheda I                    | IntraState                | 10/07/2020   | 09.18        | 10/07/2020 | 16.35      | PO          | CT Tan delta measurement by testing Unit.                                                                   |
| Taptitanda Waluj                        | IntraState                | 10/07/2020   | 11.19        | 10/07/2020 | 17.09      | PO          | Quarterly Maintenance Work                                                                                  |
| Bhusawal-Aurangabad                     | IntraState                | 10/07/2020   | 17.11        |            | Continued. | HT          | Over Voltage                                                                                                |
| Lonikand I - Koyna stage-IV             | IntraState                | 10/07/2020   | 20.32        |            | Continued. | HT          | Over Voltage                                                                                                |
| Padghe - Kalwa- I                       | IntraState                | 10/07/2020   | 21.26        |            | Continued. | HT          | Over Voltage                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                             |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe     | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                                    |
| 400/220 Kv 500 Mva ICT- I @Jejuri       | IntraState                | 09/07/2020   | 01.38        | 10/07/2020 | 07.22      | HT          | To Control over voltage.                                                                                    |
| 400/220 Kv 500 MVA ICT-III @Kalwa       | IntraState                | 09/07/2020   | 01.45        |            | Continued. | HT          | To control over voltage.                                                                                    |
| 400/220kv 315 Mva ICT II @Karad         | IntraState                | 09/07/2020   | 22.20        | 10/07/2020 | 09.57      | T           | OLTC bucholz tripped.                                                                                       |
| 400/220 Kv 500 MVA ICT II @Jejuri       | IntraState                | 11/07/2020   | 01.39        | 11/07/2020 | 06.05      | HT          | Over Voltage                                                                                                |
| <b>220 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                             |
| Mudshingi Chikodi                       | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                                                                |
| Talandage - Chikodi                     | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                                                                     |
| BOISAR BORIVALI                         | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                                                |
| Sawantwadi-Bidri                        | IntraState                | 09/07/2020   | 20.10        | 10/07/2020 | 11.42      | HT          | Over Voltage                                                                                                |
| Gadchandur - Virur-I                    | IntraState                | 10/07/2020   | 08.17        | 10/07/2020 | 14.46      | PO          | Line Maintenance work                                                                                       |
| Karad(400kv) - Ogalewadi Ckt 1          | IntraState                | 10/07/2020   | 14.15        | 10/07/2020 | 18.31      | EO          | Insulator string flashover Replacement.                                                                     |
| Gadchandur - Virur-II                   | IntraState                | 10/07/2020   | 14.51        | 10/07/2020 | 18.21      | PO          | Line Maintenance work                                                                                       |
| Sawantwadi-Bidri                        | IntraState                | 10/07/2020   | 20.15        |            | Continued. | HT          | Over Voltage                                                                                                |
| <b>220 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                             |
| 220/132 KV 100MVA ICT-I @ Shivajinagar  | IntraState                | 13/06/2020   | 01.24        |            | Continued. | T           | Differential protection & main Buchholz trip.                                                               |
| 220/100 Kv 200 MVA ICT I @Pal-Dombivali | IntraState                | 10/07/2020   | 10.03        | 10/07/2020 | 17.35      | PO          | Repairs of neutral earth pit copper strip & MS flat connection work.                                        |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage