

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Jul/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	103.800	1257.429	1) Gujrat	-8.807	-101.441
2) Hydro	7.805	106.755	2) Madhya Pradesh	3.217	47.790
3) Gas	3.202	46.044	3) Chattisgarh	2.680	36.790
Total MSPGCL	114.807	1410.228	4) Maharashtra	124.703	1524.761
B) 1) APLM	37.091	471.395	5) Goa (Amona)	-1.527	-12.971
2) JSWEL	14.551	142.546	Total	120.266	1494.929
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.706	328.524
4) RPL(AMT)	19.735	194.704	b) Mumbai Drawl	31.696	357.691
5) SWPGPL	7.455	77.957	c) MSEDCL Bilateral *	80.696	776.064
6) Other IPP	5.908	74.772	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.706	326.480
C) 1) TPCL Thermal	10.408	91.018	Include PX	0.000	0.000
2) TPCL Hydro	2.441	30.106	Standby	0.000	2.044
3) TPCL Gas	0.000	6.389	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.580	100.758	1) MSEDCL	345.397	3940.596
D) STATE			2) Mumbai Discoms	52.124	585.962
1) Thermal	206.528	2410.579	3) Other Discoms	8.517	88.641
(A1+C1+C4+(B1-B6))			TOTAL STATE	406.038	4615.199
2) Hydro (A2+C2)	10.246	136.861			
3) Gas (A3+B7+C3)	3.202	52.433			
4) Wind	61.777	455.039			
6) SOLAR	4.020	65.358			
TOTAL STATE	285.773	3120.270			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4320	3808	4865	4351
MSPGCL Hydro	338	361	407	232
MSPGCL Gas	138	127	128	138
MSPGCL Total Generation	4796	4296	5400	4721
Central Sector Receipt	6804	4977	5213	4413
WIND	2463	2832	2744	2243
CPP / IPP Thermal	3538	3196	3923	3228
CPP / IPP Gas	0	0	0	0
SOLAR	349	552	0	0
Exchange with Mumbai	-1412	-1602	-1414	-1072
MSEDCL DEMAND MET	16162	13889	15472	13246
Load Shedding	0	0	0	0
MSEDCL DEMAND	16162	13889	15472	13246
TPCL GENERATION	530	471	562	500
AEML GENERATION	315	295	316	319
MUMBAI DEMAND	2257	2368	2292	1891
OTHER DISCOM DEMAND	377	362	394	287
STATE DEMAND MET	18795	16619	18158	15424
STATE DEMAND	18795	16619	18158	15424
Frequency (Hz)	50.09	50.03	49.99	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 09:03 Hrs	49.68 Hz at 14:53 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.12	21.31	135	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	0.00	46.99	0	0
Unit 10	9.87	112.36	479	357
Total	11.98	223.93		
Bhusawal				
Unit 3	2.87	29.78	140	110
Unit 4	7.55	88.83	390	280
Unit 5	8.00	77.21	425	275
Total	18.42	195.82		
Parli				
Unit 6	4.00	48.72	217	149
Unit 7	3.49	42.35	152	140
Unit 8	0.00	0.00	0	0
Total	7.50	91.07		
Chandrapur				
Unit 3	0.00	20.97	0	0
Unit 4	1.61	24.91	95	0
Unit 5	7.26	72.29	330	268
Unit 6	6.19	64.85	280	210
Unit 7	0.00	0.00	0	0
Unit 8	8.76	99.49	435	284
Unit 9	9.11	99.72	436	291
Total	32.94	382.23		
Paras				
Unit 3	3.50	41.27	193	125
Unit 4	3.71	40.50	204	83
Total	7.21	81.77		
Khaparkheda				
Unit 1	2.30	27.72	125	0
Unit 2	2.45	29.03	115	75
Unit 3	3.44	28.35	170	115
Unit 4	0.00	0.00	0	0
Unit 5	7.93	97.68	425	280
Total	16.11	182.78		
Nasik				
Unit 3	3.31	36.45	174	120
Unit 4	3.13	33.48	150	117
Unit 5	3.21	29.91	151	121
Total	9.65	99.83		
Uran				
All Units	3.20	46.04	140	127
Total	3.20	46.04		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	1.38	22	0
Total	0.04	1.38		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.21	21.04	180	20
Stage 4	0.00	7.89	0	0
Stage 3	1.16	12.95	160	0
Total	2.37	41.88		
Hydro				
KDPH	0.00	0.65	0	0
VTRNA	0.00	5.91	0	0
TILLARI	0.46	3.28	58	0
BHIRA T.R.	0.34	2.97	40	0
SMLHY_PTN	4.59	50.68	203	183
GHATGHAR	0.00	0.00	0	0
Total	5.40	63.49		
Wind				
Total	61.78	455.04	0	0
Total	61.78	455.04		
CPP				
APML(Mus)	37.09	471.40	0	0
JSWEL(Mus)	14.55	142.55	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.74	194.70	0	0
SWPGPL-Mus	7.46	77.96	0	0
Other(Mus)	5.91	74.77	0	0
Total	84.74	961.37		
SOLAR				
Total	4.02	65.36	0	0
Total	4.02	65.36		
Tata				
Trombay 5	6.89	50.00	446	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.82	0	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	2.44	30.11	162	60
Trombay 8	3.52	41.01	228	131
Total	12.85	127.51		
AEML				
DTPS U-1&2	7.58	100.76	331	295
Total	7.58	100.76		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	103.80	1257.43	MSPGCL Total	114.81	1410.23
			MSPGCL Thml+Gas	107.00	1303.47	Koyna 1,2 & 4 Total	1.21	28.93
			MSPGCL Hydro	7.80	106.76	State Total	285.77	3120.27

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4366	228	128	4722	2356	3660	0	0	4421	4833	-1308	13925	0	13925	2167	338	16430	50.02
2	4350	224	138	4712	2306	3686	0	0	4398	4296	-1200	13493	0	13493	2060	307	15860	50.04
3	4466	231	128	4825	2270	3626	0	0	4366	4141	-1123	13445	0	13445	1961	294	15700	50.02
4	4351	232	138	4721	2243	3228	0	0	4477	4413	-1072	13246	0	13246	1891	287	15424	50.03
5	4290	249	128	4667	2141	3390	0	0	4564	4990	-1047	13856	0	13856	1872	285	16013	50.03
6	4622	253	138	5013	2278	3873	0	1	5340	5206	-1158	14874	0	14874	1960	339	17173	49.98
7	4765	267	128	5160	2177	3984	0	31	6023	5614	-1013	15601	0	15601	2015	352	17968	49.95
8	4575	277	138	4990	2212	3514	0	134	6468	6199	-987	15696	0	15696	2060	366	18122	50.00
9	4435	285	128	4848	2401	3467	0	243	6288	6548	-1095	16057	0	16057	2164	355	18576	50.08
10	4320	338	138	4796	2463	3538	0	349	6417	6804	-1412	16162	0	16162	2257	377	18795	50.09
11	4098	287	128	4513	2800	3172	0	503	6661	6247	-1591	15264	0	15264	2361	380	18005	50.10
12	3867	367	138	4372	2963	3162	0	553	6386	5522	-1623	14585	0	14585	2390	363	17339	50.03
13	3808	361	127	4296	2832	3196	0	552	5484	4977	-1602	13889	0	13889	2368	362	16619	50.03
14	3788	288	138	4214	2641	3162	0	451	4808	4777	-1523	13375	0	13375	2286	347	16008	50.08
15	3912	397	127	4436	2764	3165	0	401	4333	4328	-1443	13297	0	13297	2222	354	15873	49.85
16	4042	599	138	4779	2761	3199	0	360	4154	4136	-1397	13482	0	13482	2178	356	16016	49.92
17	3936	464	139	4539	2870	3191	0	276	4639	4247	-1345	13398	0	13398	2145	381	15923	50.02
18	4018	388	130	4536	2842	3247	0	139	4675	4964	-1338	14002	0	14002	2137	388	16527	50.03
19	4577	454	140	5171	2651	3752	0	28	4740	4924	-1366	14763	0	14763	2191	397	17351	50.01
20	4865	407	128	5400	2744	3923	0	0	5412	5213	-1414	15472	0	15472	2292	394	18158	49.99
21	4797	343	140	5280	2839	4045	0	0	4692	4884	-1438	15225	0	15225	2334	385	17944	50.01
22	4856	303	129	5288	2806	4113	0	0	4085	4085	-1431	14473	0	14473	2309	388	17170	50.07
23	4535	302	140	4977	2725	3745	0	0	4348	4479	-1405	14158	0	14158	2274	363	16795	50.03
24	4161	261	130	4552	2692	3702	0	0	4313	4439	-1365	13661	0	13661	2231	359	16251	50.01
MUs	103.80	7.81	3.20	114.81	61.78	84.74	0.00	4.02	121.49	120.27	-31.70	345.40	0.00	345.40	52.13	8.52	406.04	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jul/2022

Position as on 6.30 Hrs of 11/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Parli Unit 8	250	25/06/2022	00:00	11/07/2022	23:33	Short overhauling	10/07/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Annual Overhaul	22/07/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	17/07/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	15/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	15/07/2022
IPP	SWPGPL U-1	135	04/07/2022	02:38		Continued.	PA Fan problem	15/07/2022
MSPGCL	Uran Unit 6	108	06/07/2022	17:51		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-1	250	06/07/2022	18:30		Continued.	Governor problem	16/07/2022
TPC-G	Trombay 7A	120	07/07/2022	01:09		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21		Continued.	Gas shortage	
MSPGCL	Koradi Unit 9	660	07/07/2022	13:54		Continued.	Boiler Tube Leakage	10/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Jul/2022

Position as on 6.30 Hrs of 11/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58		Continued.	Furnace Pressure High	16/07/2022
MSPGCL	Khaparkheda Unit 1	210	10/07/2022	09:48	10/07/2022	13:56	Flame Failure	
MSPGCL	Koradi Unit 6	210	10/07/2022	10:39	10/07/2022	14:14	drum level high	
MSPGCL	Chandrapur Unit 4	210	10/07/2022	15:48	10/07/2022	20:50	Furnace Pressure High	
MSPGCL	Nasik Unit 5	210	11/07/2022	17:00		Continued.	WET COAL	
MSPGCL	Parli Unit 7	250	11/07/2022	22:03		Continued.	Boiler Tube Leakage	14/07/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (412) OF CHANDRAPUR-1 & ADANI - 1 @ WARORA	IntraState	10/07/2022	19:07	10/07/2022	21:47	HT	Low SF6 problem
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	10/07/2022	06:01	10/07/2022	09:48	EO	Hot spot attending emergency work 1) wave trap jumper top & bottom pad R & Y PH. (Temp 191 deg) 2) CB R ph , 29 B isolator side (Temp 161 deg)
DHULE - SSNNL CKT - 2	InterState	11/07/2022	03:17		Continued.	HT	HT for Overvoltage
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
KORADI-NANDGAONPETH (RPL)	IntraState	10/07/2022	02:17	10/07/2022	16:46	T	Tripped on Over Voltage.
TIRORA - WARORA CKT - 2	IntraState	10/07/2022	09:11	10/07/2022	18:26	PO	Annual Maintenace of line
PADGHE - KALWA CKT - 2	IntraState	10/07/2022	10:20	10/07/2022	22:07	PO	1) Bay Maint work 2) Diagnostic Testing work 3) MTAMC work
KHADKA-AURANGABAD (WALUJ)	IntraState	10/07/2022	17:30			HT	To control OV
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 1 @ JEJURI	IntraState	11/07/2022	16:30	11/07/2022	18:13	EO	For cleaning of Tertiary delta of ICT I in view of NDR alarm.
220 KV TBC Outages/Trippings							
BUS COUPLER @ CARNAC	IntraState	10/07/2022	10:00	10/07/2022	10:30	PO	FOR TESTING
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	11/07/2022	18:16	11/07/2022	19:32	T	TRIPPED ON BACK UP PROTECTION
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
BOISAR II - BOISAR (PG) CKT - 1	IntraState	09/07/2022	07:45	10/07/2022	23:33	PO	220kv PGCIL Line 1 Bay Strengthening work at 220kv Boisar 2 S/S by replacing existing all jumpers by Twin Jumpers.
TEMGHAR - KALWA	IntraState	09/07/2022	23:58	10/07/2022	07:22	T	Tripped on Distance Protection.
POPHALI - KDPH	IntraState	10/07/2022	04:55	10/07/2022	14:05	T	Tripped on Distance Protection.
NEW KOYNA - PEDAMBE	IntraState	10/07/2022	14:16	10/07/2022	14:36	T	Tripped at New koyna only
POPHALI - KDPH	IntraState	10/07/2022	14:22		Continued.	T	Tripped on DT
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	11/07/2022	09:29			PO	Relay replacement at MSETCL Bor Project work.
TALANDGE - ICHALKARANJI 1	IntraState	11/07/2022	10:17	11/07/2022	17:00	PO	1) Quarterly bay maintenance work at 220 kv Tilawani end. 2) Annual relay testing work. 3)MFM meter replacement work
OSMANABAD - SOLAPUR (BALE)	IntraState	11/07/2022	14:28	11/07/2022	17:43	HT	DUE TO EMERGENCY OUTAGE TO ATTEND CB PROBLEM AT OSMANABAD END.
BOISAR II - VIRAJ	IntraState	11/07/2022	18:16	11/07/2022	19:12	T	TRIPPED FROM BOISER END

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 11/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - VIRAJ	IntraState	11/07/2022	18:16	11/07/2022	19:47	T	TRIPPED ON BACK UP PROTECTION
BOISAR II - BOISAR (PG) CKT - 3	IntraState	11/07/2022	18:16		Continued.	T	TRIPPED ON BACKUP PROTECTION
PADGHE - NALASOPARA - VASAI (T)	IntraState	11/07/2022	18:16	11/07/2022	19:12	T	TRIPPED ON BACK UP PROTECTION
HALKARNI - TILARI LINE	IntraState	11/07/2022	18:17		Continued.	T	TRIPPED ON D/P
GOREGAON - VERSOVA CKT - 2	IntraState	11/07/2022	22:14		Continued.	T	Tripped at Versova end only
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	IntraState	10/07/2022	09:20	10/07/2022	18:20	HT	HT due to Sparking on LV side B-ph Bushing clamp
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/07/2022	10:46	10/07/2022	11:54	PO	FOR OIL TOP UP IN OLTC
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	11/07/2022	07:38	11/07/2022	15:36	T	Differential Protection
220 KV BR Outages/Trippings							
BUS COUPLER @ BOISAR 2	IntraState	11/07/2022	18:16	11/07/2022	19:00	T	TRIPPED ON BACK UP PROTECTION
132 KV LINE Outages/Trippings							
BOISAR II - PALGHAR 2	IntraState	11/07/2022	18:16	11/07/2022	03:33	T	DISTANCE PROTECTION
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage