

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Aug/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.335	1264.184	1) Gujrat	14.278	112.157
2) Hydro	18.603	130.772	2) Madhya Pradesh	7.769	73.570
3) Gas	0.467	1.047	3) Chattisgarh	0.370	22.260
Total MSPGCL	165.405	1396.003	4) Maharashtra	153.187	1522.376
B) 1) APML	72.188	508.630	5) Goa (Amona)	-1.597	-15.907
2) JSWEL	8.873	136.849	Total	174.007	1714.456
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.378	338.808
4) RPL(AMT)	24.902	250.917	b) Mumbai Drawl	34.211	374.736
5) SWPGPL	11.048	75.346	c) MSEDCL Bilateral *	77.551	919.294
6) Other IPP	7.007	61.667	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.378	338.808
C) 1) TPCL Thermal	13.037	106.672	Include PX	0.000	0.000
2) TPCL Hydro	7.204	49.605	Standby	0.000	0.000
3) TPCL Gas	3.447	26.283	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.141	90.057	1) MSEDCL	466.098	4300.961
D) STATE			2) Mumbai Discoms	68.040	647.353
1) Thermal	293.531	2494.322	3) Other Discoms	10.057	99.869
(A1+C1+C4+(B1-B6))			TOTAL STATE	544.195	5048.183
2) Hydro (A2+C2)	25.807	180.377			
3) Gas (A3+B7+C3)	3.914	27.330			
4) Wind	32.205	524.529			
6) SOLAR	14.731	107.169			
TOTAL STATE	370.188	3333.727			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6007	6063	6273	6063
MSPGCL Hydro	404	195	1531	323
MSPGCL Gas	0	0	86	0
MSPGCL Total Generation	6411	6258	7890	6386
Central Sector Receipt	9527	9250	6780	5884
WIND	1174	1331	1417	1202
CPP / IPP Thermal	4877	4244	5378	5531
CPP / IPP Gas	0	0	0	0
SOLAR	1786	1871	0	0
Exchange with Mumbai	-2256	-2299	-1325	-807
MSEDCL DEMAND MET	21077	20237	19680	17884
Load Shedding	0	0	1203	0
MSEDCL DEMAND	21077	20237	20883	17884
TPCL GENERATION	743	669	1280	888
AEML GENERATION	367	367	485	383
MUMBAI DEMAND	3366	3335	3090	2078
OTHER DISCOM DEMAND	442	418	460	312
STATE DEMAND MET	24885	23990	23230	20274
STATE DEMAND	24885	23990	24433	20274
Frequency (Hz)	50.02	49.97	49.89	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 16:02 Hrs	49.66 Hz at 19:14 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.54	31.88	180	110
Unit 8	14.53	128.78	630	572
Unit 9	13.10	121.13	565	505
Unit 10	0.00	0.00	0	0
Total	31.16	281.79		
Bhusawal				
Unit 3	3.09	29.18	140	110
Unit 4	9.01	87.88	430	0
Unit 5	11.02	89.08	490	410
Total	23.12	206.14		
Parli				
Unit 6	5.02	8.91	248	129
Unit 7	5.13	8.23	245	140
Unit 8	4.01	11.22	223	132
Total	14.16	28.36		
Chandrapur				
Unit 3	3.05	27.66	142	94
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	8.50	75.81	385	325
Unit 7	8.09	72.80	351	320
Unit 8	9.97	101.05	457	356
Unit 9	9.91	102.61	451	365
Total	39.53	379.94		
Paras				
Unit 3	4.37	45.17	205	157
Unit 4	4.59	43.44	218	174
Total	8.96	88.61		
Khaparkheda				
Unit 1	2.05	19.31	95	75
Unit 2	2.62	25.90	116	101
Unit 3	3.96	36.71	176	150
Unit 4	3.56	36.97	155	139
Unit 5	9.98	93.04	430	400
Total	22.16	211.94		
Nasik				
Unit 3	3.61	35.92	170	134
Unit 4	3.62	18.42	166	127
Unit 5	0.00	13.08	0	0
Total	7.24	67.42		
Uran				
All Units	0.47	1.05	89	0
Total	0.47	1.05		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.72	10.09	47	0
Total	0.72	10.09		
Koyna				
Stage 1-2	4.14	25.78	425	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.05	20.92	749	0
Stage 3	2.08	13.79	240	0
Total	12.27	60.49		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.00	0.48	0	0
TILLARI	0.74	1.17	61	0
BHIRA T.R.	0.47	4.37	80	0
SMLHY_PTN	3.82	43.58	169	148
GHATGHAR	0.59	3.45	125	0
Total	5.61	60.20		
Wind				
Total	32.20	524.53	0	0
Total	32.20	524.53		
CPP				
APML(Mus)	72.19	508.63	0	0
JSWEL(Mus)	8.87	136.85	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.90	250.92	0	0
SWPGPL-Mus	11.05	75.35	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.93	51.46	269	201
Other(Mus)	1.07	10.21	0	0
Total	124.02	1033.41		
SOLAR				
Total	14.73	107.17	0	0
Total	14.73	107.17		
Tata				
Trombay 5	8.65	70.92	452	252
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.11	15.28	109	39
Trombay 7B	1.34	11.01	64	35
TATA Hydro	7.20	49.60	431	179
Trombay 8	4.39	35.75	224	132
Total	23.69	182.56		
AEML				
DTPS U-1&2	10.14	90.06	491	325
Total	10.14	90.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	146.34	1264.18	MSPGCL Total	165.40	1396.00
			MSPGCL Thml+Gas	146.80	1265.23	Koyna 1,2 & 4 Total	10.19	46.70
			MSPGCL Hydro	18.60	130.77	State Total	370.19	3333.73

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6094	326	0	6420	1331	5611	0	0	5969	5952	-973	17959	0	0	17959	2495	382	20836	49.97
2	6141	314	0	6455	1369	5551	0	0	5971	5712	-846	17883	0	0	17883	2316	358	20557	50.03
3	6154	314	0	6468	1312	5554	0	0	6012	5892	-761	18120	0	0	18120	2184	345	20649	50.01
4	6063	323	0	6386	1202	5531	0	0	6401	5884	-807	17884	0	0	17884	2078	312	20274	50.01
5	5994	632	1	6627	1193	5419	0	0	6588	6144	-977	18057	0	0	18057	2075	349	20481	49.95
6	5935	1392	50	7377	1079	5364	0	1	6692	6696	-880	19260	0	0	19260	2204	376	21841	49.97
7	6026	1722	89	7837	1084	5282	0	90	7428	7403	-802	20487	0	0	20487	2373	407	23267	49.97
8	6121	1775	10	7906	958	5186	0	517	7907	7702	-972	20872	0	0	20872	2575	425	23872	50.03
9	6068	847	0	6915	995	5176	0	1054	8789	8741	-1469	20955	0	0	20955	2905	456	24317	49.99
10	6119	713	0	6832	1151	5121	0	1495	8688	8488	-2010	20619	0	0	20619	3181	458	24258	49.95
11	6007	404	0	6411	1174	4877	0	1786	9163	9527	-2256	21077	0	0	21077	3366	442	24885	50.02
12	6059	346	0	6405	1301	4668	0	1881	9120	9049	-2301	20559	0	0	20559	3412	444	24415	50.01
13	6063	195	0	6258	1331	4244	0	1871	8986	9250	-2299	20237	0	0	20237	3335	418	23990	49.97
14	5891	339	0	6230	1479	3963	0	1679	8723	8975	-2114	19802	0	0	19802	3219	410	23431	49.99
15	6088	215	0	6303	1659	4710	0	1689	8641	8225	-2111	20058	0	0	20058	3262	417	23737	50.02
16	6110	309	0	6419	1733	5056	0	1280	8595	8173	-2052	20155	0	0	20155	3281	455	23890	50.01
17	6193	413	0	6606	1873	5226	0	904	8073	7775	-1885	20038	0	0	20038	3246	461	23745	50.04
18	6243	441	2	6686	1773	5305	0	423	7319	6512	-1544	18685	0	0	18685	3167	470	22322	49.97
19	6277	1127	54	7458	1622	5388	0	61	6782	6601	-1328	19331	0	0	19331	3079	471	22881	49.96
20	6273	1531	86	7890	1417	5378	0	0	6599	6780	-1325	19680	1203	0	20883	3090	460	24433	49.89
21	6271	1319	88	7678	1278	5354	0	0	6426	6288	-1240	18905	728	0	19633	2969	453	23055	49.98
22	6205	1264	87	7556	1306	5348	0	0	6270	6128	-1159	18734	419	0	19153	2829	445	22427	49.98
23	6074	1235	0	7309	1254	5362	0	0	6256	6138	-1074	18553	0	0	18553	2739	436	21728	49.90
24	5866	1107	0	6973	1331	5344	0	0	6213	5972	-1026	18187	0	0	18187	2660	407	21254	49.90
MUs	146.33	18.60	0.47	165.40	32.21	124.02	0.00	14.73	177.61	174.01	-34.21	466.10	2.35	0.00	468.45	68.04	10.06	546.54	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/Aug/2023

Position as on 6.30 Hrs of 11/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	13/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Uran Unit 6	108	09/08/2023	21:18	10/08/2023	04:58	NO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
MSPGCL	Uran Unit 7	108	20/07/2023	20:00		Continued.	Boiler Inspection work	
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	DUE TO HPT DIFFERENTIAL EXPANSION ON HIGHER SIDE	22/08/2023
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	12/08/2023
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00		Continued.	ID Fan Problem(On Tolling since 18:23Hrs DT. 05-08-2023)	
IPP	RPL(AMT) U-3	270	05/08/2023	19:07		Continued.	Due to TG shaft vibration high.	14/08/2023
IPP	JSW (J) U4	300	10/08/2023	05:55		Continued.	CW system leakage	14/08/2023
MSPGCL	Uran Unit 6	108	10/08/2023	07:15	10/08/2023	17:53	Zero Schedule.	
MSPGCL	Koyna STG-IV Unit-4	250	10/08/2023	18:30	11/08/2023	00:20	Gov. Safety bolt rupture	11/08/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Aug/2023

Position as on 6.30 Hrs of 11/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	10/08/2023	22:14		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 4	500	10/08/2023	22:44		Continued.	Boiler Tube Leakage	13/08/2023
MSPGCL	Koradi Unit 6	210	11/08/2023	08:14	11/08/2023	16:19	Coal Bunkering Problem.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 11/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 406 OF FUTURE BAY @ AKOLA 2	IntraState	10/08/2023	10:45	10/08/2023	18:37	PO	Maintenance of Bay Isolator & Dropper
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	10/08/2023	23:04	11/08/2023	00:33	T	B-ph Line Reactor faulty at Talegaon PG
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 2Y2 phase Protection CT Of NTPP I (RPL 1)
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03	11/08/2023	13:12	PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	09/08/2023	23:25	10/08/2023	07:27	HT	Over voltage
DEEPNAGAR - THAPTI TANDA	IntraState	10/08/2023	08:54	10/08/2023	16:04	PO	Pending work related to work done by project division at Loc. No. 154
LONIKAND - JEJURI CKT - 2	IntraState	10/08/2023	10:01	10/08/2023	16:53	PO	PID detected weak strings replacement work
KHADKA-AURANGABAD (WALUJ)	IntraState	10/08/2023	19:43	11/08/2023	08:33	HT	H/T FOR O/V
WARORA - WARORA (PG)	IntraState	11/08/2023	10:38			PO	FOR LINE BAY 412 LINE SIDE EQUIPMENTS AMP WORK.
KORADI II - KORADI III CKT - 3	IntraState	11/08/2023	11:00	11/08/2023	17:20	PO	Annual Maintenance of Line equipment at Koradi III SS
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44			PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	06/08/2023	09:44	11/08/2023	06:58	PO	Cooling System Renovation, commissioning, HV CB timing/DCRM,SFRA,REF,NDR relay & bay Maintenance work
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	10/08/2023	04:41	10/08/2023	08:40	HT	Emergency outage taken work of Hot spot attending work & tertiary Cable tightening work.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	10/08/2023	04:42	10/08/2023	08:40	EO	Hot spot attending work. Tertiary cable tightening work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 11/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	10/08/2023	10:04	10/08/2023	19:16	PO	Quarterly Maintenance & Relay Testing Work
400/220/33 KV 500 MVA ICT - 1 @ JEJURI	IntraState	10/08/2023	15:05	10/08/2023	22:17	PO	For RRS work, Maintenance & Testing work
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	11/08/2023	13:07			PO	Oil filtration work of OLTC R phase Unit of ICT - 2 to be carried out as the given oil has low BDV value.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
BOMBAY DYEING - SAHARA	IntraState	03/08/2023	12:24	10/08/2023	16:26	T	Tripped on distance protection
APTA - BOMBAY DYEING	IntraState	03/08/2023	12:24	10/08/2023	16:23	T	Tripped on distance protection
BHOSARI- BHOSARI 2	IntraState	09/08/2023	11:25			PO	220kv Bhosari 2 Line Bay ,CB to Control relay panel 19c Cable having DC leakage . Outage required for replacement of 19C control cable of CB .
POPHLI PEDHMBE LINE- 1	IntraState	10/08/2023	08:15	10/08/2023	14:20	EO	To attend 2R2 phase Line side isolator to C.T. conductor clamp two bolt having red hot and unwound strands of 2R2 phase breaker to line side isolator
TALANDGE - HAMIDWADA	IntraState	10/08/2023	10:47	10/08/2023	16:56	PO	Q/M work & relay testing work
URAN - KHARGHAR 2	IntraState	10/08/2023	12:12	10/08/2023	20:32	PO	For making LILO of 220KV Cable at 220KV Ulwe GIS & Waghiwali
URAN - KHARGHAR 2	IntraState	10/08/2023	12:12	10/08/2023	20:32	EO	For attending red hot spot at loc no 95 next to kharghar end gantry.
BHOSARI- BHOSARI 2	IntraState	10/08/2023	12:35	10/08/2023	16:18	PO	220kv Bhosari-2 Bay CB new cable testing and CB trail work by testing team .
KHARGHAR - NET MAGIC GIS	IntraState	10/08/2023	12:48	10/08/2023	20:10	PO	For crimping of repair sleeve at Loc. No. 21-22 & 22-23 in Kharghar hilly area.
BOMBAY DYEING - SAHARA	IntraState	10/08/2023	14:14	10/08/2023	16:26	EO	Line of apta bombay dyeing and bombay dyeing sahara is now charged from by closing bypass isolator charged So restores line as it was earlier apta bombay dyeing & sahara bombay deying line.
BHUGAON - WARDHA (PG)	IntraState	10/08/2023	19:23	10/08/2023	20:01	HT	To control OD.
GHATGHAR - BAPGAON	IntraState	11/08/2023	10:12			PO	For Flashover string Y&B Phase replacement at Loc. 207 and damage conductor work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	10/08/2023	10:30	10/08/2023	13:15	PO	For Routine maintenance, diagnostic testing work (Winding & Bushing Tan Delta) .
220/100 KV 200 MVA ICT 1 @ KOLSHET	IntraState	10/08/2023	11:25	10/08/2023	17:34	PO	Arresting of oil leakages from ICT
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	10/08/2023	11:38	10/08/2023	15:50	PO	TBC Wiring & Testing Work
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	10/08/2023	13:45	10/08/2023	15:37	PO	For Routine maintenance, diagnostic testing work (Winding & Bushing Tan Delta) .
220/33 KV 50 MVA PTR NO 1 @ BHIGWAN	IntraState	10/08/2023	15:00	10/08/2023	17:50	PO	for OLTC overhauling & oil change work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 11/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	10/08/2023	15:44	10/08/2023	18:24	PO	For Routine maintenance, diagnostic testing work (Winding & Bushing Tan Delta) .
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	IntraState	11/08/2023	09:15			PO	Oil filtration work to improve oil parameters.
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	11/08/2023	10:30	11/08/2023	14:04	PO	R ph & B ph lightening arrester of ICT 02 LV side replacement work to be carried out.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
MAIN BUS @ BELEWADI	IntraState	11/08/2023	10:20			PO	For Diagnostic Testing of CT,CB & Maintenance work bus side isolators, metering CT,PT and bay equipments
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	IntraState	11/08/2023	01:36	11/08/2023	06:30	PO	Attending hot spot on B phase of Bus section 1-2 GOD

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage