

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Sep/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	121.431	1238.477	1) Gujrat	5.960	78.034
2) Hydro	11.702	140.481	2) Madhya Pradesh	-2.684	16.479
3) Gas	2.379	33.662	3) Chattisgarh	3.090	33.090
Total MSPGCL	135.512	1412.620	4) Maharashtra	155.880	1644.557
B) 1) APML	67.851	668.749	5) Goa (Amona)	-0.649	-8.994
2) JSWEL	17.462	194.601	Total	161.597	1763.166
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.121	334.772
4) RPL(AMT)	19.200	154.831	b) Mumbai Drawl	34.316	364.440
5) SWPGPL	5.450	53.532	c) MSEDCL Bilateral *	35.980	438.200
6) Other IPP	5.984	59.639	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.115	334.640
C) 1) TPCL Thermal	12.502	121.027	Include PX	0.000	0.000
2) TPCL Hydro	3.827	51.362	Standby	0.007	0.132
3) TPCL Gas	0.578	10.030	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.995	99.207	1) MSEDCL	385.500	4003.637
D) STATE			2) Mumbai Discoms	62.218	646.067
1) Thermal	260.875	2590.063	3) Other Discoms	9.172	90.707
(A1+C1+C4+(B1-B6))			TOTAL STATE	456.890	4740.411
2) Hydro	15.529	191.843			
(A2+C2)					
3) Gas	2.957	43.692			
(A3+B7+C3)					
4) Wind	7.413	58.544			
6) SOLAR	8.519	93.102			
TOTAL STATE	295.293	2977.244			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5333	4700	5160	5001
MSPGCL Hydro	429	388	1891	282
MSPGCL Gas	93	93	150	96
MSPGCL Total Generation	5855	5181	7201	5379
Central Sector Receipt	7605	8135	6821	5226
WIND	222	140	383	182
CPP / IPP Thermal	4554	4266	5195	4646
CPP / IPP Gas	0	0	0	0
SOLAR	884	1113	0	0
Exchange with Mumbai	-1621	-1939	-1345	-924
MSEDCL DEMAND MET	17090	16490	17844	14202
Load Shedding	0	0	0	0
MSEDCL DEMAND	17090	16490	17844	14202
TPCL GENERATION	597	598	1117	658
AEML GENERATION	496	499	461	496
MUMBAI DEMAND	2714	3036	2923	2078
OTHER DISCOM DEMAND	409	406	411	307
STATE DEMAND MET	20213	19932	21178	16587
STATE DEMAND	20213	19932	21178	16587
Frequency (Hz)	49.97	49.92	50.00	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 06.02 Hrs	49.81 Hz at 14.20 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.24	32.13	170	75
Unit 7	0.00	0.00	0	0
Unit 8	9.69	107.77	423	367
Unit 9	0.00	0.00	0	0
Unit 10	9.68	105.05	445	365
Total	22.60	244.95		
Bhusawal				
Unit 3	2.82	28.03	135	110
Unit 4	9.30	92.46	425	320
Unit 5	0.00	0.00	0	0
Total	12.12	120.48		
Parli				
Unit 6	4.46	44.49	198	150
Unit 7	0.78	32.06	115	0
Unit 8	2.85	38.63	178	0
Total	8.09	115.18		
Chandrapur				
Unit 3	3.47	28.10	158	120
Unit 4	2.94	33.74	148	110
Unit 5	7.39	38.88	350	240
Unit 6	7.48	76.20	385	250
Unit 7	7.73	77.84	355	265
Unit 8	0.00	49.00	0	0
Unit 9	10.59	101.38	447	433
Total	39.60	405.15		
Paras				
Unit 3	4.50	45.63	240	123
Unit 4	5.18	45.00	240	170
Total	9.67	90.63		
Khaparkheda				
Unit 1	2.88	25.96	135	105
Unit 2	2.60	23.84	135	100
Unit 3	3.61	32.58	168	120
Unit 4	3.81	35.20	185	127
Unit 5	9.14	81.62	425	270
Total	22.06	199.21		
Nasik				
Unit 3	1.38	29.36	137	0
Unit 4	2.96	5.40	140	111
Unit 5	2.95	28.11	136	110
Total	7.29	62.87		
Uran				
All Units	2.38	33.66	150	91
Total	2.38	33.66		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.58	5.75	25	24
Total	0.58	5.75		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.14	26.01	455	35
Stage 4	1.91	27.51	750	0
Stage 3	0.92	12.30	226	0
Total	4.98	65.83		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.76	7.45	61	0
TILLARI	0.00	3.71	0	0
BHIRA T.R.	0.38	4.21	60	0
SMLHY_PTN	4.81	49.91	219	176
GHATGHAR	0.20	3.63	125	0
Total	6.14	68.90		
Wind				
Total	7.41	58.54	0	0
Total	7.41	58.54		
CPP				
APML(Mus)	67.85	668.75	0	0
JSWEL(Mus)	17.46	194.60	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.20	154.83	0	0
SWPGPL-Mus	5.45	53.53	0	0
Other(Mus)	5.98	59.64	0	0
Total	115.95	1131.35		
SOLAR				
Total	8.52	93.10	0	0
Total	8.52	93.10		
Tata				
Trombay 5	8.47	81.43	426	271
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.58	6.57	114	0
Trombay 7B	0.00	3.46	0	0
TATA Hydro	3.83	51.36	381	18
Trombay 8	4.03	39.60	232	129
Total	16.91	182.42		
AEML				
DTPS U-1&2	11.00	99.21	499	291
Total	11.00	99.21		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	121.43	1238.48	MSPGCL Total	135.51	1412.62
			MSPGCL Thml+Gas	123.81	1272.14	Koyna 1,2 & 4 Total	4.05	53.52
			MSPGCL Hydro	11.70	140.48	State Total	295.29	2977.24

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5084	323	97	5504	129	5419	0	0	4993	4767	-1049	14417	0	14417	2413	353	17183	49.98
2	5096	278	95	5469	134	5270	0	0	5136	4777	-905	14412	0	14412	2271	333	17016	50.00
3	4967	280	96	5343	156	4969	0	0	5297	5129	-945	14346	0	14346	2148	306	16800	49.96
4	5001	282	96	5379	182	4646	0	0	5588	5226	-924	14202	0	14202	2078	307	16587	49.95
5	5056	288	97	5441	237	5013	0	0	5792	5652	-1046	14969	0	14969	2050	328	17347	49.98
6	5139	296	96	5531	264	5009	0	0	6331	6229	-1265	15427	0	15427	2106	341	17874	50.02
7	5181	351	96	5628	116	5194	0	47	6684	6855	-1224	16262	0	16262	2174	354	18790	50.02
8	5243	311	95	5649	84	4909	0	243	7620	7785	-1467	16820	0	16820	2278	383	19481	50.00
9	5409	304	94	5807	111	4847	0	589	7502	7636	-981	17599	0	17599	1816	410	19825	50.00
10	5333	429	93	5855	222	4554	0	884	7349	7605	-1621	17090	0	17090	2714	409	20213	49.97
11	5030	357	93	5480	269	4333	0	1131	7947	7909	-1960	16734	0	16734	3051	428	20213	50.00
12	4883	358	93	5334	168	4312	0	1121	7864	8001	-1983	16545	0	16545	3074	408	20027	50.00
13	4700	388	93	5181	140	4266	0	1113	7706	8135	-1939	16490	0	16490	3036	406	19932	49.92
14	4616	296	92	5004	191	4249	0	1022	7556	7402	-1804	15675	0	15675	2909	389	18973	49.97
15	5050	364	91	5505	309	4380	0	959	7493	7218	-1822	16172	0	16172	2925	377	19474	49.96
16	5020	308	94	5422	610	4329	0	704	7577	7334	-1873	16111	0	16111	2954	415	19480	50.04
17	4940	312	93	5345	505	4486	0	515	7441	7300	-1833	15887	0	15887	2924	431	19242	50.02
18	5037	465	93	5595	299	4645	0	182	7483	7670	-1684	16278	0	16278	2892	429	19599	49.95
19	5121	1564	98	6783	417	5141	0	9	6711	6923	-1455	17383	0	17383	2917	435	20735	50.00
20	5160	1891	150	7201	383	5195	0	0	6913	6821	-1345	17844	0	17844	2923	411	21178	50.00
21	5149	998	149	6296	585	5202	0	0	6966	6905	-1319	17272	0	17272	2809	397	20478	50.02
22	5072	501	95	5668	589	5232	0	0	6571	6548	-1334	16306	0	16306	2670	397	19373	50.01
23	5091	457	95	5643	656	5229	0	0	6309	6045	-1224	15970	0	15970	2569	379	18918	50.01
24	5053	301	95	5449	657	5118	0	0	6235	5725	-1314	15287	0	15287	2517	348	18152	50.01
MUs	121.43	11.70	2.38	135.51	7.41	115.95	0.00	8.52	163.06	161.60	-34.32	385.50	0.00	385.50	62.22	9.17	456.89	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/Sep/2022

Position as on 6.30 Hrs of 11/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31	11/09/2022	02:52	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
TPC-G	Trombay 7B	60	09/09/2022	03:36		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	09/09/2022	03:52		Continued.	Gas shortage	
MSPGCL	Parli Unit 7	250	09/09/2022	05:34	10/09/2022	15:50	Bus Bar Protection operated	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Sep/2022

Position as on 6.30 Hrs of 11/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 8	250	09/09/2022	18:07	10/09/2022	05:40	Auxiliary Transformer Tripped.	
MSPGCL	Uran Unit 5	108	09/09/2022	20:59	10/09/2022	18:44	Synchronised	
MSPGCL	Nasik Unit 3	210	10/09/2022	11:46		Continued.	Turbine Vibration	18/09/2022
MSPGCL	Uran Unit 5	108	10/09/2022	20:44	11/09/2022	17:52	Gas shortage	
MSPGCL	Bhusawal Unit 5	500	11/09/2022	05:48		Continued.	Turbine Vibration	13/09/2022
TPC-G	Bhira PSU	150	11/09/2022	06:32	11/09/2022	08:53	For slip ring cleaning	11/09/2022
MSPGCL	Bhusawal Unit 3	210	11/09/2022	17:07	11/09/2022	21:00	stator water flow reduced	
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 11/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	10/09/2022	01:10	10/09/2022	06:18	HT	Emergency Hotspot attending work
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	10/09/2022	01:10	10/09/2022	04:28	HT	Emergency Hotspot attending work
CHANDRAPUR - PADGHE POLE 1 & 2	IntraState	10/09/2022	01:10	10/09/2022	06:18	EO	To attend the Hotspot on Pole-2 Neutral Bay Isolator (P2WNQ12)
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	11/09/2022	20:58		Continued.	EO	Pole 2 B-phase Converter transformer for OLTC Diverter switch overhauling and Oil flow relay replacement.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	10/09/2022	13:06	10/09/2022	17:28	PO	Taking Oil Sample of 400 KV Tarapur Line 1 CT at Padghe MSETCL SS.
CHAKAN - TALEGAON(PG)	InterState	10/09/2022	20:12	11/09/2022	02:33	PO	For AMP and Relay testing works.
WARORA - IEPL	IntraState	01/09/2022	07:36	10/09/2022	19:45	PO	1. Dis-Connecting Horizontal Jumper and covert 400kv IEPL-PGCIL Deoli Ckt (Temporary Arrangemet for 10 Days) 400kv IEPL-Warora Ckt. 2. Connecting 400kv IEPL-Warora through new towers.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38		Continued.	T	Y Phase Ground Fault
KARAD - LONIKAND I	IntraState	07/09/2022	15:01	10/09/2022	17:42	HT	HT for Load Management
KHADKA-AURANGABAD (WALUJ)	IntraState	08/09/2022	20:04	10/09/2022	09:08	HT	H/T FOR O/V
KORADI - KHADKA	IntraState	10/09/2022	10:10	10/09/2022	13:10	PO	For CB Timing testing & attending Air leakage problem
KARAD - LONIKAND I	IntraState	11/09/2022	11:26		Continued.	HT	For line loading control of 400 KV Karad Kolhapur
400 KV ICT Outages/Trippings							
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	11/09/2022	10:57	11/09/2022	17:07	EO	Replacement of tertiary PT of all 3 phases
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	11/09/2022	11:56	11/09/2022	16:21	T	R-ph OLTC Bucholz Protection
220 KV LINE Outages/Trippings							
220 KV HARANGUL - PARLY (PG) CKT	InterState	11/09/2022	00:54	11/09/2022	01:20	T	Tripped on Dist. Protection.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/09/2022	18:16	10/09/2022	14:28	HT	HT for Load Management
BHAVEGHAR - ROMA	IntraState	09/09/2022	18:22	10/09/2022	02:52	T	TRIPPED ON DISTANCE PROTECTION
PADGHE - NALASOPARA	IntraState	09/09/2022	18:24	10/09/2022	11:14	T	TRIPPED ON DISTANCE PROTECTION
BHAVEGHAR - ROMA	IntraState	10/09/2022	05:22	10/09/2022	11:23	EO	Damaged R-ph tension string replacement work of 220kv Bhaveghar Roma Line.
KALWA - BORIVALI	IntraState	10/09/2022	06:00	10/09/2022	08:34	EO	For safety purpose to attend hot spot on Y ph jumper of 220 kv Borivali CTRLS line at loc no.51.
BORIVALI - BOISAR (PG)	IntraState	10/09/2022	06:24	10/09/2022	09:16	EO	For safety purpose to attend hot spot on Y ph jumper of 220 kv Borivali CTRLS line at loc no.51.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 11/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHARGHAR - BORIVALI CKT - 2	IntraState	10/09/2022	09:42	10/09/2022	15:26	PO	For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.
EKLAHARE (OCR) - PADGHE	IntraState	10/09/2022	09:52	10/09/2022	21:57	HT	Load management
NEW KOYNA - POPHALI	IntraState	10/09/2022	10:37	10/09/2022	12:10	PO	For replacement of damaged conductor at loc no. 26 B phase New Koyna side, Y phase jump damaged, R phase 2T Red hot-New Koyna side
KANDALGAON - KOYNA (POPHALI)	IntraState	10/09/2022	11:07	10/09/2022	13:34	T	Tripped on Distance protection
SHEDYAL-JATH	IntraState	10/09/2022	12:28	10/09/2022	14:55	PO	Relay testing work at 220KV Shedyal end
CHEMBUR (AEML) - NERUL (M)	IntraState	10/09/2022	14:29	10/09/2022	15:02	T	Tripped on Dist Prot
NEW KOYNA - POPHALI	IntraState	10/09/2022	14:46	10/09/2022	18:56	HT	Approved outage
BORIVALI - CTRLS CKT	IntraState	10/09/2022	20:03	10/09/2022	15:47	PO	For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.
HINJAWADI I- CHINCHWAD	IntraState	10/09/2022	20:05	11/09/2022	03:24	HT	For load management of 400kV Talegaon-Chakan Line Outage
SATANA - GANGAPUR	IntraState	10/09/2022	21:18	10/09/2022	23:27	T	Tripped on Dist. Protection
WAGHIVALI - DHARAVI 8	IntraState	11/09/2022	05:45	11/09/2022	08:53	PO	Project Work in vicinity for removing Khopoli Dharavi ling OPGW in Span 46-45
MULUND - GIS BHANDUP	IntraState	11/09/2022	10:28	11/09/2022	17:11	EO	For Cable Sheath Earthing and LA Earthing work at tower END
SALSETTE - SAHAR CKT	IntraState	11/09/2022	10:32	11/09/2022	13:53	PO	for LBBU relay testing, CR trials, Portection trials
CHAKAN PH II - VOLKSWAGEN	IntraState	11/09/2022	11:21	11/09/2022	19:22	PO	Stringing for tap arrangement at exiting Loc No. 42 (MCN+00) of 220kV Bridgestone - Chakan II line to Loc 1 of Proposed 220 kV Tetra Pak S/Sn with 21 Mtr span.
CHAKAN -BRIDGESTONE	IntraState	11/09/2022	11:21	11/09/2022	19:22	PO	Stringing for tap arrangement at exiting Loc No. 42 (MCN+00) of 220kV Bridgestone - Chakan II line to Loc 1 of Proposed 220 kV Tetra Pak S/Sn with 21 Mtr span.
NAGOTHANE - POSCO	IntraState	11/09/2022	16:06		Continued.	T	Tripped on Dist Protection
CHAKAN-BHOSARI 1	IntraState	11/09/2022	18:01	11/09/2022	23:53	T	Tripped on Dist Protection Y-ph.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT 2@ PETH	IntraState	10/09/2022	10:01	10/09/2022	14:05	PO	Quarterly maintenance work
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 11/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage