

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Oct/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.474	1193.118	1) Gujrat	16.282	159.546
2) Hydro	5.734	55.660	2) Madhya Pradesh	6.478	85.523
3) Gas	7.326	85.275	3) Chattisgarh	2.980	27.870
Total MSPGCL	150.534	1334.053	4) Maharashtra	128.951	1328.889
B) 1) APLM	27.895	238.733	5) Goa (Amona)	-0.792	-5.258
2) JSWEL	19.892	180.129	Total	153.899	1596.570
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.389	302.995
4) RPL(AMT)	21.504	210.194	b) Mumbai Drawl	38.509	336.584
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	20.057	268.902
6) Other IPP	8.773	84.515	Include PX	0.000	82.585
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.389	302.995
C) 1) TPCL Thermal	13.164	131.300	Include PX	15.957	142.845
2) TPCL Hydro	5.068	35.693	Standby	0.000	0.000
3) TPCL Gas	2.758	33.344	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.155	84.227	1) MSEDCL	356.341	3424.940
D) STATE			2) Mumbai Discoms	64.653	621.145
1) Thermal	233.857	2122.216	TOTAL STATE	420.994	4046.085
(A1+C1+C4+(B1-B6))					
2) Hydro	10.802	91.353			
(A2+C2)					
3) Gas	10.084	118.619			
(A3+B7+C3)					
4) Wind	5.839	57.169			
6) SOLAR	6.514	60.161			
TOTAL STATE	267.096	2449.518			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5572	5556	5967	5522
MSPGCL Hydro	311	240	695	145
MSPGCL Gas	277	273	269	338
MSPGCL Total Generation	6160	6069	6931	6005
Central Sector Receipt	7097	7407	6612	5259
WIND	233	178	279	250
CPP / IPP Thermal	3081	3338	3618	2984
CPP / IPP Gas	0	0	0	0
SOLAR	935	727	0	0
Exchange with Mumbai	-1983	-2058	-1624	-1122
MSEDCL DEMAND MET	15523	15661	15816	13376
Load Shedding	0	0	0	0
MSEDCL DEMAND	15523	15661	15816	13376
TPCL GENERATION	1067	969	1188	610
AEML GENERATION	238	203	250	193
MUMBAI DEMAND	3288	3230	3062	1925
STATE DEMAND MET	18811	18891	18878	15301
STATE DEMAND	18811	18891	18878	15301
Frequency (Hz)	50.02	49.96	49.88	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 07.59 Hrs	49.7 Hz at 18.22 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 10/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.82	27.11	390	284
Unit 9	10.08	100.87	480	360
Unit 10	10.78	103.36	475	400
Total	28.69	231.34		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.38	98.19	500	360
Unit 5	10.67	20.98	500	355
Total	21.06	119.17		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.89	7.11	250	144
Unit 7	5.18	48.84	248	186
Unit 8	4.95	48.44	233	190
Total	15.02	104.39		
Chandrapur				
Unit 3	2.38	21.55	175	0
Unit 4	1.97	33.97	168	0
Unit 5	8.09	77.45	365	305
Unit 6	9.44	82.82	440	350
Unit 7	0.00	0.00	0	0
Unit 8	8.58	87.35	400	326
Unit 9	7.67	84.71	360	177
Total	38.12	387.85		
Paras				
Unit 3	4.40	32.32	240	155
Unit 4	0.00	0.00	0	0
Total	4.40	32.32		
Khaparkheda				
Unit 1	3.04	27.46	140	100
Unit 2	3.88	31.79	180	140
Unit 3	4.22	34.14	190	160
Unit 4	4.24	38.72	190	160
Unit 5	10.84	93.45	500	365
Total	26.21	225.57		
Nasik				
Unit 3	0.00	24.52	0	0
Unit 4	0.00	31.55	0	0
Unit 5	3.98	36.41	190	148
Total	3.98	92.48		
Uran				
All Units	7.33	85.28	384	265
Total	7.33	85.28		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.47	10.07	51	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.47	10.07		
Koyna				
Stage 1-2	2.21	25.96	470	40
Stage 4	0.79	9.91	398	0
Stage 3	1.17	8.65	112	0
Total	4.18	44.51		
Hydro				
KDPH	0.30	2.81	37	0
VTRNA	0.00	0.00	0	0
TILLARI	0.33	1.17	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.27	2.48	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	0.79	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.46	2.69	20	18
GHATGHAR	0.20	1.21	125	0
Total	1.56	11.15		
Wind				
Total	5.84	57.17	0	0
Total	5.84	57.17		
CPP				
APML(Mus)	27.90	238.73	0	0
JSWEL(Mus)	19.89	180.13	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	21.50	210.19	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.77	84.52	0	0
Total	78.06	713.57		
SOLAR				
Total	6.51	60.16	0	0
Total	6.51	60.16		
Tata				
Trombay 5	8.46	83.09	480	295
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.58	20.42	97	55
Trombay 7B	1.18	12.93	58	45
Trombay 8	4.70	48.21	210	181
TATA Hydro	5.07	35.69	435	4
Total	20.99	200.34		
AEML				
DTPS U-1&2	5.16	84.23	250	192
Total	5.16	84.23		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	137.47	1193.12	MSPGCL Total	150.53	1334.05
			MSPGCL Thml+Gas	144.80	1278.39	Koyna 1,2 & 4 Total	3.00	35.87
			MSPGCL Hydro	5.73	55.66	State Total	267.10	2449.52

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5488	95	298	5881	247	2939	0	0	5880	5920	-1505	13482	0	13482	2320	15802	49.98
2	5542	105	297	5944	270	2934	0	0	5523	5542	-1327	13363	0	13363	2134	15497	49.98
3	5538	126	325	5989	225	2923	0	0	5187	5366	-1201	13302	0	13302	2008	15310	49.99
4	5522	145	338	6005	250	2984	0	0	5219	5259	-1122	13376	0	13376	1925	15301	50.02
5	5591	115	348	6054	202	2921	0	0	5395	5393	-1102	13468	0	13468	1907	15375	50.00
6	5943	95	350	6388	211	3271	0	0	5770	6019	-1184	14705	0	14705	1987	16692	49.98
7	6092	473	357	6922	267	3561	0	18	6145	6366	-1246	15888	0	15888	2124	18012	49.98
8	6102	281	357	6740	256	3495	0	175	6373	6435	-1296	15805	0	15805	2295	18100	50.03
9	6070	157	370	6597	234	3560	0	445	6568	6548	-1619	15765	0	15765	2590	18355	50.02
10	5866	239	384	6489	272	3189	0	732	6646	6766	-1865	15583	0	15583	2916	18499	50.01
11	5543	254	289	6086	259	3121	0	873	7086	7204	-2051	15492	0	15492	3162	18654	50.01
12	5572	311	277	6160	233	3081	0	935	7306	7097	-1983	15523	0	15523	3288	18811	50.02
13	5479	368	265	6112	190	3004	0	953	7193	6808	-1914	15153	0	15153	3249	18402	50.01
14	5138	346	274	5758	171	2983	0	821	7096	7518	-1813	15438	0	15438	3143	18581	50.01
15	5556	240	273	6069	178	3338	0	727	7240	7407	-2058	15661	0	15661	3230	18891	49.96
16	5645	154	265	6064	115	3411	0	551	7301	7361	-2142	15360	0	15360	3243	18603	49.99
17	5702	215	275	6192	331	3502	0	234	7154	7128	-1931	15456	0	15456	3197	18653	49.94
18	5747	80	279	6106	192	3519	0	50	7041	6770	-1843	14794	0	14794	3129	17923	49.96
19	5967	695	269	6931	279	3618	0	0	6485	6612	-1624	15816	0	15816	3062	18878	49.88
20	5937	682	293	6912	268	3654	0	0	6434	6085	-1483	15436	0	15436	2981	18417	50.00
21	5920	190	286	6396	368	3556	0	0	6337	6463	-1493	15290	0	15290	2850	18140	50.02
22	5940	164	286	6390	264	3233	0	0	6225	6112	-1509	14490	0	14490	2689	17179	50.01
23	5949	139	285	6373	306	3126	0	0	6202	5850	-1593	14062	0	14062	2682	16744	50.00
24	5625	65	286	5976	251	3141	0	0	6248	5870	-1605	13633	0	13633	2543	16176	50.04
MUs	137.47	5.73	7.33	150.53	5.84	78.06	0.00	6.51	154.05	153.90	-38.51	356.34	0.00	356.34	64.65	420.99	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/Oct/2019

Position as on 6.30 Hrs of 11/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Koyna STG- IV Unit - 1	250	18/07/2019	14.30		Continued.	Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019)	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage.Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyna Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
IPP	Adani U-2	660	30/09/2019	05.37	11/10/2019	03.58	Coal Shortage	
IPP	Adani U-5	660	01/10/2019	23.10	11/10/2019	19.11	Coal Shortage	
MSPGCL	Koyna STG-IV Unit-2	250	02/10/2019	19.19		Continued.	Down Stream Seal Leakage Problem.	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	09/10/2019	03.22	11/10/2019	11.48	Boiler Problem	
MSPGCL	Uran Unit B0	120	09/10/2019	03.23	11/10/2019	18.41	Boiler Problem	
IPP	JSW (J) U4	300	09/10/2019	12.49		Continued.	CW Duct Leakage.	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Oct/2019

Position as on 6.30 Hrs of 11/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 4	210	10/10/2019	09.31	10/10/2019	20.22	LOW INSTRUMENT AIR PRESSURE.	
MSPGCL	Chandrapur Unit 3	210	10/10/2019	09.49	10/10/2019	17.40	VACUUM PROBLEM.	
MSPGCL	Uran Unit 7	108	10/10/2019	10.15		Continued.	Balancing work of GT	
MSPGCL	Nasik Unit 5	210	11/10/2019	18.35	11/10/2019	23.55	UAT Bus DEAD	
IPP	Adani U-5	660	11/10/2019	19.21	11/10/2019	21.36	11KV Bus Transfer	
MSPGCL	Koradi Unit-8	660	11/10/2019	22.36		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 11/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT-II @ Koradi-III	IntraState	10/10/2019	10.05	10/10/2019	18.59	PO	Maintenance Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	05/10/2019	00.29	11/10/2019	10.30	HT	Over Voltage
Dabhol Nagothane I	InterState	10/10/2019	09.44	10/10/2019	13.20	PO	Tree Cutting.
Dabhol Nagothane II	InterState	10/10/2019	10.47	10/10/2019	14.09	HT	Due To Sparking On Won CB.
Padgha - Boisar (PG)	InterState	10/10/2019	14.41	10/10/2019	21.20	PO	CT REPLACEMENT WORK.
Chandrapur - Parli	IntraState	07/10/2019	13.57		Continued.	T	Distance Protection, Z-2, B-Ph, 1.3KA, 317KM.
Khadka-Aurangabad (Waluj)	IntraState	09/10/2019	18.29	10/10/2019	06.49	HT	Over Voltage
Karad-Jaigad - I	IntraState	09/10/2019	21.08		Continued.	HT	Over Voltage
karad -kolhapur-II	IntraState	10/10/2019	01.18	10/10/2019	10.36	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	10/10/2019	08.36		Continued.	PO	CB Overhauling work
Lonikand 1 - Chakan	IntraState	10/10/2019	09.34	10/10/2019	19.03	PO	Routine Maintenance Work
Chandrapu II - Chandrapur SW Ckt II	IntraState	10/10/2019	10.01	10/10/2019	16.48	PO	Diagnostic Testing Work.
Bus Coupler @ Lonikand	IntraState	10/10/2019	17.56	11/10/2019	16.17	PO	Attending Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	10/10/2019	17.58	11/10/2019	07.38	HT	Over Voltage
Akola - Bhusawal	IntraState	11/10/2019	09.33	11/10/2019	15.31	PO	Restrining of conductor
Ektuni-Bableshwar ckt I	IntraState	11/10/2019	16.20	11/10/2019	19.04	PO	Replacement of Jumper Nut Bolt at Location no-14
Khadka-Aurangabad (Waluj)	IntraState	11/10/2019	17.15		Continued.	HT	Over Voltage
New Koyna -Koyna Stage IV-I	IntraState	11/10/2019	23.59		Continued.	PO	LBB Testing
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	10/10/2019	08.33	10/10/2019	19.10	PO	CTR Make Fire Fighting System maintenance Work.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	10/10/2019	09.31	10/10/2019	16.54	PO	Half yearly maintenance work
400/220/33 kv 315 MVA ICT-I @Chandrapur GCR	IntraState	10/10/2019	09.59	10/10/2019	20.30	EO	Tan Delta Measurment of CTs
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	10/10/2019	10.50	10/10/2019	19.47	PO	Replacement Of R-PH CT.
400/220kv 315MVA ICT-III @ Kharghar	IntraState	11/10/2019	08.14	11/10/2019	20.19	PO	Diagnostic Testing & maintenance work
400/220/33 Kv 315 MVA ICT-I @Aurangabad (Waluj)	IntraState	11/10/2019	09.07	11/10/2019	19.15	PO	Routine Maintenance Work
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	11/10/2019	11.24	11/10/2019	13.04	EO	Attend fire CTR Alarm
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	10/10/2019	15.36	10/10/2019	22.02	T	Distance Protection
Talegaon(PG)-Talegaon(Ambi)-II	InterState	10/10/2019	20.45	11/10/2019	07.26	T	LA Brust.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand -Jejuri Line.
Nagothane - ACCIL	IntraState	09/10/2019	16.20	10/10/2019	03.58	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 11/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Nagothane - Posco	IntraState	09/10/2019	22.53	10/10/2019	03.17	HT	Safety Permit.
Ghodbunder - Gorai	IntraState	10/10/2019	07.00	10/10/2019	14.41	PO	Replacement Of Existing in Service Polymer insulator.
Dahanu Ghodbunder Line 2	IntraState	10/10/2019	07.41	10/10/2019	18.10	PO	Annual Bay Maintenance.
Bableshtar-Alephata ckt I	IntraState	10/10/2019	08.58	10/10/2019	17.40	PO	CRM & Tan Delta Measurement.
Karad -Mudshingi Ckt- IV	IntraState	10/10/2019	09.50	10/10/2019	15.15	PO	Faulty String Replacement Work.
Alkud Miraj	IntraState	10/10/2019	10.55	10/10/2019	17.45	PO	Faulty String Replacement Work.
Walchandnagar-Bhigwan	IntraState	10/10/2019	11.01	10/10/2019	15.40	PO	Replacement Of Flash over String.
Wardha - Wardharlytss1	IntraState	10/10/2019	11.27	10/10/2019	17.20	PO	DIAGNOSTIC TESTING WORK & RELAY TESTING WORK.
Nanded-Parbhani	IntraState	10/10/2019	12.05	10/10/2019	12.24	T	Distance Protection
Kandalgaon - Bhira	IntraState	10/10/2019	14.30	10/10/2019	19.15	PO	Routine Maintenance Work
Kandalgaon - Koyna (Pophali)	IntraState	10/10/2019	15.16	11/10/2019	01.00	T	35.2 KM, A/R L,Y-E 4.15 KAMP EARTH WIRE BROKEN AT LOCATION NO. 271 & 272.
Pophali - New Koyna	IntraState	10/10/2019	15.16	10/10/2019	15.50	T	Tripped On Back Up.
REL Borivali Aarey Line	IntraState	10/10/2019	15.17	10/10/2019	18.01	PO	MMRD Work.
Kalyani - Baramati Agro	IntraState	10/10/2019	16.08	10/10/2019	19.18	PO	Line Maintenance work
Loteparshuram- Dasturi Line	IntraState	10/10/2019	16.30	10/10/2019	22.10	HT	JUMPER REPLACEMENT.
Nanded - Parli Ext. Ckt II	IntraState	10/10/2019	20.10	10/10/2019	20.35	T	Distance Protection
Chinchwad-Hinjewadi I	IntraState	10/10/2019	21.08	10/10/2019	23.56	HT	Load Management Purpose.
Sahara-Urse	IntraState	10/10/2019	22.48	11/10/2019	07.31	HT	TO CONTROL LOADING.
Dahanu Ghodbunder Line 2	IntraState	11/10/2019	07.25	11/10/2019	18.37	PO	Replacement of Isolator
Mahad - Pedambe	IntraState	11/10/2019	08.35	11/10/2019	17.35	PO	Replacement of insulator
khaparkheda-Khaparkheda(new)-I	IntraState	11/10/2019	10.48	11/10/2019	18.10	PO	Daigonistic testing work
Temghar - Kalwa	IntraState	11/10/2019	11.02	11/10/2019	18.08	PO	Annual Maintenance Work
Ghatghar - Bapgaon	IntraState	11/10/2019	11.36	11/10/2019	12.24	T	Distance Protection
ANANDNAGAR - PALAVA	IntraState	11/10/2019	11.39	11/10/2019	13.46	PO	Replacement work
Vita Alkud	IntraState	11/10/2019	11.43	11/10/2019	16.44	PO	Faulty String Replacement work
OSMANABAD BARSHI	IntraState	11/10/2019	15.58	11/10/2019	16.32	T	Tripped from barshi end only
PARANDA BARSHI	IntraState	11/10/2019	16.24	11/10/2019	17.01	T	Distance Protection
Nashik-Padgha	IntraState	11/10/2019	20.40		Continued.	HT	Hand Tripped For Load Management
220 KV ICT Outages/Trippings							
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-I (Mudshingi)	IntraState	11/10/2019	10.50	11/10/2019	13.17	PO	Annual Maintenance Work
220/132 kv 200 Mva ICT-II @Boisar -II	IntraState	11/10/2019	10.55	11/10/2019	19.20	PO	Diagnostic Testing work
220/22 Kv 50 Mva T&R Ptr 1 @Anandnagar	IntraState	11/10/2019	11.00	11/10/2019	12.23	PO	Attending Hot Spot

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage