

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Oct/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	122.362	1198.125	1) Gujrat	10.966	102.843
2) Hydro	8.065	70.156	2) Madhya Pradesh	8.640	70.500
3) Gas	2.151	22.643	3) Chattisgarh	5.240	54.770
Total MSPGCL	132.578	1290.924	4) Maharashtra	158.573	1678.676
B) 1) APLM	52.162	457.182	5) Goa (Amona)	-1.282	-13.389
2) JSWEL	16.811	171.781	Total	182.137	1893.400
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.164	327.909
4) RPL(AMT)	25.069	228.275	b) Mumbai Drawl	38.063	359.390
5) SWPGPL	7.851	70.238	c) MSEDCL Bilateral *	61.866	717.234
6) Other IPP	8.798	76.725	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.164	327.903
C) 1) TPCL Thermal	10.581	105.282	Include PX	0.000	0.000
2) TPCL Hydro	3.898	30.497	Standby	0.000	0.007
3) TPCL Gas	3.336	23.268	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.576	90.191	1) MSEDCL	390.762	3974.039
D) STATE			2) Mumbai Discoms	65.454	608.604
1) Thermal	253.210	2397.799	3) Other Discoms	9.168	91.750
(A1+C1+C4+(B1-B6))			TOTAL STATE	465.384	4674.393
2) Hydro (A2+C2)	11.963	100.653			
3) Gas (A3+B7+C3)	5.487	45.911			
4) Wind	4.285	138.954			
6) SOLAR	8.302	97.700			
TOTAL STATE	283.247	2781.017			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4662	5465	5667	4999
MSPGCL Hydro	197	468	1690	152
MSPGCL Gas	89	87	87	92
MSPGCL Total Generation	4948	6020	7444	5243
Central Sector Receipt	8996	7905	7213	6129
WIND	99	160	81	246
CPP / IPP Thermal	4497	4740	5381	4353
CPP / IPP Gas	0	0	0	0
SOLAR	1028	49	4	0
Exchange with Mumbai	-2014	-1881	-1723	-1035
MSEDCL DEMAND MET	17125	16585	17985	14638
Load Shedding	0	0	0	0
MSEDCL DEMAND	17125	16585	17985	14638
TPCL GENERATION	771	795	953	624
AEML GENERATION	489	461	481	303
MUMBAI DEMAND	3274	3137	3157	1962
OTHER DISCOM DEMAND	429	408	415	298
STATE DEMAND MET	20828	20130	21557	16898
STATE DEMAND	20828	20130	21557	16898
Frequency (Hz)	50.03	49.85	49.96	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 13.01 Hrs	49.65 Hz at 16.54 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.66	3.96	200	95
Unit 7	0.00	0.00	0	0
Unit 8	11.09	105.41	517	388
Unit 9	2.64	37.66	395	0
Unit 10	10.03	99.48	473	385
Total	27.43	246.51		
Bhusawal				
Unit 3	2.65	19.75	120	95
Unit 4	8.40	83.90	425	280
Unit 5	8.70	79.88	430	275
Total	19.75	183.53		
Parli				
Unit 6	3.98	39.38	210	118
Unit 7	3.98	40.00	202	144
Unit 8	3.03	31.26	138	112
Total	11.00	110.64		
Chandrapur				
Unit 3	3.23	29.83	165	120
Unit 4	2.99	25.19	145	120
Unit 5	6.87	66.85	315	275
Unit 6	7.06	73.45	375	274
Unit 7	7.13	75.08	308	280
Unit 8	0.00	0.00	0	0
Unit 9	8.37	85.87	445	276
Total	35.66	356.27		
Paras				
Unit 3	4.03	37.18	205	0
Unit 4	0.00	0.00	0	0
Total	4.03	37.18		
Khaparkheda				
Unit 1	2.86	29.22	125	110
Unit 2	2.92	28.92	135	105
Unit 3	3.41	35.60	177	125
Unit 4	3.26	32.22	153	125
Unit 5	7.50	80.24	425	275
Total	19.94	206.19		
Nasik				
Unit 3	0.00	25.32	0	0
Unit 4	3.26	31.18	159	120
Unit 5	1.30	1.30	150	0
Total	4.56	57.80		
Uran				
All Units	2.15	22.64	94	87
Total	2.15	22.64		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	5.94	27	23
Total	0.59	5.94		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.06	20.16	505	35
Stage 4	1.86	11.92	841	0
Stage 3	0.94	8.13	240	0
Total	4.86	40.21		
Hydro				
KDPH	0.00	2.43	0	0
VTRNA	0.00	1.82	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.24	2.44	77	0
SMLHY_PTN	2.21	15.71	99	88
GHATGHAR	0.16	1.60	90	0
Total	2.61	24.00		
Wind				
Total	4.28	138.95	0	0
Total	4.28	138.95		
CPP				
APML(Mus)	52.16	457.18	0	0
JSWEL(Mus)	16.81	171.78	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.07	228.28	0	0
SWPGPL-Mus	7.85	70.24	0	0
Other(Mus)	8.80	76.72	0	0
Total	110.69	1004.20		
SOLAR				
Total	8.30	97.70	0	0
Total	8.30	97.70		
Tata				
Trombay 5	7.11	71.23	375	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.02	12.95	110	37
Trombay 7B	1.32	10.32	65	34
TATA Hydro	3.90	30.50	369	39
Trombay 8	3.47	34.06	222	128
Total	17.82	159.05		
AEMIL				
DTPS U-1&2	9.58	90.19	500	298
Total	9.58	90.19		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	122.36	1198.12	MSPGCL Total	132.58	1290.92
			MSPGCL Thml+Gas	124.51	1220.77	Koyna 1,2 & 4 Total	3.92	32.08
			MSPGCL Hydro	8.06	70.16	State Total	283.25	2781.02

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 10/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4944	153	91	5188	169	4248	0	0	6783	6970	-1240	15000	0	15000	2251	336	17586	49.95
2	4823	153	92	5068	210	4286	0	0	6640	6562	-1130	14678	0	14678	2096	318	17092	49.99
3	4999	152	92	5243	246	4353	0	0	6433	6129	-1035	14638	0	14638	1962	298	16898	49.97
4	4964	153	92	5209	301	4420	0	0	6490	6206	-984	14866	0	14866	1894	286	17046	50.01
5	5041	153	92	5286	319	4410	0	0	6680	6487	-971	15233	0	15233	1880	298	17411	49.97
6	5363	154	93	5610	381	4442	0	0	7083	6896	-1048	15948	0	15948	2001	334	18282	49.93
7	5686	176	93	5955	354	4513	0	32	8053	7749	-1203	17033	0	17033	2187	367	19587	49.96
8	5009	324	94	5427	334	4464	0	234	8466	8633	-1415	17280	0	17280	2362	397	20039	50.02
9	5025	354	93	5472	221	4464	0	629	8503	8529	-1750	17132	0	17132	2724	433	20289	50.00
10	5049	269	91	5409	167	4484	0	833	8509	8448	-1801	17119	0	17119	3069	421	20609	49.97
11	4662	197	89	4948	99	4497	0	1028	9051	8996	-2014	17125	0	17125	3274	429	20828	50.03
12	4878	220	87	5185	79	4287	0	1227	8781	8569	-2105	16822	0	16822	3336	420	20578	50.07
13	4583	147	87	4817	87	4499	0	1188	8488	8285	-2092	16386	0	16386	3279	397	20063	50.02
14	4534	147	88	4769	47	4361	0	1178	8553	8476	-2154	16254	0	16254	3136	423	19813	50.04
15	4652	151	88	4891	72	4321	0	1009	8781	8455	-2163	16176	0	16176	3163	409	19748	50.01
16	4668	156	87	4911	125	4622	0	642	8743	8488	-2078	16305	0	16305	3171	405	19881	49.96
17	5025	310	87	5422	120	4594	0	249	8353	8158	-2024	16105	0	16105	3157	414	19676	49.92
18	5465	468	87	6020	160	4740	0	49	7886	7905	-1881	16585	0	16585	3137	408	20130	49.85
19	5667	1690	87	7444	81	5381	0	4	7163	7213	-1723	17985	0	17985	3157	415	21557	49.96
20	5801	969	88	6858	106	5598	0	0	7768	7361	-1636	17870	0	17870	3066	418	21353	50.00
21	5659	361	87	6107	199	5208	0	0	7682	7446	-1611	16937	0	16937	2909	412	20258	50.02
22	5609	432	88	6129	134	4819	0	0	7223	6726	-1407	16010	0	16010	2793	392	19194	50.04
23	5239	411	89	5739	131	4852	0	0	7096	6822	-1296	15868	0	15868	2766	380	19014	50.00
24	5017	365	89	5471	143	4826	0	0	6958	6628	-1302	15408	0	15408	2684	358	18450	50.01
MUs	122.36	8.06	2.15	132.58	4.29	110.69	0.00	8.30	186.17	182.14	-38.06	390.76	0.00	390.76	65.45	9.17	465.38	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Oct/2022

Position as on 6.30 Hrs of 11/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	10/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/10/2022
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	10/10/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	29/09/2022	21:00	10/10/2022	09:42	Seal Trough Leakage(converted to Critical Coal Stock w.e.f.21.00 Hrs Dt.30-09-	
IPP	Adani U-4	660	04/10/2022	12:05	10/10/2022	17:49	due to APH-A hot PA bellow leakage.	10/10/2022
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	10/10/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work	10/10/2022
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	10/10/2022
MSPGCL	Ghatghar Unit-2	125	10/10/2022	02:50		Continued.	Excitation Transformer problem.	
MSPGCL	Paras Unit 3	250	10/10/2022	07:35	10/10/2022	09:50	CHP coal feeding problem	
MSPGCL	Koradi Unit 9	660	10/10/2022	07:43		Continued.	Boiler Tube Leakage	13/10/2022
MSPGCL	Parli Unit 8	250	11/10/2022	00:01		Continued.	Boiler Tube Leakage	14/10/2022
MSPGCL	Koradi Unit 6	210	11/10/2022	09:13		Continued.	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 11/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI	IntraState	10/10/2022	10:21			PO	For shifting of wave trap from R phase to Y phase of 400kv Jejuri-Lonikand-II (Future line) bay
TIE BAY (412) OF FUTURE LINE @ JEJURI	IntraState	10/10/2022	10:52			PO	For connecting jumper to the Isolator
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (410) OF FUTURE BAY @ JEJURI	IntraState	10/10/2022	10:22			PO	For shifting of wave trap from R phase to Y phase of 400kv Jejuri-Lonikand-II (Future line) bay
MAIN BAY (413) OF FUTURE LINE @ JEJURI	IntraState	10/10/2022	10:51			PO	For connecting jumper to the Isolator
MAIN BAY (407) OF RPL CKT-1 @ AKOLA 2	IntraState	10/10/2022	10:54	10/10/2022	19:42	PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Trippings							
KORADI - SATPUR	InterState	10/10/2022	11:42	10/10/2022	20:57	HT	OUTAGE AVAILED AT SATPURA END FOR APM WORK.
PUNE(GIS) - TALEGAON(PG) CKT - 1	InterState	10/10/2022	21:15			T	Tripped on Distance protection
PUNE(GIS) - TALEGAON(PG) CKT - 2	InterState	11/10/2022	04:13			HT	For safety purpose to work on Pune GIS ckt 1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	09/10/2022	16:35	10/10/2022	17:14	T	TRIPPED ON SOTF AFTER TAKING IN SERVICE AFTER OUTAGE TRIPPED ON DISTANCE PROTECTION
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	09/10/2022	17:54			PO	Distance Protection
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	10/10/2022	06:51	10/10/2022	09:54		Disc Insulator string Replacement by Long Rod Porcelain string
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
NAGOTHANE - DABHOL CKT - 2	IntraState	10/10/2022	11:10			PO	For overhauling of ABB make CB
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	10/10/2022	10:42	10/10/2022	18:00	PO	(1) C & Tan D measurement of ICT Units. (2) Bay maintenance work.
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	10/10/2022	11:42	10/10/2022	14:25	T	TRIPPED ON NDR
220 KV TBC Outages/Trippings							
TBC @ VERSOVA (AEML)	IntraState	10/10/2022	09:35	10/10/2022	18:20	PO	Annual maintenance of 220kv Versova-Boisar line.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ BABHALESHWAR	IntraState	10/10/2022	15:09	10/10/2022	17:16	PO	B/u testing
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 11/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	06/10/2022	08:15			PO	Bunching of lines at location no.SS 82 to facilitate the following project work: NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223. DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	06/10/2022	08:22			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - PADGHE	IntraState	08/10/2022	22:52			HT	For load management
BUS - 1 @ TROMBAY	IntraState	10/10/2022	00:18	10/10/2022	06:45	PO	For attending Main bus isolator of ST-5 and ST-5 (CT Replacement, Relay replacement work, Transformer device relay replacement work, Bushing testing work)
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	10/10/2022	07:09	10/10/2022	21:44	HT	H/T TO CONTROL NASIK-BABHLESHWAR DC LINE LOADING
TALANDGE - BIDRI	IntraState	10/10/2022	09:25	10/10/2022	16:03	PO	Chemical cleaning of insulator string
TALANDAGE - FIVE STAR MIDC 1	IntraState	10/10/2022	10:23	10/10/2022	17:34	PO	for diagnostic testing work of CB(CRM and timing) and CT(tan delta) and quarterly maintenance work at 220 kV Five Star MIDC S/Stn
KARAD - VITA CKT- 2	IntraState	10/10/2022	11:10	10/10/2022	16:10	PO	Diagnostic Testing Work
220KV TULJAPUR-BALE CKT	IntraState	10/10/2022	11:30	10/10/2022	14:10	PO	Outage is required for To confirm physiblity of fixing STN hardware to Suspension tower (Loc no. 37) to form second Bale-PGCIL Ckt.
VANKUSWADE - AJINKYATARA	IntraState	10/10/2022	11:46	10/10/2022	17:00	PO	Relay Testing Work
MAIN BUS SECTION - 1 @ MUDSHINGI	IntraState	10/10/2022	12:50	10/10/2022	18:18	PO	Half yearly Main Bus section isolator maintenance work and cold washing of bus insulator strings

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 11/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS @ LOTE PARSHURAM	IntraState	10/10/2022	14:10	10/10/2022	17:38	PO	Outage on 220KV bus section II at Lote s/s. 220kv Bus sec-II following bays present, 1.220 KV Lote-Dasturi line. 2.220/33 KV, 50 MVA CGL TF no 2 Work to be carried out, 1)Attending hotspot of Y ph Bus T-joint over 220KV Bus section-II. 2) 220KV Lote-Dasturi line R ph Wavetrap replacement 3) 220KV Lote-Dasturi line Y & B ph CB pole second new trip coil fitting work. 4) 220/33 KV 50 MVA CGL TF no 2 quarterly maintenance work
SATANA - GANGAPUR	IntraState	10/10/2022	15:57	10/10/2022	16:35	T	TRIPPED ON DISTANCE PROTECTION
TALANDAGE - FIVE STAR MIDC 2	IntraState	10/10/2022	17:46	10/10/2022	19:20	PO	for diagnostic testing and quarterly maintenance work on dt. 10.10.2022 at 220 kV Five Star MIDC S/Stn.
EKLAHARE (GCR) - GHATGHAR	IntraState	10/10/2022	18:18	10/10/2022	18:28	T	TRIPPED ON DISTANCE PROTECTION ONLY FROM GHATGHAR END
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33 KV 50 MVA PTR - 1 @ PHALTAN MIDC	IntraState	10/10/2022	09:10	10/10/2022	16:40	PO	Oil leakage attending work by Powerseal method & SFRA,DFRA testing work.
220/110 KV 100 MVA PTR 3	IntraState	10/10/2022	11:42	10/10/2022	19:09	PO	HV backup relay replacement work
220/33 KV 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	10/10/2022	12:50	10/10/2022	18:29	PO	Quarterly maint of TF & bay equipments & Replcement work of Bucholz Relay,Winding resistance measurment of Tf
132 KV LINE Outages/Trippings							
DHARANI - NEPANAGAR	InterState	10/10/2022	12:08	10/10/2022	17:02	PO	i)Disc replacement work , ii) Diagnostic Testing &Routine Maintenance work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 11/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALYAN KALWA SALSETTE 1	IntraState	10/10/2022	09:04	10/10/2022	13:29	PO	PROJECT WORK IN VICINITY- REMOVAL OF CROSS JUMPER

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage